

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/building

BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

Johns Manville Corporation 717 17th Street Denver, CO 80202

Scope:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County BNC - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BNC reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville Modified Bitumen Roofing Systems Over Concrete Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 09-0902.03 and consists of pages 1 through 38. The submitted documentation was reviewed by Jorge L. Acebo.



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 1 of 38

ROOFING SYSTEM APPROVAL

<u>Category:</u> Roofing

Sub-Category: Modified Bitumen

Material:SBSDeck Type:ConcreteMaximum Design Pressure-536.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT: TABLE 1

		Test	Product
Product	Dimensions	Specification	Description
DynaBase	54'-10" x 36"	ASTM D 6163	An SBS modified bitumen coated, fiber glass
		Type I Grade S	reinforced base sheet.
DynaWeld Base	39'-3/8" x 32'-10"	ASTM D 6163	An SBS modified bitumen coated, fiberglass
		Type I Grade S	reinforced base sheet for heat welded
			applications.
DynaWeld 180 S	39-3/8" x 32'-10"	ASTM D 6164	An elastomeric modified bitumen coated, 180
Base		Type I Grade S	gram, nonwoven polyester mat and bi-
			directional glass scrim reinforced, base sheet
D	2 25	A CTM D (221	for heat welded applications.
DynaFlex	3 x 25	ASTM D 6221	A flexible polyester/glass scrim reinforced,
DynaGlas	39-3/8" x 32'-10"	ASTM D 6163	granular-surfaced flashing sheet. An SBS modified bitumen membrane surfaced
DynaGias	39-3/6 X 32 -10		with granules for application in hot asphalt.
DynaWeld Cap FR	39'-3/8" x 32'-10"	ASTM D 6163	A fire resistant SBS modified bitumen
Dyna wela Cap i K	37 -3/6 X 32 -10		membrane surfaced with granules for heat
		Type I Glade G	weld applications.
DynaWeld Cap 180	39-3/8" x 32'-10"	ASTM D 6164	A fire resistant, 180 gram polyester reinforced,
FŘ			SBS modified bitumen sheet.
DynaGlas 30 FR	39-3/8" x 32'-10"	ASTM D 6163	A fire resistant SBS modified bitumen
Dyna Glas 50 T K	37 3/0 X 32 10	Type I Grade G	
		Type I Glade G	application in hot asphalt.
DynaGlas FR	39-3/8" x 32'-10"	ASTM D 6163	A fire resistant SBS modified bitumen
,		Type I Grade G	membrane surfaced with granules for
			application in hot asphalt.
DynaKap	39-3/8" x 32'-10"	ASTM D 6162	A fiberglass/polyester reinforced SBS
		Type I Grade G	modified bitumen membrane surfaced with
			granules for application in hot asphalt.
DynaKap FR	39-3/8" x 32'-10"		A fire resistant, fiberglass/ polyester
		Type I Grade G	
			surfaced with granules for application in hot
Drugo Lagria 190	20 2/9" 22' 10"	A CTM D 6164	asphalt.
DynaLastic 180	39-3/8" x 32'-10"	ASTM D 6164 Type I Grade G	A 180 gram polyester reinforced SBS modified bitumen membrane surfaced with
		1 ype i Grade G	granules for application in hot asphalt.
DynaLastic 180 FR	39-3/8" x 32'-10"	ASTM D 6164	
_ j	5, 5, 5 M 52 TV	Type I Grade S	granular-surfaced, modified bitumen cap sheet
		71	for use in fire-rated systems.



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 2 of 38

Product DynaLastic 180S	Dimensions 37" x 36'-9"	Test <u>Specification</u> ASTM D 6164	Product Description A 180 gram polyester mat reinforced,
•		Type I Grade S	modified bitumen cap sheet for use in fire- rated systems.
DynaPly	39-3/8" x 32'-10"	ASTM D 6162 Type II Grade S	A polyester reinforced SBS modified bitumen ply sheet for use in conventional and modified bitumen built-up roof systems.
DynaLastic 250	39-3/8" x 32'-10"	ASTM D 6164 Type II Grade G	
DynaLastic 250 FR	39-3/8" x 32'-10".		A 250 gram polyester mat reinforced, granular-surfaced, modified bitumen cap sheet
DynaLastic 250 S	39-3/8" x 32'-10"		for use in fire-rated systems. A 250 gram polyester reinforced, SBS modified bitumen Base/Ply sheet for use as a
DynaMax	39-3/8" x 32'-10"	ASTM D 6162 Type III Grade G	base or ply sheet only . A fiberglass/polyester reinforced SBS modified bitumen membrane surfaced with granules for application in hot asphalt or heat weld.
DynaMax FR	39-3/8" x 32'-10"	ASTM D 6162 Type III Grade G	A fire resistant, fiberglass/ polyester
DynaClad	39-3/8" x 33'-6''	ASTM D 6298	An aluminum foil faced, glass reinforced, SBS modified membrane for application in hot asphalt.
DynaBase XT	39-3/8" x 49'-2''	ASTM D 6163 Type I Grade S	A heavyweight glass reinforced SBS Base/Ply sheet.
DynaGlas FR XT	39-3/8" x 32'-10"	ASTM D 6163 Type I Grade S	A heavyweight glass reinforced granular surfaced SBS Cap sheet.
GlasKap	36" x 36'	ASTM 3909	A mineral surfaced, asphalt coated, fiberglass cap sheet.
GlasKap CR	36" x 36'	ASTM 3909	A white mineral surfaced, white acrylic coated, fiberglass cap sheet.
Ventsulation Felt	36" x 36'	ASTM D 4897 Type II	Heavy duty fiber glass base sheet impregnated and coated on both sides with asphalt with or without fine mineral stabilizer. Surfaced on the bottom side with coarse mineral granules embedded in asphaltic coating.
GlasBase Plus	36" x 108'	ASTM D 4601	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
GlasPly IV	36" x 200'	ASTM D 2178 Type IV	Type IV asphalt impregnated glass felt for use in conventional and modified bitumen built-up
GlasPly Premier	36" x 180'	ASTM D 2178 Type VI	roofing. Type VI asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
PermaPly 28	36" x 108'	ASTM D 4601 Type II	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 3 of 38

		Test	Product
Product	Dimensions	Specification	Description
FesCant Plus Cant Strips, and Taper Edge	various	ASTM C 728	Factory pre-fabricated cant strips and taper edge, manufactured from expanded perlite insulation.
MBR Flashing Cement Base and Activator	N/A	Proprietary	A two component elastomeric, cold application adhesive, consisting of a modified proprietary compound with an asphalt base.
MBR Bonding Adhesive	N/A	proprietary	A two component urethane cold application adhesive.
JM Two Part Urethane Insulation Adhesive	N/A	Proprietary	A two-part urethane insulation adhesive
Bestile Industrial Roof Cement	various	ASTM D 4586, type I	A trowel grade, cutback bitumen flashing grade cement mixture including inorganic fibers and mineral stabilizers.
Flex-I-Drain	various	BOCA 76-61 SBCCI 89204 UBC 3236	Two piece flexible drain system composed of a Noryl deck flange, a flexible neoprene bellows and no hub connection. Available in various sizes and styles for most retro-fit applications.
PC/PET RetroDrain	various	N/A	Engineered resin copolymer fabricated drain for retrofit applications.
USII RetroDrain	various	N/A	One piece, aluminum fabricated drain for retrofit applications.
SuperDome RetroDrain	various	N/A	Cast aluminum, heavy-duty drain for retrofit applications.
FP-10 Vents	10" deck flange, base diameter of 4" and a height of 6"	N/A	One-way roof vent, designed for use in various roof systems, for the release of pressure created by gases or moisture vapor trapped within the roofing system.
Expand-O-Guard	various	N/A	Elastomeric expansion joint cover for vertical expansion and seismic joints. Manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges.
Expand-O-Flash	various	N/A	Expansion joint covers manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges.
Presto-Lok Fascia and Flashing System	various	TAS 114	A multi-piece fascia and flashing system for built-up and modified bitumen roofing systems manufactured from aluminum or steel.
DynaTred & DynaTred Plus Roof Walkway	various	N/A	Preformed, skid-resistant boards.



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 4 of 38

APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ENRGY 3	Polyisocyanurate Insulation.	Johns Manville
Fesco Foam, DuraFoam	Polyisocyanurate Insulation with perlite facer	Johns Manville
Retro-Fit Board, DuraBoard	A high-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Invinsa Roof Board	High density polyisocyanurate board	Johns Manville
SECUROCK Gypsum-Fiber Roof Board	Rigid, gypsum-based board stock	USG Corp.

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	UltraFast (#14 Only)	Insulation fastener for concrete decks.	Various	Johns Manville
2.	JM CD-10	Insulation fastener for concrete decks.	Various	Johns Manville
3.	JM Standard Metal Plate	Galvalume AZ55 steel plate	3" round	Johns Manville
4.	JM Plastic Plate	Polypropylene round plate	3.25" round	Johns Manville
5.	UltraFast Metal Plate	Galvalume AZ55 steel plate	3" round 3" square	Johns Manville
6.	UltraFast Plastic Plate	Polypropylene round plate	3" round	Johns Manville
7.	CD-10	Insulation fastener for concrete decks.	Various	OMG, Inc.
8.	OMG Fastener #14	Insulation fastener	Various	OMG, Inc.
9.	OMG Fastener ASAP	Pre-assembled Insulation fastener and plate	Various	OMG, Inc.
10.	OMG Standard	Galvalume AZ55 steel plate.	3" round	OMG, Inc.
11.	OMG G-2	Galvalume AZ55 steel plate.	3.5" round	OMG, Inc.
12.	OMG Polypropylene	Polypropylene plastic plate	3" round	OMG, Inc.
13.	High Load Fasteners and Plates	#15 fasteners and 20 gauge metal plates	2-3/8" round	Johns Manville



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 5 of 38

EVIDENCE SUBMITTED:

Test Agency/Identifier	<u>Name</u>	Report	<u>Date</u>
Factory Mutual Research Corp.	J.I. #3001482	FM Class 4470	08/11/98
•	J.I. #3001629	FM Class 4470	09/10/98
	J.I. #0Z8A9.AM		
	J.I. #3D4A4.AM	FM Class 4470	09/28/98
	J.I. #3000949		
	3007148	FM Class 4450	04/19/00
	3006346	FM Class 4450	09/15/00
	3001457	FM Class 4470	03/04/02
	3009499	FM Class 4470	04/04/01
	3011248	FM Class 4470	11/01/02
	3014090	FM Class 4470	09/05/02
	3012974	FM Class 4450	06/03/02
	3020703	FM Class 4470	07/30/04
	3037222	FM Class 4470	10/02/09
	3026130	FM Class 4470	04/26/09
Dynatech Engineering, Inc.	4360.03.95-1	TAS 114	3/95
	4360.03.95-2		
	4361.5.95-1	TAS 114	5/95
Underwriters Laboratories, Inc.	R-10167 (N)	Fire Classification Listing	01/01/95
Exterior Research & Design,	#4361-2.04.97-1	TAS 114	04/28/97
LLC	#10390A-10.97-1	TAS 114	10/97
	#10390A-12.97-1		12/97
	#4251.08.96-1	TAS 114	01/20/99
	10391.01.03		01/29/03
	02843.02.05-10-R1	TAS 114	02/07/07
	00257.03.05-1	ASTM D 6162/63/64	03/17/05
T.::	02042 02 07	ASTM D6298	02/07/07
Trinity ERD	02843.02.07	TAS 114	02/07/07
	J7670.06.08	ASTM D3909	06/16/08
	J6990.12.07-R1	ASTM D6162/D6164	03/24/10
	J17040.11.09-R1	ASTM D6164	03/11/10
	J13700.05.10-1-R1	ASTM D5147/D6163	01/25/11
Indonesia dont Doof Tooting &	J13700.05.10-2	ASTM D5147/D6164	05/11/10
Independent Roof Testing &	# 99006.1.20.99	TAS 114	01/20/99
Consulting, Inc.	#99007.1.20.99	TAC 114	02/00
	#99008.1.20.99	TAS 114	03/99
	#99009.1.20.99 #99016.1.20.99		
IRT-ARCON Inc		TAC 114	07/26/02
IKI-AKCON INC	02-026	TAS 114	07/26/02
	02-011		02/06/02



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 6 of 38

APPROVED ASSEMBLIES

Membrane Type: SBS

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(1): One or more layers of insulation adhered with approved asphalt or adhesive.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.5" thick	N/A	N/A
Fesco Foam, DuraFoam Minimum 1.5" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A
Retro-Fit Minimum ½" thick	N/A	N/A

Note: All insulation shall be adhered to the primed deck in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAs 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One ply of GlasPly Premier, GlasPly IV or PermaPly 28 Base Sheet

adhered in a full mopping of approved asphalt applied within the EVT range and at

a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the

EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq.,

respectively.

Maximum Design

Pressure: -305 psf (See General Limitation #9).

MIAMI-DADE COUNTY
APPROVED

NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 7 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(2): Optional anchor sheet bonded in hot asphalt or heat welded; One or more layers of

insulation fully adhered with approved asphalt or adhesive.

Anchor Sheet: (Optional) One or more plies of GlasBase Plus, DynaBase, DynaBase XT,

DynaPly, GlasPly Premier, PermaPly 28 or GlasPly IV adhered to the properly primed concrete deck with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq. or DynaWeld Base, heat welded.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3	,	•
Minimum 1.5" thick	N/A	N/A
Fesco Foam, DuraFoam Minimum 1.5" thick	N/A	N/A
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A
Retro-Fit		
Minimum ½" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Tapered Fesco Board, DuraBoard	,	·
Minimum ¾" thick	N/A	N/A
Retro-Fit		
Minimum ½" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet or primed deck in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAs 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 8 of 38 Ply Sheet: One or more plies of GlasBase Plus, PermaPly No. 28, GlasPly Premier, GlasPly

IV, DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or DynaWeld Base heat welded.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq.,

respectively.

Maximum Design

Pressure: -167.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11

Page 9 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(3): Optional anchor sheet bonded in hot asphalt or heat welded; One or more layers of

insulation fully adhered with approved asphalt or adhesive.

All General and System limitations apply.

Anchor Sheet: (Optional) One or more plies of GlasBase Plus, DynaBase, DynaBase XT,

DynaPly, GlasPly Premier, PermaPly 28 or GlasPly IV adhered to the properly primed concrete deck with a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq. or DynaWeld Base, heat welded.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3	,	•
Minimum 1.5" thick	N/A	N/A
Fesco Foam, DuraFoam Minimum 1.5" thick	N/A	N/A
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A
Retro-Fit		
Minimum ½" thick	N/A	N/A
Top Insulation Layer (Optional)	Insulation Fasteners	Fastener
	(Table 3)	Density/ft ²
Tapered Fesco Board, DuraBoard		
Minimum ¾" thick	N/A	N/A
Retro-Fit		
Minimum ½" thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet or primed deck in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAs 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or DynaWeld Base heat welded.



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 10 of 38 Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq.,

respectively.

Maximum Design

Pressure: -150 psf (See General Limitation #9)



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 11 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(4): All layer of insulation adhered to deck. Membrane is subsequently fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.5 thick	N/A	N/A
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A

Note: All layers of insulation shall be adhered with MBR Bonding Adhesive at an application rate of 1.5 gal./ 100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: GlasBase Plus, PermaPly 28, DynaBase, DynaBase XT, GlasPly Premier or

GlasPly IV applied to the insulation in MBR Bonding Adhesive at an application

rate of 1.5 gal./sq.

Ply Sheet: (Optional) One or more plies of GlasPly Premier or GlasPly IV fiber glass felts

adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in

MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -187.5 psf (for Fesco Board or DuraBoard) (See General Limitation #9).

-375 psf (for ENRGY 3) (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 12 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(5): All layer of insulation adhered to a primed deck. Membrane is subsequently fully

adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Foam, DuraFoam	N	N T/A
Minimum 1.5" thick	N/A	N/A
ENRGY 3		
Minimum 1.4" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Retro-Fit, DuraBoard		
Minimum ½" thick	N/A	N/A

Note: All layers of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: GlasBase Plus, PermaPly 28, DynaBase, DynaBase XT, GlasPly Premier or

GlasPly IV applied to the insulation in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One or more plies of GlasPly Premier or GlasPly IV fiber glass felts

adhered in a full mopping of approved asphalt applied within the EVT range and at

a rate of 20-40 lbs./sq. or DynaWeld Base heat welded.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -155 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 13 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(6): All layer of insulation adhered to a primed deck. Membrane is subsequently fully

adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Foam, DuraFoam Minimum 1.5" thick	N/A	N/A
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A

Note: All layers of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: GlasBase Plus, PermaPly 28 DynaBase, DynaBase XT, GlasPly Premier or

GlasPly IV applied to the insulation in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One or more plies of GlasPly Premier, PermaPly 28 or GlasPly IV fiber

glass felts adhered in a full mopping of approved asphalt applied within the EVT

range and at a rate of 20-40 lbs./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -130 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 14 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(7): All layer of insulation adhered to a primed deck. Membrane is subsequently fully

adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.4" thick	N/A	N/A
Fesco Board, DuraBoard Minimum ¾" thick	N/A	N/A

Note: All layers of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: GlasBase Plus, PermaPly 28, DynaBase, DynaBase XT, GlasPly Premier or

GlasPly IV applied to the insulation in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One or more plies of GlasPly Premier or GlasPly IV fiber glass felts

adhered in a full mopping of approved asphalt applied within the EVT range and at

a rate of 20-40 lbs./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -107 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 15 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(8): All layer of insulation adhered to a primed or unprimed deck. Membrane is

subsequently fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer Insulation Fasteners Fastener (Table 3) Density/ft²

ENRGY 3

Minimum 1.5 thick N/A N/A

Top Insulation Layer Insulation Fasteners Fastener (Table 3) Density/ft²

Fesco Board, DuraBoard Minimum ½" thick

Minimum ½" thick N/A N/A

Note: All layers of insulation shall be adhered to primed deck with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: GlasBase Plus, PermaPly 28, DynaBase, DynaBase XT, GlasPly Premier or

GlasPly IV applied to the insulation in MBR Bonding Adhesive at an application

rate of 1.5 gal./sq.

Ply Sheet: (Optional) One or more plies of GlasPly Premier or GlasPly IV fiber glass felts

adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in

MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -82.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 16 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(9): Insulation adhered to deck in insulation adhesive. Membrane is subsequently

fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Board Minimum ¾" thick	N/A	N/A
DuraBoard Minimum ½" thick	N/A	N/A
RetroFit Board Minimum ½" thick	N/A	N/A

Note: Insulation shall be adhered with OlyBond 500 (SpotShot) or JM Two Part Urethane Insulation Adhesive in 3/4" to 1" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate in a full mopping of approved asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or DynaWeld Base, heat-welded (to

DuraBoard only).

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -285 psf for Fesco Board (See General Limitation #9).

-305 psf for DuraBoard or RetroFit Board (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 17 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(10): Insulation adhered to deck in insulation adhesive. Membrane is subsequently

fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Insulation Layer Insulation Fasteners Fastener (Table 3) Density/ft²

DuraBoard

Minimum ½" thick N/A N/A

Note: Insulation shall be adhered with OlyBond 500 (SpotShot) or JM Two Part Urethane Insulation Adhesive in 3/4" to 1" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Ply Sheet: One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaBase, DynaBase XT or DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or DynaWeld Base, heat welded.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in

MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -187.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 18 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(11): Insulation adhered to deck in insulation adhesive. Membrane is subsequently

fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 2" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²

SECUROCK Gypsum-Fiber Roof Board

Minimum ¼" thick N/A N/A

Note: Insulation shall be adhered with OlyBond 500 (SpotShot) or JM Two Part Urethane Insulation Adhesive in 3/4" to 1" wide beads at maximum spacing of 12" o.c. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding

Adhesive at an application rate of 1.5 gal./sq.

Ply Sheet: One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq. or DynaWeld Base.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. or one ply DynaWeld Cap FR heat welded..

Ôг

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sa.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -442.5 psf with OlyBond 500 or JM Two Part Urethane Insulation Adhesive(See

General Limitation #9).

-367.5 psf with MBR Bonding Adhesive (See General Limitation #9).

MIAMI-DADE COUNTY
APPROVED

NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 19 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(12): Insulation adhered to primed deck in approved asphalt or to unprimed deck in

insulation adhesive. Membrane is subsequently fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 2" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
SECUROCK Gypsum-Fiber Roof Board		

Minimum 1/4" thick N/A N/A

Note: All layers of insulation shall be adhered to primed deck with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or to unprimed deck in OlyBond in full coverage at 1 gal/square or with MBR Bonding Adhesive at an application rate of 1.5 gal./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

> adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding

Adhesive at an application rate of 1.5 gal./sq.

One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV, Ply Sheet:

DynaLastic 180 S, DynaLastic 250 S. DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

> DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq.

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -495 psf with hot-asphalt or OlyBond (See General Limitation #9).

-367.5 psf with MBR Bonding Adhesive (See General Limitation #9).



NOA No: 11-0126.06 **Expiration Date: 07/19/12** Approval Date: 07/21/11 Page 20 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(13): Insulation adhered to primed deck in approved asphalt or to unprimed deck in

insulation adhesive. Membrane is subsequently fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3	,	•
Minimum 2" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
SECUROCK Gypsum-Fiber Roof Board	, ,	•
Minimum 1/4" thick	N/A	N/A

Note: All layers of insulation shall be adhered to primed deck with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft² or to unprimed deck in OlyBond in full coverage at 1 gal/square. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One or more plies of DynaWeld Base.

Ply Sheet: None

Membrane: One ply DynaWeld Cap FR heat welded.

Maximum Design

Pressure: -536.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 21 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(14): All layer of insulation adhered to deck. Membrane is subsequently fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.5 thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
DuraBoard Minimum ½" thick	N/A	N/A

Note: All layers of insulation shall be adhered with MBR Bonding Adhesive or OlyBond 500 (Spot Shot) or JM Two Part Urethane Insulation Adhesive in ³/₄" to 1" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) GlasBase Plus, PermaPly 28, DynaBase, DynaBase XT, GlasPly

Premier or GlasPly IV applied to the insulation in MBR Bonding Adhesive at an

application rate of 1.5 gal./sq.

Ply Sheet: One ply of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV, DynaLastic

180 S, DynaBase, DynaBase XT or DynaPly adhered in MBR Bonding Adhesive

at an application rate of 1.5 gal./sq or DynaWeld Base, heat welded.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in

MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -147.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 22 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(15): Anchor sheet heat welded; One or more layers of insulation adhered with

insulation adhesive.

Anchor Sheet: DynaWeld Base, heat welded.

All General and System limitations apply.

One or more layers of the following insulations:

Base and/or Top Insulation Layer Insulation Fasteners (Table 3) Fastener Density/ft²

ENRGY 3

Minimum 1.5" thick N/A N/A

Note: All layers of insulation shall be adhered with MBR Bonding Adhesive in 3/4" to 1" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) GlasBase Plus, PermaPly 28, DynaBase, DynaBase XT, GlasPly

Premier or GlasPly IV applied to the insulation in MBR Bonding Adhesive at an

application rate of 1.5 gal./sq.

Ply Sheet: One ply of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV, DynaLastic

180 S, DynaBase, DynaBase XT or DynaPly adhered in MBR Bonding Adhesive

at an application rate of 1.5 gal./sq or DynaWeld Base, heat welded.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in

MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq.,

respectively.

Maximum Design

Pressure: -147.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 23 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(16): One or more layers of insulation adhered with approved adhesive.

All General and System limitations apply.

One or more layers of the following insulations:

Fesco Board

Minimum ³/₄" thick N/A N/A

Note: All layers of insulation shall be adhered with JM Urethane Insulation Adhesive in ½" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply GlasPly Premier, GlasPly IV or PermaPly 28 Base Sheet

adhered in a full mopping of approved asphalt applied within the EVT range and at

a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the

EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq.,

respectively.

Maximum Design

Pressure: -112.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 24 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(17): All layer of insulation adhered to deck. Membrane is subsequently fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.5 thick	N/A	N/A
Fesco Board Minimum ¾" thick	N/A	N/A

Note: All layers of insulation shall be adhered with JM Urethane Insulation Adhesive in ½" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: GlasBase Plus, PermaPly 28, DynaBase, DynaBase XT, GlasPly Premier or

GlasPly IV applied to the insulation in MBR Bonding Adhesive at an application

rate of 1.5 gal./sq.

Ply Sheet: (Optional) One or more plies of GlasPly Premier or GlasPly IV fiber glass felts

adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in

MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -112.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 25 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(18): Insulation adhered to deck in insulation adhesive. Membrane is subsequently

fully adhered.

All General and System limitations apply.

One or more layers of the following insulations:

Insulation Fasteners Fastener (Table 3) Density/ft²

ENRGY 3

Max. 4 ft x 4 ft x Minimum 2" thick N/A N/A

Note: Insulation shall be adhered with MBR Bonding Adhesive applied in full coverage at an application rate of 1.5 gal./sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase, DynaBase XT or GlasBase Plus

adhered to the insulated substrate with MBR Bonding Adhesive at an application

rate of 1.5 gal./sq.

Ply Sheet: Two or more plies of GlasPly Premier, GlasPly IV, DynaLastic 180 S, DynaLastic

250 S or DynaPly adhered to the base sheet with MBR Bonding Adhesive at an

application rate of 1.5 gal./sq.

Membrane: One ply of DynaWeld Cap FR, heat welded.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -367.5 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 26 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type C(1): All layers of insulation simultaneously mechanically fastened.

All General and System limitations apply.

Base Insulation Layer (Optional)

Insulation Fasteners
(Table 3)

Fastener
Density/ft²

ENRGY 3

Minimum 1.5" thick N/A N/A

Note: Both layers of insulation shall be simultaneously mechanically fastened; see top layer below for fasteners and density.

Top Insulation Layer Insulation Fasteners (Table 3) Density/ft²
Fesco Board, DuraBoard
Minimum ¾" thick 1 or 8 1:1.33 ft²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: One or more plies of DynaWeld Base heat welded.

Membrane: One ply of DynaWeld Cap FR heat welded.

Maximum Design

Pressure: -75 psf (See General Limitation #7).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 27 of 38

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type C(2): All layers of insulation simultaneously mechanically fastened.

All General and System limitations apply.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3	,	·
Minimum 1" thick	N/A	N/A
Fesco Foam, DuraFoam		
Minimum 1.5" thick	N/A	N/A
Fesco Board, DuraBoard		
Minimum ¾" thick	N/A	N/A

Note: Both layers of insulation shall be simultaneously mechanically fastened; see top layer below for fasteners and density.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Fesco Foam, DuraFoam	` '	·
Minimum 1.5" thick	1, 2, 7 or 8	1:2 ft ²
Fesco Board, DuraBoard		
Minimum ¾" thick	1, 2, 7 or 8	1:2 ft ²
Retro-Fit		
Minimum ½" thick	1, 2, 7 or 8	1:2 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) One ply of PermaPly 28, DynaBase or GlasBase Plus adhered to the

insulated substrate in a full mopping of approved asphalt applied within the EVT

range and at a rate of 20-40 lbs./sq.

Ply Sheet: One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier, GlasPly IV,

DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied within the

EVT range and at a rate of 20-40 lbs./sq.



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 28 of 38 Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq.,

respectively.

Maximum Design

Pressure: -52.5psf (See General Limitation #7).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11

Page 29 of 38

Deck Type 2I: Concrete, Insulated

Deck Description: 2,500 psi structural concrete or concrete plank

System Type D(1): All layers of insulation simultaneously mechanically fastened with base sheet.

All General and System limitations apply.

One or more layers of any of the following insulations:

Insulation Fasteners Fastener Density/ft² **Base Insulation Layer** (Table 3) **ENRGY 3** Minimum 1.5" thick N/A N/A **Insulation Fasteners Top Insulation Layer** Fastener Density/ft² (Table 3) RetroFit Board Minimum ½" thick N/A N/A

Note: Top layer shall have preliminary attachment prior to the installation of the base sheet at a minimum application rate of five (5) fasteners per 4 x 8 ft board. All layers of insulation and base

sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: DynaLastic 180 S fastened to the deck as described below:

Fastening: Fasten base sheet over the 4-inch wide laps using JM CD-10 Fasteners and High

Load Plates spaced 6" o.c.

Ply Sheet: DynaWeld Base, heat welded.

Membrane: DynaWeld Cap FR, heat welded.

Maximum Design

Pressure: -112.5 (See General Limitation #7).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 30 of 38

Deck Type 2I: Concrete, Insulated

Deck Description: 2,500 psi structural concrete or concrete plank

System Type D(2): All layers of insulation simultaneously mechanically fastened with base sheet.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
RetroFit Board Minimum 1/2" thick	N/A	N/A

Note: Top layer shall have preliminary attachment prior to the installation of the base sheet at a minimum application rate of five (5) fasteners per 4 x 8 ft board. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: DynaLastic 180 S fastened to the deck as described below:

Fastening: Fasten base sheet within the 5-inch wide laps using JM CD-10 Fasteners and High

Load Plates spaced 6" o.c. The lap is heat welded.

Ply Sheet: (Optional) DynaWeld Base, heat welded.

Membrane: DynaWeld Cap FR, heat welded.

Maximum Design

Pressure: -112.5 (See General Limitation #7).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 31 of 38

Concrete, Insulated Deck Type 2I:

2,500 psi structural concrete or concrete plank **Deck Description:**

System Type D(3): All layers of insulation simultaneously mechanically fastened with base sheet.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer Insulation Fasteners Fastener Density/ft² (Table 3)

Fesco Board

Minimum 3/4" thick N/A N/A **Insulation Fasteners** Fastener **Middle Insulation Layer** Density/ft²

(Table 3)

ENRGY 3

Minimum 1" thick

Top Insulation Layer Insulation Fasteners Fastener

Density/ft² (Table 3)

Plywood

Minimum 5/8" thick N/A N/A

Note: Top layer shall have preliminary attachment prior to the installation of the base sheet at a minimum application rate of five (5) fasteners per 4 x 8 ft board. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: DynaLastic 180 S fastened to the deck as described below:

Fastening: Fasten base sheet within the 5-inch wide laps using JM CD-10 Fasteners and High

Load Plates spaced 6" o.c. The lap is heat welded.

Ply Sheet: (Optional) DynaWeld Base, heat welded.

Membrane: DynaWeld Cap FR, heat welded.

Maximum Design

Pressure: -135 (See General Limitation #7).



NOA No: 11-0126.06 **Expiration Date: 07/19/12** Approval Date: 07/21/11 Page 32 of 38

Deck Type 2I: Concrete, Insulated

Deck Description: 2,500 psi structural concrete or concrete plank

System Type D(4): All layers of insulation simultaneously mechanically fastened with base sheet.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
RetroFit Board Minimum ½" thick	N/A	N/A

Note: Top layer shall have preliminary attachment prior to the installation of the base sheet at a minimum application rate of five (5) fasteners per 4 x 8 ft board. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: DynaLastic 180 S fastened to the deck as described below:

Fastening: Fasten base sheet within the 5-inch wide laps using JM CD-10 Fasteners and High

Load Plates spaced 6" o.c. The lap is heat welded.

Ply Sheet: (Optional) DynaWeld Base, heat welded.

Membrane: DynaWeld Cap FR, heat welded.

Maximum Design

Pressure: -135 (See General Limitation #7).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 33 of 38

Deck Type 2I: Concrete, Insulated

Deck Description: 2,500 psi structural concrete or concrete plank

System Type D(5): All layers of insulation simultaneously mechanically fastened with base sheet.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer Insulation Fasteners Fastener (Table 3) The Density/ft²

Fesco Board

Minimum ¾" thick N/A N/A

Middle Insulation Layer Insulation Fasteners (Table 3) Fastener Density/ft²

ENRGY 3

Minimum 1" thick

Top Insulation Layer Insulation Fasteners Fastener (Table 3) Fensity/ft²

Plywood

Minimum 5/8" thick N/A N/A

Note: Top layer shall have preliminary attachment prior to the installation of the base sheet at a minimum application rate of five (5) fasteners per 4 x 8 ft board. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: DynaLastic 180 S fastened to the deck as described below:

Fastening: Fasten base sheet over the 4-inch wide laps using JM CD-10 Fasteners and High

Load Plates spaced 6" o.c.

Ply Sheet: DynaWeld Base, heat welded.

Membrane: DynaWeld Cap FR, heat welded.

Maximum Design

Pressure: -150 (See General Limitation #7).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 34 of 38

Deck Type 2I: Concrete, Insulated

Deck Description: 2,500 psi structural concrete or concrete plank

System Type D(6): All layers of insulation simultaneously mechanically fastened with base sheet.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3 Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
RetroFit Board Minimum ½" thick	N/A	N/A

Note: Top layer shall have preliminary attachment prior to the installation of the base sheet at a minimum application rate of five (5) fasteners per 4 x 8 ft board. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: DynaLastic 180 S fastened to the deck as described below:

Fastening: Fasten base sheet over the 4-inch wide laps using JM CD-10 Fasteners and High

Load Plates spaced 6" o.c.

Ply Sheet: DynaWeld Base, heat welded.

Membrane: DynaWeld Cap FR, heat welded.

Maximum Design

Pressure: -150 (See General Limitation #7).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 35 of 38

SBS **Membrane Type:**

Deck Type 3: Concrete Decks, Non-Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(1): Base sheet fully adhered.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: One or more plies of One ply of DynaBase, DynaBase XT or Ventsulation applied

to the deck in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Ply Sheet: (Optional) One or more plies of GlasPly Premier or GlasPly IV fiber glass felts

adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

> DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180, DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250FR or

> DynaPly adhered in MBR Bonding Adhesive at an application rate of 1.5 gal./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. and 400

lbs./sq., respectively.

Maximum Design

Pressure: -495 psf (See General Limitation #9).

Membrane Type: SBS

Concrete Decks, Non-Insulated, New Construction Deck Type 3:

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(2): (Optional) Base sheet fully adhered with approved asphalt.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: One or more plies of DynaWeld Base, DynaWeld PR or DynaWeld 180 S heat

welded to concrete deck.

Membrane: One ply of DynaWeld Cap FR or DynaWeld Cap 180 FR heat welded to the base

sheet.

Maximum Design

Pressure: -315 psf (See General Limitation #9).



NOA No: 11-0126.06 **Expiration Date: 07/19/12** Approval Date: 07/21/11 Page 36 of 38

Deck Type 3: Concrete Decks, Non-Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type F(3): (Optional) Base sheet fully adhered with approved asphalt.

All General and System limitations apply.

Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of anchor sheet.

Base Sheet: One ply of PermaPly 28, DynaBase, DynaBase XT, DynaPly or GlasBase Plus

adhered to the properly primed concrete deck in a full mopping of approved asphalt

applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: (Optional) One or more plies of GlasBase Plus, PermaPly 28, GlasPly Premier,

GlasPly IV, DynaLastic 180 S, DynaLastic 250 S, DynaBase, DynaBase XT or DynaPly adhered to the base sheet with approved mopping of asphalt applied

within the EVT range and at a rate of 20-40 lbs./sq.

Membrane: One ply of DynaKap, DynaKap FR, DynaMax, DynaMax FR, DynaGlas,

DynaGlas FR, DynaGlas 30 FR, DynaGlas 30 FR XT, DynaLastic 180,

DynaLastic 180 FR, DynaLastic 180 S, DynaLastic 250, DynaLastic 250 FR or DynaPly adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or one ply DynaWeld Cap FR heat welded.

(See application instructions for approved method of installation).

Or

(Only with a modified Base or Ply sheet) GlasKap or GlasKap CR adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40

lbs./sq.

Surfacing: (Optional) Install one of the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq.,

respectively.

Maximum Design

Pressure: -275 psf (See General Limitation #9).



NOA No: 11-0126.06 Expiration Date: 07/19/12 Approval Date: 07/21/11 Page 37 of 38

CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

- 1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
- 3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
- 4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
- 5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as fieldtested, are below 275 lbf. Insulation attachment shall not be acceptable.
- 6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
- 7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant (When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
- 8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
- 9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). (When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)

END OF THIS ACCEPTANCE



NOA No: 11-0126.06 **Expiration Date: 07/19/12** Approval Date: 07/21/11

Page 38 of 38