



**BUILDING AND NEIGHBORHOOD COMPLIANCE
DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION**

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building

NOTICE OF ACCEPTANCE (NOA)

**Tamko Building Products, Inc.
P.O. Box 1404
Joplin, MO 64802**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County BNC - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. BNC reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: TAMKO BUR Roofing System over Recover Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 09-0820.08 and consists of pages 1 through 20.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No: 11-0415.14
Expiration Date: 08/23/12
Approval Date: 08/18/11
Page 1 of 20**

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Built-up Roofing
Material:	Fiberglass
Deck Type:	Recover
Maximum Design Pressure:	See Specific deck type

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
Awaplan 170 FR	Roll weight: 98 lbs.; 33' 11" x 39 ^{3/8} "	ASTM D 6164 Type I	A 180 g/m ² polyester reinforced SBS modified bitumen membrane surfaced with granules and treated for additional fire resistance. Applied in hot asphalt or cold adhesive.
Awaplan 170™	Roll weight: 98 lbs.; 33' 11" x 39 ^{3/8} "	ASTM D 6164 Type I	A 180 g/m ² polyester reinforced SBS modified bitumen membrane surfaced with granules. Applied in hot asphalt or cold adhesive.
Awaplan Premium FR™	Roll weight: 101 lbs.; 33' 11" x 39 ^{3/8} "	ASTM D 6164 Type II	A 250 g/m ² polyester reinforced modified bitumen membrane surfaced with granules. Applied by hot asphalt and also used as a walkway material.
Awaplan Premium™	Roll weight: 101 lbs.; 33' 11" x 39 ^{3/8} "	ASTM D 6164 Type II	A 250 g/m ² polyester reinforced SBS modified bitumen membrane surfaced with granules. Applied in hot asphalt or cold adhesive, and also used as a walkway material.
Awaplan Versa-Smooth	Roll weight: 100 lbs. 33' 11" x 39 ^{3/8} "	ASTM D 6164 Type I	A 180 g/m ² polyester reinforced SBS modified bitumen membrane. Applied in hot asphalt, by torch, or mechanically fastened, as a base ply in 2 ply modified systems.
Awaplan Versa-Flex	Roll weight: 76 lbs.; 33' 11" x 39-3/8"	ASTM D 6164 Type I	A 190 g/m ² nonwoven polyester reinforced SBS modified bitumen membrane. Applied in hot asphalt, as a base ply in 2 ply-modified systems.
Base-N-Ply®	Roll weight: 72 lbs.; 108' x 36"	ASTM D 4601 Type II	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Glass-Base™	Roll weight: 72 lbs.; 108' x 36";	ASTM D 4601 Type II	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Tam-Cap™	Roll weight: 83 lbs.; 36' x 36"	ASTM D 3909	Asphalt impregnated and coated felt surfaced with mineral granules used as the top ply in conventional built-up roof membranes.
Tam-Glass Premium™	Roll weight: 53 lbs.; 180' x 36"	ASTM D 2178 Type VI	Type VI asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
Tam-Ply IV™	Roll weight: 44 lbs.; 180' x 36"	ASTM D 2178 Type IV	Type IV asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
Type 43 Base Sheet	Roll weight: 85 lbs.; 72' x 36"	ASTM D 2626	An organic felt reinforced asphalt base sheet. Applied in hot asphalt or mechanically fastened.
Vapor-Chan™	Roll weight: 86 lbs.; 36' x 36"	ASTM D 4897 Type II	Heavy-duty fiberglass base sheet impregnated and coated on both sides with asphalt with or without a fine mineral stabilizer. Surfaced on the bottom side with coarse mineral granules embedded in hot asphaltic coating.
Versa-Base™	Roll weight: 94 lbs.; 54' x 36"	ASTM D 6163 Type I	Asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
Tam-Pro Fibered Emulsion Coating	5 gallon	ASTM D 1227, type II	Protective coating.
Tam-Pro Quick Dry Primer	5 gallon	ASTM D 41	Asphalt based primer
Tam-Pro FR Fibered Aluminum Coating	5 gallons	ASTM D2824, type III	Flame retardant protective coating



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
Pyrox, White Line	Isocyanurate Insulation	Apache Products Co.
ACFoam Composite	Isocyanurate Insulation with perlite facer	Atlas Roofing Corp.
ACFoam II	Isocyanurate Insulation	Atlas Roofing Corp.
EnergyGuard Perlite	Expanded mineral fiber	GAF Mat'l. Corp.
EnergyGuard Fiberboard	Wood fiber board	GAF Mat'l. Corp.
Dens Deck	Silicon treated gypsum	G-P Products
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
ENRGY 3, PSI-25	Isocyanurate Insulation.	Johns Manville
ENRGY 3 Plus	Polyisocyanurate / woodfiber insulation	Johns Manville
ENRGY 3 Composite, Fesco Foam	Polyisocyanurate / woodfiber insulation	Johns Manville
Retro-Fit Board, DuraBoard	A high-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Structodeck, Structodek FS	High Density Wood Fiber insulation board.	Masonite
Multi-Max-3, Multi-Max FA-3	Expanded Glass	Rmax, Inc.
H-Shield	Polyisocyanurate foam insulation	Hunter Panels
H-Shield WF	Wood fiber/Isocuanurate Composite Insulation	Hunter Panels
ISO 95+ GL	Polyisocyanurate Foam Insulation	Firestone Building Products
ISO 95+ Composite	Polyisocyanurate / Woodfiber insulation	Firestone Building Products



APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Dekfast Fasteners #12, #14 & #15	Insulation fastener for wood, steel and concrete decks		SFS Intec, Inc.
2.	Dekfast Hex Plate	Galvalume hex stress plate.	2 7/8" x 3 1/4"	SFS Intec, Inc.
3.	Dekflat Plate	Polypropylene plastic plate.	3" round	SFS Intec, Inc.
4.	#12 Roofgrip Fasteners	Insulation fastener for wood and steel.		OMG
5.	Metal Plate	Galvalume stress plate.	3" round 3" square	OMG
6.	Gearlok Plastic Plate	Polypropylene round plate	3.2"	OMG
7.	OMG Fastener #12 & #14	Insulation fastener		OMG
8.	OMG G-2	Galvalume AZ55 steel plate	3.5" round	OMG
9.	OMG Standard	Galvalume AZ50 steel plate	3" round	OMG
10.	OMG Polypropylene	Polypropylene plastic plate	3.25" round	OMG
11.	Insul-Fixx Fastener	Insulation fastener for steel and wood decks		SFS Intec, Inc.
12.	HD Insul-Fixx Fastener	Insulation fastener for steel and wood decks		SFS Intec, Inc.
13.	Insul-Fixx S Plate	Galvalume AZ50 steel plate	3" round	SFS Intec, Inc.
14.	Insul-Fixx P Plate	3" round polyethylene stress plate	3" round	SFS Intec, Inc.
15.	Tru-Fast	Insulation fastener for steel and wood decks		The Tru-Fast Corp.
16.	Tru-Fast Plates	Galvalume AZ55 steel plate	3" round	The Tru-Fast Corp.
17.	Gripdek Fastener	Insulation and Base sheet Fastener	Various	OMG



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corporation	Class 4470	J.I. 4D0A7.AM	10.21.98
	Class 4470	J.I. 0Z4A3.AM	08.27.97
	Class 4470	J.I. 1D4A7.AM	10.20.97
	Class 4470	J.I. 3B5A9.AM	08.27.97
	Class 4470	3027787	08/14/06
	Class 4470	3027789	08/14/06
	Class 4470	3027790	08/14/06
	Class 4470	3027791	08/14/06
Underwriters Laboratories, Inc.	UL 790	R3225	Published Annually
Dynatech Engineering Corporation	TAS 114	4440.05.95-2	05.01.95
	TAS 114	4440.05.95-1	05.01.95
Exterior Research & Design, LLC.	TAS 114	4444.06.98-1	06.15.98
Trinity ERD	TAS 117	C8500SC.00.07	11.30.07
	TAS 117 & TAS 114	C12410.08.09	08/14/09



APPROVED ASSEMBLIES

Membrane Type: BUR

Deck Type 7I: Recover

Deck Description: wood/steel/concrete

System Type A(1): Optional anchor sheet mechanically attached; all layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

Anchor Sheet: One ply of Tamko Glass-Base, Vapor-Chan, Base-N-Ply or Awaplan Versa-Smooth fastened to the deck as described below:

Fastening: *(Option #1 – wood decks only)* Attach anchor sheet using 11 ga. annular ring shank nails and 1-5/8" diameter tin caps spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet.

(Meets –52.5 psf, See General Limitation #7.)

(Option #2 – wood or steel decks only) Attach anchor sheet using CF Dekfast or #14 Dekfast Fasteners with CF Hex Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

(Meets –60 psf, See General Limitation #7.)

(Option #3 – steel or concrete decks only) Attach anchor sheet using SFS #12 or HD Insulfixx S, or OMG Accutrak Fasteners or #14, #15 Roofgrip and 3" Square Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

(Meets –75 psf, See General Limitation #7.)

(Option #4 – steel or concrete decks only - Awaplan Versa-Smooth only) Attach anchor sheet using OMG Accutrak Fasteners or #14, #15 Roofgrip and 3" Square Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.

(Meets –120 psf, See General Limitation #7.)

Note: Anchor sheet fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements set forth in applicable Building Code.

Insulation Layer

Insulation Fasteners (Table 3)

Fastener Density/ft²

One or more layers of any of the following insulations:

ACFoam II, ENRGY 3, ENRGY 3 Plus, IsoTherm R, ENRGY 3 Composite, ISO 95+GL, ISO 95+ Composite, ISO-Roc, UltraGard Gold, ACFoam Composite, Multi-Max FA-3, H-Shield, H-Shield WF

Minimum 1" thick

N/A

N/A

Fesco Board

Minimum 1/2" thick

N/A

N/A

High Density Wood Fiberboard, Structodek FS

Minimum 1/2" thick

N/A

N/A



Note: All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) Install one ply of Type 43 coated base sheet, Glass-Base™ or Base-N-Ply® base sheet directly to the insulated substrate. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Note: **Type 43 coated base sheet cannot be spot mopped.**

Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..(See specification number for appropriate number of plies).

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. (See Tamko application instructions for approved method of installation).

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure: *See Anchor Sheet Fastening Options.*



Membrane Type: BUR

Deck Type 7I: Recover

Deck Description: Concrete

System Type A(2): One or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
One or more layers of any of the following insulations:		
ACFoam II, ENRGY 3, ENRGY 3 Plus, IsoTherm R, ENRGY 3 Composite, ISO 95+GL, ISO 95+ Composite, ISO-Roc, UltraGard Gold, ACFoam Composite, Multi-Max FA-3, H-Shield, H-Shield WF Minimum 1” thick	N/A	N/A
Fesco Board Minimum 1/2” thick	N/A	N/A
High Density Wood Fiberboard, Structodek FS Minimum 1/2” thick	N/A	N/A

Note: Existing roof shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered to the anchor sheet in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) Install one ply of Type 43 coated base sheet, Glass-Base™ or Base-N-Ply® base sheet directly to the insulated substrate. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Note: **Type 43 coated base sheet cannot be spot mopped.**

Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See specification number for appropriate number of plies).

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. (See Tamko application instructions for approved method of installation).



Surfacing:

(Required if no cap sheet is used) Install one of the following:

1. Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure:

- 165 psf (for minimum 1.5” thick Approved polyisocyanurate followed by minimum ¾” thick Approved perlite applied in hot asphalt.) (See General Limitation #9)
- 230 psf (for minimum 1.5” thick Approved polyisocyanurate followed by minimum ¼” thick Dens Deck or minimum ½” Approved High Density Wood Fiberboard applied in hot asphalt.) (See General Limitation #9)
- 147 psf (for minimum 1.5” thick Approved polyisocyanurate followed by minimum ½” thick Approved Regular Density Wood Fiberboard applied in hot asphalt.) (See General Limitation #9)
- 200 psf (for minimum 1.5” thick ACFoam II Composite or E’NRG’Y-2 Composite applied in hot asphalt.) (See General Limitation #9)
- 230 psf (for minimum ¼” thick Dens Deck applied in hot asphalt with no underlying insulation.) (See General Limitation #9)



Membrane Type: BUR

Deck Type 7I: Recover

Deck Description: concrete/lightweight concrete/cementitious wood fiber/wood/steel

System Type B(1): Base layer of insulation mechanically fastened; top layer adhered with hot asphalt.

All General and System Limitations apply.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners</u> <u>(Table 3)</u>	<u>Fastener</u> <u>Density/ft²</u>
ACFoam II, H-Shield Minimum 1.3" thick	1, 2, 4, 5, 7, 8, 9, 17	1:3 ft²
ENRGY 3 Minimum 1.4" thick	1, 4, 7, 8, 9, 15, 17	1:3 ft²
ENRGY 3 Plus Minimum 1.5" thick	1, 2, 4, 11, 12, 13, 14, 15, 17	1:4 ft²
Multi-Max-3 Minimum 1.5" thick	1, 4, 7, 8, 9, 11, 12, 13, 14, 15	1:2.9 ft²
ISO 95+ GL Minimum 1.4" thick	1, 4, 7, 8, 9, 11, 12, 13, 14, 15, 17	1:4 ft²
Fesco Foam Minimum 1.5" thick	1, 2, 4, 5, 7, 8, 9, 11, 13, 15, 17	1:4 ft²
ENRGY 3 Composite Minimum 1.25" thick	1, 2, 4, 7, 8, 9, 11, 12, 13, 14, 15, 17	1:4 ft²
ACFoam Composite Minimum 1.5" thick	4, 7, 8, 9, 11, 12, 13, 14, 15	1:2.67 ft²
ISO 95+ Composite Minimum 1.4" thick	1, 2, 4, 5, 7, 8, 9, 11, 12, 13, 14, 15, 17	1:3 ft²
Foamglas Minimum 1.5" thick	1, 15	1:4 ft²
Fesco Board Minimum 3/4" thick	1, 4, 5, 7, 9, 15, 17	1:2 ft²
High Density Wood Fiberboard Minimum 1/2" thick	1, 4, 7, 8, 15	1:2 ft²



Note: Base layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Protocol TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Any of the insulations listed for Base Layer, above or;		
H-Shield-WF Minimum 1.5" thick	N/A	N.A

Note: Apply top layer of insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) Install one ply of Type 43 coated base sheet, Glass-Base™ or Base-N-Ply® base sheet directly to the insulated substrate. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Note: **Type 43 coated base sheet cannot be spot mopped.**

Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..(See specification number for appropriate number of plies)

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. (See Tamko application instructions for approved method of installation).

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: BUR
Deck Type 7I: Recover
Deck Description: wood/steel/concrete
System Type B(2): Base insulation layer mechanically fastened; top layer adhered with approved asphalt.

All General and System Limitations apply.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam II, ENRGY-3, PSI-25, H-Shield Minimum 1.5" thick	7, 11	1:1.33 ft ²

Note: Base layers of insulation shall be mechanically attached using the fastener density listed. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Protocol TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
High Density Wood Fiberboard Minimum 1/2" thick	N/A	N/A

Note: Apply top layer of insulation in a full mopping of any approved mopping asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) Install one ply of Type 43 coated base sheet, Glass-Base™ or Base-N-Ply® base sheet directly to the insulated substrate. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Note: **Type 43 coated base sheet cannot be spot mopped.**

Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See specification for appropriate number of plies).

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See Tamko application instructions for approved method of installation).

Surfacing: (Required if no cap sheet is used) Install one of the following:
 1. Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
 2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure:
 -60 psf – wood deck (See General Limitation #7.)
 -75 psf – steel or concrete deck (See General Limitation #7.)



NOA No: 11-0415.14
Expiration Date: 08/23/12
Approval Date: 08/18/11
Page 13 of 20

Membrane Type: BUR
Deck Type 7I: Recover
Deck Description: wood/steel/concrete/cementitious wood fiber/gypsum
System Type C: All layers of insulation simultaneously fastened.

All General and System Limitations apply.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam II, H-Shield Minimum 1.3" thick	N/A	N/A
ENRGY 3, ISO 95 + GL, ISO 95+ Composite Minimum 1.4" thick	N/A	N/A
Fesco Foam, ACFoam Composite Minimum 1.5" thick	N/A	N/A
ENRGY 3 Plus, H-Shield WF Minimum 1.5" thick	N/A	N/A
Multi-Max FA-3 Minimum 1.5" thick	N/A	N/A
ENRGY 3 Composite Minimum 1.25" thick	N/A	N/A
Fesco Board Minimum 1/2" thick	N/A	N/A
High Density Wood Fiberboard Minimum 1/2" thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam II, H-Shield Minimum 1.3" thick	1, 2, 4, 5, 7, 8, 9, 17	1:3 ft ²
ENRGY 3 Minimum 1.4" thick	1, 4, 7, 8, 9, 15, 17	1:3 ft ²
ENRGY 3 Plus Minimum 1.5" thick	1, 2, 4, 11, 12, 13, 14, 15, 17	1:4 ft ²
Multi-Max-3 Minimum 1.5" thick	1, 4, 7, 8, 9, 11, 12, 13, 14, 15	1:2.9 ft ²
ISO 95+ GL Minimum 1.4" thick	1, 4, 7, 8, 9, 11, 12, 13, 14, 15, 17	1:4 ft ²



<u>Top Insulation Layer (Continued)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Fesco Foam Minimum 1.5" thick	1, 2, 4, 5, 7, 8, 9, 11, 13, 15, 17	1:4 ft ²
ENRGY 3 Composite Minimum 1.25" thick	1, 2, 4, 7, 8, 9, 11, 12, 13, 14, 15, 17	1:4 ft ²
ACFoam Composite Minimum 1.5" thick	4, 7, 8, 9, 11, 12, 13, 14, 15	1:2.67 ft ²
ISO 95+ Composite Minimum 1.4" thick	1, 2, 4, 5, 7, 8, 9, 11, 12, 13, 14, 15, 17	1:3 ft ²
Fesco Board Minimum 3/4" thick	1, 4, 5, 7, 9, 15, 17	1:2 ft ²
High Density Wood Fiberboard Minimum 1/2" thick	1, 4, 7, 8, 15	1:2 ft ²

Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Insulation fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (Optional) Install one ply of Type 43 coated base sheet, Glass-Base™ or Base-N-Ply® base sheet directly to the insulated substrate. Adhere in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; see General Limitation #4.

Note: **Type 43 coated base sheet cannot be spot mopped.**

Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See specification for appropriate number of plies).

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See Tamko application instructions for approved method of installation).

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure: -45 psf (See General Limitation #9.)



Membrane Type: BUR
Deck Type 7I: Recover
Deck Description: wood/steel/concrete
System Type D: Base sheet attached over insulation.

All General and System Limitations apply.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
One or more layers of any of the following insulations: ACFoam II, ENRGY 3, ENRGY 3 Plus, IsoTherm R, ENRGY 3 Composite, ISO 95+GL, ISO 95+ Composite, ISO-Roc, UltraGard Gold, ACFoam Composite, Pyrox, Multi-Max FA, H-Shield, H-Shield WF		
Minimum 1" thick	N/A	N/A
Fesco Board		
Minimum 1/2" thick	N/A	N/A
High Density Wood Fiberboard, Structodek FS		
Minimum 1/2" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

Base Sheet: One ply of Tamko Glass-Base, Vapor-Chan, Base-N-Ply, or Awaplan Versa-Smooth fastened to the deck as described below:

Fastening: *(Option #1 – wood decks only)* Attach anchor sheet using 11 ga. annular ring shank nails and 1-5/8" diameter tin caps spaced 9" o.c. in a 4" lap and 9" o.c. in two staggered rows in the center of the sheet.
(Meets –52.5 psf, See General Limitation #7.)

(Option #2 – wood or steel decks only) Attach anchor sheet using CF Dekfast or #14 Dekfast Fasteners with CF Hex Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
(Meets –60 psf, See General Limitation #7.)

(Option #3 – steel or concrete decks only) Attach anchor sheet using SFS #12 or HD Insulfixx S, or Buildex Accutrac Fasteners or #14, #15 Roofgrip and 3" Square Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
(Meets –75 psf, See General Limitation #7.)

(Option #4 – steel or concrete decks only - Awaplan Versa-Smooth only) Attach anchor sheet using Buildex Accutrac Fasteners or #14, #15 Roofgrip and 3" Square Plates spaced 12" o.c. in a 4" lap and 12" o.c. in two staggered rows in the center of the sheet.
(Meets –120 psf, See General Limitation #7.)

Note: Base sheet fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements set forth in applicable Building Code.



Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See specification number for appropriate number of plies.)

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. (See Tamko application instructions for approved method of installation).

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure: *See Base Sheet Fastening Options.*



Membrane Type: BUR
Deck Type 7: Recover
Deck Description: wood/steel/concrete
System Type E: Base sheet mechanically attached.

All General and System Limitations apply.

Base Sheet: One ply of Tamko Glass-Base, Vapor-Chan, Base-N-Ply, or Awaplan Versa-Smooth fastened to the deck as described below:

Fastening: *(Option #1 – wood decks only)* Attach anchor sheet using 11 ga. annular ring shank nails and 1-5/8” diameter tin caps spaced 9” o.c. in a 4” lap and 9” o.c. in two staggered rows in the center of the sheet.

(Meets –52.5 psf, See General Limitation #7.)

(Option #2 – wood or steel decks only) Attach anchor sheet using CF Dekfast or #14 Dekfast Fasteners with CF Hex Plates spaced 12” o.c. in a 4” lap and 12” o.c. in two staggered rows in the center of the sheet.

(Meets –60.0 psf, See General Limitation #7.)

(Option #3 – steel or concrete decks only) Attach anchor sheet using SFS #12 or HD Insulfixx S, or OMG Accutrak Fasteners or #14, #15 Roofgrip and 3” Square Plates spaced 12” o.c. in a 4” lap and 12” o.c. in two staggered rows in the center of the sheet.

(Meets –75.0 psf, See General Limitation #7.)

(Option #4 – steel or concrete decks only - Awaplan Versa-Smooth only) Attach anchor sheet using OMG Accutrak Fasteners or #14, #15 Roofgrip and 3” Square Plates spaced 12” o.c. in a 4” lap and 12” o.c. in two staggered rows in the center of the sheet.

(Meets –120.0 psf, See General Limitation #7.)

Note: Base sheet fasteners shall be tested for withdrawal resistance in compliance with Testing Application Standard TAS 105 to confirm compliance with the wind load requirements set forth in applicable Building Code.

Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq..(See specification for appropriate number of plies).

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. (See Tamko application instructions for approved method of installation).

Surfacing: (Required if no cap sheet is used) Install one of the following:
1 Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure: *See Base Sheet Fastening Options.*



Membrane Type: BUR

Deck Type 7: Recover

Deck Description: concrete

System Type F: Base sheet adhered with approved asphalt.

All General and System Limitations apply.

Note: Existing roof surface deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application.

Base Sheet: One ply of one of Glass-Base™, Base-N-Ply® or Vapor-Chan® venting base sheet adhered directly to the existing system in a spot mopping of ASTM D 312, type III or type IV asphalt, 12" diameter circles, 24" o.c., or strip mopped according to the manufacturers' recommendations. Application of either system shall be at a rate of 12 lbs./sq..

Ply Sheet: Two or more plies of Tam-Glass Premium® or Tam-Ply IV ply sheet adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. (See specification for appropriate number of plies.)

Cap Sheet: (Optional) One ply of Tam-Cap® adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.. (See Tamko application instructions for approved method of installation).

Surfacing: (Required if no cap sheet is used) Install one of the following:

1. Tam-Pro FR Fibered Aluminum Coating applied at 1½ gal./sq. or Tam-Pro Fibered Emulsion at 3 gal./sq.
2. Flood coat of approved asphalt with an application rate of 60 lbs./sq.; plus gravel or slag with an application rate of 400 or 300 lbs./sq. respectively.

Maximum Design Pressure: -230 psf (See General Limitation #9.)



RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9B-72 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No: 11-0415.14
Expiration Date: 08/23/12
Approval Date: 08/18/11
Page 20 of 20