



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/building/

NOTICE OF ACCEPTANCE (NOA)

Tremco Inc.
3735 Green Road
Beachwood, OH 44122

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Tremco Modified Bitumen Roofing Systems Over Cementitious Wood Fiber Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 11-0301.07 and consists of pages 1 through 10.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 11-0623.06
Expiration Date: 08/09/21
Approval Date: 07/28/16
Page 1 of 10

ROOFING SYSTEM APPROVAL

Category:	Membrane Roofing System
Sub-Category:	Modified Bitumen
Material:	SBS
Deck Type:	Cementitious Wood Fiber
Maximum Design Pressures:	-45 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
BURmastic Adhesive	5 or 55 gallon	Proprietary	Cold applied ply sheet and surfacing adhesive.
BURmastic Composite Ply	3' x 72'	ASTM D 4601 Type II	Asphalt coated, polyester/fiberglass reinforced base/ply sheet.
BURmastic Glass Ply	3' x 72'	ASTM D 4601 Type II	Asphalt coated, fiberglass reinforced base/ply sheet.
BURmastic Glass Ply 28 lb	3' x 108'	ASTM D 4601 Type II	Asphalt coated, fiberglass reinforced base/ply sheet.
Double Duty Aluminum	5 gallons	ASTM D 2824	Aluminum pigmented roof coating.
FAS-N-FREE	System	Proprietary	One part, solvent free insulation adhesive.
ICE Coating	5 and 55 gallons	Proprietary	High solids, water-based, elastomeric coating.
Alumanation 301	5 and 55 gallons	ASTM D 2824 Type III	Asphalt based, fibered aluminum roof coating.
PolyTHERM Roofing Ply	39 3/4" x 318'	Proprietary	Non-woven, heat resistant polyester ply sheet.
POWERply Standard FR	39 1/2" x 34.5'	ASTM D 6163	Fiberglass reinforced modified-bitumen membrane.
POWERply Premium FR	39 1/2" x 34.5'	ASTM D 6162	Composite reinforced modified-bitumen membrane.
POWERply Supreme FR	39 1/2" x 34.5'	ASTM D 6162	Composite reinforced modified-bitumen membrane.
POWERply Premium Smooth	39 1/2" x 51.5'	ASTM D 6162	Composite reinforced modified-bitumen membrane.
POWERply Supreme Smooth	39 1/2" x 34.5'	ASTM D 6162	Composite reinforced modified-bitumen membrane.
POWERply Standard Cold Adhesive	5 and 55 gallon containers	Proprietary	Cold applied ply sheet and membrane adhesive.
Premium III	100 lb. keg	ASTM D 312	Premium grade Type III asphalt.



TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Premium IV	100 lb. keg	ASTM D 312	Premium grade Type IV asphalt.
THERMastic 80	60 lb. Containers	Proprietary	Polymer modified hot melt adhesive.
THERMglass Type IV	3' x 180'	ASTM D 2178 Type IV	Type IV asphalt impregnated glass felt.
THERMglass Premium VI	3' x 180'	ASTM D 2178 Type VI	Type VI asphalt impregnated glass felt.
TremLastic S Adhesive	5 or 55gallon	Proprietary	Non-fibered, polymer modified asphalt emulsion.
TREMprime Q.D. primer	1,5 or 55 gallon containers	ASTM D 41	Asphalt based roofing primer.
TREMprime WB primer	5 gallon container	Proprietary	Water based roofing primer.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS

TABLE 2

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
ACFoam-II	Various	TAS 110	Polyisocyanurate foam insulation	Atlas Roofing Corporation
ISO 95+ GL	Various	TAS 110	Polyisocyanurate foam insulation	Firestone Building Products Company, LLC
ENRGY 3 ENRGY 3 Plus	Various	TAS 110	Polyisocyanurate foam insulation	Johns Manville Corp.
Ultra-Max	Various	TAS 110	Polyisocyanurate foam insulation	Rmax Operating, LLC
Multi-Max FA-3	Various	TAS 110	Polyisocyanurate foam insulation	Rmax Operating, LLC
High Density Wood Fiberboard	Various	TAS 110	Wood fiber insulation board	Generic
Perlite Insulation Board		TAS 110	Perlite insulation board	Generic



APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Polymer GypTec	Insulation and Base sheet Fastener	Various	OMG, Inc.
2.	Polymer GypTec Insulation Plate	Galvalume round stress plate	3” round	OMG, Inc.
3.	Polymer GypTec Plate 2” with barbs	Galvalume round stress plate	2” round	OMG, Inc.

EVIDENCE SUBMITTED:

<u>Test agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Factory Mutual Research Corporation	1994 FM	Current Insulation Fastening Requirements	01/01/94
	2Y9A5.AM	FM 4470	11/13/95
	2D1A8.AM	FM 4470	07/27/2000
	0D0A9.AM	FM 4470	08/01/2000
PRI Asphalt Technologies, Inc.	TRE-15-02-01	Physical Properties	05/25/99
Underwriters Laboratories, Inc.	R6692	Fire Classification Compliance	01/01/94
Momentum Technologies, Inc.	DX12K5A	ASTM D 6163	11/07/05
	CX13K5A	ASTM D 6162	11/07/05
	DX11K5A	ASTM D 6164	11/07/05



APPROVED ASSEMBLIES:

- Membrane Type:** SBS
- Deck Type 5I:** Cementitious Wood Fiber, Insulated
- Deck Description:** Cementitious Wood Fiber
- System Type A(1):** Anchor sheet mechanically fastened; one or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Perlite Insulation Board Minimum 1” thick	N/A	N/A
<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Perlite Insulation Board Minimum 1” thick	N/A	N/A

Note: All insulation shall be adhered to the anchor sheet in THERMastic 80 at 2.5 gal./sq. or in full mopping of approved hot asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment.

- Anchor Sheet:** One ply of BURmastic Composite Ply or BURmastic Glass Ply or BURmastic Glass Ply 28 lb mechanically fastened to the deck as detailed below.
- Fastening:** Fasten anchor sheet with approved fasteners at a 4" side lap 9" o.c. and two rows staggered in the center of the sheet 18" o.c.
- Base Sheet:** (Optional) One ply of PolyTHERM Roofing Ply or BURmastic Composite Ply adhered to the insulated substrate with THERMastic 80 or Premium III asphalt at an application rate of 32 lb./sq. ± 15%.
- Ply Sheet:** (Optional) Two plies of THERMglass Type IV adhered to the insulated substrate with THERMastic 80, Premium III or Premium IV asphalt at an application rate of 32 lb./sq. ± 15%.
- Cap Sheet:** (Optional) POWERply Supreme FR, POWERply Standard FR, POWERply Premium FR adhered with THERMastic 80 or Premium III asphalt at an application rate of 32 lb./sq. ± 15% or POWERply Standard Cold Adhesive at a rate of 1.5-2 gal./sq.



Surfacing:

Use one of the following surfacing.

1. Gravel or slag applied at 300 lbs. or 400 lbs., respectively, in THERMastic 80 or ASTM D312 asphalt at an application rate of 60 lb./sq. \pm 15%.
2. A coat of Double Duty Aluminum at 1 gal./sq.

**Maximum Design
Pressure:**

-45 psf. (See General Limitation #9.)



Membrane Type: SBS
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type A(2): Anchor sheet mechanically fastened; one or more layers of insulation adhered with approved asphalt.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, Ultra-Max Minimum 1.5" thick	N/A	N/A

Note: Base layers of insulation shall be bonded to anchor sheet with ½" ribbons of FAS-N-FREE adhesive applied at 1.5 gal./sq. for perlite and polyisocyanurate insulation.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Perlite Insulation Board Minimum 1" thick	N/A	N/A

Note: Top layer of insulation shall be bonded with ½" ribbons of FAS-N-FREE adhesive applied at 1.5 gal./sq. for perlite and polyisocyanurate insulation.

Anchor Sheet: One ply of BURmastic Composite Ply or BURmastic Glass Ply or BURmastic Glass Ply 28 lb mechanically fastened to the deck as detailed below.

Fastening: Fasten anchor sheet with approved fasteners at a 4" side lap 9" o.c. and two rows staggered in the center of the sheet 18" o.c.

Base Sheet: (Optional) One ply of PolyTHERM Roofing Ply or BURmastic Composite Ply adhered to the insulated substrate with THERMastic 80 or Premium III asphalt at an application rate of 32 lb./sq. ± 15%.

Ply Sheet: (Optional) Two plies of THERMglass Type IV adhered to the insulated substrate with THERMastic 80, Premium III or Premium IV asphalt at an application rate of 32 lb./sq. ± 15%.

Cap Sheet: (Optional) POWERply Supreme FR, POWERply Standard FR, POWERply Premium FR adhered with THERMastic 80 or Premium III asphalt at an application rate of 32 lb./sq. ± 15% or POWERply Standard Cold Adhesive at a rate of 1.5-2 gal./sq.



Surfacing:

Use one of the following surfacing.

1. Gravel or slag applied at 300 lbs. or 400 lbs., respectively, in THERMastic 80 or ASTM D312 asphalt at an application rate of 60 lb./sq. \pm 15%.
2. A coat of Double Duty Aluminum at 1 gal./sq.

Maximum Design Pressure:

-45 psf. (See General Limitation #9.)



Membrane Type: SBS
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type C: All layers of insulation simultaneously fastened.

All General and System Limitations apply.

One or more layers of any of the following insulations.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Perlite Insulation Board Minimum 3/4" thick	N/A	N/A

Note: All layers shall be simultaneously attached; see top layer below for fasteners and density.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Perlite Insulation Board Minimum 3/4" thick	1, 2, 3	1:2 ft ²

Note: Refer to Roofing Application Standard RAS 117 for insulation attachment requirements. Insulation panels listed are minimum sizes and dimensions; if larger panel are used the number of fasteners per board shall be increased maintaining the same fastener density (see Roofing Application Standard RAS 117 for fasteners details).

Base Sheet: (Optional) One ply of PolyTHERM Roofing Ply or BURmastic Composite Ply adhered to the insulated substrate with THERMastic 80 or Premium III asphalt at an application rate of 32 lb./sq. ± 15%.

Ply Sheet: (Optional) Two plies of THERMglass Type IV adhered to the insulated substrate with THERMastic 80, Premium III or Premium IV asphalt at an application rate of 32 lb./sq. ± 15%.

Cap Sheet: (Optional) POWERply Supreme FR, POWERply Standard FR, POWERply Premium FR adhered with THERMastic 80 or Premium III asphalt at an application rate of 32 lb./sq. ± 15% or POWERply Standard Cold Adhesive at a rate of 1.5-2 gal./sq.

Surfacing: Use one of the following surfacing.

1. Gravel or slag applied at 300 lbs. or 400 lbs., respectively, in THERMastic 80 or ASTM D312 asphalt at an application rate of 60 lb./sq. ± 15%.
2. A coat of Double Duty Aluminum at 1 gal./sq.

Maximum Design Pressure: -45 psf. (See General Limitation #9.)



NOA No.: 11-0623.06
 Expiration Date: 08/09/21
 Approval Date: 07/28/16
 Page 9 of 10

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 11-0623.06
Expiration Date: 08/09/21
Approval Date: 07/28/16
Page 10 of 10