



DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY
 AFFAIRS (PERA)
 BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
 PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786)315-2590 F (786) 31525-99
www.miamidade.gov/pera

Intertape Polymer Corp.
50 Abbey Ave
Truro, Nova Scotia, Canada B2N6W4

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Nova Seal Premium Roofing Underlayment

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 07-0307.08 and consists of pages 1 through 3.
 The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 11-1101.04
 Expiration Date: 02/01/17
 Approval Date: 02/02/12
 Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

SCOPE:

This acceptance is for **Nova Seal Premium Roofing Underlayment** as manufactured by Intertape Polymer Corporation, as described in this Notice of Acceptance, for use with approved prepared roof assemblies where ASTM D 226 Type I or II underlayment is specified. (See Limitations Below). Designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Nova Seal Premium Roofing Underlayment	Width = 36", 38", up to 144" Length = min. 25'	ASTM D 226 Type I & Type II TAS 104	A hybrid underlayment composed of a woven-polypropylene core, coated on both sides with a polymer coating.

MANUFACTURING LOCATION:

1. Truro, Nova Scotia, Canada

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Intertek ETL SEMKO	3092073COQ-002	TAS-104	08/16/06

INSTALLATION:

1. Nova Seal Premium Roofing Underlayment and its components shall be installed in strict compliance with applicable Building Code.
2. Nova Seal Premium Roofing Underlayment shall be installed with a minimum 4-inch head lap in a shingle layer fashion and a 6" end lap where required. Fastener spacing shall be a maximum of 4" o.c. on the head and end laps and 12" o.c. vertically and horizontally in the field of the membrane in compliance with Florida Building Code 1518.2 .
3. Nova Seal Premium Roofing Underlayment may be used with Asphaltic shingles, Wood shakes and shingles, Non-structural metal roofing, and quarry slate.
4. Nova Seal Premium Roofing Underlayment shall not be used as roof tile underlayment or anchor sheet within a roof tile underlayment system.
5. For fire classifications of specific roof assemblies using Nova Seal Premium Roofing Underlayment refer to a current Approved Roofing Materials Directory for fire ratings of this product.



NOA No.: 11-1101.04
Expiration Date: 02/01/17
Approval Date: 02/02/12
Page 2 of 3

LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. Nova Seal Premium Roofing Underlayment is a component used in roof assemblies. Roof assemblies are approved under specific assembly Notice of Acceptance.
4. Nova Seal Premium Roofing Underlayment shall not be left exposed as a temporary roof for longer than 30 days of application. Intertape Polymer Corp., reserves the right to revise or alter product exposure times; not to exceed the preceding maximum time limitations.
5. Nova Seal Premium Roofing Underlayment can be used in any prepared roof assemblies were an ASTM D 226 Type I & II is required with the exception of Roof Tile Systems.
6. Nova Seal Premium Roofing Underlayment may be used with any approved roof covering Notice of Acceptance listing Nova Seal Premium Roofing Underlayment as a component part of an assembly in the Notice of Acceptance. If Nova Seal Premium Roofing Underlayment is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

END OF THIS ACCEPTANCE



NOA No.: 11-1101.04
Expiration Date: 02/01/17
Approval Date: 02/02/12
Page 3 of 3