



DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY  
AFFAIRS (PERA)  
BOARD AND CODE ADMINISTRATION DIVISION  
**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/pera/](http://www.miamidade.gov/pera/)

**Mitten, Inc.**  
70 Curtis Avenue North  
Paris, Ontario N3L 3T2 Canada

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

**DESCRIPTION: Vinyl Siding & Soffit Panels**

**APPROVAL DOCUMENT:** Engineering Report & Drawing No. 11-107, titled "Vinyl Siding & Soffit Panels" sheets 1 through 10 of 10, dated 11/04/2011, prepared by CBUCK Engineering, signed and sealed by James L. Buckner, P.E., bearing the Miami-Dade County Product Control revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

**MISSILE IMPACT RATING: None**

**LABELING:** Each Siding piece shall bear a permanent label marked at not more than 4' o.c. with the manufacturer's name or logo, Paris, Ontario, Canada, and following statement: "Miami-Dade County Product Control Approved" and per FBC 1715.9 on Soffits.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA revises NOA # 10-0722.02 and consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by Carlos M. Utrera, P.E.



*[Signature]*  
05/17/2012

NOA No. 11-1213.10  
Expiration Date: January 13, 2016  
Approval Date: May 24, 2012  
Page 1

**NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED**

**A. DRAWINGS**

1. Engineering Report & Drawing No. **11-107**, titled "Vinyl Siding & Soffit Panels" sheets 1 through 10 of 10, dated 11/04/2011, prepared by CBUCK Engineering, signed and sealed by James L. Buckner, P.E.

**B. TESTS**

	<b>Test Report No.</b>	<b>Standard</b>	<b>Date</b>	<b>Signature</b>
1.	ATI-93164.03-109-18	TAS 202 and 203	02/07/11	Michael D. Stremmel, P.E.
2.	ATI-93166.01-109-18	TAS 202 and 203	04/14/11	Michael D. Stremmel, P.E.
3.	ATI-93158.01-109-18	TAS 202 and 203	04/08/11	Michael D. Stremmel, P.E.
4.	ATI-93160.01-109-18	TAS 202 and 203	04/08/11	Michael D. Stremmel, P.E.
5.	ATI-93163.01-109-18	TAS 202 and 203	04/13/11	Michael D. Stremmel, P.E.
6.	ATI-93167.01-109-18	TAS 202 and 203	04/14/11	Michael D. Stremmel, P.E.
7.	HETI-11-A101	ASTM G155	10/11/11	Rafael E. Droz-Seda, P.E.
8.	HETI-11-T135A	ASTM D 638	10/11/11	Rafael E. Droz-Seda, P.E.
9.	HETI-11- T136A	ASTM D 638	10/10/11	Rafael E. Droz-Seda, P.E.
10.	HETI-11-A102	ASTM G155	10/13/11	Rafael E. Droz-Seda, P.E.
11.	HETI-11-T141	ASTM D 638	10/13/11	Rafael E. Droz-Seda, P.E.
12.	HETI-11- T136B	ASTM D 638	10/11/11	Rafael E. Droz-Seda, P.E.
	<i>"Submitted under NOA # 10-0722.02"</i>			
13.	ATI-92398.01-106-18	ASTM D1929,		
		D2843/D635	06/10/10	Joseph A. Reed, P.E.
14.	ATI-93453.01-106-18	ASTM D3679/D696	09/10/10	Joseph A. Reed, P.E.

**C. CALCULATIONS:**

1. None.

**D. QUALITY ASSURANCE**

1. Miami-Dade Department of Permitting, Environment, and Regulatory Affairs (PERA)

**E. MATERIAL CERTIFICATIONS**

1. None.

**F. STATEMENTS**

1. Statement letter of code conformance to FBC 2010, issued by CBUCK Engineering, dated 12/01/2011, signed and sealed by James L. Buckner, P.E.
2. Statement letter of no financial interest, issued by CBUCK Engineering, dated 12/01/2011, signed and sealed by James L. Buckner, P.E.

  
05/17/2012

Carlos M. Utrera, P.E.  
Product Control Examiner  
NOA No. 11-1213.10

Expiration Date: January 13, 2016  
Approval Date: May 24, 2012

**Engineering Report & Drawings**  
of  
**Mitten, Inc.**  
**Vinyl Siding & Soffit Panels**  
for  
**Miami-Dade Notice of Acceptance (N.O.A.)**

**Category: Cladding**  
**Sub - Category: Siding / Soffit**

Product: Vinyl Siding & Soffit Panels

**Prepared by:**  
**James L. Buckner, P.E.**  
Florida Professional Engineer # 31242  
Project Manager: Diana Galloway  
Report No.: 11-107-ENGREPORT  
Date: 11 / 04 / 11

Contents:

Cover Page	Page 1
Product Description/Performance	Page 2-4
Limitations/Reference Data	Page 4
Product Components	Page 5
Product Drawings & Details	Page 6-10

**PRODUCT REVISED**  
as complying with the Florida  
Building Code  
Acceptance No 11-1213.10  
Expiration Date 01/13/2016  
By [Signature]  
Miami Dade Product Control

*[Signature]*  
**JAMES L. BUCKNER, P.E.**  
FLORIDA P.E. #31242  
3/20/12

**MITTEN, INC. VINYL SIDING / SOFFIT PANELS**  
**ENGINEERING REPORT**

**CBUCK Engineering**  
Specialty Structural Engineering  
**CBUCK, Inc.**  
1399 N. Killian Dr., Ste 4  
W. Palm Beach, FL 33403  
(561) 491-9927

**MANUFACTURER:**  
Mitten, Inc.  
70 Curtis Avenue North  
Paris, Ontario N3L 3T2 CANADA

<b>DATE:</b>	11/04/11
<b>PAGE #:</b>	1 OF 10
<b>PROJECT #:</b>	11-107
<b>DRAWN BY:</b>	DG
<b>REVISION:</b>	1

PRODUCT REVISED  
 as complying with the Florida  
 Building Code  
 Acceptance No 11-1213.10  
 Expiration Date 01/13/2016  
 By *[Signature]*  
 Miami-Dade Product Control

- 1.0 Product:
  - 1.1 Manufacturer: Mitten, Inc.
  - 1.2 Product Name: Vinyl Siding & Soffit Panels
  - 1.3 Category: Cladding
  - 1.4 Subcategory: Siding - Soffits

2.0 Evaluation Scope:

2.1 Evaluation Criteria:

- 2.1.1 Florida Building Code (FBC) 2010
  - 2.1.1.1 Code Section: High Velocity Hurricane Zone (HVHZ)
  - 2.1.1.2 Miami-Dade Building and Neighborhood Compliance (BNC) Checklist # 0280

2.2 Properties Evaluated:

- 2.2.1 Wind Resistance Properties
  - 2.2.1.1 Uniform Static Air Pressure  
(Structural only. This system has not been tested for water & air infiltration.)
  - 2.2.1.2 Cyclic Wind Pressure
- 2.2.2 Material Properties
  - 2.2.2.1 Standard specification for PVC vinyl siding
  - 2.2.2.2 Outdoor exposure for 4500 hours
  - 2.2.2.3 Tensile test
- 2.2.3 Fire Resistance Properties
  - 2.2.3.1 Self-ignition temperature greater than 650° F
  - 2.2.3.2 Smoke density rating
  - 2.2.3.3 Rate of burning

2.3 Limits of Evaluation:

This product is limited to compliance with the criteria in section 2.1 and properties in section 2.2 of this report.

3.0 Evaluated Uses:

Mitten, Inc.'s "Vinyl Siding & Soffit Panels" are evaluated for use as exterior siding or soffit panels.

4.0 Product Description:

4.1 General:

"Mitten, Inc.'s "Vinyl Siding & Soffit"" panels are exterior siding and/or soffit panels manufactured from a PVC compound with a wood-grain texture appearance, concealed fasteners and an interlocking seam edge. Panels are attached with roofing nails.

*[Signature]*  
 JAMES L. BUCKNER, P.E.  
 FLORIDA P.E. #31242  
 3/20/12

MITTEN, INC. VINYL SIDING / SOFFIT PANELS  
 ENGINEERING REPORT

 <b>CBUCK Engineering</b> Specialty Structural Engineering CBUCK, Inc. 1399 N. Killian Dr., Ste 4 W. Palm Beach, FL 33403 (561) 491-9927	<b>MANUFACTURER:</b>	<b>DATE:</b> 11/04/11
	Mitten, Inc.	<b>PAGE #:</b> 2 OF 10
	70 Curtis Avenue North	<b>PROJECT #:</b> 11-107
	Paris, Ontario N3L 3T2 CANADA	<b>DRAWN BY:</b> DG
		<b>REVISION:</b> 1

**5.0 Support:**

Walls and soffit where vinyl siding is to be installed shall be designed by others in accordance with FBC 2010 and have been evaluated based on the following minimum characteristics:

**5.1 Siding Panel**

- 5.1.1 Support Description: Plywood supported by wood studs (By Others)
- 5.1.2 Plywood Thickness: 5/8"
- 5.1.3 Stud Description: 2" (min. thickness) Dimensional Lumber (By Others)
- 5.1.4 Stud Spacing: 16" o.c.

**5.2 Soffit Panel**

- 5.2.1 Support Description: Wood battens
- 5.2.2 Batten Description: 2" x 2" (min. thickness) Dimensional Lumber
- 5.2.3 Batten Spacing: Per Table "A"

**6.0 Performance:**

**6.1 Wind Resistance:**

Design Pressure: Refer to Table "A"

**6.1.1 Uniform Static Air Pressure:**

- Standard: TAS 202
- Results: Per Section 6.1

**6.1.2 Cyclic Wind Loading:**

- Standard: TAS 203
- Results: PASS

**6.2 Material Properties:**

**6.2.1 Vinyl Siding Specification:**

- Standard: ASTM D3679
- Results: PASS

**6.2.2 Outdoor Exposure:**

- Standard: ASTM G155
- Results: PASS

**6.2.3 Tensile:**

- Standard: ASTM D638
- Results: PASS

**7.0 Fire Resistance Properties:**

**7.1 Self-ignition Temperature:**


- Standard: ASTM D1929
- Test Results: 806°F (> 650°F per NOA Criteria)
- Results: PASS


**7.2 Smoke Density:**

- Standard: ASTM D2843
- Test Results: 39.5 (< 75 per NOA Criteria)
- Results: PASS

**7.3 Rate of Burning:**

- Standard: ASTM D635
- Test Results: No self sustained burn, Class C1
- Results: PASS

**PRODUCT REVISED**  
 as complying with the Florida  
 Building Code  
 Acceptance No 11-1213.10  
 Expiration Date 01/13/2016  
 By   
 Miami/Dade Product Control

  
**JAMES L. BUCKNER, P.E.**  
 FLORIDA P.E. #31242  
 3/20/12

**MITTEN, INC. VINYL SIDING / SOFFIT PANELS  
 ENGINEERING REPORT**

 **CBUCK Engineering**  
 Specialty Structural Engineering  
 CBUCK, Inc.  
 1399 N. Killian Dr., Ste 4  
 W. Palm Beach, FL 33403  
 (561) 491-9927

**MANUFACTURER:**  
 Mitten, Inc.  
 70 Curtis Avenue North  
 Paris, Ontario N3L 3T2 CANADA

**DATE:** 11/04/11  
**PAGE #:** 3 OF 10  
**PROJECT #:** 11-107  
**DRAWN BY:** DG  
**REVISION:** 1

**8.0 Installation:**

(Refer to Tables "A", "B" & Drawings on pages 7 - 10 of this report)

Install "Mitten, Inc's "Vinyl Siding & Soffit" panels per the following:

- Attach panels with fasteners per Section 13.2, & Tables "A" & "B"
- Fastener spacing: Per Tables "A" & "B"
- Ensure panels are fully engaged along bottom length of panels, do not force up to tighten when fastening.

Refer to manufacturer's installation instructions as a supplemental guide for attachment.

**9.0 Limitations & Conditions of Use:**

- 9.1 Areas where soffits and vinyl siding is to be installed shall be checked for structural adequacy and free of cracks or defects.
- 9.2 Walls shall have a minimum water-resistant barrier equivalent to one layer of #15 asphalt felt complying with ASTM D 226, Type I in accordance with FBC 2010, Section 1404.2.
- 9.3 Design of support system is outside the scope of this report. Support shall be designed by others and comply with the FBC 2010 (HVHZ Section).
- 9.4 This evaluation is limited to the siding/soffit panel, panel fasteners and its attachment to the supports. The structural properties and design of all other items are outside the scope of this evaluation and should be submitted to the permitting jurisdiction for review and approval. Siding/soffit accessories shall be in accordance with FBC 2010 (HVHZ Section) and manufacturer's recommendations.

**10.0 Code Compliance:**

- 10.1 Product meets the High Velocity Hurricane Zone (HVHZ) Requirements of the Florida Building Code (FBC) 2010 for the properties evaluated.


**11.0 Identification:**

- 11.1 Each Panel shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved".
- 11.2 Labeling shall comply with FBC 2010, Section 1715.9.


**12.0 Referenced Data:**

**12.1 Test Reports:**

LABORATORY / REPORT	TEST	DATE	SIGNATURE
1. ATI / 93158.01-109-18	TAS 202 & 203	4/09/10	Micheal Stremmel, P.E.
2. ATI / 93160.01-109-18	TAS 202 & 203	4/09/10	Micheal Stremmel, P.E.
3. ATI / 93163.01-109-18	TAS 202 & 203	4/09/10	Micheal Stremmel, P.E.
4. ATI / 93166.01-109-18	TAS 202 & 203	4/09/10	Micheal Stremmel, P.E.
5. ATI / 93167.01-109-18	TAS 202 & 203	4/09/10	Micheal Stremmel, P.E.
6. ATI / 93164.03-109-18-r2	TAS 202 & 203	2/07/11	Micheal Stremmel, P.E.
7. ATI / 93453.01-106-18	ASTM D 3679	9/10/09	Joseph Reed, P.E.
8. ATI / 92398.01-106-18	ASTM D 1929, ASTM D2843, ASTM D 635	6/10/10	Joseph Reed, P.E.
9. HET / HETI-11-T135A	ASTM D 638-08 & 10	10/11/11	Rafael E. Droz-Seda, P.E.
10. HET / HETI-11-T136A	ASTM D 638-08 & 10	10/11/11	Rafael E. Droz-Seda, P.E.
11. HET / HETI-11-T136B	ASTM D 638-08 & 10	10/11/11	Rafael E. Droz-Seda, P.E.
12. HET / HETI-11-A101	ASTM G 155-05A	10/11/11	Rafael E. Droz-Seda, P.E.
13. HET / HETI-11-A102	ASTM G 155-05A	10/13/11	Rafael E. Droz-Seda, P.E.
14. HET / HETI-11-T141	ASTM D 638-08 & 10	10/13/11	Rafael E. Droz-Seda, P.E.

  
 JAMES L. BUCKNER, P.E.  
 FLORIDA P.E. #31242  
 3/20/12

MITTEN, INC. VINYL SIDING / SOFFIT PANELS  
 ENGINEERING REPORT

  
 Specialty Structural Engineering  
 CBUCK, Inc.  
 1399 N. Killian Dr., Ste 4  
 W. Palm Beach, FL 33403  
 (561) 491-9927

MANUFACTURER:  
 Mitten, Inc.  
 70 Curtis Avenue North  
 Paris, Ontario N3L 3T2 CANADA

DATE: 11/04/11  
 PAGE #: 4 OF 10  
 PROJECT #: 11-107  
 DRAWN BY: DG  
 REVISION: 1

**13.0 Product Components:**

**13.1 Vinyl Siding & Soffit Panels:**

**13.1.1 Profiles / Dimensions:**

Refer to Tables "A", "B" & Profile Drawings

**13.1.2 Properties:**

<b>13.1.2.1</b>	Material:	Polyvinyl Chloride (PVC)
<b>13.1.2.2</b>	Tensile Strength:	7,344 psi
<b>13.1.2.3</b>	Standard:	ASTM D 3679-05
<b>13.1.2.4</b>	Color:	Painted, by manufacturer

**13.2 Fasteners:**

<b>13.2.1</b>	Manufacturer:	Generic
<b>13.2.2</b>	Standard:	Miami-Dade approved
<b>13.2.3</b>	Corrosion Resistance:	Electro-Galvanized or Hot-Dipped


**13.2.3.1 Fastener Option #1:** Ring Shank Roofing Nail  
Size/Dimensions

<b>13.2.3.1.1</b>	Length:	1-1/2"
<b>13.2.3.1.2</b>	Shank Diameter:	1/8"
<b>13.2.3.1.3</b>	Head Diameter:	3/8"

**13.2.3.2 Fastener Option #2:** Ring Shank Roofing Nail with Steel Washer  
Size/Dimensions

<b>13.2.3.2.1</b>	Nail Length:	1-1/2"
<b>13.2.3.2.2</b>	Nail Shank Diameter:	1/8"
<b>13.2.3.2.3</b>	Nail Head Diameter:	3/8"
<b>13.2.3.2.4</b>	Washer Material:	Steel, corrosion resistant
<b>13.2.3.2.5</b>	Washer Diameter:	5/8"
<b>13.2.3.2.6</b>	Washer Thickness:	1/16"

PRODUCT REVISED  
as complying with the Florida  
Building Code  
Acceptance No 11-1213-10  
Expiration Date 01/13/2016  
By   
Miami Dade Product Control

  
JAMES L. BUCKNER, P.E.  
FLORIDA P.E. #31242  
3/20/12

MITTEN, INC. VINYL SIDING / SOFFIT PANELS  
ENGINEERING REPORT

  
Specialty Structural Engineering  
CBUCK, Inc.  
1399 N. Killian Dr., Ste 4  
W. Palm Beach, FL 33403  
(561) 491-9927

MANUFACTURER:  
Mitten, Inc.  
70 Curtis Avenue North  
Paris, Ontario N3L 3T2 CANADA

DATE:	11/04/11
PAGE #:	5 OF 10
PROJECT #:	11-107
DRAWN BY:	DG
REVISION:	1

**MITTEN, INC.**  
**"VINYL SIDING & SOFFIT" PANELS**

Table "A" SOFFIT PANELS - DESIGN PRESSURES							
Model	Configuration	Thickness (±.002")	Exposure (x)	Nail Spacing (Y)	Fastener (per 13.2)	Batten Spacing (Z)	Design Pressure (PSF)
D5 Soffit	Double 5"	0.040"	10"	8"	Ring Shank Nail	8"	±50
D5 Soffit (Perforated)	Double 5"	0.040"	10"	8"	Ring Shank Nail	8"	±50
T4 Soffit	Triple 4"	0.040"	12"	12"	Ring Shank Nail with Washer	12"	±45
T4 Soffit (Perforated or Basketweave)	Triple 4"	0.040"	12"	12"	Ring Shank Nail with Washer	12"	±45

Table "B" SIDING - DESIGN PRESSURES							
Model	Configuration	Thickness (±.002")	Exposure (x)	Nail Spacing (y)	Fastener (per 13.2)	Stud Spacing (z)	Design Pressure (PSF)
Board & Batten	Single 7"	0.045"	7"	8"	Ring Shank Nail	16"	-50
D4.5 Horizontal	Double 4.5"	0.040"	9"	8"	Ring Shank Nail	16"	-40
D4.5 Dutchlap	Double 4.5"	0.040"	9"	8"	Ring Shank Nail	16"	-50
D5 Vertical	Double 5"	0.040"	10"	8"	Ring Shank Nail	16"	-37

Table "C" SOFFIT PANELS - NET FREE AREA	
Soffit Type	Free Flow Area (sq-in/sq-ft)
D5 (Perforated)	4.2
T4 (Perforated)	5.89
(Basketweave/Lanced)	7.2

**PRODUCT REVIEWED**  
 as complying with the Florida  
 Building Code  
 Acceptance No 11-1213.10  
 Expiration Date 01/13/2016  
 By *[Signature]*  
 Mitten/Date Product Control

*[Signature]*  
**JAMES L. BUCKNER, P.E.**  
 FLORIDA P.E. #31242  
 3/20/12


**MITTEN, INC. VINYL SIDING / SOFFIT PANELS  
 ENGINEERING REPORT**

**CBUCK Engineering**  
 Specialty Structural Engineering  
 CBUCK, Inc.  
 1399 N. Killian Dr., Ste 4  
 W. Palm Beach, FL 33403  
 (561) 491-9927


**MANUFACTURER:**  
 Mitten, Inc.  
 70 Curtis Avenue North  
 Paris, Ontario N3L 3T2 CANADA

**DATE:** 11/04/11  
**PAGE #:** 6 OF 10  
**PROJECT #:** 11-107  
**DRAWN BY:** DG  
**REVISION:** 1


**MITTEN, INC.**  
**"VINYL SIDING & SOFFIT" DRAWINGS**




**Board & Batten**




**D4.5 Horizontal**




**D4.5 Dutchlap**



**"J" Channel**



**D5 Vertical / D5 Soffit**



**T4 Soffit**


**TYPICAL PROFILE VIEWS  
& PANEL INTERLOCK**

**PRODUCT REVISED**  
 as complying with the Florida  
 Building Code  
 Acceptance No 11-1213.10  
 Expiration Date 01/13/2016  
 By [Signature]  
 Mitten, Inc. Product Control


[Signature]  
**JAMES L. BUCKNER, P.E.**  
 FLORIDA P.E. #31242  
 3/20/12

MITTEN, INC. "VINYL SIDING / SOFFIT PANELS" TYPICAL ASSEMBLY SIDE VIEWS		DATE: 11/04/11
<b>CBUCK Engineering</b> Specialty Structural Engineering CBUCK, Inc. 1399 N. Killian Dr., Ste 4 W. Palm Beach, FL 33403 (561) 491-9927	MANUFACTURER:	PAGE #: 7 OF 10
	Mitten, Inc. 70 Curtis Avenue North Paris, Ontario N3L 3T2 CANADA	PROJECT #: 11-107
		DRAWN BY: DG
		REVISION: 1

**MITTEN, INC.**  
**"VINYL SIDING & SOFFIT" DRAWINGS**



**TYPICAL SOFFIT SECTION AT SUPPORT  
 ASSEMBLY SIDE VIEW**



**TYPICAL SIDING SECTION AT SUPPORT  
 ASSEMBLY SIDE VIEW**

**PRODUCT REVISED**  
 as complying with the Florida  
 Building Code  
 Acceptance No 11-1213.10  
 Expiration Date 01/15/2016  
 By *[Signature]*  
 Miami Dade Product Control

*[Signature]*  
**JAMES L. BUCKNER, P.E.**  
 FLORIDA P.E. #31242  
 3/20/12


MITTEN, INC. "VINYL SIDING / SOFFIT PANELS"  
 TYPICAL ASSEMBLY SIDE VIEWS

**CBUCK Engineering**  
 Speciality Structural Engineering  
 CBUCK, Inc.  
 1399 N. Killian Dr., Ste 4  
 W. Palm Beach, FL 33403  
 (561) 491-9927

**MANUFACTURER:**  
 Mitten, Inc.  
 70 Curtis Avenue North  
 Paris, Ontario N3L 3T2 CANADA

DATE:	11/04/11
PAGE #:	8 OF 10
PROJECT #:	11-107
DRAWN BY:	DG
REVISION:	1

**MITTEN, INC.**  
**"VINYL SIDING & SOFFIT" DRAWINGS**



**SOFFIT**  
**TYPICAL ASSEMBLY PLAN VIEW**


**NOTES:**  
 1. SUPPLEMENTAL ATTACHMENT DETAILS DESIGNED BY OTHERS  
 2. REFER TO MANUFACTURER FOR SUPPLEMENTAL ATTACHMENT DETAILS

**PRODUCT REVISED**  
 re complying with the Florida Building Code  
 Acceptance No 11-1213-10  
 Expiration Date 01/13/2016  
 By *[Signature]*  
 Miami Dade Product Control

*[Signature]*  
**JAMES L. BUCKNER, P.E.**  
 FLORIDA P.E. #31242  
 3/20/12

MITTEN, INC. "VINYL SIDING / SOFFIT PANELS" TYPICAL ASSEMBLY PLAN VIEW		DATE: 11/04/11
<b>CBUCK Engineering</b> Specialty Structural Engineering CBUCK, Inc. 1399 N. Killian Dr., Ste 4 W. Palm Beach, FL 33403 (561) 491-9927	MANUFACTURER:	PAGE #: 9 OF 10
	Mitten, Inc. 70 Curtis Avenue North Paris, Ontario N3L 3T2 CANADA	PROJECT #: 11-107
		DRAWN BY: DG
		REVISION: 1

**MITTEN, INC.**  
**"VINYL SIDING & SOFFIT" DRAWINGS**



Ring Shank Nails  
 Note: Nails are concealed in the interlocking joints

1/2 Nails Thru Studs  
 1/2 Nails Thru Plywood

Exposure (x) Per Table "B"

**SIDING**  
**TYPICAL ASSEMBLY PLAN VIEW**

**PRODUCT REVISED**  
 as complying with the Florida Building Code  
 Acceptance No. 11-1213-10  
 Expiration Date 01/19/2016  
 By *[Signature]*  
 Miami Dade Product Control

- NOTES:**
1. SUPPLEMENTAL ATTACHMENT DETAILS DESIGNED BY OTHERS
  2. REFER TO MANUFACTURER FOR SUPPLEMENTAL ATTACHMENT DETAILS

*[Signature]*  
**JAMES L. BUCKNER, P.E.**  
 FLORIDA P.E. #31242  
 3/20/12

MITTEN, INC. "VINYL SIDING / SOFFIT PANELS"  
 TYPICAL ASSEMBLY PLAN VIEW

**CBUCK Engineering**  
 Specialty Structural Engineering  
 CBUCK, Inc.  
 1399 N. Killian Dr., Ste 4  
 W. Palm Beach, FL 33403  
 (561) 491-9927

**MANUFACTURER:**  
 Mitten, Inc.  
 70 Curtis Avenue North  
 Paris, Ontario N3L 3T2 CANADA

DATE:	11/04/11
PAGE #:	10 OF 10
PROJECT #:	11-107
DRAWN BY:	DG
REVISION:	1