



**DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY
AFFAIRS (PERA)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)**

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/pera

**Sika Sarnafil Inc.
100 Dan Road
Canton, MA 02021**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA – Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Sika Sarnafil PVC Single Ply Roofing over Cementitious Wood Fiber Deck.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/ or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 11-0526.04 and consists of pages 1 through 14.
The submitted documentation was reviewed by Jorge L. Acebo.



**NOA No.: 12-0313.13
Expiration Date: 08/02/13
Approval Date: 06/28/12
Page 1 of 14**

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Single Ply
Material: PVC
Deck Type: Cementitious Wood Fiber
Maximum Design Pressure -52.5 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

| TABLE 1 | | | |
|-----------------------|--------------------------|----------------------------------|---|
| <u>Product</u> | <u>Dimensions</u> | <u>Test Specification</u> | <u>Product Description</u> |
| G410 | Various | ASTM D 4434 | Fiberglass reinforced PVC roofing membrane. |
| G410 Felt | Various | ASTM D 4434 | Fiberglass reinforced PVC roofing membrane with a non-woven felt backing. |
| G410 PS | Various | ASTM D 4434 | Fiberglass reinforced PVC roofing membrane with a peel & stick self-adhering backing. |
| S327 | Various | ASTM D 4434 | Polyester reinforced PVC roofing membrane. |
| S327 Felt | Various | ASTM D 4434 | Polyester reinforced PVC roofing membrane. |
| Sikaplan 45 | 45 mil thick | ASTM D 4434 | White polyester reinforced PVC roofing membrane. |
| G459 | Various | ASTM D 4434 | Fiberglass reinforced PVC Alloy asphalt compatible flashing membrane. |
| Sarnatape | Various | | Air flow barrier tape |
| Sarnacol 2170 | 5 gallons | | Solvent based bonding adhesive. |
| Sarnacol 2121 | 5 gallons | | Water based bonding adhesive. |
| Sarnacol 2163 | | | Insulation adhesive. |
| Sarnacol 2164 | | | Insulation adhesive. |
| Sarnacorner | 5", 6", 8.5" | | Prefabricated inside and outside corner flashing. |
| Sarnaflash | 18" x 40" | | Prefabricated expansion joints. |
| Sarnatred | 3.25' x 32.8' | | PVC walkway protection sheet. |
| SarnaWalkways | Various | | PVC walkway protection sheet. |
| Sarnastack | Various | | Prefabricated cone flashing. |
| Sarnadrain RAC | Various | | Aluminum drain insert. |
| Sarnaclad | Various | | Heat weldable PVC/galvanized steel flashing |



NOA No.: 12-0313.13
Expiration Date: 08/02/13
Approval Date: 06/28/12
Page 2 of 14

APPROVED INSULATIONS:

TABLE 2

| <u>Product</u> | <u>Product Description</u> | <u>Manufacturer (with current NOA)</u> |
|------------------------------|--|---|
| Sarnatherm | Isocyanurate Insulation | Sarnafil, Inc. |
| Sarnatherm 25 PSI | Polyisocyanurate insulation board. | Sarnafil, Inc. |
| ACFoam Composite | Isocyanurate Insulation with perlite facer | Atlas Roofing Corp. |
| ACFoam II, ACFoam III | Isocyanurate Insulation | Atlas Roofing Corp. |
| ACFoam Supreme | Isocyanurate Insulation | Atlas Roofing Corp. |
| DensDeck, DensDeck Prime | Silicon treated gypsum | G-P Products |
| ENRGY 3 | Isocyanurate Insulation | Johns Manville |
| ENRGY 3 Plus | Isocyanurate Insulation with wood fiberboard facer | Johns Manville |
| ENRGY 3 PSI-25 | Isocyanurate Insulation | Johns Manville |
| High Density Wood Fiberboard | Wood fiber insulation | Generic |
| H-Shield | Isocyanurate Insulation | Hunter Panels |
| ISO 95+ GL | Isocyanurate Insulation | Firestone |
| Multi-Max FA-3 | Isocyanurate Insulation | Rmax, Inc. |
| Perlite Insulation Board | Perlite Insulation | Generic |
| Thermarroof-3 | Isocyanurate Insulation | Rmax, Inc. |
| Thermarroof Composite-3 | Isocyanurate Insulation | Rmax, Inc. |
| Type X Gypsum | Gypsum Wallboard | Generic |
| Structodek HD Fiberboard | High Density Wood Fiber insulation board. | Blue Ridge Fiberboard |



APPROVED FASTENERS:

TABLE 3

| <u>Fastener Number</u> | <u>Product Name</u> | <u>Product Description</u> | <u>Dimensions</u> | <u>Manufacturer (With Current NOA)</u> |
|------------------------|--------------------------------|--|-------------------|--|
| 1 | Polymer GypTec | Glass reinforced nylon fastener used with Polymer GypTec Insulation Plate (3" round) | Various | OMG, Inc. |
| 2 | Polymer GypTec | Glass reinforced nylon | Various | OMG, Inc. |
| 3 | OMG Lite-Deck with the 3"plate | Carbon Steel CR-10 Coating (black) | Various (min.2") | OMG, Inc. |
| 4 | Sarnafastener | Insulation and membrane fastener | Various | Sarnafil, Inc. |
| 5 | Sarnafastener Polymer GypTec | Glass reinforced nylon fastener used with Sarnadisc GypTec plate (3" round) | Various | Sarnafil, Inc. |
| 6 | Sarnadisc | Membrane fastening stress plate. | 2" Round | Sarnafil, Inc. |
| 7 | Sarnaplate | Insulation fastening plate. | 3" Round | Sarnafil, Inc. |
| 8 | Sarnabar | Galvanized or stainless steel membrane fastening bar. | Various | Sarnafil, Inc. |

EVIDENCE SUBMITTED:

| <u>Test Agency</u> | <u>Test Identifier</u> | <u>Description</u> | <u>Date</u> |
|-------------------------------------|------------------------|--------------------|-------------|
| Celotex Technical Center | MTS Job No. 258215 | TAS 114 | 09/09/97 |
| Exterior Research & Design | 02767.02.06 | TAS 114 | 02/08/06 |
| Factory Mutual Research Corporation | 0P6A6.AM | FM 4470 | 03/03/94 |
| | 0X3A3.AM | FM 4470 | 07/31/94 |
| | 2X2A5.AM | FM 4470 | 07/31/94 |
| | 0B9A0.AM | FM 4470 | 10/22/96 |
| | 1Z5A6.AM | FM 4470 | 07/18/97 |
| | 4B3A2.AM | FM 4470 | 06/19/97 |
| | 3016201 | FM 4470 | 01/28/03 |
| | 3028309 | FM 4470 | 03/30/07 |
| Underwriters Laboratories, Inc. | R8992 | ASTM E 108 | 1994 |



NOA No.: 12-0313.13
 Expiration Date: 08/02/13
 Approval Date: 06/28/12
 Page 4 of 14

APPROVED ASSEMBLIES:

- Membrane Type:** Single Ply, Thermoplastic, PVC
- Deck Type 5I:** Cementitious Wood Fiber, Insulated
- Deck Description:** Cementitious Wood Fiber
- System Type A(1):** One or more layers of insulation adhered with approved adhesive

All General and System Limitations apply.

| <u>Insulation Base Layer:</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam II, H-Shield, ENRGY 3, Sarnatherm Minimum: 1.5” thick | N/A | N/A |
| Structodek High Density Fiberboard Minimum: 0.5” thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 0.25” thick | N/A | N/A |
| (Optional) <u>Insulation Top Layer:</u> | | |
| ACFoam II, H-Shield, ENRGY 3, Sarnatherm Minimum 1.5” thick | N/A | N/A |
| Structodek High Density Fiberboard Minimum: 0.5” thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 0.25” thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in OlyBond 500 or SpotShot adhesive applied in continuous ¾” – 1” wide ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: G410, G410 Felt, S327 or S327 Felt adhered with Sarnacol 2121 adhesive applied at 2.25 gal/sq. to the insulation using a ¼” x ¼” notched squeegee.

Maximum Design Pressure: -45.0 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, PVC
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type A(2): One or more layers of insulation adhered with approved adhesive

All General and System Limitations apply.

| <u>Insulation Base Layer:</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam II, H-Shield, ENRGY 3, Sarnatherm Minimum: 1.5" thick | N/A | N/A |
| Approved High Density Wood Fiber Minimum: 0.5" thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 0.25" thick | N/A | N/A |
| <u>Insulation Top Layer:</u> | | |
| Approved High Density Wood Fiber Minimum: 0.5" thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in full coverage of OlyBond Insulation Adhesive at a rate of 1 gal/sq. Refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: G410, G410 Felt, S327 or S327 Felt adhered with Sarnacol 2121 adhesive applied at 2.25 gal/sq. to the insulation using a 1/4" x 1/4" notched squeegee.

Maximum Design Pressure: -45.0 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, PVC
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type A(3): One or more layers of insulation adhered with approved adhesive

All General and System Limitations apply.

| <u>Insulation Base Layer:</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam II, Multi-Max FA-3, H-Shield, ENRGY 3, Sarnatherm Minimum: 1.5" thick | N/A | N/A |
| <u>(Optional) Insulation Middle Layer:</u> | | |
| ACFoam II, Multi-Max FA-3, H-Shield, ENRGY 3, Sarnatherm Tapered | N/A | N/A |
| <u>(Optional) Insulation Top Layer:</u> | | |
| Structodek High Density Fiberboard Minimum: 0.5" thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Sarnafil G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive applied at 2.25 gal/sq. to the insulation using a 1/4" x 1/4" notched squeegee or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller.

Or

Sarnafil G410 or S327 adhered with Sarnacol 2170 applied at 1.25gal/sq. to the substrate and .5 gal/sq. to the back of the membrane.

Maximum Design Pressure: -52.5 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, PVC
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type A(4): One or more layers of insulation adhered with approved adhesive

All General and System Limitations apply.

| <u>(Optional) Insulation Base Layer:</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|--|---|
| ACFoam II, Multi-Max FA-3, H-Shield, ENRGY 3, Sarnatherm Minimum: 1.5" thick | N/A | N/A |
| <u>(Optional) Insulation Middle Layer:</u> | | |
| ACFoam II, Multi-Max FA-3, H-Shield, ENRGY 3, Sarnatherm Tapered | N/A | N/A |
| <u>Insulation Top Layer:</u> | | |
| Structodek High Density Fiberboard Minimum: 0.5" thick | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 0.25" thick | N/A | N/A |

Note: All insulation shall be adhered to the deck in TITE-SET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: Sarnafil G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive applied at 2.25 gal/sq. to the insulation using a 1/4" x 1/4" notched squeegee or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller.

Or

Sarnafil G410 or S327 adhered with Sarnacol 2170 applied at 1.25gal/sq. to the substrate and .5 gal/sq. to the back of the membrane.

Maximum Design Pressure: -52.5 psf (See General Limitation #9)



Membrane Type: Single Ply, Thermoplastic, PVC

Deck Type 5I: Cementitious Wood Fiber, Insulated

Deck Description: Cementitious Wood Fiber

System Type B: Base Layer of insulation mechanically attached, top insulation layer fully adhered with approved asphalt..

Vapor Retarder: (Optional) Any FMRC approved vapor barrier approved for use with hot asphalt may be applied to the deck or perlite base layer.

All General and System Limitations apply:

One or more of the following insulations:

| <u>Insulation Base Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ACFoam II, ACFoam Composite (bottom layer only), H-Shield | | |
| Minimum 1.3" thick or tapered | 1, 2, or 3 | 1:2 ft ² |
| Minimum 2" thick or tapered | 1, 2, or 3 | 1:4 ft ² |
| Sarnatherm, Sarnatherm-25 PSI, ENRGY 3, ENRGY 3 Plus, ENRGY 3 PSI-25 | | |
| Minimum 1.4" thick or tapered | 1, 2, or 3 | 1:3 ft ² |
| Minimum 2" thick or tapered | 1, 2, or 3 | 1:4 ft ² |
| DensDeck, DensDeck Prime | | |
| Minimum 1/4" thick | 1, 2, or 3 | 1:1.2 ft ² |
| Minimum 1/2" thick | 1, 2, or 3 | 1:1.7 ft ² |
| Approved High Density Wood Fiber (base layer only) | | |
| Minimum 1" thick | 1, 2, or 3 | 1:2 ft ² |
| Multi-Max FA-3, Therमारoof Composite-3 (bottom layer only) | | |
| Minimum 1.25" thick or tapered | 1, 2, or 3 | 1:2 ft ² |
| Minimum 2" thick or tapered | 1, 2, or 3 | 1:4 ft ² |
| Approved Perlite (base layer only) | | |
| Minimum 3/4" thick | 1, 2, or 3 | 1:2 ft ² |

Note: Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

| <u>Insulation Top Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ACFoam II | | |
| Minimum: 1.3' Thick or tapered | N/A | N/A |
| Sarnatherm, Sarnatherm-25 PSI, ENRGY 3, ENRGY 3 Plus, ENRGY 3 PSI-25 | | |
| Minimum 1.4" Thick or tapered | N/A | N/A |
| DensDeck, DensDeck Prime | | |
| Minimum 1/4" Thick | N/A | N/A |
| Multi-Max FA-3 | | |
| Minimum 1.25" Thick or tapered | N/A | N/A |



NOA No.: 12-0313.13
 Expiration Date: 08/02/13
 Approval Date: 06/28/12
 Page 9 of 14

Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft². Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Membrane: Sarnafil G410 or S327, smooth backed adhered with Sarnacol 2170 applied at 1.25gal/sq. to the substate and .5 gal/sq. to the back of the Membrane, or Sarnacol 2121 applied to the substrate only at 1.5 to 2.5 gal./sq.

Maximum Design

Pressure: -45 psf. (See General Limitation #9)



NOA No.: 12-0313.13
Expiration Date: 08/02/13
Approval Date: 06/28/12
Page 10 of 14

Membrane Type: Single Ply, Thermoplastic, PVC
Deck Type 1I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type C: All layers of insulation simultaneously fastened; membrane fully adhered.
All General and System Limitations apply.
Vapor Retarder: (Optional) An FMRC approved vapor barrier approved for use with hot asphalt may be applied to the deck or perlite base layer.

| <u>Insulation Base Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|---|--|
| ACFoam II, ACFoam III, ACFoam Composite, ACFoam Supreme, H-Shield Minimum: 1.3" Thick or tapered | N/A | N/A |
| Sarnatherm, Sarnatherm-25 PSI, ENRGY 3, ENRGY 3 Plus, ENRGY 3 PSI-25, ISO 95+ GL, Minimum: 1.4" Thick or tapered | N/A | N/A |
| Approved High Density Wood Fiberboard Minimum: 1" Thick or tapered | N/A | N/A |
| Multi-Max FA-3, Thermarroof-3 Minimum: 1.25" Thick or tapered | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 1/4" Thick | N/A | N/A |
| Approved Perlite Minimum: 3/4" Thick | N/A | N/A |

Note: All insulation layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners shall be increased maintaining the same fastener density. Please refer Roofing Application Standard RAS 117 for insulation attachment.

| <u>Insulation Top Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|---|---|--|
| ACFoam II Minimum 1.3" thick or tapered | 1, 2, or 3 | 1:2 ft ² |
| Minimum 2" thick or tapered | 1, 2, or 3 | 1:4 ft ² |
| Sarnatherm, Sarnatherm-25 PSI, ENRGY 3, ENRG 3 Plus, ENRGY 3 PSI-25 Minimum 1.4" thick or tapered | 1, 2, or 3 | 1:3 ft ² |
| Minimum 2" thick or tapered | 1, 2, or 3 | 1:4 ft ² |
| DensDeck, DensDeck Prime Minimum 1/4" thick | 1, 2, or 3 | 1:1.2 ft ² |
| Minimum 1/2" thick | 1, 2, or 3 | 1:1.7 ft ² |
| Multi-Max FA-3 Minimum 1.25" thick or tapered | 1, 2, or 3 | 1:2 ft ² |
| Minimum 2" thick or tapered | 1, 2, or 3 | 1:4 ft ² |



Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Sarnafil G410 or S327, smooth backed adhered with Sarnacol 2170 applied at 1.25gal/sq. to the substrate and .5 gal/sq. to the back of the Membrane, or Sarnacol 2121 applied to the substrate only at 1.5 to 2.5 gal./sq.

Maximum Design Pressure: -45 psf. (See General Limitation #9)



NOA No.: 12-0313.13
Expiration Date: 08/02/13
Approval Date: 06/28/12
Page 12 of 14

Membrane Type: Single Ply, Thermoplastic, PVC
Deck Type 5I: Cementitious Wood Fiber, Insulated
Deck Description: Cementitious Wood Fiber
System Type D: Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply.

Barrier: (Optional) Minimum 1/4" Type X Gypsum or DensDeck

| <u>Insulation Layer</u> | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft²</u> |
|--|---|--|
| ACFoam II, ACFoam III, ACFoam Composite (bottom layer only), ACFoam Supreme, H-Shield Minimum: 1.3" Thick or tapered | N/A | N/A |
| Sarnatherm, Sarnatherm-25 PSI, ENRGY 3, ENRGY 3 Plus, ENRGY 3 PSI-25, ISO 95+ GL Minimum: 1.4" Thick or tapered | N/A | N/A |
| Approved High Density Wood Fiberboard (base layer only) Minimum: 1" Thick or tapered | N/A | N/A |
| Multi-Max FA-3, Thermarroof-3 Minimum: 1.25" Thick or tapered | N/A | N/A |
| DensDeck, DensDeck Prime Minimum: 1/4" Thick | N/A | N/A |
| Approved Perlite (base layer only) Minimum: 3/4" Thick | N/A | N/A |

Note: All insulations shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft.

Membrane: Sarnafil S327 or Sikaplan 45 attached to deck as specified below.

Fastening: Approved fasteners with approved discs spaced 6" o.c. within the 5.5" side lap spaced 73" o.c. and sealed with a minimum 1.5" weld or approved fasteners with approved discs spaced 6" o.c. in rows 12' o.c. maximum, or Sarnabars spaced 12' o.c. maximum fastened with Sarnafasteners spaced 6 in. o.c. through the field of the membrane and covered with a 7" minimum width cover strip with 1.5" welds on each side.

Maximum Design Pressure: -52.5 psf. (See General Limitations #9)



NOA No.: 12-0313.13
 Expiration Date: 08/02/13
 Approval Date: 06/28/12
 Page 13 of 14

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 12-0313.13
Expiration Date: 08/02/13
Approval Date: 06/28/12
Page 14 of 14