



**DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY AFFAIRS (PERA)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)**

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/pera/

**Janus International Corporation
134 Janus International Blvd.
Temple, GA 30179**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series 850 Steel Roll-up Door up to 8'-8" Wide

APPROVAL DOCUMENT: Drawing No. **T1006**, titled "Dade County Mini Door Series 850 Max. Size 8'-8" x 12'-0", dated 09/15/2003, with last revision B dated 06/10/2005, sheets 1 and 2 of 2, prepared by Janus International Corporation, signed and sealed by Joseph H. Dixon, Jr., P.E., bearing the Miami-Dade County Product Control revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: A permanent label with the manufacturer's name or logo, city, state, model/series number, the positive and negative design pressure rating, indicate impact rated if applicable, installation instruction drawing reference number, approval number (NOA), the applicable test standards, and the statement reading 'Miami-Dade County Product Control Approved' is to be located on the door's side track, bottom angle, or inner surface of a panel.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises NOA # 08-1204.04** and consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



Carlos M. Utrera
08/06/2012

NOA No. 12-0326.01
Expiration Date: February 26, 2014
Approval Date: August 16, 2012
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS *"Submitted under NOA # 05-0623.04"*

1. Drawing No. **T1006**, titled "Dade County Mini Door Series 850 Max. Size 8'-8" x 12'-0", dated 09/15/2003, with last revision B dated 06/10/2005, sheets 1 and 2 of 2, prepared by Janus International Corporation, signed and sealed by Joseph H. Dixon, Jr., P.E.

B. TESTS *"Submitted under NOA # 03-0929.05"*

1. Test report on Large Missile Impact Test per TAS 201, Cyclic Wind Pressure Test per TAS 203 and Uniform Static Air Pressure Test per TAS 202 on Specimens 1, 2, 3 & 4 Door 8'-8" wide, 8'-0" high, prepared by Certified Testing Laboratories, Test Report No. **CTLA 1115W**, dated 08/20/2003, signed and sealed by K. Patel, P.E.

C. CALCULATIONS *"Submitted under NOA # 05-0623.04"*

1. Revised anchorage calculations prepared by Joseph H. Dixon Jr., P.E., dated 05/27/2005, sheets 1 through 11, signed and sealed by J. H. Dixon Jr., P.E., on 05/27/2005.

"Submitted under NOA # 03-0929.05"

2. Calculations for attachment of guide to steel, concrete or masonry jamb, prepared by Joseph H. Dixon, Jr., P.E., dated 06/29/2003, sheets 1 to 11, signed and sealed by J. H. Dixon, Jr., P.E., on 09/22/2003.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Permitting, Environment, and Regulatory Affairs (PERA)

E. MATERIAL CERTIFICATIONS *"Submitted under NOA # 03-0929.05"*

1. Tensile test report per ASTM E8/A370 or B557, prepared by Certified Testing Laboratories, Test Report No. **1115W**, dated 07/22/2003, signed by K. Patel, P.E.

F. STATEMENTS

1. Statement letter of code conformance to 2010 FBC, dated 03/14/2012, signed and sealed by Joseph H. Dixon, Jr., P.E.
2. Testing quotation issued by Element Materials Technology, dated 06/27/2012, submitted by David Whelchel.

"Submitted under NOA # 03-0929.05"


3. Statement letter of code conformance, dated 09/22/2003, signed and sealed by Joseph H. Dixon, Jr., P.E.
4. Statement letter of no financial interest, dated 09/22/2003, signed and sealed by Joseph H. Dixon, Jr., P.E.


08/06/2012

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 12-0326.01

Expiration Date: February 26, 2014
Approval Date: August 16, 2012

REVISIONS			
REV	DESCRIPTION	DATE	APPROVAL
—	DRAWING RELEASE	9-15-03	DM
A	DADE COUNTY CHANGES	1-16-04	DM
B	GDE FAS SPA 10'-8.5'	6-10-05	DM




PRODUCT REVISED
 as complying with the Florida Building Code
 Acceptance No 12-0326.01
 Expiration Date 02/26/2014
 By *[Signature]*
 Miami Dade Product Control

PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No 08-1209.04
 Expiration Date 02/26/2014
 By *[Signature]*
 Miami Dade Product Control Division

HEADROOM REQUIRED

OPENING HEIGHT	VERTICAL HEADROOM	HORIZONTAL HEADROOM
THRU 7'-4"	15-1/2"	17-1/8"
OVER 7'-4" THRU 8'-8"	16"	18"
OVER 8'-8" THRU 10'-0"	17"	18-1/4"



ASTM A653 GR 80 MIN FY=80 KSI.
 G90 GALVANIZED STEEL.
 CURTAIN PANELS LOCK SEAMED TOGETHER.

PART NUMBER: NA	
MATERIAL: NA	
APPLIED FINISH: NA	
UNIT OF MEASURE: NA	
APPROVALS	DATE
DRAWN: BECKY NELSON	7-25-03
CHECKED: DON MILLS	9-15-03
APPROVED: DON MILLS	9-15-03

JANUS INTERNATIONAL CORPORATION
 134 EAST LUKE ROAD TEMPLE, GA 30179-4435
 770-562-2850/Fax 770-562-2284
 © 2005 Janus International Corporation All Rights Reserved

DADE COUNTY MINI DOOR SERIES 850
 MAX. SIZE 8'-8" X 12'-0"

SIZE: B	DRAWING NUMBER: T1006	REV: B
SCALE: NONE	SHEET: 1	OF: 2

SEE SHEET 2 FOR NOTES

[Handwritten Signature]
 6/20/05
 FC 7768

PRODUCT REVISED
 05-06-23.04
 02/26/09

