

DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY AFFAIRS (PERA) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/pera

NOTICE OF ACCEPTANCE (NOA)

Boral Roofing LLC. 7575 Irvine Center Drive, Suite 100 Irvine, CA. 92618

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: BORAL TileSeal

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

ANGHA

This renews NOA# 12-0306.26 and consists of pages 1 through 4. The submitted documentation was reviewed by Alex Tigera.



NOA No.: 12-0417.06 Expiration Date: 07/31/17 Approval Date: 07/05/12

Page 1 of 4

ROOFING COMPONENT APPROVAL

<u>Category:</u> Roofing <u>Sub-Category:</u> Underlayment

Material: SBS

PRODUCTS DESCRIPTION:

Product	<u>Dimensions</u>	Test Specification	Product <u>Description</u>
BORAL TileSeal	36" x 36" rolls 36" x 72" rolls	TAS 103	SBS self-adhering asphalt sheet material with a white glass re-enforced polyester surfacing fabric; for use as an underlayment in sloped roof assemblies.

MANUFACTURING LOCATION:

1. Brentwood, NH

EVIDENCE SUBMITTED:

Test Agency	Test Identifier	Test Name/Report	<u>Date</u>
Underwriters Laboratories, Inc.	R14610	Follow up Service	03/28/02
IRT-Arcon, Inc.	02-012	TAS 103	02/28/02
PRI Asphalt Technologies, Inc.	NEI-006-02-01	TAS 103	04/01/02
PRI Asphalt Technologies, Inc.	NEI-008-02-01	TAS 114 (H)	07/30/02
PRI Construction Materials Technologies, LLC.	NEI-045-02-01	ASTM D 4798 & ASTM G 155	08/08/07
	NEI-053-02-01	ASTM D 4798 & ASTM G 155	05/01/08
	NEI-076-02-01	TAS 103 / ASTM D4798	02/14/11



NOA No.: 12-0417.06 Expiration Date: 07/31/17 Approval Date: 07/05/12

Page 2 of 4

APPROVED ASSEMBLIES:

Deck Type 1: Wood, non-insulated

¹⁵/₃₂" or greater plywood or wood plank **Deck Description:**

System E(1): Anchor sheet mechanically fastened deck, membrane adhered.

Base Sheet: One or more plies of ASTM D 226 Type II or ASTM D 2626 with a minimum 4" head lap and a

6" end lap mechanically fastened to deck with approved nails and tin caps 6" o.c. at the laps and

two staggered rows 12" o.c. the field of the roll.

One or more plies of BORAL TileSeal Underlayment with a minimum 3" head lap and minimum **Membrane:**

> 6" end lap. Place the first course of membrane parallel to the eave, rolling the membrane to obtain maximum contact. Remove the release membrane as the membrane is applied. Vertical strapping of the roof with BORAL TileSeal Underlayment is acceptable. All end laps and laps

without black selvage area shall be sealed under lap using an SBS modified mastic.

Surfacing: Approved for Approved Adhesive Set Roof Tile Systems, Mechanically Fastened Roof Tile,

Metal Roofing, Wood Shake & Shingles, and Asphaltic Shingle assemblies.



NOA No.: 12-0417.06 **Expiration Date: 07/31/17** Approval Date: 07/05/12

Page 3 of 4

LIMITATIONS:

- 1. Fire classification is not part of this acceptance.
- 2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code. BORAL TileSeal underlayment shall be installed in strict compliance with applicable Building Code.
- 3. BORAL TileSeal underlayment shall be applied to a smooth, clean and dry surface with deck free of irregularities.
- 4. BORAL TileSeal underlayment shall not be applied over an existing roof membrane as a recover, but may be applied over a roofing Base/Anchor sheet underlayment.
- 5. BORAL TileSeal underlayment shall not be left exposed as a temporary roof for longer than 90 days of application.
- 6. The standard maximum roof pitch for BORAL TileSeal underlayment shall be 6:12 when tiles are loaded directly to the BORAL TileSeal underlayment; loading boards or battens are required on roof pitches greater than 6:12".
- 7. Refer to Prepared Roofing system Product Control Notice of Acceptance for listed approval of this product with specific prepared roofing products.
- 8. Tiles shall be stored on battens on roof pitches greater than 6:12".
- 9. BORAL TileSeal underlayment may be used with any approved roof covering Notice of Acceptance listing BORAL TileSeal underlayment as a component part of an assembly in the Notice of Acceptance. If BORAL TileSeal underlayment is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
- 10. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
- 11. When applying the membrane in the valley, start at the low point and work to the high point, rolling the membrane from the center outward in both directions. For ridge applications, center the membrane and roll from the center outward in both directions.
- 12. Roll or broom the entire membrane surface so as to have 100% contact with the surface, giving special attention to overlap areas.
- 13. Flash vent pipes, stacks, chimneys and penetrations in compliance with Roof Assembly current Product Control Notice of Acceptance and applicable Building Code.
- 14. All protrusions or drains shall be initially taped with a 6" piece of underlayment. This target piece shall be pressed in place and formed around the protrusion to ensure a tight fit. A second layer of BORAL TileSeal underlayment shall be applied over the underlayment, and sealed using an SBS modified mastic.
- 15. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.
- 16. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.





NOA No.: 12-0417.06 Expiration Date: 07/31/17 Approval Date: 07/05/12 Page 4 of 4