



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Armor Screen Corp.
1881 Old Okeechobee Road
West Palm Beach, FL 33409

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER- Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: "Armor Screen Series 63 " Flexible Wind Abatement System

APPROVAL DOCUMENT: Drawing No. 01-2010, titled " Armor Screen Series 63 Hurricane Protection ", sheets 1 through 11 of 11, prepared by Gary D. Foreman, P.E., dated October 01, 2010, signed and sealed by Gary D. Foreman, P.E. on January 30, 2013, bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and the expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each panel shall bear a permanent label with the manufacturer's name or logo, City, State, the following statement: "Miami-Dade County Product Control Approved", and NOA number, per TAS-201, TAS-202, and TAS-203, unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 12-0223.13 and consists of this page 1, evidence submitted pages E-1 & E-2 as well as approval document mentioned above.

The submitted documentation was reviewed by Helmy A. Makar, P.E., M.S.



Helmy A. Makar
02/07/2013

NOA No. 12-0417.14
Expiration Date: 01/26/2017
Approval Date: 02/07/2013
Page 1

Armor Screen Corp.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

1. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 10-1104.03

A. DRAWINGS

1. *Drawing No. 01-2010, titled " Armor Screen Series 63 Hurricane Protection ", sheets 1 through 11 of 11, prepared by Gary D. Foreman, P.E., dated October 01, 2010, signed and sealed by Gary D. Foreman, on January 09, 2012.*

B. TESTS

1. *Test report on Large Missile Impact Test, Cyclic Wind Pressure Test and Uniform Static Air Pressure Test of Armor Screen Flexible Hurricane Wind Abatement System, prepared by Fenestration Testing Laboratory, Inc., Report No. 5889, dated August 26, 2009, signed and sealed by Julio E. Gonzalez, P.E.*
2. *Test report on Large Missile Impact Test, Cyclic Wind Pressure Test and Uniform Static Air Pressure Test of Armor Screen Flexible Hurricane Wind Abatement System, prepared by Fenestration Testing Laboratory, Inc., Report No. 5533, dated February 08, 2008, signed and sealed by Marlin Brinson, P.E.*
3. *Test report on Large Missile Impact Test, Cyclic Wind Pressure Test and Uniform Static Air Pressure Test of Armor Screen Flexible Hurricane Wind Abatement System, prepared by Fenestration Testing Laboratory, Inc., Report No. 5279, dated August 26, 2009, signed and sealed by Julio E. Gonzalez, P.E.*

C. CALCULATIONS

1. *Comparative Analysis and Anchor calculations dated October 20, 2010, 66 pages, prepared by Gary D. Foreman, P.E., signed and sealed by Gary d. Foreman, P.E.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Department of Permitting, Environment, and Regulatory Affairs (PERA).*

E. MATERIAL CERTIFICATIONS

1. *Fabric specifications.*


2. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 12-0223.13

A. DRAWINGS

1. *Drawing No. 01-2010, titled " Armor Screen Series 63 Hurricane Protection ", sheets 1 through 11 of 11, prepared by Gary D. Foreman, P.E., dated October 01, 2010, signed and sealed by Gary D. Foreman, on February 16 & 17, 2012.*

B. TESTS

1. *None.*



Henry A. Makar, P.E., M.S.
Product Control Unit Supervisor
NOA No. 12-0417.14
Expiration Date: 01/26/2017
Approval Date: 02/07/2013

Armor Screen Corp.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

C. CALCULATIONS

1. *None.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Department of Permitting, Environment, and Regulatory Affairs (PERA).*

E. MATERIAL CERTIFICATIONS

1. *None.*

F. OTHERS

1. *Florida Building Code, 2010 Edition, Compliance Statement Letter by GD Foreman PE, SE, AIA, dated February 16, 2012, signed and sealed by Gary D Foreman, P.E.*

3. NEW EVIDENCE SUBMITTED

A. DRAWINGS

1. *Drawing No. 01-2010, titled " Armor Screen Series 63 Hurricane Protection ", sheets 1 through 11 of 11, prepared by Gary D. Foreman, P.E., dated October 01, 2010, signed and sealed by Gary D. Foreman, P.E. on January 30, 2013.*

B. TESTS

1. *Test report on End Retention Component B of Armor Screen Flexible Hurricane Wind Abatement System, prepared by Architectural Testing, Report No. C5783.01-450-43, dated 01/29/2013, signed and sealed by Vinu J. Abraham, P.E.*
2. *Test report on Large Missile Impact Test, Cyclic Wind Pressure Test and Uniform Static Air Pressure Test of Armor Screen Flexible Hurricane Wind Abatement System, prepared by prepared by Architectural Testing, Report No. C1475.01-450-18, dated 08/31/2012, signed and sealed by Vinu J. Abraham, P.E.*

C. CALCULATIONS


1. *None.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Department of Regulatory and Economic Resources.*

E. MATERIAL CERTIFICATIONS

1. *Self Ignition Temp. test, Rate of Burning test, and Smoke Density test by Hurricane Engineering & Testing, test report # HETI-12-F105, dated 04/11/2012, signed and sealed by Rafael E. Droz-Seda, P.E.*



Helmy A. Makar, P.E., M.S.
Product Control Unit Supervisor
NOA No. 12-0417.14
Expiration Date: 01/26/2017
Approval Date: 02/07/2013

ARMOR SCREEN SERIES 63 HURRICANE PROTECTION

REVISIONS

GENERAL NOTES:

- This Wind Abatement / Impact Hurricane Protection System is designed and tested to comply with the High Velocity Hurricane Zone (HVHZ) of the Florida Building Code, 2010 Edition.
- The design loads are calculated in accordance with ASCE-7 per the Florida Building Code and ASCE/SEI 7-10 per allowable stress design (ASD).
- Testing meets the current Florida Building Code; TAS 201; TAS 202; TAS 203 and fulfills its requirement for opening protection.
- The unbreached envelope criterion is met when this approved wall component encloses the protected opening all around.
- The open areas in the Armor Screen Fabric are small enough that the surface tension of water causes the barrier screen to become solid in the presence of rain, and in actual hurricane conditions has been shown to prevent damaging voluminous water intrusion, even from torrential rains.
- Has satisfied checklist #0445 for resistance to burning, smoke, ignition, temperature, and weathering and qualifies as a permanently installed building component; ASTM G155, ASTM D638, ASTM C158, ASTM D635 - C1, ASTM D1929.

- ASTM G155
- ASTM D638
- ASTM C158
- ASTM D635 - C1
- ASTM D1929

- Product Marking: A permanent label shall be affixed to the screen barrier with the following statement: "Armor Screen Corporation, Current Address, "Miami-Dade County Product Control Approved", Patented and Patents Pending, US Patent No. 6176050".

PRODUCT DATA:

- Geosynthetic hurricane screen: The hurricane screen shall be produced from a polypropylene, woven geotextile fabric with filaments woven such that the filaments retain dimensional stability relative to each other.

The woven geotextile fabric shall have the following minimum average roll values:

Grab Textile Strength	(ASTM D4632)	425 x 325 LBS
Puncture Strength	(ASTM D4833)	130 LBS
Mullen Burst	(ASTM D3786)	675 PSI
Trapezoidal Tear	(ASTM D4533)	150 x 125 LBS
Wide Width Tensile Strength	(ASTM D4595)	225 x 205 LBS/IN
Thickness	(ASTM D5199)	20 MIL.
Wide Width Elongation	(ASTM D4595)	22 x 21%
Apparent Opening Size		30 US STD Sieve
Percentage of Open Area		5%

All Geosynthetic Hurricane Screen assembly details depicted within these drawings are typical for the installation of this wind / rain abatement and impact system only. All other building components shown herein are depicted as existing or samples and not constructed by the screen company.

LIMITATIONS OF USE:

- Maximum Span 144"
- Maximum Non-Span Unlimited, Utilizing side overlapping details, page 4
- Maximum Design Pressure +60 / -63 PSF
- Span (anchor span) equals the distance between the primary rows of anchors on opposing sides of the screen and when calculated with negative wind pressure, determines fastener size and spacing. "Opening Span" is equal to the opening size of the protected opening and when calculated with the positive wind pressure, determines the deflection for HVHZ applications. Refer to page 11 for Deflection Table.

INSTALLATION NOTES:

- Deflection is the minimum glass separation measured at mid span of the screen and subject to interpolation between listed spans (see tables on page 11). Separation offset may be achieved alone or by any combination thereof, Natural Deflection, Angled Style Screens, Storm Bars and Pneumatic Devices.
- Screen may be mounted with opposing primary anchored perimeters (span) in vertical, horizontal, or any alignment appropriate to the structure being protected.
- If the screen does not return to the structure it should extend past protected opening by distance equal to or greater than 1 1/2 times the offset. For trapped openings the screen should extend complete to fill the opening.
- The screens may be installed at any height on the structure as long as the design pressure rating for the screens is not exceeded.
- Anchors on the non-primary perimeter side (span side) of the screen are optional (e.g. to limit potential sag in the screen or reduce movement on the free side or other site specific reasons).
- The thickness of typical facing materials i.e. stucco, siding, stone, brick, pavers, etc. are not to be considered part of the anchor embedment. Longer fasteners should be used to allow for facing materials.
- Anchor embedment into masonry shall be into the face shell, not mortar joints.
- All fully embedded anchors may be flush with the finished facing provided they have the correct embedment into the structure behind the finish material.
- Anchor installations should follow the manufacturer's recommended methods.
- Hex Nuts, Flange Nuts, Cap Nuts, Wing Nuts, etc. (3/4" o.d. minimum), are acceptable when used with Hanger Bolt or Male Studs penetrating the fabric only.
- For attachment into female anchors, sidewalk bolts, washered head bolts or bolts with a standard washer are required.
- A caulk or sealant should be used with all wood penetrating anchors.
- All fasteners shall be corrosion resistant as specified in the IRC and IBC or stainless steel.
- Refer to pages 9 and 10 for approved anchors and anchor spacing.
- Refer to page 11 for deflection and storm bar tables.

Date:

Date:

Date:

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0417.14
Expiration Date 01/26/2017
By *[Signature]*
Miami Dade Product Control

Engineering Review By:

Gary D Foreman PE
FL PE 57343









ARMOR SCREEN
SERIES 63
HURRICANE PROTECTION

ARMOR SCREEN CORP.
1881 Old Okeechobee Road
West Palm Beach, FL 33409
(561) 841-8890 www.armorscreen.com

Date: 10/01/10 Scale: Not to Scale Page: 1 of 11

DRAWING NO. 01-2010

STRUCTURAL ANCHORING HEMS





SAMPLE ANCHORING FOR PROFILES 1 - 5
APPLIES TO VERTICAL WALL OR HORIZONTAL MOUNTING APPLICATIONS

NOTES:


1. For Direct Screen Attachment, PROFILES 1 and 2, create a hem (see details on this page) by folding and creasing the screen, followed by creating the anchor penetration holes using a Scratch All, nail, or pointed object.
2. Pre-drill the furring strip 6" o.c. per anchor size or use a self-drilling screw (see pages 9 and 10). Secure the screen to the furring strip with staples to ensure positive attachment and eliminate the screen from unrolling.
3. For PROFILES 4 and 5, fastener must utilize a 1 1/2" O.D. x 5/16" (or 1/4") I.D. flat washer.
4. Structural anchoring hem for PROFILES 4 and 5 may utilize woven or non-woven polypropylene.
5. Refer to pages 9 and 10 for anchor selection.

SCREEN PANEL & HEM DETAILS

Engineering Review By:  1/20/13	ARMOR SCREEN SERIES 63 HURRICANE PROTECTION		
	ARMOR SCREEN CORP. 1881 Old Okeechobee Road West Palm Beach, FL 33409 (561) 841-8890 www.armorscreen.com		
Gary D. Foreman PE FL PE: 67343	Date: 10/01/10	Scale: Not to Scale	Page: 2 of 11
DRAWING NO. 01-2010			

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 12-0417-14
Expiration Date 01/26/2017
By 
Miami Dade Product Control


1.5" - 2 Sided Screen
 1.0" - 3 Sided Screen #2 Nickel Plated Brass Grommet



Grommet with Stitching Detail

Stitching Detail


- Support Edge, Trifold Seam around 4" Polypro webbing
- Sewing includes 2 rows, Double Lock Stitch, of Anafil Nylon T135 bonded thread or equal.
- Grommeted through seam.




Welded Hemcord with Stitching Detail

Stitching Detail


- Hemcord Style A or B
- See test report for hemcord and insert details.
- Sewing includes 2 rows, Double Lock Stitch, of Anafil Nylon T135 Bonded Thread or equal.
- Reinforced welded hemcord includes a 2" trifold Polypro Seam sewn over the weld.



Keyhole Slot in Continuous C-Channel



Keyhole Slot in Segmented C-Channel



10" Segmented C-Channel Alloy: 6063-T6 Aluminum


5" Segmented C-Channel Alloy: 6063-T6 Aluminum

NOTES:

1. The length of the segmented C-Channel is governed by the strength of the fabric to C-Channel connection, not the hardware attachment to the C-Channel.
2. When a Keyhole Slot or washer is used on continuous C-Channel, a set screw through the channel and into the substrate is required to lock in place.
3. Refer to pages 9 and 10 for anchor selection.
4. A 1/4" TEK Screw may be used to secure the C-Channel end to limit screen movement.

USE HEMCORD STYLE A WITH THESE EXTRUSIONS

USE HEMCORD STYLE B WITH INSERT



C-Channel Alloy: 6063-T6 Aluminum

NOTE: Heavier alternate extrusion may be used.

GROMMET / HEMCORD / C-CHANNEL

REVISIONS

Date:
Date:
Date:

Engineering Review By:

[Signature]
 Gary D. Foreman PE
 FL PE 67343




ARMOR SCREEN
 SERIES 63
 HURRICANE PROTECTION

ARMOR SCREEN CORP.
 1881 Old Okeechobee Road
 West Palm Beach, FL 33409
 (561) 841-8890 www.armorscreen.com

Date: 10/01/10 Scale: Not to Scale Page: 3 of 11


DRAWING NO. 01-2010

PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No 12-0417-14
 Expiration Date 01/26/2017
 By *[Signature]*
 Miami Dade Product Control




NOTES:
 1. Screens may incorporate any combination of Structural Hem PROFILES 1 - 3 (page 2) with the appropriate anchors listed on pages 9 and 10.

See Tables on pages 9 and 10 for minimum edge distances for specific fasteners and structure.




FURRING STRIP TYPICAL VERTICAL SECTIONAL VIEW


DIRECT MOUNT TYPICAL VERTICAL WINDOW SECTIONAL VIEW



DIRECT MOUNT COLUMNS PLAN VIEW




FURRING STRIP TYPICAL WINDOW PLAN VIEW




NON-SPAN SECTION MINIMUM EDGE OVERLAP (Vertical and Horizontal)


VERTICAL & HORIZONTAL SCREENS

Engineering Review By:  Gary D. Foreman PE FL PE 57343	ARMOR SCREEN SERIES 63 HURRICANE PROTECTION	
	ARMOR SCREEN CORP. 1881 Old Okeachobee Road West Palm Beach, FL 33409 (561) 841-8890 www.armorscreen.com	
Date: 10/01/10	Scale: Not to Scale	Page: 4 of 11
DRAWING NO. 01-2010		

REVISIONS
Date:
Date:
Date:

PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No. 12-0417.14
 Expiration Date 01/26/2017
 By 
 Miami Dade Product Control


CONCRETE, CMU & FILLED CMU



DIRECT MOUNT

F TRACK TYPE
(FLUSH, 1", 2", and 3", Build-Out)

STUD



MALE / FEMALE ANCHORS
OR SCREW

3/8" ANCHOR SPACING ~ ALUMINUM TO SUBSTRATE ONLY																					
Dia.	Anchor Description	Min. Embed	Min. E.D.	Pressure (psf)	Span																
					2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'						
1/2"	Drop-In Anchor	1 1/2"	3 3/4"	30 (psf)	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	8"	8"	8"	
				40 (psf)	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	8"	8"	8"
				60 (psf)	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	8"	8"
3/8"	Calk-In Anchor	1 1/4"	3 3/4"	30 (psf)	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	8"	8"	8"	
				40 (psf)	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	8"	8"	8"
				60 (psf)	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	12"	8"	8"

NOTE: All spans for 1/4" hardware are designed to +60 psf / -63 psf.


REVISIONS

Date:

Date:


Date:

FRAME / BRICK FACADE




1/4" HANGER BOLT OR FEMALE ANCHOR
(Non-Structural Facing)
(Caulk or Sealant suggested to seal facing)
Some damage to the facing maybe expected.

PAVERS & TILE




DROP-IN OR SOLID SET ANCHOR
THREADED ROD / COUPLER
WITH SIDEWALK BOLT

DROP-IN OR SOLID SET ANCHOR
THREADED ROD / COUPLER
WITH SIDEWALK BOLT



SAMPLE ALUMINUM ANGLE
ANCHORING

CONCRETE SLABS




STUDLESS ANGLE / REVERSE
F TRACK
6" o.c. Screen Attachment
• 1" Bolt & Wingnut

CUSTOM DRILLED
ANGLE ALUMINUM
6" o.c. Screen Attachment
• Sidewalk Bolt & Nut
• Bolt, Nut & Washer


CUSTOM DRILLED
ANGLE ALUMINUM
6" o.c. Screen Attachment
• Sidewalk Bolt & Nut
• Bolt, Nut & Washer

STUDDED ALUMINUM ANGLE 2" x 2"
6" o.c. Screen Attachment
• Wingnut / Nut & Washer

FURRING STRIP / SCREEN
CONCRETE ATTACHMENT
6" o.c. Screen Attachment
• 1/4" Anchors



F-Track / Studded Angle



Aluminum Angle Custom Drilled

NOTES:

- For 1/4" anchors, see pages 9 and 10.
- For 3/8" anchor spacing for Aluminum Angle to substrate, see above table.
- Screen attachment to aluminum requires 6" on center maximum.
- Do not use Furring Strip System with F Track.
- Screens may incorporate any combination of Structural Hem PROFILES 1 - 3 (page 2) with the appropriate anchors listed on pages 9 and 10.
- F Track and Studded Angle to be minimum 6063-T6 x .093.
- Aluminum Angle, Custom Drilled to be minimum 6063-T6 x .125.


ANCHOR DETAILS

Engineering Review By: Gary D. Foreman PE FL PE 57343	ARMOR SCREEN SERIES 63 HURRICANE PROTECTION	
	ARMOR SCREEN CORP. 1881 Old Okeechobee Road West Palm Beach, FL 33409 (561) 841-8890 www.armorscreen.com	
Date: 10/01/10	Scale: Not to Scale	Page: 5 of 11
DRAWING NO. 01-2010		

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0417.14
Expiration Date 01/26/2017
By
Miami Dade Product Control

REVISIONS

Date: _____
 Date: _____
 Date: _____



- ANGLED SCREEN NOTES:**
1. Refer to Deflection Table on page 11.
 2. Bottom Return Requires a midpoint anchor.
 3. Side Return (span side) anchors are optional.
 4. Screens may incorporate any combination of Structural Hem PROFILES 1 - 3 (page 2) with the appropriate anchors listed on pages 9 and 10.

ANGLED SCREEN

Engineering Review By:  Gary D. Foreman PE FL PE 67343	ARMOR SCREEN SERIES 63 HURRICANE PROTECTION		
	ARMOR SCREEN CORP. 1881 Old Okeechobee Road West Palm Beach, FL 33409 (561) 841-8890 www.armorscreen.com		
Date: 10/01/10	Scale: Not to Scale	Page: 6 of 11	
DRAWING NO. 01-2010			


PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No 12-0417-14
 Expiration Date 01/26/2017
 By 
 Miami Date Product Control

REVISIONS

Date:
Date:
Date:

STORM BAR NOTES:

1. Refer to page 11 for deflection tables, storm bar tables, and storm bar alloy.
2. The storm bar system is designed to achieve required deflection and may utilize one or more storm bars. The offset may be increased with blocking at the support.
3. Storm bars may be positioned horizontal, vertical, angled or as required.
4. The storm bar bracket may be permanent or removable and attached to the structure using a minimum of two (2) approved 1/2" anchors. Refer to pages 9 and 10.
5. The storm bar bracket may be permanent or removable and attached to the structure using a minimum of one approved 1/2" anchor. Refer to pages 9 and 10.
6. The storm bar bracket may be wall, floor or ceiling mounted.
7. The storm bar and screen should extend past the protected opening by the distance equal to or greater than 1 1/2 times the offset.
8. The storm bar splits the anchor / screen span into multiple spans, each of which is used to determine the minimum deflection.
9. Screen anchors should be sized and spaced using full anchor / screen span.
10. Use "opening" span and positive wind pressure to determine minimum separation between screen and glazing.
11. Use "anchor" span and negative wind pressure to determine fastener size and spacing.



Building Structure between adjacent window / door frames may act as a Storm Bar if proper offset to the glazing is present. This applies to both vertical and horizontal applications.

2" x 2" x 1/8" ALUMINUM TUBE
Type 6063-T6
Refer to Storm Bar #4, page 11
Support Point of Storm Bar (typ.)


STORM BAR DEFLECTION SYSTEM

Engineering Review By: Gary D. Foreman PE FL PE 57343	ARMOR SCREEN SERIES 63 HURRICANE PROTECTION	
	ARMOR SCREEN CORP. 1881 Old Okeechobee Road West Palm Beach, FL 33409 (561) 841-8890 www.armorscreen.com	
Date: 10/01/10	Scale: Not to Scale	Page: 7 of 11
DRAWING NO. 01-2010		


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 12-0417.14
Expiration Date 01/26/2017
By
Miami Dade Product Control

3000 PSI CONCRETE					
Dia.	Anchor Description	Min. Embed.	Min. E.D.	Maximum Span (Inches)	Anchor Spacing
	Manufacturer Part Number				
1/4"	Tapcon	1 1/2"	3"	144"	6"
	Elco or ITW				
1/2"	Maxi-Set Tapcon	1 1/2"	2 1/2"	144"	6"
	ITW				
3/4"	Panelmate (Male or Female)	1 3/4"	2 1/2"	144"	6"
	Elco				
1/2"	Panelmate Inserts	1 5/8"	3"	144"	6"
	Elco				
1/2"	Tapcon SG	1 3/4"	2 1/2"	144"	6"
	ITW (1/4" x 2 1/4")				
1/2"	Sammy's SSC	2 1/4"	2 1/2"	144"	6"
	ITW				
1/2"	Solid Set Anchor	7/8"	3"	132"	6"
	All Points				
1/2"	Calk-In Anchor	7/8"	3"	132"	6"
	Powers				
1/2"	Drop-In Anchor	1"	3"	144"	6"
	Powers				

SOLID GROUTED CMU					
Dia.	Anchor Description	Min. Embed.	Min. E.D.	Maximum Span (Inches)	Anchor Spacing
	Manufacturer Part Number				
1/4"	Spax Screw	1 1/2"	2 1/2"	144"	6"
	Spax				
1/4"	Tapcon	1 1/2"	3"	144"	6"
	Elco or ITW				
1/4"	Maxi-Set Tapcon	1 1/2"	2 1/2"	144"	6"
	ITW				
1/4"	Panelmate (Male or Female)	1 3/4"	2 1/2"	144"	6"
	Elco				
1/4"	Panelmate Inserts	1 5/8"	3"	108"	6"
	Elco				
1/4"	Tapcon SG	1 3/4"	2 1/2"	144"	6"
	ITW (1/4" x 2 1/4")				
1/4"	Sammy's SSC	2 1/4"	2 1/2"	144"	6"
	ITW				
1/4"	Solid Set Anchor	7/8"	3"	96"	6"
	All Points				
1/4"	Calk-In Anchor	7/8"	3"	108"	6"
	Powers				
1/4"	Drop-In Anchor	1"	3"	132"	6"
	Powers				

CONCRETE BLOCK (CMU)					
Dia.	Anchor Description	Min. Embed.	Min. E.D.	Maximum Span (Inches)	Anchor Spacing
	Manufacturer Part Number				
1/4"	Spax Screw	1 1/4"	2 1/2"	72"	6"
	Spax				
1/4"	Tapcon	1 1/4"	2 1/2"	72"	6"
	Elco or ITW				
1/4"	Maxi-Set Tapcon	1"	4"	36"	6"
	ITW				
1/4"	Panelmate (Male or Female)	1 1/4"	3 1/2"	120"	6"
	Elco				
1/4"	Panelmate Inserts	1 1/4"	3 1/2"	120"	6"
	Elco				
1/4"	Tapcon SG	1 1/4"	2 1/2"	72"	6"
	ITW				
1/4"	Sammy's SSC	1 1/4"	2 1/2"	72"	6"
	ITW				
1/4"	Solid Set Anchor	7/8"	3"	96"	6"
	All Points				
1/4"	Calk-In Anchor	7/8"	3"	84"	6"
	Powers				

- NOTES:
1. Maximum spans designed to +60 psf / -63 psf.
 2. Provide longer fasteners, if required, to allow for thickness of non-structural finishes such as stucco, plaster, brick, stone, siding, etc.
 3. All anchor holes to be clean and dust free before inserting intended anchor.
 4. All anchors to be as specified.
 5. Edge distances and embedments are minimums.

Engineering Review By:  Gary D. Foreman PE FL PE 57343	ARMOR SCREEN SERIES 63 HURRICANE PROTECTION	
	ARMOR SCREEN CORP. 1881 Old Okeechobee Road West Palm Beach, FL 33409 (561) 841-8890 www.armorscreen.com	
Date: 10/01/10	Scale: Not to Scale	Page: 9 of 11
DRAWING NO. 01-2010		

REVISIONS	
Date:	
Date:	
Date:	

PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No 12-0417.14
 Expiration Date 01/26/2017
 By 
 Miami Dad Product Control

STORM BAR TABLE									
Storm Bar Span / Length		3'	4'	5'	6'	8'	10'	12'	14'
Max. PSF		Per Deflection Table							
Deflection		Per Deflection Table							
1	Wood 2" x 6"	x	x	x	x				
2	Wood 2" x 8"	x	x	x	x	x			
3	Alum. Tube 1" x 2" x 1/8" 6063-T6	x							
4	Alum. Tube 2" x 2" x 1/8" 6063-T6	x	x	x					
5	Alum. Tube 2" x 4" x 1/8" 6061-T6	x	x	x					
6	Alum. Tube 2" x 4" x 1/4" 6061-T6	x	x	x	x				
7	Alum. Tube 2" x 6" x 1/8" 6063-T6	x	x	x	x	x			
8	Alum. Tube 2" x 6" x 1/4" 6061-T6	x	x	x	x	x	x		
9	Alum. Tube 2" x 8" x 1/4" 6061-T6	x	x	x	x	x	x	x	

NOTES:

- Wood Storm Bar #1 and #2 requires alternate storm bar bracket, see detail on pages 7.
- Wood Storm Bar #1 and #2 to be #2 SYP (Southern Yellow Pine) or Douglas Fir-Larch.
- Storm Bars #3, #4, #5 and #6, screen width supported by storm bars shall be equal to span or 6' maximum. For screens wider than maximum width use multiple storm bars.

MINIMUM GLASS SEPARATION TABLE					
Span in feet	Span in inches	Deflection in inches			
		30 psf	40 psf	50 psf	60 psf
2 ft.	24	3.0	3.1	3.3	3.5
3 ft.	36	4.0	4.2	4.4	4.8
4 ft.	48	4.9	5.3	5.5	6.0
5 ft.	60	5.9	6.3	6.7	7.3
6 ft.	72	7.2	7.8	8.1	9.0
7 ft.	84	8.2	8.8	9.3	10.2
8 ft.	96	9.2	9.9	10.4	11.5
9 ft.	108	10.2	11.0	11.5	12.8
10 ft.	120	11.2	12.0	12.7	14.0
11 ft.	132	12.2	13.1	13.8	15.3
12 ft.	144	13.1	14.2	14.7	16.5


NOTES:

- Deflection is the minimum glass separation measured at MID SPAN of the screen and subject to interpolation between listed spans.
- One inch (1") has been added to actual minimum separation for safety factor.

SCREEN REACTIONS FOR PRESSURE AND SPAN												
Load (psf)		Span										
		2'	3'	4'	5'	6'	7'	8'	9'	10'	11'	12'
		24"	36"	48"	60"	72"	84"	96"	108"	120"	132"	144"
30	Rh	30	45	60	75	90	105	120	135	150	165	180
	Rv	94	141	188	234	281	328	375	422	469	516	563
40	Rh	40	60	80	100	120	140	160	180	200	220	240
	Rv	112	169	225	281	337	393	449	506	562	618	674
50	Rh	50	75	100	125	150	175	200	225	250	275	300
	Rv	129	193	258	322	387	451	515	580	644	709	773
60	Rh	60	90	120	150	180	210	240	270	300	330	360
	Rv	143	214	286	357	429	500	571	643	714	786	857


NOTES:

- Reaction Rh can be positive (towards structure) or negative (away from structure).
- Rv is always tension as shown.



EMBEDDED ANCHOR DIAMETER		
	1/4"	3/8"
A	1/2"	5/8"
B	5/16"	7/16"

A - Internal Thread Length
B - Minimum Thread Engagement



NOTES:

- Table applies to any threaded connection.
- Refer to anchor spacing tables, pages 9 and 10, for anchor embedment.
- Edge distances and embedments are minimums.

REVISIONS

Date:

Date:

Date:

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0417.14
Expiration Date 01/26/2017
By: *[Signature]*
Miami Dade Product Control

Engineering Review By:

[Signature]
Gary D Foreman PE
FL PE 57343

ARMOR SCREEN
SERIES 63
HURRICANE PROTECTION

ARMOR SCREEN CORP.
1881 Old Okeechobee Road
West Palm Beach, FL 33409
(561) 841-8890 www.armorscreen.com

Date: 10/01/10 Scale: Not to Scale Page: 11 of 11

DRAWING NO. 01-2010