



MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786)315-2590 F (786) 31525-99
www.miamidade.gov/economy

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
 BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

Firestone Building Products Company, LLC
250 West 96th Street
Indianapolis, IN 46260

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Firestone BASEGARD SA Modified Bitumen Roof Systems for Steel Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 16.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 12-0508.01
 Expiration Date: 02/07/18
 Approval Date: 02/07/13
 Page 1 of 16

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Modified
Material:	APP, SBS
Deck Type:	Steel
Maximum Design Pressure	-105 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
BASEGARD SA	36" x 108'	ASTM D6163	Fiberglass reinforced modified bitumen, self-adhering base sheet with a smooth sanded surface.
APP 180	39.4" x 32'10"	ASTM D6222	Polyester reinforced modified bitumen, granule surfaced membrane. Torch applied.
APP 180 UltraWhite	39.4" x 32'10"	ASTM D6222	Polyester reinforced modified bitumen, UltraWhite granule surfaced membrane. Torch applied.
APP 180 FR	39.4" x 32'10"	ASTM D6222	Polyester reinforced, fire retardant modified bitumen, granule surfaced membrane. Torch applied.
APP 180 FR UltraWhite	39.4" x 32'10"	ASTM D6222	Polyester reinforced, fire retardant modified bitumen, UltraWhite granule surfaced membrane. Torch applied.
SBS Glass	39.4" x 33'10"	ASTM D6163	Fiberglass reinforced, granule surfaced, modified bitumen membrane. Applied in hot asphalt.
SBS Torch	48" x 39"	ASTM D6164	Granule surfaced, SBS cap reinforced with a non-woven polyester mat, with burn off film and fiberglass enhanced.
SBS Torch UltraWhite	48" x 39"	ASTM D6164	UltraWhite granule surfaced, SBS cap reinforced with a non-woven polyester mat, with burn off film and fiberglass enhanced.
SBS FR Torch	48" x 39"	ASTM D6164	Granule surfaced, fire rated, SBS cap reinforced with a non-woven polyester mat, with burn off film and fiberglass enhanced.
SBS FR Torch UltraWhite	48" x 39"	ASTM D6164	UltraWhite granule surfaced, fire rated, SBS cap reinforced with a non-woven polyester mat, with burn off film and fiberglass enhanced.



SBS Cap	39.4" x 33'10"	ASTM D6164	Granule surfaced, modified bitumen membrane reinforced with non-woven polyester mat.
SBS Cap UltraWhite	39.4" x 33'10"	ASTM D6164	UltraWhite granule surfaced, modified bitumen membrane reinforced with non-woven polyester mat.
SBS FR Cap	39.4" x 33'10"	ASTM D6164	Granule surfaced, modified bitumen membrane reinforced with non-woven polyester mat.
SBS FR Cap UltraWhite	39.4" x 33'10"	ASTM D6164	UltraWhite granule surfaced, modified bitumen membrane reinforced with non-woven polyester mat.
SBS Premium FR	39.4" x 33'10"	ASTM D6164	Granule surfaced, fire rated, modified bitumen membrane reinforced with non-woven polyester mat.
SBS Premium FR UltraWhite	39.4" x 33'10"	ASTM D6164	UltraWhite granule surfaced, fire rated, modified bitumen membrane reinforced with non-woven polyester mat.
SBS Premium	39.4" x 33'10"	ASTM D6164	Granule surfaced, modified bitumen membrane reinforced with polyester mat. Applied in hot asphalt.
SBS Premium Torch	39.4" x 33'10"	ASTM D6164	Granule surfaced, modified bitumen membrane with a burn-off film and reinforced with non-woven polyester mat.
SBS Premium Torch UltraWhite	39.4" x 33'10"	ASTM D6164	UltraWhite granule surfaced, modified bitumen membrane with a burn-off film and reinforced with non-woven polyester mat.
SBS Premium FR Torch	39.4" x 33'10"	ASTM D6164	Granule surfaced, fire rated, modified bitumen membrane with a burn-off film and reinforced with non-woven polyester mat.
SBS Premium FR Torch UltraWhite	39.4" x 33'10"	ASTM D6164	UltraWhite granule surfaced, fire rated, modified bitumen membrane with a burn-off film and reinforced with non-woven polyester mat.
I.S.O. Twin Pack Insulation Adhesive	750 ml cartridges	Proprietary	A two-component polyurethane insulation adhesive.
I.S.O. Fix II	30 lbs.	Proprietary	A single component polyurethane insulation adhesive.
I.S.O. Stick	5 gal.	Proprietary	A two-component polyurethane insulation adhesive.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ISO 95+ GL	Polyisocyanurate Insulation	Firestone Building Products
ISOGARD HD	Polyisocyanurate with a coated fiberglass facer	Firestone Building Products
DensDeck, DensDeck Prime	Silicon treated gypsum	G-P Gypsum
RESISTA	Polyisocyanurate Insulation	Firestone Building Products

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Firestone All-Purpose	Insulation and membrane fastener	Various	Firestone Building Products
2.	Firestone Heavy-Duty	Insulation and membrane fastener	Various	Firestone Building Products
3.	Insulation Fastening Plate	Insulation plate for use with Firestone Fasteners	3" round	Firestone Building Products
4.	OMG 3" Galvalume Steel Plate	Galvalume coated steel plate for use with approved fasteners screw	3" round	OMG, Inc.
5.	OMG Heavy Duty	Insulation and membrane fastener	Various	OMG, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research Corp.	3044812	FM 4470	05/04/12
	3014537	FM 4470	11/29/04
	3020395	FM 4470	11/29/04
	3022492	FM 4470	01/17/05
	3031943	FM 4470	08/12/08
	3035017	FM 4470	04/15/09
	3038197	FM 4470	08/04/11
	3040795	FM 4470	03/24/11
	3042665	FM 4470	05/04/12
	3040109	FM 4470	03/09/11
Underwriters Laboratories	R9516/11NK04032	UL 790	11/18/11
Trinity ERD	F8800.01.08-R1	ASTM D903 / TAS114	01/17/08
	F36650.08.11-1-R2	ASTM D6163	05/08/12
	F36650.09.12	ASTM D4601/ASTM D2178	09/04/12
	F31960.05.10-1	ASTM D4977	05/19/10
	F41070.08.12	ASTM D6222	08/24/12
	F31960.08.10-1	ASTM D4977	08/25/10
PRI Construction Materials Technologies, LLC	FBP-018-02-01	ASTM D6163	09/07/04
	FBP-038-02-02	ASTM D6164	01/12/11
	FBP-038-02-03	ASTM D6164	01/12/11
	FBP-038-02-04	ASTM D6164	01/12/11
	FBP-042-02-02	ASTM D6164	07/27/11
	FBP-042-02-01	ASTM D6164	07/26/11
	FBP-043-02-01	ASTM D6164	08/02/11
	FBP-043-02-02	ASTM D6164	08/02/11
	FBP-043-02-04	ASTM D6164	07/26/11
	FBP-042-02-02	ASTM D6164	07/26/11
	FBP-043-02-03	ASTM D6164	07/26/11
	FBP-053-02-01	ASTM D6163	03/23/12
	FBP-059-02-01	ASTM D1876	07/20/12
	FBP-071-02-01	TAS 114-J	04/25/12



APPROVED ASSEMBLIES

- Membrane Type:** SBS/APP
- Deck Type 2I:** Steel, Insulated
- Deck Description:** 18-22 ga. steel deck
- System Type B(1):** Base layer of insulation mechanically attached, top layer adhered with approved adhesive. Membrane fully adhered.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck or DensDeck Prime Minimum 0.5” thick	1 or 2 with 3	1:2 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Middle Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISO 95+GL Minimum 1.5” thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime Minimum 0.25” thick	N/A	N/A

Note: All Insulations shall be adhered to the base insulation layer using I.S.O. Twin Pack Insulation Adhesive, applied ½” to ¾” wide ribbons spaced 12” o.c. or I.S.O. Fix II or I.S.O. Stick applied in continuous ¾” to 1” wide ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

- Base Sheet:** One ply of Firestone BASEGARD SA, self-adhered with a 3” lap.
- Ply Sheet:** None
- Membrane:** One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3” lap.

Or
One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3” lap.

Maximum Design Pressure: -45 psf. (See General Limitation #9)



Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: 18-22 ga.(33 ksi) steel deck is secured to min. ¼” thick support at a maximum spacing of 6 ft. o.c. Steel deck is attached to supports with ITW Buildex TRAXX 5 fasteners spaced a maximum 6” o.c. one fastener at each bearing attachment point. Side Laps are fastened at 24” o.c. with ITW Buildex TRAXX 1 fasteners.

System Type B(2): Base layer of insulation mechanically attached, top layer adhered with approved adhesive. Membrane fully adhered.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISO 95+ GL Minimum 2.0” thick	1 or 2 with 3	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime Minimum ½” thick	N/A	N/A

Note: Top layer of insulation shall be adhered with I.S.O. Twin Pack Insulation Adhesive applied in ½” to ¾” wide ribbons spaced 4” o.c. or with I.S.O. Fix II or I.S.O. Stick applied in ¾” to 1” wide ribbons spaced 4” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3.5” lap.

Ply Sheet: None

Membrane: One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite, SBS Glass cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. Minimum 3.5” side and end laps are sealed with hot asphalt.

Maximum Design Pressure: -67.5 psf. (See General Limitation #7)



Membrane Type: SBS

Deck Type 2I: Steel, Insulated

Deck Description: 18-22 ga.(33 ksi) steel deck is secured to min. ¼” thick support at a maximum spacing of 6 ft. o.c. Steel deck is attached to supports with ITW Buildex TRAXX 5 fasteners spaced a maximum 6” o.c. one fastener at each bearing attachment point. Side Laps are fastened at 24” o.c. with ITW Buildex TRAXX 1 fasteners.

System Type B(3): Base layer of insulation mechanically attached, top layer adhered with approved adhesive. Membrane fully adhered.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISO 95+ GL Minimum 2.0” thick	1 or 2 with 3	1:1 ft ²

Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISOGARD HD Minimum ½” thick	N/A	N/A

Note: Top layer of insulation shall be adhered with I.S.O. Twin Pack Insulation Adhesive applied in ½” to ¾” wide ribbons spaced 4” o.c. or with I.S.O. Fix II or I.S.O. Stick applied in ¾” to 1” wide ribbons spaced 4” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3.5” lap.

Ply Sheet: None

Membrane: One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite, SBS Glass cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. Minimum 3.5” side and end laps are sealed with hot asphalt.

Maximum Design Pressure: -105 psf. (See General Limitation #7)



Membrane Type: SBS/APP
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type C(1): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISO 95+GL Minimum: 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime Minimum: 0.25" thick	1 or 2 with 3	1:2 ft ²

Note: Top Layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3" lap.
Ply Sheet: None
Membrane: One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3" lap.
 Or
 One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3" lap.

Maximum Design Pressure: -45 psf. (See General Limitation #9)



Membrane Type: SBS
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. Steel
System Type C(2): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISO 95+GL Minimum: 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISOGARD HD Minimum: 0.5" thick	1 or 2 with 3	1:2.7 ft ²

Note: Top Layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3" lap.
Ply Sheet: None
Membrane: One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, or SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3" lap.
 Or
 One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3" lap.

Maximum Design Pressure: -45 psf. (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga.(33 ksi) steel deck is secured to min. ¼” thick support at a maximum spacing of 6 ft. o.c. Steel deck is attached to supports with ITW Buildex TRAXX 5 fasteners spaced a maximum 6” o.c. one fastener at each bearing attachment point. Side Laps are fastened at 24” o.c. with ITW Buildex TRAXX 1 fasteners.
System Type C(3): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISO 95+GL Minimum: 2.2” thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime Minimum: 0.5” thick	1 or 2 with 3	1:1.33ft ²

Note: Top Layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3” lap.
Ply Sheet: None
Membrane: One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3” lap.
 Or
 One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3” lap.

Maximum Design Pressure: -45 psf. (See General Limitation #7)



Membrane Type: SBS/APP
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel deck
System Type C(4): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ISO 95+ GL Minimum 2.2" thick	1 or 2 with 3	1:4 ft ²

Note: All Insulation shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3" lap.
Ply Sheet: None
Membrane: One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3" lap.
 Or
 One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3" lap.

Maximum Design Pressure: -45 psf. (See General Limitation #9)



Membrane Type: SBS
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga. steel deck is secured to min. 1/4" thick support
System Type C(5): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
RESISTA Minimum 1.5" thick	1 or 2 with 3	1:2.7 ft ²

Note: All Insulation shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3" lap.
Ply Sheet: None
Membrane: One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3" lap.
 Or
 One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3" lap.

Maximum Design Pressure: -45 psf. (See General Limitation #9)



Membrane Type: SBS/APP
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga.(33 ksi) steel deck is secured to min. ¼” thick support at a maximum spacing of 6 ft. o.c. Steel deck is attached to supports with ITW Buildex TRAXX 5 fasteners spaced a maximum 6” o.c. one fastener at each bearing attachment point. Side Laps are fastened at 24” o.c. with ITW Buildex TRAXX 1 fasteners.
System Type C(6): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ISO 95+GL Minimum 2.0” thick	1 or 2 with 3	1:2 ft ²

Note: All Insulation shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3” lap.
Ply Sheet: None
Membrane: One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3” lap.
 Or
 One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3” lap.

Maximum Design Pressure: -45 psf. (See General Limitation #7)



Membrane Type: SBS/APP
Deck Type 2I: Steel, Insulated
Deck Description: 18-22 ga.(33 ksi) steel deck is secured to min. ¼” thick support at a maximum spacing of 6 ft. o.c. Steel deck is attached to supports with ITW Buildex TRAXX 5 fasteners spaced a maximum 6” o.c. one fastener at each bearing attachment point. Side Laps are fastened at 24” o.c. with ITW Buildex TRAXX 1 fasteners.
System Type C(7): Membrane fully adhered over mechanically fastened insulation.

All General and System Limitations apply.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ISO 95+ GL Minimum 2.2” thick	1 or 2 with 3	1:1.33 ft ²

Note: All Insulation shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

Base Sheet: One ply of Firestone BASEGARD SA, self-adhered with a 3” lap.
Ply Sheet: None
Membrane: One ply of Firestone SBS Torch, SBS Torch UltraWhite, SBS Premium Torch, SBS Premium Torch UltraWhite, SBS FR Torch, SBS FR Torch UltraWhite, SBS Premium FR Torch, SBS Premium FR Torch UltraWhite, APP 180, APP 180 UltraWhite, APP 180 FR or APP 180 FR UltraWhite cap sheet torch adhered to the base sheet with a 3” lap.
 Or
 One ply of Firestone SBS Cap, SBS Cap UltraWhite, SBS FR Cap, SBS FR Cap UltraWhite, SBS Glass, SBS Premium, SBS Premium FR or SBS Premium FR UltraWhite cap sheet fully adhered to the base sheet with hot asphalt adhesive applied within the EVT range and at a rate of 20-40 lbs./sq. with a 3” lap.
Maximum Design Pressure: -45 psf. (See General Limitation #7)



STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each sidelap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 12-0508.01
Expiration Date: 02/07/18
Approval Date: 02/07/13
Page 16 of 16