



MIAMI-DADE COUNTY
 DEPARTMENT OF PERMITTING, ENVIRONMENT, AND REGULATORY
 AFFAIRS (PERA)
 BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786) 315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/pera

Curv-A-Tech Corporation
 930 W. 23rd Street
 Hialeah, FL 33010

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County PERA - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. PERA reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "400" Aluminum Horizontal Sliding Window – N. I.

APPROVAL DOCUMENT: Drawing No. **W97-31**, titled "Series "400" Aluminum Horizontal Sliding Window – N. I.", sheets 1 through 6 of 6, prepared by Al Farooq Corporation, dated 10/06/97 with revision I dated 05/17/12, signed and sealed by Javad Ahmad, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: None.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises **NOA# 09-0423.07** and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Jaime D. Gascon, P.E.**



J. Gascon
 8/13/12

NOA No. 12-0529.20
Expiration Date: July 1, 2014
Approval Date: August 23, 2012
 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
(Submitted under previous NOA# 09-0423.07)
2. Drawing No. W97-31, titled "Series "400" Aluminum Horizontal Sliding Window – N. I.", sheets 1 through 6 of 6, prepared by Al Farooq Corporation, dated 10/06/97 with revision I dated 05/17/12, signed and sealed by Javad Ahmad, P.E.

B. TESTS

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411 3.2.1 and TAS 202-94
Along with marked-up drawings and installation diagram of an aluminum horizontal sliding window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-5821**, dated March 03, 2009, signed and sealed by Carlos S. Rionda, P. E.
(Submitted under previous NOA# 09-0423.07)
2. Test reports on: 1) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
Along with marked-up drawings and installation diagram of an aluminum horizontal sliding window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-3802**, dated March 15, 2003, signed and sealed by Joseph C. Chan, P. E.
(Submitted under NOA# 03-0807.06)
3. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411 3.2.1 and TAS 202-94
Along with marked-up drawings and installation diagram of an aluminum horizontal sliding window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-1386**, dated July 11, 1996 and reissued July 25, 1996, all signed and sealed by Gilbert Diamond, P. E. *(Submitted under NOA# 00-0327.12)*
4. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Forced Entry Test, per FBC 2411 3.2.1 and TAS 202-94
Along with marked-up drawings and installation diagram of an aluminum horizontal sliding window, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-1364**, dated February 1, 1996 and reissued July 25, 1996, all signed and sealed by Gilbert Diamond, P. E. *(Submitted under NOA# 00-0327.12)*



Jaime D. Gascon, P.E.
Product Control Section Supervisor
NOA No. 12-0529.20
Expiration Date: July 1, 2014
Approval Date: August 23, 2012

Curv-A-Tech Corporation

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

C. CALCULATIONS

1. Anchor verification calculations and structural analysis, complying with FBC-2010, prepared by Al-Farooq Corporation, dated 05/17/12, signed and sealed by Javad Ahmad, P.E.
2. Glazing complies with ASTM E1300-04.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Permitting, Environment, and Regulatory Affairs (PERA)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of conformance, complying with FBC-2010, and of no financial interest, dated May 17, 2012, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.
2. Laboratory compliance letter for Test Report no. **FTL- 5821**, issued by Fenestration Testing Laboratory, Inc., dated March 03, 2009, signed and sealed by Carlos S. Rionda, P. E. *(Submitted under previous NOA# 09-0423.07)*
3. Laboratory compliance letter for Test Report no. **FTL- 3802**, issued by Fenestration Testing Laboratory, Inc., dated May 27, 2003, signed and sealed by Joseph C. Chan, P. E. *(Submitted under NOA# 03-0807.06)*
4. Laboratory addendum letter for Test Report no. **FTL-1364** and **FTL-1386** issued by Fenestration Testing Laboratory, Inc., dated July 15, 1998, signed and sealed by Gilbert Diamond, P. E. *(Submitted under NOA# 00-0327.12)*

G. OTHER



1. Notice of Acceptance No. **09-0423.07**, issued to Curv-A-Tech Corporation for their Series **"400" Aluminum Horizontal Sliding Window-N.I.**", approved on 07/01/09 and expiring on 07/01/14.



Jaime D. Gascon, P.E.
Product Control Section Supervisor
NOA No. 12-0529.20
Expiration Date: July 1, 2014
Approval Date: August 23, 2012

no	date	description
F	6.11.03	3/16" TEMP. GL. CHART REV.
G	8.12.05	UPDATED FOR 2004 FBC
H	04.08.09	GENERAL REVISION
I	05.17.12	UPDATED TO 2010 FBC

date:	10-06-97
scale:	1/2"=1'-0"
dr. by:	HAMID
chk. by:	



TYPICAL ELEVATIONS

SERIES 400
ALUMINUM HORIZONTAL SLIDING WINDOW

DESIGN LOAD RATINGS FOR THESE WINDOWS TO BE AS PER CHARTS SHOWN ON SHEET 2.

APPROVAL APPLIES TO SINGLE HORIZONTAL SLIDING WINDOWS, ALSO COMBINATIONS OF H.S./H.S. OR HORIZONTAL SLIDING WITH OTHER WINDOW TYPES IN MODULES OF TWO OR MORE WINDOWS USING MIAMI-DADE COUNTY APPROVED MULLIONS IN BETWEEN. LOWER DESIGN PRESSURE FROM WINDOWS OR MULLION APPROVAL WILL APPLY TO ENTIRE SYSTEM.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).


WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS, ANCHORS EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BLDG. CODE SECTION 2003.8.4.



GLAZING DETAIL

WINDOWS NOT RATED FOR IMPACT.
 INSTALLATION OF THIS PRODUCT IN THE HVHZ AREA REQUIRES THE USE OF APPROVED SHUTTERS OR EXTERNAL PROTECTION DEVICES COMPLYING WITH HVHZ REQUIREMENTS.
 INSTALLATION OF THIS SYSTEM OUTSIDE THE HVHZ AREA SHALL MEET THE APPLICABLE REQUIREMENTS FOR WIND BORNE DEBRIS PROTECTION.


Engr: JAVAD AHMAD
 CIVIL
 FLA. PE # 170592
 C.A.N. 3538
 MAR 18 2012

PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No. **12-0529.20**
 Expiration Date **7/1/2014**

DESIGN LOAD CAPACITY - PSF
XO OR OX SIZES

WINDOW DIMS.		A	STD. MEETING RAILS				H.D. MEETING RAILS					
			WITHOUT SHEAR CLIPS				WITH SHEAR CLIPS					
			1/8" ANN. GLASS		3/16" ANN. GLASS		3/16" TEMP. GLASS		3/16" ANN. GLASS		3/16" TEMP. GLASS	
WIDTH	HEIGHT	EXT.(+)	INT.(-)	EXT.(+)	INT.(-)	EXT.(+)	INT.(-)	EXT.(+)	INT.(-)	EXT.(+)	INT.(-)	
24"	24"	4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
36"		4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
48"		6	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
60"		6	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
72"		6	61.3	69.8	61.3	125.0	61.3	200.4	61.3	125.0	61.3	210.0
24"	36"	4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
36"		4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
48"		6	61.3	74.2	61.3	125.0	61.3	208.9	61.3	125.0	61.3	210.0
60"		6	61.3	63.7	61.3	109.1	61.3	188.6	61.3	109.1	61.3	196.0
72"		6	54.8	54.8	61.3	91.6	61.3	148.4	61.3	91.6	61.3	167.1
24"	48"	4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
36"		4	61.3	63.6	61.3	117.3	61.3	156.3	61.3	125.0	61.3	175.9
48"		6	48.1	48.1	61.3	94.1	61.3	128.5	61.3	94.1	61.3	142.9
60"		6	-	-	61.3	78.1	61.3	113.8	61.3	78.1	61.3	124.7
72"		6	-	-	61.3	69.6	61.3	106.1	61.3	69.6	61.3	114.3
24"	60"	4	54.3	54.3	61.3	125.0	61.3	163.0	61.3	125.0	61.3	183.5
36"		4	36.9	36.9	61.3	89.7	61.3	115.7	61.3	98.6	61.3	130.3
48"		6	-	-	61.3	71.5	61.3	92.8	61.3	75.1	61.3	104.5
60"		6	-	-	57.2	57.2	61.3	79.8	57.2	57.2	61.3	89.8
72"		6	-	-	52.4	52.4	61.3	71.9	52.4	52.4	61.3	80.9
26-1/2"	26"	4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
37"		4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
53-1/8"		6	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
74"		6	61.3	64.9	61.3	124.0	61.3	182.0	61.3	124.0	61.3	204.8
26-1/2"	38-3/8"	4	61.3	78.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
37"		4	61.3	77.4	61.3	125.0	61.3	210.0	61.3	125.0	61.3	210.0
53-1/8"		6	61.3	65.0	61.3	114.3	61.3	178.6	61.3	114.3	61.3	185.3
74"		6	-	-	61.3	83.3	61.3	137.1	61.3	83.3	61.3	154.4
26-1/2"	50-5/8"	4	61.3	76.6	61.3	125.0	61.3	185.3	61.3	125.0	61.3	208.6
37"		4	58.3	58.3	61.3	107.6	61.3	142.2	61.3	118.3	61.3	160.1
53-1/8"		6	43.5	43.5	61.3	79.2	61.3	111.3	61.3	79.2	61.3	124.5
74"		6	-	-	61.3	64.5	61.3	95.2	61.3	64.5	61.3	103.9
26-1/2"	63"	4	42.5	42.5	61.3	110.2	61.3	140.8	61.3	121.2	61.3	158.5
37"		4	31.0	31.0	61.3	82.8	61.3	106.2	61.3	91.1	61.3	119.6
53-1/8"		6	-	-	61.3	61.4	61.3	80.6	61.3	61.4	61.3	90.8
74"		6	-	-	48.4	48.4	61.0	65.5	48.4	48.4	61.0	73.7

A = NO. OF ANCHORS PER HEAD & SILL




NOTE:
GLASS CAPACITIES ON THIS SHEET ARE
BASED ON ASTM E1300-04 (3 SEC. GUSTS)
AND FLORIDA BUILDING COMMISSION
DECLARATORY STATEMENT DCA05-DEC-219

DESIGN LOAD CAPACITY - PSF
XOX SIZES

WINDOW DIMS.		A	H.D. MEETING RAILS			
			3/16" ANN. GLASS AT VENTS 1/4" TEMP. GLASS AT FIX. LITE			
			W/O SHEAR CLIPS		WITH SHEAR CLIPS	
WIDTH	HEIGHT	EXT.(+)	INT.(-)	EXT.(+)	INT.(-)	
72"	24"	6	61.3	125.0	61.3	125.0
84"		8	61.3	125.0	61.3	125.0
96"		11	61.3	125.0	61.3	125.0
108"		11	61.3	125.0	61.3	125.0
120"		12	61.3	125.0	61.3	125.0
72"	36"	6	61.3	125.0	61.3	125.0
84"		8	61.3	125.0	61.3	125.0
96"		11	61.3	125.0	61.3	125.0
108"		11	61.3	118.7	61.3	118.7
120"		12	61.3	106.6	61.3	106.6
72"	48"	6	61.3	104.8	61.3	118.0
84"		8	61.3	108.7	61.3	108.7
96"		11	61.3	91.4	61.3	91.4
108"		11	61.3	82.4	61.3	82.4
120"		12	61.3	77.1	61.3	77.1
72"	60"	6	61.3	84.8	61.3	95.5
84"		8	61.3	81.0	61.3	91.2
96"		11	61.3	71.9	61.3	71.9
108"		11	61.3	61.6	61.3	61.6
74"		26"	6	61.3	125.0	61.3
106-1/4"	11		61.3	125.0	61.3	125.0
111"	11		61.3	125.0	61.3	125.0
74"	38-3/8"	6	61.3	125.0	61.3	125.0
106-1/4"		11	61.3	112.0	61.3	112.0
111"		11	61.3	107.8	61.3	107.8
74"	50-5/8"	6	61.3	96.8	61.3	109.0
106-1/4"		11	61.3	77.6	61.3	77.6
111"		11	61.3	75.1	61.3	75.1
74"	63"	6	61.3	78.7	61.3	88.6
106-1/4"		11	59.5	59.5	59.5	59.5
111"		11	56.6	56.6	56.6	56.6

A = NO. OF ANCHORS PER HEAD & SILL



OPERATING VENTS TO BE 1/4 OF THE WINDOW WIDTH

Engr: JAVAD AHMAD,
CIVIL
FLA. PE # 70592
C.A.N. 3538
MAR 18 2012



PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0529-20
Expiration Date 7/1/2014
By: [Signature]
Miami Dade Product Control

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W97-31CC



SERIES 400 ALUMINUM HORIZ. SLIDING WDW. (N.I.)
CURV-A-TECH CORPORATION
930 W. 23rd STREET
HIALEAH, FL 33010
TEL. (305) 888-9631 FAX. (305) 888-9969

no	date	by	description
G	08.12.05		UPDATED FOR 2004 FBC
H	04.08.09		GENERAL REVISION
I	05.17.12		UPDATED TO 2010 FBC

date: 10-06-97
scale: 1/2"=1'-0"
dr. by: HAMID
chk. by:
drawing no. W97-31
sheet 2 of 6



HEAD ANCHORS WITH SHEAR CLIPS
SEE SHEET 2 FOR CAPACITY




SEALANTS:

ALL FRAME CORNERS, FIXED MEETING RAIL AT EACH END, INSTALLATION SCREWS IN SILL AND JAMBS SEALED WITH ALUMINUM COLORED SEALANT.

WEEPHOLES:

- W1 - 3/8" NOTCH IN LEG AT EACH END
- W2 - 3/16" X 2" NOTCH 4 PER SILL
- W3 - 3/16" X 2" NOTCH 3 AT XO & OX SIZES
4 AT XOX SIZES
- OPEN CELL FOAM PAD (1/2" X 3/4" X 3-1/4") AT EACH W3
- W4 - 1/2" X 1/8" NOTCH AT SILL TRACK
AT 2" & 39-7/8" FROM EACH END (XOX SIZES)
AT 1-1/4" FROM EACH END (XO OR OX SIZES)



WOOD BUCKS AND METAL STRUCTURES NOT BY CURV-A-TECH MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

TYPICAL ANCHORS: SEE ELEV. FOR SPACING

- 1/4" DIA. ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)
- INTO 2BY WOOD BUCKS OR WOOD STRUCTURES
1-1/2" MIN. PENETRATION INTO WOOD
- THRU 1BY BUCKS INTO CONC. OR MASONRY
1-1/4" MIN. EMBED INTO CONC. OR MASONRY
- DIRECTLY INTO CONC. OR MASONRY
1-1/4" MIN. EMBED INTO CONC. OR MASONRY

#14 SMS OR SELF DRILLING SCREWS (GRADE 2 CRS)
INTO METAL STRUCTURES
STEEL : 12 GA. MIN. (Fy = 36 KSI MIN.)
ALUMINUM : 1/8" THK. MIN. (6063-T5 MIN.)
(STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

#14 SMS OR SELF DRILLING SCREWS
INTO MIAMI-DADE COUNTY APPROVED MULLIONS (MIN. THK. = .090")
(NO SHIM SPACE)

TYPICAL EDGE DISTANCE
INTO CONCRETE AND MASONRY = 1-3/4" MIN. (EXCEPT AT PRECAST SILL)
INTO WOOD STRUCTURE = 1" MIN.
INTO METAL STRUCTURE = 3/4" MIN.

CONCRETE AT HEAD, SILL OR JAMBS f'c = 3000 PSI MIN.
C-90 HOLLOW/FILLED BLOCK AT JAMBS f'm = 2000 PSI MIN.

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 1538
MAR 18 2012

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0524-20
Expiration Date 7/1/2014

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
COMP-ANL\W97-31CC


SERIES 400 ALUMINUM HORIZ. SLIDING WDW. (N.I.)
CURV-A-TECH CORPORATION
930 W. 23rd STREET
HIALEAH, FL 33010
TEL. (305) 888-9631 FAX. (305) 888-9969

no	date	by	description
F	6.11.03		ANCHOR NOTE ADDED
G	8.12.05		UPDATED FOR 2004 FBC
H	04.08.09		GENERAL REVISION
I	05.17.12		UPDATED TO 2010 FBC


date: 10-06-97
scale: 1/2" = 1"
dr. by: HAMID
chk. by:

drawing no.
W97-31


sheet 3 of 6



TYPICAL ANCHORS
SEE ELEV.
FOR SPACING



TYPICAL ANCHORS
SEE ELEV.
FOR SPACING



Eng: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538
MAR 18 2012


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 12-0529.00
Expiration Date 7/1/2014
By *[Signature]*
Miami Dade Product Control

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL (305) 264-8100 FAX (305) 262-6978
COMP-ANL W97-31CC

SERIES 400 ALUMINUM HORIZ. SLIDING WDW. (N.I.)
CURV-A-TECH CORPORATION
930 W. 23rd STREET
HIALEAH, FL 33010
TEL. (305) 888-9631 FAX. (305) 888-9969


no	date	by	description
F	6.11.03		NO CHANGE THIS SHEET
G	8.12.05		UPDATED FOR 2004 FBC
H	04.08.09		GENERAL REVISION
I	05.17.12		NO CHANGE THIS SHEET

date: 10-06-97
scale: 1/2" = 1"
dr. by: HAMID
chk. by:
drawing no.
W97-31
sheet 4 of 6




FRAME HEAD
10248
6063-T5

①




VENT SIDE RAIL
10257
6063-T6

⑧




SHEAR CLIP
6063-T6

②②




VENT TOP/BOTTOM RAIL
10250
6063-T6

⑥




H.D. VENT INTERLOCK RAIL
11823
6063-T6

⑨




SILL TRACK
10846
6063-T5

⑤




H.D. FIXED MEETING RAIL
11822
6063-T6

④




FRAME SILL
10845
6063-T5

②




STD. VENT INTERLOCK RAIL
10256
6063-T6

⑨S



FRAME JAMB
10847
6063-T5

③



STD. FIXED MEETING RAIL
10249
6063-T6

④S

ITEM	PART #	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPPLIER/REMARKS
1	10248	1	FRAME HEAD	6063-T5	-
2	10845	1	FRAME SILL	6063-T5	-
3	10847	2	FRAME JAMBS	6063-T5	-
4	11822	1/ VENT	H.D. FIXED MEETING RAIL	6063-T6	-
4S	10249	1/ VENT	STD. FIXED MEETING RAIL	6063-T6	-
5	10846	1	SILL TRACK	6063-T5	-
6	10250	2/ VENT	VENT TOP/BOTTOM RAIL	6063-T6	-
7	-	1/ VENT	5/16" BOX SCREEN	-	-
8	10257	2/ VENT	VENT SIDE RAIL	6063-T6	-
9	11823	1/ VENT	H.D. VENT INTERLOCK RAIL	6063-T6	-
9S	10256	1/ VENT	STD. VENT INTERLOCK RAIL	6063-T6	-
10	C-3055	4/ VENT	WHEEL HOUSING & GUIDE	NYLON	-
11	C-3056	2/ VENT	ROLLER PIN	ST. STEEL	-
12	C-3085	4/ VENT	VENT FACE GUIDE	NYLON	-
13	-	2/ WINDOW	WEEPHOLE HOUSING & FLAP	NYLON OR CELCON	-
14	-	AS REQD.	ROLL FORMED GLAZING BEAD	ALUMINUM	-
15	OSI HM-270	AS REQD.	GLAZING COMPOUND	SILICONE	-
16	7916-187	AS REQD.	FINSEAL WEATHER STRIP	-	-
17	#8 X 1"	AS REQD.	ASSEMBLY SCREWS	-	PHP SMS
18	-	2/ VENT	SWEEP LATCH	ZAMAK	AT 7-1/4" FROM EACH END
18A	10255	2/ VENT	ALUMINUM VENT LATCH	6063-T6	-
19	C-3081	4	LATCH SPRING CLIP	ST. STEEL	-
20	C-3057	3/ VENT	BRASS ROLLER	-	-
21	#8 X 3"	1/ VENT	FIX. RAIL BOTTOM SCREW	-	-
22	-	AS REQD.	SHEAR CLIP	6063-T6	2" LONG

af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL (305) 262-6978
FAX (305) 264-8100
COMP-ANL\W97-31CC


SERIES 400 ALUMINUM HORIZ. SLIDING WDW. (N.I.)
CURV-A-TECH CORPORATION
930 W. 23rd STREET
HIALEAH, FL 33010
TEL (305) 888-9631 FAX (305) 888-9969

no	date	by	description
F	6.11.03		ITEM NUMBERS ADDED
G	8.12.05		UPDATED FOR 2004 FBC
H	04.08.09		GENERAL REVISION
I	05.17.12		NO CHANGE THIS SHEET



date: 10-06-97
scale: 1/2" = 1"
dr. by: HAMID
chk. by:
drawing no. W97-31
sheet 5 of 6

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538
MAR 18 2012


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 12-0529-20
Expiration Date 7/1/2014
Miami Dade Product Control



VENT CORNER



FRAME TOP CORNER



FRAME BOTTOM CORNER

Engr: UAYAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A. # 3538
 MAR 18 2012

PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No. 12-0529.20
 Expiration Date 7/1/2014

[Signature]
 Product Control

Revisions:

no	date	by	description
F	6.11.03		ITEM NUMBERS ADDED
G	8.12.05		UPDATED FOR 2004 FBC
H	04.08.09		GENERAL REVISION
I	05.17.12		NO CHANGE THIS SHEET

date: 10-06-97
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:

drawing no.
W97-31
 sheet 6 of 6

SERIES 400 ALUMINUM HORIZ. SLIDING WDW. (N.I.)
CURV-A-TECH CORPORATION
 930 W. 23rd STREET
 HIALEAH, FL 33010
 TEL. (305) 888-9631 FAX. (305) 888-9969

AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978

afc
 COMP-ANL\W97-31CC