



MIAMI-DADE COUNTY
 PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786)315-2590 F (786) 31525-99
www.miamidade.gov/economy

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
 BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

Commercial Innovations, Inc.
 9105 Way Ave.
 Cleveland, OH 44105

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Commercial Innovations Cements, Coatings and Adhesives

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 12-0117.01 and consists of pages 1 through 4.
 The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 12-1102.03
 Expiration Date: 02/14/17
 Approval Date: 02/14/13
 Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Materials: Asphalt,

SCOPE:

This approves **Commercial Innovations Cements, Coatings and Adhesives**, for use on existing roof assemblies, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

MANUFACTURING LOCATIONS:

1. Cleveland, OH
2. Wickliffe, OH

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
The Center For Applied Engineering, Inc.	Project 307019	Physical Properties	09/01/94
Underwriters Laboratories, Inc.	File R8384 94NK23637	UL 790	10/26/94
PRI Asphalt Technologies, Inc.	GRD-08-02-03 GRD-08-02-04 GRD-08-02-05	Physical Properties	01/02/98 01/02/98 11/17/98
PRI Construction Technologies, Inc.	GRD-044-02-01 GRD-031-02-01		06/11/07 05/23/07
Intertek Testing Services NA, Inc.	J98024642-231	ASTM E 108	11/18/98
Factory Mutual Research Corporation	3021718 3019046	FM 4470	04/11/05 03/04/05
Trinity ERD	G40250.11.12-2 G40250.11.12-4-R1 G40250.11.12-7 G40250.11.12-8	ASTM D450 ASTM D2824 ASTM D4586 ASTM D5643	11/28/12 02/04/13 11/28/12 11/28/12



PHYSICAL PROPERTIES OF COMPONENTS

Trade Name(s): Viking AB Mastic (25081)
Specifications: ASTM D 4586
Description: Cold applied, trowel-grade mastic designed for use as a patching and leak repair material on tar or asphalt built-up roofing.
Container Size(s): 5 gallon, 55 gallon

Manufacturing Location #1

Trade Name(s): Viking CTP (25011)
Specifications: Proprietary
Description: Polymer modified coal tar pitch, fire-rated, roof coating.
Container Size(s): 200 lb. keg

Manufacturing Location #2

Trade Name(s): Viking Sun Shield Fibered (25131)
Specifications: ASTM D 2824, Type III
Description: Premium quality, high solids content, aluminized roof coating formulated from selected asphalts, oils and resins.
Container Size(s): 5 gallon, 55 gallon

Manufacturing Location #1

Trade Name(s): Viking TB Mastic (25091)
Specifications: ASTM D 5643
Description: Cold applied, trowel-grade coal tar based polymer modified roofing mastic.
Container Size(s): 5 gallon

Manufacturing Location #2



LIMITATIONS

1. All products shall be applied in strict compliance with Manufacturer's published application instructions.
2. Commercial Innovations products shall not be applied in inclement weather conditions.
3. Commercial Innovations coatings and mastics are components of roof assemblies and are approved for use only with approved roof assemblies. See roof assemblies NOA for application rates and acceptances.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test result shall be made available to Miami-Dade Product Control upon request.
5. Fire classifications are not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this products.
6. Change in materials use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. These roof coatings shall not be applied over, prepared roofing; i.e., fibercement shingles, quarry slate, cement or clay roof tile, metal shingles, wood shingles or shakes.
8. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE

