



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

### Siplast

1111 Highway 67 South  
Arkadelphia, AR 71923

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Siplast Self-Adhered Modified Bitumen Roof Systems over Concrete Decks.

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 09-1216.01 consists of pages 1 through 9.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 12-1220.07  
Expiration Date: 04/14/18  
Approval Date: 04/11/13  
Page 1 of 9

## ROOFING SYSTEM APPROVAL

<b>Category:</b>	Roofing
<b>Sub-Category:</b>	Modified Bitumen
<b>Deck Type:</b>	Concrete
<b>Material:</b>	SBS
<b>Maximum Design Pressure:</b>	-405 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Paradiene 20 TS SA	3.28' x 33.5'; 76 lbs./sq.	ASTM D6163	High performance, semi adhered, self adhesive, SBS modified bitumen with random fiberglass mat reinforcement used as a base ply of Paradiene 20/30 systems.
Paradiene 20 SA	3.28' x 33.5'; 72 lbs./sq.	ASTM D6163	High performance, self adhesive, SBS modified bitumen with random fiberglass mat reinforcement used as a utility sheet.
Paradiene 20 EG SA	3.28' x 33.5'; 90 lbs./sq.	ASTM D6163	High duty, self-adhesive, asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply in Paradiene systems.
Paradiene 20 HT SA	3.28' x 50'; 90 lbs./sq.	ASTM D6163	High performance, self adhesive, asphalt elastomer sheet with fiberglass scrim reinforcement for use as a base ply of a Paradiene 20/30 systems.
Paradiene 30 FR Paradiene 30 FR CR	3.28' x 33.5'; 85 lbs./sq.	ASTM D6163	Asphalt elastomer sheet with mineral surfacing and random glass mat reinforcement, for use as the top ply of a Paradiene 20/30 system.
Paradiene 30 HT FR	3.28' x 33.5'; 87 lbs./sq.	ASTM D6163	Fire-rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 MW FR	3.28' x 33.5'; 87 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing and ultra high tensile fiberglass reinforcement for use as the top ply of a Paradiene 20/30 FR system.
Paradiene 30 FR TG Paradiene 30 CR FR TG	3.28' x 25.25'; 80 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing and random fiberglass mat reinforcement for use as the top ply sheet of a Paradiene 20/30 TG Series system.
Paradiene 30 HT FR TG	3.28' x 25.25'; 80 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing and fiberglass scrim reinforcement for use as the top ply of a Paradiene TG Series system.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Paradiene 40 FR	3.28' x 26'; 115 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing, glass mat/glass scrim reinforced.
Paradiene 40 FR TG	3.28' x 26'; 115 lbs./sq.	ASTM D6163	Fire rated asphalt elastomer sheet with mineral surfacing, glass mat/glass scrim reinforced.
Parafor 50 LT	3.28' x 17.5'; 114 lbs./sq.	ASTM D6164	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat/fiberglass scrim reinforced.
Parafor 50 TG	3.28' x 17.5'; 114 lbs./sq.	ASTM D6164	Heavy duty asphalt elastomer sheet with mineral surfacing, polyester mat/fiberglass scrim reinforced.
Veral Aluminum	3.28' x 33.5'; 90 lbs./sq.	ASTM D6298	Aluminum clad asphalt elastomer sheet with woven fiberglass reinforcement for use as the top ply sheet of a Veral system.
Veral Copper	3.28' x 33.5'; 105 lbs./sq.	ASTM D6298	Copper clad asphalt elastomer sheet with fiberglass scrim reinforcement for use as the top ply of a Veral system.
PA 100 Mopping Asphalt		ASTM D312 Type IV	Mopping Asphalt
PA 311/311 M/311LS Adhesive	5 or 55 gal.	ASTM D4479	Blend of adhesive asphalts and quick-drying solvents.
PA 828 Flashing Cement	5 gal.	ASTM D4586	Flashing Cement
PA 1021 Plastic Cement	5 gal.	ASTM D4586	Asphalt cutback reinforced general purpose cement with non-asbestos fibers.
PA 1125 Asphalt Primer	5 or 55 gal.	ASTM D41	Asphalt primer.
PC – 227	5 or 55 gal	ASTM D6083	Elastomeric roof coating.
Para-Stik Insulation Adhesive	30 lb pressurized cylinders	Proprietary	A single component moisture curing Urethane foam adhesive

## APPROVED INSULATIONS:

TABLE 2

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
Paratherm W, Paratherm H	Polyisocyanurate Insulation	Siplast
ACFoam II, ACFoam III	Polyisocyanurate Insulation	Atlas Roofing Corp.
DensDeck Prime, DensDeck DuraGuard	Water resistant gypsum	Georgia-Pacific Gypsum LLC
H-Shield	Polyisocyanurate Foam Insulation.	Hunter Panels LLC
ENRGY 3	Polyisocyanurate Insulation.	Johns Manville
SECUROCK Gypsum-Fiber Roof Board	Water resistant recycled cellulose and synthetic gypsum	US Gypsum Corporation



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	N/A	N/A	N/A	N/A

**EVIDENCE SUBMITTED:**

<b><u>Test Agency/Identifier</u></b>	<b><u>Name</u></b>	<b><u>Report</u></b>	<b><u>Date</u></b>
Factory Mutual Research Corp.	FM 4470	J.I. 2Y1A1.AM	04/15/96
	FM 4470	J.I. 3Z3A7.AM	04/12/96
	FM 4470	3008071	01/18/01
	FM 4470	3008210	04/10/01
	FM 4470	3015680	11/24/03
	FM 4470	3021507	11/04/05
	FM 4470	3023079	05/12/06
	FM 4470	3026749	07/27/06
	FM 4470	3031655	05/27/08
Atlantic & Caribbean Roof Consulting, LLC	TAS 114-D	04-002	10/05/04
	TAS 114-D	04-003	10/05/04
	TAS 114-D	06-025	06/28/06
Underwriters Laboratories, Inc.	UL 790	R10630	03/11/13
Exterior Research & Design, LLC.	TAS 114	#4701.02.96-1	02/28/96
	TAS 114	#4701.09.96-1	08/22/96
	TAS 117	C8500SC.11.07	11/30/07
PRI Construction Materials Technologies LLC	ASTM D6163	SRI-037-02-01	11/15/12
	ASTM D6163	SRI-039-02-01	11/20/12
	ASTM D6164	SRI-041-02-01	11/15/12
	ASTM D6163	SRI-042-02-01	11/16/12
	ASTM D6163	SRI-042-02-02	11/18/12
	ASTM D5147/D6163	SRI-043-02-01	11/15/12
	ASTM D5147/D6164	SRI-044-02-01	12/07/12
	ASTM D5147/D6163	SRI-045-02-01	12/10/12
	ASTM D5147/D6163	SRI-045-02-03	11/18/12
	ASTM D5147/D6163	SRI-046-02-01	11/16/12
	ASTM D6164	SRI-047-02-01	12/07/12
	ASTM D6298	SRI-048-02-01	01/11/13
	ASTM D4601	SRI-049-02-01	11/13/12
	ASTM D4601	SRI-050-02-01	11/12/12
	ASTM D4601	SRI-051-02-01	11/12/12



**APPROVED ASSEMBLIES**

**Membrane Type:** SBS/SBS Foil

**Deck Type 3I:** Concrete Decks, Insulated

**Deck Description:** 2500 psi structural concrete or concrete plank

**System Type A(1):** All layers of insulation adhered to deck with approved asphalt or adhesive.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners Table 3</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Paratherm H, ENRGY 3, ACFoam-II, Paratherm W, H-Shield Minimum 1.5” thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners Table 3</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck Prime Minimum ¼” thick</b>	N/A	N/A

**Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or Insta-Stik/Para-Stik adhesive applied in continuous ¾” to 1” wide beads at a maximum spacing of 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**

**Base Sheet:** Paradiene 20 TS SA self-adhered sheet applied onto insulation layer.

**Ply Sheet:** None.

**Membrane:** Paradiene 30 FR TG, 30 CR FR TG, 30 HT FR TG, Parafor 50 TG, Veral Aluminum or Veral Cooper adhered by torch onto the base sheet.

**Note:** Refer to manufacturer's specifications for specific application requirements.

**Maximum Design Pressure:** -90 psf (See General Limitation #9)



**Membrane Type:** SBS/SBS Foil

**Deck Type 3I:** Concrete Decks, Insulated

**Deck Description:** 2500 psi structural concrete or concrete plank

**System Type A(2):** All layers of insulation adhered to deck with approved asphalt or adhesive.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b>Insulation Layer</b>	<b>Insulation Fasteners Table 3</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Paratherm H, H-Shield, Paratherm W Minimum 1.5" thick</b>	N/A	N/A
<b>AC Foam III Minimum 2" thick</b>	N/A	N/A

**Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup> or Insta-Stik/Para-Stik adhesive applied in continuous 3/4" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**

**Base Sheet:** Paradiene 20 TS SA self-adhered sheet applied onto insulation layer.

**Ply Sheet:** None.

**Membrane:** Paradiene 30 FR TG, 30 CR FR TG, 30 HT FR TG, Parafor 50 TG, Veral Aluminum or Veral Cooper adhered by torch onto the base sheet.

**Note:** Refer to manufacturer's specifications for specific application requirements.

**Maximum Design**

**Pressure:** -127.5 psf (using Paratherm and H-Shield) (See General Limitation #9)  
-135 psf (using AC Foam III) (See General Limitation #9)



**Membrane Type:** SBS

**Deck Type 3I:** Concrete Decks, Insulated

**Deck Description:** 2500 psi structural concrete or concrete plank

**System Type A(3):** All layers of insulation adhered to deck with approved asphalt or adhesive.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners Table 3</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Paratherm W, H-Shield, Paratherm H Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners Table 3</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board, DensDeck DuraGuard Minimum ¼" thick</b>	N/A	N/A

**Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered with Insta-Stik/Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**

**Base Sheet:** Paradiene 20 TS SA base membrane is self-adhered to the insulation layer.

**Ply Sheet:** None.

**Membrane:** Paradiene 30 FR, 30 CR FR, 30 HT FR, or Parafor 50 LT adhered in PA 311/311M/311 LS adhesive applied at a rate of 1.5-2.5 gal/square onto the base sheet.

**Note:** Refer to manufacturer's specifications for specific application requirements.

**Maximum Design Pressure:**  
 -112.5 psf (using Securock) (See General Limitation #9)  
 -187.5 psf (using DensDeck) (See General Limitation #9)



**Membrane Type:** SBS/SBS Foil

**Deck Type 3I:** Concrete Decks, Insulated

**Deck Description:** 2500 psi structural concrete or concrete plank

**System Type A(4):** All layers of insulation adhered to deck with approved asphalt or adhesive.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b>Base Insulation Layer</b>	<b>Insulation Fasteners Table 3</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Paratherm W, H-Shield, Paratherm H Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners Table 3</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board, DensDeck DuraGuard Minimum ¼" thick</b>	N/A	N/A

**Note:** Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of insulation. All insulation shall be adhered with Insta-Stik/Para-Stik adhesive applied in continuous ¾" to 1" wide beads at a maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

**Base Sheet:** Paradiene 20 SA base membrane is self-adhered to the insulation layer.

**Ply Sheet:** None.

**Membrane:** Paradiene 30 FR TG, 30 CR FR TG, 30 HT FR TG, Parafor 50 TG, Veral Aluminum or Veral Copper surfacing membrane is torch adhered onto the base sheet.

**Note:** Refer to manufacturer's specifications for specific application requirements.

**Maximum Design Pressure:**  
 -255 psf (using Securock) (See General Limitation #9)  
 -405 psf (using DensDeck DuraGuard) (See General Limitation #9)



## CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 12-1220.07  
Expiration Date: 04/14/18  
Approval Date: 04/11/13  
Page 9 of 9