



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
 BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
 PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

JB Garage Door, Inc.
 12195 NW 98th Avenue
 Hialeah Gardens, FL 33018

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Models 724/720 Steel Sectional Garage Door up to 18'-2" Wide x 22' High

APPROVAL DOCUMENT: Drawing No. 99-03, titled "Steel Overhead Garage Door", sheets 1 through 5 of 5, dated 02/01/1999, with revision E dated 09/13/2013, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E., bearing the Miami-Dade County Product Control renewal stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: A permanent label with the manufacturer's name or logo, manufacturing address, model number, the positive and negative design pressure rating, indicate impact rated if applicable, installation instruction drawing reference number, approval number (NOA), the applicable test standards, and the statement reading 'Miami-Dade County Product Control Approved' is to be located on the door's side track, bottom angle, or inner surface of a panel.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA # 12-0222.05 and consists of this page 1 and evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



[Handwritten Signature]
 10/10/2013

NOA No. 13-0212.04
 Expiration Date: July 22, 2017
 Approval Date: October 17, 2013
 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **99-03**, titled "Steel Overhead Garage Door", sheets 1 through 5 of 5, dated 02/01/1999, with revision E dated 09/13/2013, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.

B. TESTS

1. Test report on Large Missile Impact Test and Cyclic Wind Pressure Loading Test per FBC, TAS 202-94 of a Model 724 24 ga Sectional Garage Door, prepared by Hurricane Engineering & Testing, Inc., Test Report No. **HETI-13-4077**, dated 07/16/2013, signed and sealed by Rafael E. Droz-Seda, P.E.
2. Test report of Uniform Static Air Pressure Test, Loading and Forced Entry Resistance Test per FBC, TAS 202-94 of a Model 724 24 ga Sectional Garage Door, prepared by Hurricane Engineering & Testing, Inc., Test Report No. **HETI-13-4076**, dated 07/16/2013, signed and sealed by Rafael E. Droz-Seda, P.E.
3. Test report of Tensile Test per ASTM E8 of a Sectional Garage Door Skin, prepared by Hurricane Engineering & Testing, Inc., Test Report No. **HETI-13-T394**, dated 09/04/2013, signed and sealed by Rafael E. Droz-Seda, P.E.

C. CALCULATIONS "*Submitted under NOA # 09-0218.11*"

1. Anchoring verification calculations prepared by Al-Farooq Corporation, complying with F.B.C 2007, dated 01/21/2009, signed and sealed by Humayoun Farooq, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **12-0628.10**, issued to Insulfoam, LLC, for their Insulfoam Expanded Polystyrene Insulation, approved on 01/31/2013 and expiring on 11/29/2017.
2. Notice of Acceptance No. **11-0926.07**, issued to Dyplast Products, LLC, for their Expanded Polystyrene Block Type Insulation, approved on 11/10/2011 and expiring on 01/11/2017.
3. Notice of Acceptance No. **11-0926.06**, issued to Dyplast Products, LLC, for their Dyplast ISO-C1 Polyisocyanurate Insulation, approved on 11/10/2011 and expiring on 01/11/2017.

F. STATEMENTS

1. Statement letter of code conformance to 2010 FBC issued by Al-Farooq Corporation, dated 02/07/2013, signed and sealed by Javad Ahmad, P.E.


"Submitted under NOA # 09-0218.11"

2. Statement letter of no financial interest issued by Al-Farooq Corporation, dated 01/08/2009, signed and sealed by Humayoun Farooq, P.E.



Carlos M. Utrera, P.E.
Product Control Examiner
NOA No. 13-0212.04


Expiration Date: July 22, 2017
Approval Date: October 17, 2013




DOOR WIDTH	NO. OF STILES
12'-3" TO 16'-11"	(4) CENTER STILES
17'-0" TO 18'-2"	(5) CENTER STILES

INTERMEDIATE STILES FASTENED TO PANEL SKIN W/ (6) 3/16" ALUM RIVETS AND TO TOP & BOTTOM RAIL W/ (4) 3/16" RIVETS

(2) TOP ROLLER BRACKETS SEE SHEET 3 FOR DETAIL




SPRING LOADED SLIDE BOLT LOCK (BOTH SIDES) FASTENED W/ (4) 1/4 X 5/8" HH SMS 5/8" MIN. LOCK ENGAGEMENT CONFORMS TO FBC 1012 REGARDING GARAGE DOORS




ALTERNATE LOCK 2/ DOOR

16 GA. GALV. STEEL MOUNTING PLATE FASTENED W/ FOUR # 10-24 X 1/2" CARRIAGE BOLT & LOCK NUT.




INSIDE SPRING LATCH FASTENED W/ FOUR #10 X 1/2" S.M.S.

.128 DIA. GALV. AIRCRAFT TYPE CABLE & NICO-PRESS SLEEVE W/ MIN. 5 TO 1 SAFETY FACTOR



BRACKET STD. LIFT DOOR

7-7/8" X 3-1/8" X .010" STEEL PLATE WITH (4) #14 X 3/4" SDS



BRACKET LOW HEADROOM DOOR OPTION

INSIDE ELEVATION

THIS PRODUCT IS RATED FOR LARGE MISSILE IMPACT

J.B. DOOR MODELS: 18'-2"W X 22'H MAX	
MODEL	DESCRIPTION
724	24 GA. ROLL FORMED STEEL DOOR
720	20 GA. ROLL FORMED STEEL DOOR

NOTE: MODEL 724 TESTED.

MAXIMUM DESIGN LOAD RATING = + 50.0 PSF (FOR SIZES SHOWN OR SMALLER) - 60.0 PSF

GENERAL NOTES

1. THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE 2010 EDITION INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).
2. ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS. ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.
3. ALL BOLTS, NUTS AND WASHERS SHALL BE ZINC PLATED CARBON STEEL.
4. ANCHORING OR LOADING CONDITIONS OTHER THAN THOSE SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

Engr. JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538

SEP 11 2013

PRODUCT RENEWED as complying with the Florida Building Code
Acceptance No 13-0212.04
Expiration Date 07/22/2017

By *[Signature]*
Miami Trade Product Control

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
12395 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX. (305) 262-6978
GARAGE\99-03JB

STEEL OVERHEAD GARAGE DOOR



J.B. GARAGE DOORS INC.
12195 N.W. 98 TH. AVE.
HIALEAH GARDENS, FL. 33016
TEL. (305) 558 - 1658

revisions:

no	date	by	description
A	4.30.99	H	GENERAL REVISION
B	8.09.05	H	UPDATED FOR 2004 FBC
C	1.23.09	H	UPDATED FOR 2007 FBC
D	11.21.11	H	UPDATED TO 2010 FBC
E	8.13.13	H	NO CHANGE THIS SHEET

date: 02-01-99
scale: NONE
dr. by: HAMID
chk. by:

drawing no. 99-03
sheet 1 of 5



FOR CONNECTION OF WOOD BUCK TO MASONRY SEE NOTE ON SHEET 5
 FOR CONNECTION DIRECTLY TO CONCRETE SEE ALTERNATE DETAIL SHEET 5
 CONNECTION TO METAL BUILDING TO BE ENGINEERED ON JOB TO JOB BASIS.

Engr: JAVAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A.N. 3538

SEP 2013

PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No. 13-0212.04
 Expiration Date 07/27/2017


By: *[Signature]*
 Miami Dade Product Control

STEEL OVERHEAD GARAGE DOOR
J.B. GARAGE DOORS INC.
 12195 N.W. 98 TH. AVE.
 HIALEAH GARDENS, FL. 33016
 TEL. (305) 558 - 1658

no	date	by	description
B	8.09.05	H	SHEET ADDED
C	1.23.09		UPDATED FOR 2007 FBC
D	11.21.11		NO CHANGE THIS SHEET
E	9.13.13		NO CHANGE THIS SHEET

date: 02-01-99
 scale: NONE
 dr. by: HAMID
 chk. by:


drawing no.
99-03
 sheet 2 of 5



SECTION A-A


SEE SECTIONS AT RIGHT FOR LOCATION OF REINFORCING TRUSSES

TWO (2) REINFORCING TRUSSES PER SECTION EXCEPT THREE (3) ON THE BOTTOM SECTION




1ST SECTION (BOTTOM)

REINFORCING



2ND SECTION (BOTTOM)

REINFORCING



ALL TOP SECTIONS

REINFORCING

Engr: JAVAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A.N. 3538

SEP 27 2013

PRODUCT RENEWED as complying with the Florida Building Code
 Acceptance No 13-0212.04
 Expiration Date 07/27/2017

By *[Signature]*
 Miami Dade Product Control



af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 GARAGE 99-03JB

STEEL OVERHEAD GARAGE DOOR
J.B. GARAGE DOORS INC.
 12195 N.W. 98 TH. AVE.
 HIALEAH GARDENS, FL. 33016
 TEL. (305) 558 - 1658


no.	date	by	description	NOA NO.	REV.
B	8.09.05	H	UPDATED FOR 2007 FBC		
C	1.23.09		NO CHANGE THIS SHEET		
D	11.21.11				
E	9.13.13				

date: 02-01-99
 scale: NONE
 dr. by: HAMID
 chk. by:

drawing no.
99-03
 sheet 3 of 5



DOOR TRACK AS VIEWED FROM CENTER OF OPENING



DOOR HEIGHT	NO. OF TRUSSES	SECTION HEIGHTS *												
		1ST	2ND	3RD	4TH	5TH	6TH	7TH	8TH	9TH	10TH	11TH		
7'-0"	9	21"	21"	21"	21"	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
8'-0"	9	24"	24"	24"	24"	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
9'-0"	11	24"	21"	21"	21"	21"	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
10'-0"	11	24"	24"	24"	24"	24"	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
11'-0"	13	24"	24"	21"	21"	21"	21"	N/A	N/A	N/A	N/A	N/A	N/A	N/A
12'-0"	13	24"	24"	24"	24"	24"	24"	N/A	N/A	N/A	N/A	N/A	N/A	N/A
13'-0"	15	24"	24"	24"	21"	21"	21"	21"	N/A	N/A	N/A	N/A	N/A	N/A
14'-0"	15	24"	24"	24"	24"	24"	24"	24"	N/A	N/A	N/A	N/A	N/A	N/A
15'-0"	17	24"	24"	24"	24"	21"	21"	21"	21"	N/A	N/A	N/A	N/A	N/A
16'-0"	17	24"	24"	24"	24"	24"	24"	24"	24"	N/A	N/A	N/A	N/A	N/A
17'-0"	19	24"	24"	24"	24"	24"	21"	21"	21"	21"	N/A	N/A	N/A	N/A
18'-0"	19	24"	24"	24"	24"	24"	24"	24"	24"	24"	N/A	N/A	N/A	N/A
19'-0"	21	24"	24"	24"	24"	24"	24"	21"	21"	21"	21"	N/A	N/A	N/A
20'-0"	21	24"	24"	24"	24"	24"	24"	24"	24"	24"	24"	24"	N/A	N/A
21'-0"	23	24"	24"	24"	24"	24"	24"	24"	21"	21"	21"	21"	N/A	N/A
22'-0"	23	24"	24"	24"	24"	24"	24"	24"	24"	24"	24"	24"	24"	24"

*--SECTIONS ARE NUMBERED STARTING AT THE BOTTOM

Engr: JAVAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A.N. 3538
 SEP 17 2013

PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No 13-0212.04
 Expiration Date 07/22/2017
 By: *[Signature]*
 Miami Dade Product Control

afC

AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 GARAGE 99-03JB

STEEL OVERHEAD GARAGE DOOR

J.B. GARAGE DOORS INC.
 12195 N.W. 98 TH. AVE.
 HIALEAH GARDENS, FL. 33016
 TEL. (305) 558 - 1658


no	date	description
B	8.09.05	H ANCHOR SPACING REV.
C	1.23.09	UPDATED FOR 2007 FBC
D	11.21.11	NO CHANGE THIS SHEET
E	9.13.13	NO CHANGE THIS SHEET

date: 02-01-99
 scale: NONE
 dr. by: HAMID
 chk. by:

drawing no.
99-03

sheet 4 of 5

ANCHOR SPACING				
ANCHORS	STRUCTURE	EMBED	SPACING	EDGE DIST.
3/8" HLC SLEEVE BY 'HILTI'	CONC.	1-1/4"	8"	3"
1/2" HLC SLEEVE BY 'HILTI'	FILLED BLOCK	1-1/2"	8"	4"
3/8" DYNABOLT BY 'ITW'	CONC.	1-1/2"	8"	3-1/2"
1/2" DYNABOLT BY 'ITW'	FILLED BLOCK	1-7/8"	6"	4"
3/8" POWER-BOLT BY 'POWERS'	CONC.	2"	8"	1-7/8"
3/8" SLEEVE-ALL BY 'SIMPSONS'	CONC.	1-1/2"	8"	3-1/2"



CONCRETE f'c = 3000 PSI MIN.
 C-90 GROUT FILLED BLOCK f'm = 2000 PSI MIN.

TRACK INSTALLATION

WOOD FRAME BUILDINGS

STUD WALLS OR DOOR OPENING (NOT BY J.B. DOORS) SHALL BE FRAMED SOLID BY NOT LESS THAN (3) 2X6 PRESSURE TREATED GRADE 2 SYP OR BETTER WOOD STUDS.
 STUD WALLS TO BE CONT. FROM FOOTING TO TIE BEAM. ENGINEER OF RECORD TO VERIFY ADEQUACY OF THE SUPPORTING STRUCTURE.

WOOD BUCK CONNECTION TO MASONRY

TRACK SHALL BE SECURED WITH CONT. STEEL ANGLE TO PRESSURE TREATED 2X6 SYP WOOD JAMBS WHICH SHALL BE ANCHORED TO GROUTED REINFORCED MASONRY BLOCK WALL OR CONC. COLUMN WITH

1/4" ULTRACON BY 'ELCO' WITH SPACING OF 8" O.C. INTO BLOCK WALL, WITH 2-1/4" MIN. EMBED
 7" O.C. INTO 3000 PSI CONCRETE, WITH 1-3/4" MIN. EMBED
 2-1/2" MIN. EDGE DISTANCE


1/4" TAPPER BY 'POWERS' WITH SPACING OF 5" O.C. INTO BLOCK WALL, WITH 1-1/2" MIN. EMBED
 5" O.C. INTO 3000 PSI CONCRETE, WITH 1-3/4" MIN. EMBED
 3" MIN. EDGE DISTANCE

3/8" CONFLX BY 'ELCO' OR
 3/8" LDT BY 'ITW' WITH SPACING OF 12" O.C. INTO 3000 PSI CONCRETE, WITH 2-1/2" MIN. EMBED
 3" MIN. EDGE DISTANCE

3/8" HLC SLEEVE BY 'HILTI' WITH SPACING OF 7" O.C. INTO 3000 PSI CONCRETE, WITH 1-1/4" MIN. EMBED AND 2-1/2" MIN. EDGE DISTANCE

THE BLOCK WALL CELLS SHALL BE GROUT FILLED AND REINFORCED WITH FOUR # 5 BARS EXTENDING INTO FOOTING AND INTO TIE BEAMS ALL BARS SHALL BE CONTINUOUS FROM TIE BEAMS TO FOOTING.

PREPARATION OF JAMBS BY OTHERS



Engr. JAVAD AHMAD
 CML
 FLA. PE # 70592
 C.A.N. 3538
 SEP 17 2013

PRODUCT RENEWED
 as complying with the Florida Building Code
 Acceptance No. 13-0212.04
 Expiration Date 07/22/2017
 By: *[Signature]*
 Mizzi Dade Product Control

STEEL OVERHEAD GARAGE DOOR
J.B. GARAGE DOORS INC.
 12195 N.W. 98 TH. AVE.
 HIALEAH GARDENS, FL. 33016
 TEL. (305) 558 - 1658

no	date	description
B	18.09.05	H ANCHOR SPACING REV.
C	1.23.09	UPDATED FOR 2007 FBC
D	11.21.11	NO CHANGE THIS SHEET
E	9.13.13	NO CHANGE THIS SHEET

date: 02-01-99
 scale: NONE
 dr. by: HAMID
 chk. by:

drawing no.
99-03
 sheet 5 of 5