

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

OMG, Inc. 153 Bowles Road Agawam, MA 01001

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: OMG Roof Fastening Systems

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This revises NOA# 12-0214.02 and consists of pages 1 through 16. The submitted documentation was reviewed by Juan E. Collao, R.A.



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13

Page 1 of 16

ROOFING ASSEMBLY APPROVAL

Category: Roofing

Roofing Fasteners **Sub-Category**

Material: Steel

MANUFACTURING LOCATIONS:

- 1. Itasca, IL.
- 2. Agawam, MA
- Thomaston, CT 3.
- 4. Pittsfield, MA
- 5. Elk Grove Village, IL

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

FASTENERS:

		Test	
Product	Dimensions	Specifications	Product Description
AccuTrac Hextra	#12 x 8" max. Length, 1/4" hex washer head.	TAS 114 TAS 117	Hex washer head, modified buttress thread pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating.
#12 Standard Roofgrip	#12 x 8" max. Length, #3 Phillips head.	TAS 114 TAS 117	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating.
#14 Roofgrip	#14- x 24" max. Length, #3 Phillips head.	TAS 114 TAS 117	Phillips head, standard thread, pinch point, carbon steel fastener for use in metal, wood or concrete decks. With CR-10 coating.
#15 Roofgrip	#15 x 14" max. Length, #3 Phillips head.	TAS 114 TAS 117	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel, wood, or concrete decks. With CR-10 coating.
#12 Standard Hex Head	#12 x 8" max. Length, 1/4" hex washer head.	TAS 114 TAS 117	Hex washer head, modified buttress thread pinch point, carbon steel fastener for use in steel or wood decks. With CR-10 coating.
#12 Standard Stainless Steel	#12 x 8" max. Length, #3 Phillips head.	TAS 114 TAS 117	Phillips head, modified buttress thread, pinch point, stainless steel fastener for use in steel or wood decks.
#15 SPM	#15 x 14" max. Length, #3 Phillips head.	TAS 114 TAS 117	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel, wood, or concrete decks. With CR-10 coating.
#15 Roofgrip Large Head	#15 x 14" max. Length, oversized #3 Phillips head.	TAS 114 TAS 117	Phillips head, modified buttress thread, pinch point, carbon steel fastener for use in steel, wood, or concrete decks.
CR Base Sheet Fastener (1.2 ")	1.125" head x 1.2" length.	TAS 114	G-90 galvanized fastener for base sheet attachment to gypsum decks and on lightweight insulating concrete decks less than 2" thick. With Olympic CR-10 coating.



NOA No.: 13-0326.14 **Expiration Date: 09/27/17** Approval Date: 05/02/13

Page 2 of 16

FASTENERS:

Product	Dimensions	<u>Test</u> Specifications	Product Description
CR Base Sheet Fastener (1.7 ")	1.125" head x 1.75" length.	TAS 114	G-90 galvanized fastener for base sheet attachment to gypsum decks and lightweight insulating concrete decks. With Olympic CR-10 coating.
CD-10	0.214" min. dia. x 12" max. length; wafer head	TAS 114	Carbon steel expansion fastener for use in structural concrete decks. CR-10 coated.
Fluted Nail	0.212" to 0.225" dia. x 12" max. length; octagonal head	TAS 114	Spiral shanked nail, for use in structural concrete decks. CR-10 coated.
Lite Deck	0.240" to 0.375" x 12" max. length; #3 Phillips flat head	TAS 114	Carbon steel fastener for insulation attachment in gypsum and cementitious wood fiber decks. CR-10 coated.
Polymer GypTec	0.675" Thread dia. X 1" dia. Head x 12" max. length	TAS 114	One piece, glass reinforced nylon fastener for use in gypsum and cementitious wood fiber decks.
OMG Heavy Duty	#14 x 16" max. length; #3 Phillips head	TAS 114	Truss head, self-drilling, pinch point, high thread fastener for steel use in wood, steel or concrete decks.
OMG XHD	#15 x 16" max. length; #3 Phillips head	TAS 114	Truss head, self-drilling, pinch point, high thread fastener for steel use in wood, steel or concrete decks.
OMG Super XHD	#21 x 16" max. length; #3 Phillips head	TAS 114	Truss head, self-drilling, pinch point, high thread fastener for steel use in wood, steel or concrete decks.
Maxload Fastener	#21 x 10" max. length; #3 Phillips head	TAS 114	Truss head, self-drilling, pinch point, high thread fastener for steel use in wood, steel or concrete decks.
OMG HeadLok DP	#12 x max. 8 ³ / ₄ "	TAS 114	Large Head carbon steel screw, drill point, for, use into min 18ga steel purlin CR-10 coated.
OMG HeadLok SP	#14- x 14" max. Length, #3 Phillips head.	TAS 114 TAS 117	Large Head Phillips head, standard thread, pinch point, carbon steel fastener for use in metal, wood or concrete decks. With CR-10 coating.
OMG Purlin	#12 x max. 8 ³ / ₄ "	TAS 114	Hex head carbon steel screw, drill point, for use into min 18ga steel purlin.
Strap Toggle	¹ / ₄ " dia. x 24" max. length bolt; 2" wide toggle	TAS 114	Metal spring loaded toggle bolt with a plastic locking strap for use in wood, steel or gypsum decks.
RhinoBond (Retro) Driller	4" - 10" max. length With #3 Square Head	TAS 114 TAS 117	Carbon steel screw, drill point, for use into min 16 ga steel purlin. With CR-10 coating.



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 3 of 16

PLATES:

D 1 4	D	$\frac{\text{Test}}{\text{c}}$	
<u>Product</u>	<u>Dimensions</u>	Specifications The Control of the	Product Description
3 in. Ribbed Galvalume Plate	3" round	TAS 114	Round Galvalume plated steel stress plate with reinforcing ribs for use with OMG fasteners
3 in. Round Metal Plate	3" round	TAS 114	Round Galvalume steel stress plate for use with OMG fasteners.
AccuTrac Plate	3" square; .018"- .021" thick.	TAS 114 TAS 117	Galvalume steel plate for use with Standard Roofgrip and Standard Hex Head fasteners.
AccuTrac Flat Bottom	3" square; .018"021" thick	TAS 114 TAS 117	A2-SS aluminized steel plate for use with #12 Roofgrip, #14 Roofgrip and #15 Roofgrip.
Base Sheet Plate	2.75" Galvalume steel stress plate.	TAS 114	galvalume stress plate for use with OMG C-R Base Sheet Fasteners.
Flat Bottom Metal Plate	3" square; .018"021" thick	TAS 114 TAS 117	A2-SS aluminized steel plate for use with #12, 14 or 15 Standard Roofgrip
Lite Deck Plate	3" round	TAS 114	Round, galvalume plate for use with Lite-Deck Fasteners.
Polymer GypTec Insulation Plate	3" round	TAS 114 TAS 117	AZ-55 Galvalume plate for use with the Polymer GypTec fastener.
OMG Plastic Plate	3" round	TAS 114	Round high density polypropylene stress plate for use with OMG fasteners.
OMG 2" Barbed Plate	2" round	TAS 114	Round galvanized steel stress plates for use with OMG fasteners.
OMG 2-3/4" Super XHD Barbed Plate	2-3/4" round	TAS 114	Round galvanized steel stress plates for use with OMG fasteners.
OMG 3" Galvalume Steel Plate	3" round, .018"021" thick.	TAS 114 TAS 117	Galvalume coated steel plate for use with approved fasteners screw.
Recessed Metal Plate	3" square; .018"- .021" thick.	TAS 114 TAS 117	Galvalume steel plate for use with Standard Roofgrip, Hex Head or Stainless fasteners.
RhinoBond Insulation Plate	3" round	TAS 114	Primer coated plate for use with heat welded TPO and PVC membranes.
RhinoBond TreadSafe Plate	3" round	TAS 117	Round, coated galvalume plate (Gold and Black) used for TPO and PVC membranes.



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 4 of 16

PRE-ASSEMBLED SYSTEMS:

		<u>Test</u>	
Product	Dimensions	Specifications	Product Description
AccuTrac Fastening System	See components above	TAS 114	AccuTrac Galvalume plates with approved fasteners.
C-R Base Sheet 2X	2.4" x 1.3" rectangular cap x 1.7" leg length.	TAS 114	G-90 galvanized fastener preassembled with a 3.6" x 2.5" AZ-55 Galvalume steel rectangular disc for base sheet attachment to lightweight insulating concrete decks. With Olympic CR-10 coating.
CR Assembled Base Sheet Fastener (1.2 ")	1.125" head x 1.2" length.	TAS 114	G-90 galvanized fastener for base sheet attachment to gypsum decks and on lightweight insulating concrete decks less than 2" thick. With OMG CR-10 fluorocarbon coating. With Galvalume plate.
CR Assembled Base Sheet Fastener (1.7")	1.125" head x 1.75" length.	TAS 114	G-90 galvanized fastener for base sheet attachment to gypsum decks and lightweight insulating concrete decks. With OMG CR-10 fluorocarbon coating. With Galvalume plate.
ASAP RoofGrip Pre- Assembled System	See components above	TAS 114	Pre-assembled Roofgrip #12, #14 and #15 fasteners with approved plates.
ASAP Hex Head RoofGrip Pre-Assembled System	See components above	TAS 114	Pre-assembled #12, #14, #15 Hex Head fasteners with approved plates.
Stainless ASAP RoofGrip Pre-Assembled System	See components above	TAS 114	Pre-assembled Stainless #12 and #14 fasteners with approved plates.



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 5 of 16

EVIDENCE SUBMITTED

Test Agency	Test Identifier	Test Name/Report	<u>Date</u>
Factory Mutual	FM 4470	J.I. 3Z5A4.AM	02/23/96
Research Corporation	FM 4470	J.I. 1R0A4.AM	04/03/90
•	FM 4470	J.I. 1N5A6.AM	06/22/87
	FM 4470	J.I. 1T3A3.AM	11/26/91
	FM 4470	J.I. 1V9A5.AM	09/16/92
	FM 4470	J.I. 0E6A9.AM	01/22/80
	FM 4470	J.I. 0G1A9.AM	10/19/82
	Wind Uplift	J.I. 0T0A5.AM	06/01/91
	Pull Out/Sheer Data	J.I. 0M3A6.AM	07/31/85
	Pull Out/Shear Data	J.I. 1T2A6.AM	02/22/93
	FMRC 4450	J.I. 1Y5A4.AM	07/19/94
	Tensile/Sheer Data	No. MA 4907 Lab # 2386	01/13/83
	Pull Out	No. MA 4907 Lab # 9098	04/24/85
	Wind Uplift	J.I. 0W7A2.AM	09/01/93
	Wind Uplift	J.I. 1X2A6.AM	08/01/93
	Wind Uplift	J.I. 2V0A5.AM	02/01/92
	FM 4470	3031546	03/25/08
	FM 4470	3026774	01/21/08
	FM 4470	3040926	11/10/10
	FM 4450	3032397	02/28/08
	FM Letter	3036723	06/03/09
	FM Small Scale Testing	3035599	04/01/09
	FM 4450	3037608	08/18/10
	FM 4450	797-03187-267	10/11/07
	FM 4470	797-06631-267	07/18/11
Trinity ERD	TAS 117(A), (B) & (C)	Base Sheet Testing	07/12/94
	PA 117(A), (B) & (C)	#4251.08.96-1	08/01/96
	TAS 117(A), (B) & (C)	O8050.04.08-R2	04/04/08



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 6 of 16

TYPICAL PHYSICAL PROPERTIES

Concrete Deck

Product	Min. psi	Property(s)	<u>Test</u>	Min. Embedment/	Typical Results
		<u>Tested</u>		Penetration	<u>(lbf)</u>
#14 Standard Roofgrip		Shear Test	ASTM E 488	N/A	1019
	N/A	Pull Out Test	TAS 117(A)		783.3
		Pulsating Load			480
OMG Heavy Duty	2 000	Pull Out Test	TAS 117(A)	1"	798.0
	3,000	Pulsating Load			578.0
CD-10	3,000	Pulsating Load	TAS 117(A)	1"	410.0
Fluted Nail	3,000	Pulsating Load	TAS 117(A)	1"	466.5

Steel Deck

<u>Product</u>	<u>Deck</u> <u>Thickness</u>	Property(s) Tested	<u>Test</u>	Min. Embedment/ Penetration	Typical Results (lbf)
AccuTrac Hextra	22 ga.	Pull Out Test	ASTM E 488	N/A	519.0
#12 Standard Roofgrip	22 ga.	Pull Out Test Pulsating Load	ASTM E 488 TAS 117(A)	N/A	519.0 213.0
#12 Standard Hex Head	22 ga.	Pull Out Test Pulsating Load	ASTM E 488 TAS 117(A)	N/A	519.0 213.0
#12 Standard Stainless Steel	22 ga.	Pull Out Test Pulsating Load	ASTM E 488 TAS 117(A)	N/A	519.0 213.0
#14 Roofgrip	22 ga.	Pull Out Test Pulsating Load	ASTM E 488 TAS 117(A)	N/A	415.0 220.0
#15 Roofgrip	22 ga.	Pull Out Test Pulsating Load	ASTM E 488 TAS 117(A)	N/A	550.0 248.0
#15 Roofgrip Large Head	22 ga.	Pull Out Test Pulsating Load	ASTM E 488 TAS 117(A)	N/A	550.0 248.0
#15 SPM	22 ga.	Pull Out Test Pulsating Load	ASTM E 488 TAS 117(A)	N/A	550.0 248.0
OMG Heavy Duty	22 ga., grd. A	Pull Out Test Pulsating Load	TAS 117(A)	1/2"	151.5 136.5
OMG XHD	22 ga.	Pull Out Test Pulsating Load	ASTM E 488	N/A	550.0 248.0



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 7 of 16

Plywood Deck

<u>Product</u>	<u>Deck</u> <u>Thickness</u>	Property(s) Tested	<u>Test</u>	Min. Embedment/ Penetration	Typical Results (lbf)
AccuTrac Hextra	Min. 3/4"	Pull Out Test	ASTM E 488	N/A	517.0
#12 Standard Roofgrip	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	535.2 238.0
#12 Standard Hex Head	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	535.2 238.0
#12 Standard Stainless Steel	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	535.2 238.0
#14 Roofgrip	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	613.6 282.0
#15 Roofgrip	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	581.7 300.0
#15 Roofgrip Large Head	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	581.7 300.0
#15 SPM	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	581.7 300.0
OMG Heavy Duty	Min. 15/32"	Pull Out Test Pulsating Load	TAS 117(A)	1/2"	137.5 133.0
OMG XHD	Min. ¹⁹ / ₃₂ "	Pull Out Test Pulsating Load	TAS 117(A)	N/A	581.7 300.0

Cementitious Wood Fiber Decks

<u>Product</u>	<u>Deck</u>	Property(s) <u>Tested</u>	<u>Test</u>	Min. Embedment/ Penetration	Typical Results (lbf)
Polymer GypTec	Any	Pulsating Load	TAS 117(A)	1.5"	106.0
Lite Deck	Any	Pulsating Load	TAS 117(A)	2"	115.5

Gypsum Decks

Product	Deck	Property(s)	<u>Test</u>	Min. Embedment/	Typical Results
		Tested		Penetration	<u>(lbf)</u>
CR Base Sheet Fastener	Poured	Pulsating Load	TAS 117(A)	N/A	65.0
(1.2 ")		Static Load			68.0
Polymer GypTec	Poured	Pulsating Load	TAS 117(A)	1.5"	257.0
Lite Deck	Poured	Pulsating Load	TAS 117(A)	2"	300.0



NOA No.: 13-0326.14 **Expiration Date: 09/27/17** Approval Date: 05/02/13

Page 8 of 16

Lightweight Concrete Deck

<u>Product</u>	Min. psi	Property(s) <u>Tested</u>	<u>Test</u>	Min. Embedment/ Penetration	Typical Results (lbf)
CR Base Sheet Fastener (1.7")	200	Pulsating Load Static Load	TAS 117(A)	N/A	28 day cure, 48.0 3 day cure, 45.5 28 day cure, 59.5
CR Assembled Base Sheet Fastener (1.2")	200	Pulsating Load Static Load	TAS 117(A)	N/A	28 day cure, 38.5 3 day cure, 29.5 28 day cure, 48.5
C-R Base Sheet 2X	200	Pulsating Load Static Load	TAS 117(A)	N/A	28 day cure, 65.0 3 day cure, 44.0 28 day cure, 82.0



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13

Page 9 of 16

Base Sheet Rupture Performance – TAS 117(B)

OMG Product	Manufacturer	Base Sheet	Typical Results (lbf)*
AccuTrac Plate	Tamko	TamGlas	136.0
AccuTrac Flat Bottom Recessed Metal Plate	Schuller	Glasbase	120.0
	Intec	Ultrabase	134.0
	Malarkey	Malarkey 501	107.0
	1viuiuino y	Malarkey 601	129.0
		Black Warrior	126.0
	GAF	GAF # 75	137.0
	Celotex	Vaporbar GB	117.0 113.0
_		Vaporbar	
		GS GlasBase	115.0
	Any	ASTM # 30	106.0
		ASTM # 43	106.0
Lite Deck Plate,	Honeywell	Glass Fiber Base Sheet	63.0
OMG 3" Galvalume Steel		Premium Glass Fiber Felt	89.0
Plate, and		Vented Base Sheet	66.0
Polymer GypTec Insulation	Celotex	Channel Vent GB	59.0
Plate		Vaporbar GB	65.0
	GAF	GAFGLAS #75	70.5
		Stratavent	67.0
		GAFGLAS Ply 4	62.0
		Ruberoid Base	90.0
	Johns Manville	PermaPly 28	71.0
		PermaPly-R	131.5
		Dynabase	84.0
		Glasbase	65.0
		Ventsulation	65.5
		GlasPly Premier	97.5
	Soprema	Sopra-G	64.0
		Modified Sopra-G	60.0
		Sopraglass 100	98.0
		Sopravent	61.5
	GS Roofing	Flex-I-Glas Base	62.5
		PolySMS	125.0
	Siplast	Parabase	93.5
	•	Parabase Plus	77.5
	Malarkey	#501	53.5
	- 3	#601	72.0
	Tow1	Class Deed	065
	Tamko	Glass-Base	86.5
		Vapor-Chan	73.5
	Tremco	BURMastic Glass Ply	53.5 NOA No : 13 0326 14



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 10 of 16

Base Sheet Rupture Performance – TAS 117(B)

OMG Product	<u>Manufacturer</u>	Base Sheet	Typical Results (lbf)*
		BURMastic Composite Ply	112.0
	US Intec	Ultrabase	55.0
Base Sheet Plate	Honeywell	Glass Fiber Base Sheet	81.0
	•	Premium Glass Fiber Felt	95.5
		Vented Base Sheet	70.0
	Celotex	Channel Vent GB	82.0
		Vaporbar GB	83.0
		Hydrostop	81.0
	GAF	GAFGLAS #75	74.5
		Stratavent	80.0
		GAFGLAS Ply 4	65.5
		Ruberoid Base	90.0
	Johns Manville	PermaPly 28	72.5
		PermaPly-R	91.5
		Dynabase	85.0
		Glasbase	63.5
		Ventsulation	74.0
		GlasPly Premier	102.0
	GS Roofing	Flex-I-Glas Base	58.5
		PolySMS	107.5
	Siplast	Parabase	82.5
		Parabase Plus	93.5
	Soprema	Sopra-G	76.5
		Modified Sopra-G	64.0
		Sopraglass 100	87.0
		Sopravent	88.0
	Tamko	Glass-Base	65.0
		Vapor-Chan	76.5
	Tremco	BURMastic Glass Ply	87.0
		BURMastic Composite Ply	109.0
Flat Bottom Metal Plate	GAF	GAFGLAS 75	176.9
		Stratavent Eliminator	197.5
		#80 Ultima Base Sheet	212.1
		Liberty MA base	275.4
	JM	Permaply #28	200.9
		Ventsulation	190.2
		Glastite flexible Base	326.1
		Dynabase	322.9
		APP Base	204.9
	Tamko	Glass base	198.9



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 11 of 16

Base Sheet Rupture Performance – TAS 117(B)

OMG Product	<u>Manufacturer</u>	Base Sheet	Typical Results (lbf)*
		Versa Base	257.9
		Tam-Glas Premium	189.6
		Vapor Chan	212.9
		Base-n-Ply	207.1
3 in. Round Metal Plate	GAF	GAFGLAS 75	173.1
		Stratavent Eliminator	178.6
		#80 Ultima Base Sheet	185.3
		Liberty MA base	236.3
	JM	Permaply #28	146.2
		Ventsulation	151.4
		Glastite flexible Base	314.5
		Dynabase	296.6
		APP Base	262.1
	Tamko	Glass base	138.1
		Versa Base	234.9
		Tam-Glas Premium	179.9
		Vapor Chan	199.6
		Base-n-Ply	173.5

^{*} A 2 to 1 margin of safety has been applied to test results providing the above noted design values.

Single Ply Lap Rupture Performance – TAS 117(B)

OMG Product	<u>Manufacturer</u>	Base Sheet	Typical Results (lbf)
OMG 2" Barbed Plate	Seaman	FiberTite	189.5
	JPS	Hi-Tuff	186.5
	BondCote	350 Series	106.5
	Sarnafil	S327	204.5
	GenFlex	GenFlex RM	205.0
	Durolast	Durolast 35 mil	149.5

The physical properties listed above are presented at typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.



NOA No.: 13-0326.14 **Expiration Date: 09/27/17** Approval Date: 05/02/13

Page 12 of 16

APPROVED APPLICATIONS:

Tradename: AccuTrac Hextra

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, Gearlok plastic, 3" round metal plate, and 3" square metal

plates; and proprietary seam and fastening assembly plates listed in the specific Roof

Assembly, Product Control Approval (NOA).

Insulation Types: Polyisocyanurate, Perlite, Fesco board, High Density Wood Fiber, Fiberglass, Perlite/

Urethane Composite, with current NOA.

Application: Mechanical attachment of roof insulation and membrane fastening assemblies. See

specific Roof Assembly, Product Control Approval (NOA) for fastener density and

approved attachment patterns.

Deck: 16-22 Ga. steel, wood, min. ¹⁹/₃₂" plywood or wood plank.

Tradename: #12 Standard Roofgrip, #12 Standard Stainless Steel

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, Gearlok plastic, Standard plastic and 3" square metal

plates; and proprietary seam and fastening assembly plates listed in the specific Roof

Assembly, Product Control Approval (NOA).

Insulation Types: Polyisocyanurate, Perlite, Fesco board, High Density Wood Fiber, Fiberglass, Perlite/

Urethane Composite, with current NOA.

Application: Mechanical attachment of roof insulation and membrane fastening assemblies. See

specific Roof Assembly, Product Control Approval (NOA) for fastener density and

approved attachment patterns.

Deck: 18-22 Ga. steel, wood, min. 19/32" plywood or wood plank

Tradename: #14 Roofgrip, #15 Roofgrip, #15 Roofgrip Large Head

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, RhinoBond Insulation Plate or RhinoBond Treadsake Plate,

Gearlock plastic, Standard 3" plastic and 3" square metal plates; and proprietary seam and fastening assembly plates listed in the specific Roof System Assembly, Product Control

Approval (NOA).

Insulation Types: Polyisocyanurate, Perlite, Fesco board, High Density Wood Fiber, Fiberglass, Perlite/

Urethane Composite, with current NOA.

Application: Mechanical attachment of roof insulation. See specific Roof Assembly, Product Control

Approval (NOA) for fastener density and approved attachment patterns.

Deck: 18-22 Ga. steel, wood, min. 19/32" plywood or wood plank, 2500psi concrete or concrete

plank

Tradename: #12 Standard Hex Head

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, Gearlok plastic, 3" round metal plate, and 3" square metal

plates; and proprietary seam and fastening assembly plates listed in the specific Roof

Assembly, Product Control Approval (NOA).

Insulation Types: Polyisocyanurate, Perlite, Fesco board, High Density Wood Fiber, Fiberglass, Perlite/

Urethane Composite, with current NOA.

Application: Mechanical attachment of roof insulation and membrane fastening assemblies. See

specific Roof Assembly, Product Control Approval (NOA) for fastener density and

approved attachment patterns.

Deck: 16-22 Ga. steel, wood, min. 19/32" plywood or wood plank

MIAMI-DADE COUNTY
APPROVED

NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 13 of 16 Tradename: OMG Heavy Duty, OMG XHD or OMG Super XHD

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, RhinoBond Insulation Plate or RhinoBond Treadsake Plate,

3" metal or plastic plate, and proprietary seam and fastening assembly plates listed in the

specific Roof Assembly Notice of Acceptance.

Application: Mechanical attachment of roof insulation and membrane. See specific Roof Assembly

Notice of Acceptance for fastener density and approved attachment patterns.

Deck: 18-22 ga. steel, wood, min. 19/32" plywood or wood plank, 2500 psi concrete or concrete

plank

Tradename: CD-10 or Fluted Nail

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, 3" metal or plastic plate, and proprietary seam and fastening

assembly plates listed in the specific Roof Assembly Notice of Acceptance.

Application: Mechanical attachment of roof insulation and membrane. See specific Roof Assembly

Notice of Acceptance for fastener density and approved attachment patterns.

Deck: 2500 psi concrete or concrete plank

Tradename: Lite Deck

Compatible Plate(s): 3" Lite-Deck Plate.

Application: Mechanical attachment of roof insulation. See specific Roof Assembly Notice of

Acceptance for fastener density and approved attachment patterns.

Deck: Cementitious wood fiber or gypsum

Tradename: Polymer GypTec Compatible Plate(s): 3" Steel Plate.

Application: Mechanical attachment of roof insulation. See specific Roof Assembly Notice of

Acceptance for fastener density and approved attachment patterns.

Deck: Cementitious wood fiber or gypsum

Tradename: Strap Toggle

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, 3" metal or plastic plate.

Application: Mechanical attachment of roof insulation. See specific Roof Assembly Notice of

Acceptance for fastener density and approved attachment patterns.

Deck: 18-22 ga. steel, wood, min. 19/32" plywood or wood plank, gypsum

Tradename: OMG Purlin

Compatible Plate(s): 3 in. Ribbed Galvalume Plate, 2" Barbed Plates, ASAP, OMG Plastic, OMG Standard,

OMG G-2, and proprietary seam and fastening assembly plates listed in the specific Roof

Assembly Notice of Acceptance.

Application: Mechanical attachment of roof insulation. See specific Roof Assembly Notice of

Acceptance for fastener density and approved attachment patterns.

Deck: 18-22 ga. steel, wood, min. 19/32" plywood or wood plank, gypsum

Tradename: CR Base Sheet Fastener (1.2")

Compatible Plate(s): OMG Base Sheet Plate.

Application: See specific Roof Assembly Notice of Acceptance for base sheets and fastener densities.

Decks: Gypsum, NVS or Hybrid lightweight insulating concrete.



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13 Page 14 of 16 Tradename: CR Base Sheet Fastener (1.7")

Compatible Plate(s): OMG Base Sheet Plate.

Application: See specific Roof Assembly Notice of Acceptance for base sheets and fastener densities.

CR 1.75" Base Sheet Fastener may be used in any approved Roof Assembly NOA where the FM-90 Base Ply Fastener or the ITW Buildex Lite Weight Concrete Fastener is referenced. Approved fastening patterns and densities listed in any approved Roof Assembly NOA containing the FM-90 Base Ply Fastener or the ITW Buildex Lite Weight

Concrete Fastener shall be acceptable when using OMG CR 1.75" Base Sheet Fastener.

Decks: Aggregate or Cellular lightweight insulating concrete.

Tradename: C-R Base Sheet Fastener 2X

Compatible Plate(s): N/A

Application: See specific Roof Assembly Notice of Acceptance for base sheets and fastener densities.

Decks: Cellular lightweight insulating concrete.

Tradename: RhinoBond (Retro) Driller

Compatible Plate(s): RhinoBond Insulation Plate or Rhinobond TreadSafe Plate, 3in. Ribbed Galvalume Plate,

3" metal or plastic plate, and proprietary seam and fastening assembly plates listed in the

specific Roof Assembly Notice of Acceptance.

Application: Mechanical attachment of roof insulation. See specific Roof Assembly Notice of

Acceptance for fastener density and approved attachment patterns.

Deck: 16-22 ga., 50 ksi steel

Tradename: Maxload Fastener

Compatible Plate(s): 3in. Ribbed Galvalume Plate, RhinoBond Insulation Plate, 3" metal or plastic plate, and

proprietary seam and fastening assembly plates listed in the specific Roof Assembly

Notice of Acceptance.

Application: Mechanical attachment of roof insulation and membrane. See specific Roof Assembly

Notice of Acceptance for fastener density and approved attachment patterns.

Deck: 18-22 ga. steel, wood, min. 19/32" plywood or wood plank, 2500 psi concrete or concrete

plank



NOA No.: 13-0326.14 Expiration Date: 09/27/17 Approval Date: 05/02/13

Page 15 of 16

GENERAL LIMITATIONS:

- OMG, Inc., fasteners are a component part of a Miami-Dade Approved Roof Assembly. These products are approved for use only with those roof assemblies listing these products as an approved component. Refer to an approved Roof Assemblies Notices of Acceptance for use, density and attachment patterns.
- 2. Only those specific fasteners listed in this approval shall be utilized in Approved Roof Assemblies Notice of Acceptance.
- Fasteners shall be installed in strict compliance with manufacturer's installation instructions, and in compliance 3. with the requirements set forth in Roofing Application Standard RAS 111, 117 & 137.
- 4. Care shall be taken not to puncture or tear the base sheet or insulation facer during fastener installation. Application recommendations are noted in Roofing Application Standard RAS 117.
- Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117 or RAS 137.
- Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
- All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.
- All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 13-0326.14 **Expiration Date: 09/27/17** Approval Date: 05/02/13

Page 16 of 16