



MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786)315-2590 F (786) 31525-99
www.miamidade.gov/economy

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
 BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

Blue Ridge Fiberboard, Inc.
250 Celotex Drive
Danville, VA. 24541

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Structodek® High Density Fiberboard Roof Insulation

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 10-0120.04 and consists of pages 1 through 2.
 The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 13-0626.02
 Expiration Date: 09/18/18
 Approval Date: 08/29/13
 Page 1 of 2

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Insulation
Material: Wood Fiberboard

SCOPE:

This approves Structodek® High Density Fiberboard Roof Insulation, as manufactured by Blue Ridge Fiberboard, Inc. as described in this Notice of Acceptance. These products have been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

Trade name: **Structodek High Density Fiberboard Roof Insulation**
Thickness: 0.5" - 1.5" (12.5-40 mm)
Board Size(s) 4' x 4' (1.2 x 1.2 m) and 4' x 8' (1.2 x 2.4 m)
Core: Wood Fiber
Facers: None; Top face treated to reduce asphalt absorption
Decks: Concrete, Steel, Wood
Covers: Single Ply, Glass Felt BUR, Organic Felt BUR, Modified Bitumen
Special Application: Tapered or flat boards. Multilayer systems to a maximum thickness of 12 inches. See specific Roof Assembly NOA and RAS 117 for specific system approvals.

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
PRI Construction Materials Technologies, LLC	TAS 110/ ASTM C209	KIL-004-02-01	08/19/08

MANUFACTURING LOCATION:

1. Danville, VA

LIMITATIONS:

1. Fire classification is not a part of this Notice of Acceptance
2. Roof assemblies are approved under specific roof cover's Product Control Notice of Acceptance.
4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list the products listed herein as part of their roof assemblies Notice of Acceptance. See roof system Notice of Acceptance (NOA) for application rates and uses.
5. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade County Product Control upon request.
6. Change in materials, use, or manufacture of any products listed herein shall be cause for termination of this Notice of Acceptance.
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.
8. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI-DADE COUNTY
APPROVED

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY
APPROVED

NOA No.: 13-0626.02
Expiration Date: 09/18/18
Approval Date: 08/29/13
Page 2 of 2