



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Florida Metal Products Inc.
P.O. Box 6310
Jacksonville, FL 32236-6310

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Flamco Hurricane Country Shingle Over Vent

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This renews NOA#08-0909.12 and consists of pages 1 through 4.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 13-0723.04
Expiration Date: 11/20/18
Approval Date: 10/31/13
Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Ventilation
Material: Plastic
Minimum Slope: 2:12

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Flamco Hurricane Country Shingle Over Vent	15" x 48"	TAS 100(A)	Plastic ridge ventilation system

MANUFACTURING LOCATION

1. Statesville, N.C.

EVIDENCE SUBMITTED

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
PRI Construction Materials Corporation	FMP-001-02-01	TAS 100(A)	11/06/07
	FMP-001-02-02	ASTM G638 ASTM G155	07/29/08
ETC Laboratories	ETC-08-718-20484.0	ASTM D2843 ASTM D1929 ASTM D635	01/21/08



NOA No.: 13-0723.04
Expiration Date: 11/20/18
Approval Date: 10/31/13
Page 2 of 4

APPROVED APPLICATIONS



- Tradename:** Flamco Hurricane Country Shingle Over Vent Ridge Vent
- System Type:** Mechanical attachment of ridge vent system over asphalt composition shingles.
- Cutout:** Truss Construction: Cut shall be 1-3/4" wide, and length shall be 4" (plus overhang length) shorter on both sides of gable end or hips.
- Ridge Pole Construction: Cut shall be 3" wide, and length shall be 4" (plus overhang length) shorter on both sides of gable end or hips
- Installation:** Align the vent over the center of the slot. Secure the vent with 2-1/2" long galvanized corrosion resistant ring shank nails in the pre-marked locations. Join the 4' ridge vent by snapping the male end into the female end and secure as noted above. Apply 1/4" wide bead of 100% silicone sealant caulk to the bottom of the vent parallel to the vent to seal the vent to the shingles.
- Ridge Shingle:** Apply cap shingles to the vent with 2-1/2" long galvanized corrosion resistant ring shank nails in the same premarked location used to nail the vent to the deck.
- Ventilation Calculations:** Refer to manufacturer's published literature

LIMITATIONS:

1. Refer to applicable Building Code required ventilation.
2. Flamco Hurricane Country Shingle Over Vent shall not be installed in conjunction with Gable vents.
3. Flamco Hurricane Country Shingle Over Vent shall comply with applicable building code.
4. Flamco Hurricane Country Shingle Over Vent shall not be installed on roof mean heights greater than 33 feet.
5. Flamco Hurricane Country Shingle Over Vent shall comply with 1517.6 of the Florida Building Code (FBC).



DETAIL A



END OF THIS ACCEPTANCE

