



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Bristol Fiberlite Industries, Inc.
401 E. Goetz Avenue
Santa Ana, CA 92707

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER- Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida building Code.

DESCRIPTION: Self Flashing and Curb Mount Skylights

APPROVAL DOCUMENT: Drawing No. 13-156, titled " Heavy Weather Skylight ", sheets # 1 through 5 of 5, prepared by EngCo, Inc., dated July 25, 2013 signed and sealed by Pedro De Figueiredo, P.E., on January 28, 2014 bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and the expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large & Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein and the dome shall be properly marked by the manufacturers of GE XL-10 and Lexan 9034.

RENEWAL of this NOA shall not be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #10-0216.02 and consists of this page 1, evidence submitted pages E-1 and E-2 as well as approval document mentioned above.

The submitted documentation was reviewed by **Helmy A. Makar, P.E., M.S.**



Helmy A. Makar
02/13/2014

NOA No. 13-1007.05
Expiration Date: 07/28/2015
Approval Date: 02/13/2014
Page 1

Bristol Fiberlite Industries, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

- 1. EVIDENCE SUBMITTED UNDER PREVIOUS APPROVAL # 10-0216.02**
 - A. DRAWINGS**
 1. *Drawing No. 09-025, titled "Heavy Weather Skylight", sheets # 1 through 5 of 5, prepared by EngCo, Inc., on January 26, 2010 signed & sealed by Pedro De Figueiredo, P.E. on June 30, 2010.*
 - B. TESTS**
 1. *Test report on Large Missile Impact Test, Cyclic Wind Pressure Test and Uniform Static Air Pressure Test on "Heavy weather Skylight", prepared by Architectural Testing, report No. 92682.01-301-18, dated 01/12/2010, signed and sealed Joshua M. Royce, PE.*
 - C. CALCULATIONS**
 1. *Anchor calculations, dated 02/08/2010, 8 pages, prepared by EngCo, Inc., signed and sealed by Pedro De Figueiredo, P.E.*
 - D. QUALITY ASSURANCE**
 1. *By Miami-Dade County Building Code Compliance Office.*
 - E. MATERIAL CERTIFICATIONS**
 1. *Die drawings prepared by Bristol Fiberlite Industries, Inc.*
 - F. STATEMENTS**
 1. *FBC 2007 edition Code compliance letter issued by EngCo, Inc., dated 02/08/2010, signed and sealed by Pedro De Figueiredo, P.E.*
- 2. NEW EVIDENCE SUBMITTED**
 - A. DRAWINGS**
 1. *Drawing No. 13-156, titled " Heavy Weather Skylight ", sheets # 1 through 5 of 5, prepared by EngCo, Inc., dated July 25, 2013 signed and sealed by Pedro De Figueiredo, P.E., on January 28, 2014.*
 - B. TESTS**
 1. *None.*
 - C. CALCULATIONS**
 1. *None.*
 - D. QUALITY ASSURANCE**
 1. *By Miami-Dade County Department of Regulatory and Economic Resources.*



Helmy A. Makar, P.E., M.S.
Product Control Unit Supervisor
NOA No. 13-1007.05
Expiration Date: 07/28/2015
Approval Date: 02/13/2014

Bristol Fiberlite Industries, Inc.


NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

E. MATERIAL CERTIFICATIONS

1. *None.*

F. STATEMENTS

1. *FBC 2010 edition Code compliance letter issued by EngCo, Inc., dated 07/25/2013, signed and sealed by Pedro De Figueiredo, P.E.*



Helmy A. Makar, P.E., M.S.
Product Control Unit Supervisor
NOA No. 13-1007.05
Expiration Date: 07/28/2015
Approval Date: 02/13/2014

GENERAL NOTES: FLORIDA BUILDING CODE 2010 HVHZ

- 1- CODE: THIS PRODUCT HAS BEEN TESTED AND DESIGNED IN ACCORDANCE WITH THE HIGH VELOCITY HURRICANE ZONE (HVHZ) OF THE 2010 FLORIDA BUILDING CODE.
- 2- DEFINITION: THIS PRODUCT IS A SKYLIGHT UNIT MANUFACTURED WITH DUAL POLYCARBONATE SHEETS SECURED BY AN ALUMINUM FRAMING. THE PRODUCT IS CONSTRUCTED AND TESTED TO PROVIDE PROTECTION FROM HURRICANE FORCE WINDS AND WIND BORNE DEBRIS (LARGE & SMALL MISSILE) WITHIN THE ALLOWABLE DESIGNED PRESSURES AND LIMITATIONS STATED IN THIS APPROVAL.
- 3- POSTING:
 "BRISTOL FIBERLITE INDUSTRIES, INC.
 SANTA ANA - CALIFORNIA
 MIAMI-DADE COUNTY PRODUCT CONTROL APPROVED"
- 4- DESIGN LOADS: A PROJECT DESIGN PRESSURES, DETERMINED FROM SECTION 1620 AND ASCE 7-10, SHALL BE PROVIDED BY A PROFESSIONAL ARCHITECT OR ENGINEER. THE PRESSURES MUST BE MULTIPLIED BY 0.6 FACTOR AND MUST NOT EXCEED THE PRODUCT ALLOWABLE PRESSURES HERE IN SPECIFIED..
- 5- MATERIAL: ALL EXTRUDED ALUMINUM PARTS TO BE 6063-T5 ALLOY OR AS NOTED AND GLAZING TO BE APPROVED POLYCARBONATE GE XL-10 AND LEXAN 9034 AS SPECIFIED ON THIS APPROVAL.
- 6- FASTENERS: ASSEMBLY SCREWS AND ANCHORS SHALL BE AS SPECIFIED IN THE CURRENT SET OF DRAWINGS. INSTALLATION AND LOADS AS PER THIS APPROVAL. ANCHOR SPACING AND LOADS MUST NOT EXCEED THE MAXIMUM LIMITS SPECIFIED BY THIS APPROVAL.
- 7- USE: IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR, ARCHITECT OR ENGINEER OF RECORD TO VERIFY THE FOLLOWING:
 - 7.1- THE STABILITY OF THE STRUCTURE WHERE THE PRODUCT IS TO BE ATTACHED INSURING PROPER ANCHORAGE.
 - 7.2- THE SITE SPECIFIC PROJECT CRITERIA, SUCH AS BUT NOT LIMITED TO, LOCAL CODE REQUIREMENTS, DESIGNED PRESSURES ETC.
 - 7.3- THAT THIS APPROVAL IS ADEQUATE TO THE SPECIFIC PROJECT.
- 8- 33 1/3% INCREASE IN ALLOWABLE LOADS HAVE NOT BEEN USED IN THE DESIGN OF THE ANCHORS FOR THIS PRODUCT APPROVAL, HOWEVER, WOOD SCREWS WITH 1.6 INCREASE FOR WIND LOAD DURATION HAVE BEEN USED.
- 9- DISSIMILAR MATERIALS: MATERIALS, INCLUDING BUT NOT LIMITED TO STEEL, THAT COME IN CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF 2010 FLORIDA BUILDING CODE.
- 10- ALL ROOFING DETAIL SHALL COMPLY WITH CHAPTER 15 OF THE FLORIDA BUILDING CODE 2010 ED.
- 11- MOUNTING: THE UNIT SKYLIGHT MUST BE INSTALLED AT LEAST 4" ABOVE THE PLANE OF THE ROOF WITH EXCEPTION FOR UNITS INSTALLED ON ROOFS HAVING A MINIMUM 25% SLOPE IN OCCUPANCIES IN GROUP R-3 AND ON BUILDINGS WITH A NONCLASSIFIED ROOF COVERING. USE THE 4" MINIMUM HIGH CURB FOR SHINGLE & BUR. WITHOUT INSULATION AND FOR INSULATION AND TILE ADD THE TILE HEIGHT AND THE INSULATION THICKNESS TO THE 4" MINIMUM HEIGHT.

TABLE OF CONTENTS

SHEET	CONTENTS
1	GENERAL NOTES, DESIGN RATING & TABLE OF CONTENTS
2	OPTION 1: SELF FLASHING MOUNT (MAXIMUM 12")
3	OPTION 2: SELF FLASHING MOUNT (W/ CF-6 BASE)
4	OPTION 3 CURB MOUNT
5	COMPONENTS

DESIGNED RATING:

MAXIMUM SIZE: 64 1/16" X 100 1/16"
 MAXIMUM CLEAR OPENING: 60" X 96"
 POSITIVE WIND PRESSURE: +55 PSF
 NEGATIVE WIND PRESSURE: -65 PSF
 LARGE & SMALL MISSILE IMPACT RESISTANT

MANUFACTURER:
Bristol Fiberlite Industries

WEST COAST
 401 EAST GOETZ AVENUE
 SANTA ANA, CA 92707
 TEL.: (714) 540-8950
 FAX: (714) 540-5415

EAST COAST
 1180 HAYES INDUSTRIAL DR.
 MARIETTA, GA 30062
 TEL: (770) 514-8085
 FAX: (770) 514-8086

WWW.BRISTOLITE.COM

PRODUCT:
HEAVY WEATHER SKYLIGHT

ENGINEERING:
ENGCO INC. CA 8116
 5595 ORANGE DR. 201
 DAVIE, FL. 33314
 Tel.: (954) 585-0304
 ENGCO@AOL.COM



JAN 28 2014
 Engineer Seal
 Pedro De Figueiredo - PE 52609

MIAMI-DADE BCCO:

PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No. 13-1007.05
 Expiration Date 07/28/2015
 By *[Signature]*
 Miami Dade Product Control



Date: 07/25/13
 Scale: NA
 Design by: PPMF

SHEET 1 OF 5	DRAWING #: 13-156
-----------------	----------------------


SECTION C

OPTION 1 - MAXIMUM 12" SELF FLASHING MOUNTING


* OUTER DOME RISE ABOVE THE MOUNTING FLANGE: MINIMUM 10% OF THE MAXIMUM DOME SPAN BUT NOT LESS THAN 3"




TOP VIEW



SECTION A



SECTION B



CORNER SECTION

MANUFACTURER:
Bristol Fiberlite Industries

WEST COAST
401 EAST GOETZ AVENUE
SANTA ANA, CA 92707
TEL.: (714) 540-8950
FAX: (714) 540-5415

EAST COAST
1180 HAYES INDUSTRIAL DR.
MARIETTA, GA 30062
TEL: (770) 514-8085
FAX: (770) 514-8086

WWW.BRISTOLITE.COM

PRODUCT:
HEAVY WEATHER SKYLIGHT

ENGINEERING:
ENGCO INC. CA 8116
5595 ORANGE DR. 201
DAVIE, FL. 33314
Tel.: (954) 585-0304
ENGCO@AOL.COM



JAN 28 2014
Engineer Seal
Pedro De Figueiredo - PE 52609

MIAMI-DADE BCCO:
PRODUCT REVISED
as complying with the Florida Building Code
Acceptance No. 13-1007.05
Expiration Date 07/28/2015
By: *[Signature]*
Miami Dade Product Control

Date: 07/25/13
Scale: NA
Design by: PPMF






SHEET
2 OF 5

DRAWING #:
13-156

OPTION 2 - MAXIMUM 6" SELF FLASHING MOUNTING

SECTION C

* OUTER DOME RISE ABOVE THE MOUNTING FLANGE: MINIMUM 10% OF THE MAXIMUM DOME SPAN BUT NOT LESS THAN 3'



MANUFACTURER:
Bristol Fiberlite Industries


WEST COAST
401 EAST GOETZ AVENUE
SANTA ANA, CA 92707
TEL: (714) 540-8950
FAX: (714) 540-5415

EAST COAST
1180 HAYES INDUSTRIAL DR.
MARIETTA, GA 30062
TEL: (770) 514-8085
FAX: (770) 514-8086

WWW.BRISTOLITE.COM

PRODUCT:
HEAVY WEATHER SKYLIGHT

ENGINEERING:
ENGCO INC. CAB116
5595 ORANGE DR. 201
DAVIE, FL. 33314
Tel.: (954) 585-0304
ENGCO@AOL.COM



JAN 28 2014

Engineer Seal
Pedro De Figueiredo - PE 52609

MIAMI-DADE BCCO:


PRODUCT REVISED
as complying with the Florida Building Code
Acceptance No 13-1007.05
Expiration Date 07/28/2015
By *[Signature]*
Miami Dade Product Control

Date: 07/25/13
Scale: NA
Design by: PPMF


SHEET 3 OF 5
DRAWING #: 13-156

SECTION C


* OUTER DOME RISE ABOVE THE MOUNTING FLANGE: MINIMUM 10% OF THE MAXIMUM DOME SPAN BUT NOT LESS THAN 3'




OPTION 3 - CURB MOUNTING




TOP VIEW



SECTION A



SECTION B



CORNER SECTION

MANUFACTURER:
Bristol Fiberlite Industries


WEST COAST
401 EAST GOETZ AVENUE
SANTA ANA, CA 92707
TEL: (714) 540-8950
FAX: (714) 540-5415

EAST COAST
1180 HAYES INDUSTRIAL DR.
MARIETTA, GA 30062
TEL: (770) 514-8085
FAX: (770) 514-8086

WWW.BRISTOLITE.COM

PRODUCT:
HEAVY WEATHER SKYLIGHT

ENGINEERING:
ENGCO INC. CA8116
5595 ORANGE DR. 201
DAVIE, FL. 33314
Tel: (954) 585-0304
ENGCO@AOL.COM



JAN 28 2014
Engineer Seal
Pedro De Figueiredo - PE 52609

MIAMI-DADE BCCO:


PRODUCT REVISED
as complying with the Florida Building Code
Acceptance No 13-1007.05
Expiration Date 07/28/2015
By *[Signature]*
Miami Dade Product Control

Date: 07/25/13
Scale: NA
Design by: PPMF


SHEET
4 OF 5

DRAWING #:
13-156


PRODUCT COMPONENTS




1- CM BASE
CURB MOUNT BASE
6063-T5 ALUMINUM ALLOY




2- SF-6 BASE
HW 6" SELF-FLASHING BASE
6063-T5 ALUMINUM ALLOY



3- HW RETAINER
6063-T5 ALUMINUM ALLOY



4- SF-9 BASE
0.13" THK. BRAKE FORMED
ALUMINUM SELF-FLASHING
5052-H32 ALUMINUM ALLOY



5- SF-12 BASE
0.13" THK. BRAKE FORMED
ALUMINUM SELF-FLASHING
5052-H32 ALUMINUM ALLOY

MANUFACTURER:
Bristol Fiberlite Industries

WEST COAST
401 EAST GOETZ AVENUE
SANTA ANA, CA 92707
TEL.: (714) 540-8950
FAX: (714) 540-5415

EAST COAST
1180 HAYES INDUSTRIAL DR.
MARIETTA, GA 30062
TEL: (770) 514-8085
FAX: (770) 514-8086

WWW.BRISTOLITE.COM

PRODUCT:
HEAVY WEATHER SKYLIGHT

ENGINEERING:
ENGCO INC. CA 8116
5595 ORANGE DR. 201
DAVIE, FL. 33314
Tel.: (954) 585-0304
ENGCO@AOL.COM



JAN 28 2014

Engineer Seal
Pedro De Figueiredo - PE 52609

MIAMI-DADE BCCO:

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 13-1007.05
Expiration Date 2/28/2015
By *Healy*
Miami Dade Product Control

Date: 07/25/13
Scale: NA
Design by: PPMF

SHEET
5 OF 5

DRAWING #:
13-156