



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Polyglass USA, Inc.
150 Lyon Drive
Fernley, NV 89408

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Polyglass Self-Adhered Roof System over Recover Deck

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 13-0514.06 and consists of pages 1 through 15.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 13-1217.03
Expiration Date: 11/22/17
Approval Date: 11/06/14
Page 1 of 15

ROOFING ASSEMBLY APPROVAL

Category:	Roofing
Sub-Category:	Modified Bitumen
Materials	SBS/APP/TPO
Deck Type:	Recover
Maximum Design Pressure	See Specific Deck Type

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

Product	Dimensions	Test Specification	Product Description
Polyanchor	250' x 48"	ASTM D 4601 Type II	A polymer woven, high performance, synthetic base sheet.
Elastobase	65' 8" x 3' 3-3/8"	ASTM D 6163, Type I	SBS modified asphalt coated fiberglass reinforced base sheet.
XtraFlex SBS Glass Base	65' 8" x 3' 3-3/8"	ASTM D 6163, Type I	SBS modified asphalt coated fiberglass reinforced base sheet.
Elastobase P	65' 8" x 3' 3-3/8"	ASTM D 6164, Type I	SBS modified asphalt coated polyester reinforced base sheet.
Elastoflex SA V FR (1.5-mm)	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fire-rated, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V PLUS FR	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fire-rated, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V (1.5-mm)	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA V PLUS	32' 6" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
XtraFlex SBS Base SA	66' 8" x 3' 3-3/8"	ASTM D 6163, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a smooth top surface.
Elastoflex SA P FR	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fire-rated, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
XtraFlex SBS G SA	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fire-rated, polyester reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.

Elastoflex SA P	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyflex G	32' 10" x 3' 3-3/8"	ASTM D 6222	Torch applied, polyester reinforced, APP modified bitumen membrane with a burn off polyethylene back face and a granule top surface.
Polyflex SA P	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyflex SA P FR	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
XtraFlex APP G SA	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyfresko G SBS SA	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyfresko G SBS SA FR	32' 10" x 3' 3-3/8"	ASTM D 6164, Type I	Self-adhered, fire-rated, fiberglass reinforced, SBS modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyfresko G APP SA	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
Polyfresko G APP SA FR	32' 10" x 3' 3-3/8"	ASTM D 6222, Type I	Self-adhered, fire-rated, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a granule top surface.
PolyKool	32' 10" x 3' 3-3/8"	ASTM D6222 Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a white film laminate on the top surface.
XtraFlex Kool APP S SA	32' 10" x 3' 3-3/8"	ASTM D6222 Type I	Self-adhered, polyester reinforced, APP modified bitumen membrane with a self-adhering back face and a white film laminate on the top surface.
PG325 Cold Process Adhesive	1, 3, 5, 50, 55 gal. or tube	ASTM D3019 Type III	A fibered cold process adhesive for use with roll or BUR roofing.
PG100 Asphalt Primer	1, 3, 5, 50, 55 gal, tube or 17 oz. spray can	ASTM D41	A penetrating solution of solvent and a blend of selected asphalts used to promote adhesion.
XtraFlex 10 Asphalt Primer	1, 3, 5, 50, 55 gal, tube or 17 oz. spray can	ASTM D41	A penetrating solution of solvent and a blend of selected asphalts used to promote adhesion.
PG350 Mod Bit Adhesive	1, 3, 5, 50, 55 gal. or tube	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.



PG400 Plastic Roof Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG425 Wet/Dry Roof Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586 ASTM D3409	A thick, fibered, rubberized flashing cement for use in dry or damp conditions.
PG450 Flashing Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.
PG500 MB Flashing Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
Polyplus 35 Premium Mod Bit Adhesive	1, 3, 5, 50, 55 gal. or tube	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
XtraFlex 35 Premium Mod Bit Adhesive	1, 3, 5, 50, 55 gal. or tube	ASTM D3019 Type III	A fibered rubberized adhesive designed for use with modified bitumen membranes.
Polyplus 45 Premium Flashing Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement.
Polyplus 50 Premium MB Flashing Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
XtraFlex 50 Premium Modified Wet/Dry Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A thick, fibered, rubberized flashing cement for use with modified bitumen membranes.
Polyplus 55 Premium Modified Flashing Cement	1, 3, 5, 50, 55 gal. or tube	ASTM D4586	A mastic compound for use as a roof flashing adhesive.



APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
Polytherm-H	Polyisocyanurate foam insulation	Polyglass USA, Inc.
Polytherm	Polyisocyanurate foam insulation	Polyglass USA, Inc.
ACFoam-II, ACFoam-III	Polyisocyanurate foam insulation	Atlas Roofing Corp.
ENRGY-3	Polyisocyanurate foam insulation	Johns Manville Corp.
Multi-Max FA-3	Polyisocyanurate foam insulation	Rmax Operating LLC.
H-Shield, H-Shield CG	Polyisocyanurate insulation	Hunter Panels, LLC.
DensDeck, DensDeck Prime	Gypsum insulation board	Georgia Pacific Gypsum LLC.
Expanded Polystyrene	2.0 pcf insulation board	Generic

APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	FM-90	Pre-assembled Galvalume Base Sheet Fastener and stress plate.	Various	ES Products, Inc.
2.	Twin Loc-Nails	Pre-assembled Galvalume Base Sheet Fastener and stress plate.	Various	ES Products, Inc.



APPROVED SURFACING:

TABLE 4

<u>Product Name</u>	<u>Product Description</u>	<u>Application Rate</u>	<u>Specification</u>	<u>Manufacturer</u>
PG200 Non-Fibered Roof Coating	A non fibered asphaltic coating used to add life and rejuvenate existing BUR roofing substrates.	1½-2 gal/sq	TAS 140	Polyglass USA, Inc.
XtraFlex 20 Bituminous Roof Coating	A non fibered asphaltic coating used to add life and rejuvenate existing BUR roofing substrates.	1½-2 gal/sq	TAS 140	Polyglass USA, Inc.
PG300 Fibered Roof Coating	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR	1½-2 gal/sq	ASTM D4479	Polyglass USA, Inc.
XtraFlex Bituminous Roof Coating Fibered	An asphalt cutback fibered roof coating. May be applied by brush or spray equipment to rejuvenate aged BUR	1½-2 gal/sq	ASTM D4479	Polyglass USA, Inc.
PG600 Non-Fibered Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
PG650 Fibered Aluminum Roof Coating	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
PG700 Elastomeric Roof Coating	A premium white elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
PG800 Non-Fibered Asphalt Emulsion Roof Coating	An asphalt base, un-fibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
XtraFlex 80 Emulsion Roof Coating	An asphalt base, un-fibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
PG850 Fibered Asphalt Emulsion Roof Coating	An asphalt base, fibered clay emulsion	3 gal/sq in two coats	ASTM D1227	Polyglass USA, Inc.
Polyplus 65 Premium Fibered Aluminum Roof Coating	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
XtraFlex 65 Aluminum Roof Coating Fibered	Fibered aluminum roof coating.	1½-2 gal/sq	ASTM D2824 Type III	Polyglass USA, Inc.
Polyplus 60 Premium Non-Fibered Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.
XtraFlex 60 Aluminum Roof Coating	Non-fibered aluminum roof coating.	½-1 gal/sq	ASTM D2824 Type I	Polyglass USA, Inc.



APPROVED SURFACING:

TABLE 4

<u>Product Name</u>	<u>Product Description</u>	<u>Application Rate</u>	<u>Specification</u>	<u>Manufacturer</u>
Polybrite 70 Premium Grade Elastomeric Roof Coating	A premium white elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
XtraFlex 70 Premium Acrylic FR Roof Coating	A premium white elastomeric acrylic based roof coating (water-based). A polyester fabric may be used for reinforcement with this coating.	1-1½ gal/sq	ASTM D6083	Polyglass USA, Inc.
Polybrite 90 High Solids Silicone Roof Coating	A premium grade high solids, single component, moisture cure, fluid applied silicone coating	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
XtraFlex SRC 9600 High Solids Silicone Roof Coating	A premium grade high solids, single component, moisture cure, fluid applied silicone coating	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
Polybrite 95 Silicone Roof Coating	A single component, solvent, moisture cure silicone coating.	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
XtraFlex SRC 8000 Silicone Roof Coating	A single component, solvent, moisture cure silicone coating.	1.25 gal/sq	ASTM D6694	Polyglass USA, Inc.
Gravel	To be installed in a flood coat of approved asphalt at 60 lbs/sq	400 lbs/sq	N/A	Generic
Slag	To be installed in a flood coat of approved asphalt at 60 lbs/sq	300 lbs/sq	N/A	Generic



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Name/Report</u>	<u>Report No.</u>	<u>Date</u>
Factory Mutual Research Corporation	4470	2W7A7.AM	08.04.94
	4450	2D5A9.AM	06.22.99
	4470	3001334	02.15.00
	4470	3000857	01.12.00
	4470	3004091	01.12.00
	4470	3012321	07.29.02
	4450	3014751	08.27.03
	4450	3019317	06.30.04
	4470	3014692	08.05.03
Trinity ERD	TAS 114	11752.09.99-1	02.08.00
	TAS 114	02764.09.05	09.09.05
	TAS 114	02762.03.05	03.30.05
	TAS 117(B)-ASTM D903	020841.06.04	06.02.04
	TAS 114	P1734.07.06-R1	02.27.07
	TAS 114	P1738.02.07	02.05.07
	TAS 114	P1739.01.07	01.23.07
	TAS 117(B)-ASTM D6862	C8500SC.11.07	11.30.07
	ASTM D6164 / ASTM D6222	P10490.08.08	08.13.08
	ASTM D6164 / ASTM D6222	P10490.10.08-R1	10.03.08
	ASTM D6222	P7400.03.08-R2	10.09.08
	TAS 114(D) – ASTM D1876	P10070.10.08	10.09.08
	ASTM D6222	P10490.10.08-2	10.30.08
	TAS 114 (H)	P13760.09.09	09.10.09
	FM 4470 & TAS 114	P33970.03.11	03.15.11
	ASTM D6163 / ASTM D 4601	P33960.03.11	03.15.11
	ASTM D6164	P37590.07.13-1	07.02.13
	ASTM D6164	P37590.03.13-3A	03.06.13
	ASTM D6163	P37590.03.13-2-R1	02.05.13
	ASTM D6222	P37590.09.13	09.12.13
	ASTM D4601 / TAS 117	P45940.09.13	09.04.13
	ASTM D4601	P45970.05.14	05.12.14
PRI Construction Materials Technologies	ASTM D6222	PUSA-061-02-02	01.28.08
	ASTM D6222	PUSA-062-02-02	12.04.08
	ASTM D6163	PUSA-064-02-02	02.27.08
	ASTM D6694	PUSA-134-02-01	05.16.14
	ASTM D6694	PUSA-135-02-01	05.16.14



APPROVED ASSEMBLIES:

- Membrane Type:** SBS/APP
- Deck Type 7I:** Recover over existing asphalt BUR
- Deck Description:** Concrete
- System Type A(1):** One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, Polytherm, ENRGY-3, H-Shield, Polytherm-H Minimum 1.5” thick	N/A	N/A
Approved Expanded Polystyrene min 2.0 pcf Minimum 1” thick	N/A	N/A
DensDeck, DensDeck Prime Minimum ¼” thick	N/A	N/A
<u>Top Insulation Layer (Optional)</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
DensDeck, DensDeck Prime (Required with ENRGY-3 and Approved EPS 2.0 pcf) Minimum ¼” thick	N/A	N/A

Note: Apply insulation in OlyBond 500 Adhesive in ¾” to 1” continuous beads/ribbons spaced 12” o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Additional layers of insulation should be adhered in OlyBond 500 Adhesive in ¾” to 1” continuous beads/ribbons spaced 12” o.c.

- Base Sheet:** One or more plies of Elastoflex SA V (1.5-mm), Elastoflex SA V PLUS, XtraFlex SBS Base SA, Elastoflex SA V FR (1.5-mm) or Elastoflex SA V PLUS FR, self-adhered.
- Membrane:** One ply of Polyfresko G SBS SA, Polyfresko G SBS SA FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Elastoflex SA P, Elastoflex SA P FR, XtraFlex SBS G SA, Polyflex SA P, PolyKool, XtraFlex Kool APP S SA, Polyflex SA P FR or XtraFlex APP G SA, self-adhered.
Or
One ply of Polyflex G, torch-applied.



Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -120.0 psf; (See General Limitation #9.)



Membrane Type: SBS/APP
Deck Type 7I: Recover over existing asphalt BUR
Deck Description: Concrete
System Type A(2): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, Polytherm, ENRGY-3, H-Shield, Polytherm-H, Multi-Max FA-3 Minimum 1.5" thick	N/A	N/A
DensDeck, DensDeck Prime Minimum 1/4" thick	N/A	N/A

Note: Apply insulation in Millennium One-Step Foamable Adhesive in 1/2" to 3/4" continuous beads/ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Additional layers of insulation should be adhered in Millennium One-Step Foamable Adhesive in 1/2" to 3/4" continuous beads/ribbons spaced 12" o.c.

Base Sheet: One or more plies of Elastoflex SA V (1.5-mm), Elastoflex SA V PLUS, XtraFlex SBS Base SA, Elastoflex SA V FR (1.5-mm), or Elastoflex SA V PLUS FR, self-adhered.

Membrane: One ply of Polyfresko G SBS SA, Polyfresko G SBS SA FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Elastoflex SA P, Elastoflex SA P FR, XtraFlex SBS G SA, Polyflex SA P, PolyKool, XtraFlex Kool APP S SA, Polyflex SA P FR or XtraFlex APP G SA, self-adhered.
 Or
 One ply of Polyflex G, torch-applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -157.5 psf; (See General Limitation #9.)



Membrane Type: SBS/APP
Deck Type 7I: Recover over existing asphalt BUR
Deck Description: Concrete/Steel
System Type A(3): One or more layers of insulation adhered with approved adhesive. Membranes subsequently adhered to insulation layer.

All General and System limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of any of the following insulations:

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
ACFoam-II, Polytherm, ACFoam-III, ENRGY-3, H-Shield, Polytherm-H, H-Shield CG, Multi-Max FA-3 Minimum 1.5" thick	N/A	N/A
DensDeck, DensDeck Prime (For Steel Deck use with a maximum thickness of 1") Minimum 1/2" thick	N/A	N/A

Note: Apply insulation in TITESET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 in 3" to 3-1/2" continuous beads/ribbons spaced 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Additional layers of insulation should be adhered in TITESET Roofing Adhesive or 3M Polyurethane Foam Insulation Adhesive CR-20 in 3" to 3-1/2" continuous beads/ribbons spaced 12" o.c.

Base Sheet: One or more plies of Elastoflex SA V (1.5mm), Elastoflex SA V PLUS, XtraFlex SBS Base SA, Elastoflex SA V FR (1.5-mm) or Elastoflex SA V PLUS FR, self-adhered.

Membrane: One ply of Polyfresko G SBS SA, Polyfresko G SBS SA FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Elastoflex SA P, Elastoflex SA P FR, XtraFlex SBS G SA, Polyflex SA P, PolyKool, XtraFlex Kool APP S SA, Polyflex SA P FR or XtraFlex APP G SA, self-adhered.
 Or
 One ply of Polyflex G, torch-applied.

Surfacing: (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.

Maximum Design Pressure: -262.5 psf; (See General Limitation #9.)



- Membrane Type:** SBS/APP
- Deck Type 7I:** Recover LWIC
- Deck Description:** Elastizell with Zell-Crete fibers; 350-400 psi Compressive strength. *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 44 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.
- System Type E(1):** Base sheet mechanically fastened. Membranes subsequently adhered.

All General and System limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

- Base Sheet:** Elastobase, XtraFlex SBS Glass Base, Elastobase P, Polyanchor fastened as outlined below:
- Fastening:** Twin Loc-Nails at 6" o.c. in 4" lap and 6" o.c. in three equally spaced center rows.
- Ply Sheet:** One or more plies of Elastoflex SA V (1.5-mm), Elastoflex SA V PLUS, XtraFlex SBS Base SA, Elastoflex SA V FR (1.5-mm) or Elastoflex SA V PLUS FR, self-adhered.
- Membrane:** One ply of Polyfresko G SBS SA, Polyfresko G SBS SA FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Elastoflex SA P, Elastoflex SA P FR, XtraFlex SBS G SA, Polyflex SA P, PolyKool, XtraFlex Kool APP S SA, Polyflex SA P FR or XtraFlex APP G SA, self-adhered.
Or
One ply of Polyflex G, torch-applied.
- Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
- Maximum Design Pressure:** -60 psf; (See General Limitation #7.)



- Membrane Type:** SBS/APP
- Deck Type 7I:** Recover LWIC
- Deck Description:** Celcore MF Lightweight Concrete; 300 psi Compressive strength. *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 59 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.
- System Type E(2):** Base sheet mechanically fastened. Membranes subsequently adhered.

All General and System limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

- Base Sheet:** Elastobase, XtraFlex SBS Glass Base, Elastobase P, Polyanchor fastened as outlined below:
- Fastening:** FM-90 Fasteners at 8” o.c. in 4” lap and 8” o.c. in three equally spaced center rows.
- Ply Sheet:** One or more plies of Elastoflex SA V (1.5-mm), Elastoflex SA V PLUS, XtraFlex SBS Base SA, Elastoflex SA V FR (1.5-mm) or Elastoflex SA V PLUS FR, self-adhered.
- Membrane:** One ply of Polyfresko G SBS SA, Polyfresko G SBS SA FR, Polyfresko G APP SA, Polyfresko G APP SA FR, Elastoflex SA P, Elastoflex SA P FR, XtraFlex SBS G SA, Polyflex SA P, PolyKool, XtraFlex Kool APP S SA, Polyflex SA P FR or XtraFlex APP G SA, self-adhered.
Or
One ply of Polyflex G, torch-applied.
- Surfacing:** (Optional) Install one of the approved surfacing products listed in Table 4 to obtain desired coating or required fire classification.
- Maximum Design Pressure:** -60 psf; (See General Limitation #7.)



RECOVER SYSTEM LIMITATIONS:

- 1 All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE