



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

Soprema, Inc.  
310 Quadral Drive  
Wadsworth, OH 44281

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Soprema Modified Bitumen Roofing Systems over Steel Decks.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 11-0119.05 and consists of pages 1 through 97.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 14-0603.08  
Expiration Date: 03/01/16  
Approval Date: 12/31/14  
Page 1 of 97

## ROOFING SYSTEM APPROVAL

Category: Roofing  
Sub-Category: Modified Bitumen  
Material: SBS  
Deck Type: Steel  
Maximum Design Pressure: -172.5 psf.

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopra G	39" x 108' (3.5 sq.)	ASTM D4601	Fiberglass reinforced oxidized asphalt base sheet for bonding or mechanically attaching to substrate. <b>For use as a base/ply sheet only.</b>
Modified Sopra G	39" x 108' (3.5 sq.)	ASTM D4601	Fiberglass reinforced modified asphalt base sheet for bonding or mechanically attaching to substrate. <b>For use as a base/ply sheet only.</b>
Soprabase	39" x 99' (3 sq.)	ASTM D4601	Oxidized asphalt, polyester reinforced, sand-surface base sheet. <b>For use as a base/ply sheet only.</b>
Soprabase S	39" x 65' (2 sq.)	ASTM D4601	SBS modified bitumen, polyester reinforced, sand-surfaced base sheet. <b>For use as a base/ply sheet only.</b>
Soprabase TG	39" x 65' (2 sq.)	ASTM D4601	SBS modified bitumen, polyester reinforced, film-surfaced base sheet. <b>For use as a base/ply sheet only.</b>
Sopra IV	36" x 180' (5 sq.)	ASTM D2178 Type IV	Type IV, fiberglass reinforced, smooth surfaced ply sheet used in multi-ply systems and complies with ASTM and UL Standards. Applied in hot asphalt or cold adhesive.
Sopra VI	36" x 180' (5 sq.)	ASTM D2178 Type IV	Type IV, fiberglass reinforced, smooth surfaced ply sheet used in multi-ply systems and complies with ASTM and UL Standards. Applied in hot asphalt or cold adhesive.
Colvent TG	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied heat weldable strips on back side.
Colvent 180 TG	39" x 33' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side.
Colvent Flam TG	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side and a plastic burn-off film surface.



<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
Colvent Flam 180 TG	39" x 33' (1 sq.)	ASTM D6164	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side and a plastic burn-off film surface.
Elastophene Sanded	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Colphene Sanded	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Sanded 3.0	39" x 33' (1sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripped.
Elastophene HS	39" x 66' (2 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene PS	39" x 49' (1.5 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film for heat weld bonding to the top side. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene PS 3.0	39" x 49' (1.5 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film for heat weld bonding to the top side. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene SP	39" x 49' (1.5 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene SP 2.2	39" x 49' (1.5 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene SP 3.0	39" x 49' (1 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Colphene SP 3.0	39" x 49' (1 sq.)	ASTM D6163	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastophene Flam	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam 2.2	39" x 49' (1.5 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
Elastophene Flam HS	39" x 33' (1 sq.)	ASTM D6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants and plastic burn-off film on both sides. Applied by heat welding.
Elastophene HS 62	39" x 33' (1 sq.)	ASTM D6162	Woven fiberglass/polyester composite reinforced modified bitumen membrane with sanded surface on both sides. Applied in hot asphalt, cold adhesive.
Elastophene 180 Sanded	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Colphene 180 Sanded	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene 180 PS	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Colphene 180 PS	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene LS FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Elastophene FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene FR+ GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
Elastophene Flam GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam LS FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Elastophene Flam FR+ GR	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Sopralene 180 Sanded	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 250 Sanded	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
Sopralene 180 Sanded 2.2	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt or cold adhesive.
Sopralene 180 PS	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the top and sanded on the bottom.
Sopralene 180 PS 2.2	39" x 49' (1.5 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Sopralene 180 SP 3.5	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene 180 SP 3.5	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 SP 3.0	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top.
Sopralene 250 SP	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top.
Soprafix Base 610	39" x 30' (1 sq.)	ASTM D6162	Composite reinforced modified bitumen membrane with a film surface. Applied by mechanical attachment.
Soprafix Base 611	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a film surface. Applied by mechanical attachment.
Soprafix Base 621	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a sanded surface. Applied by mechanical attachment.
Soprafix Base 630	39" x 33' (1 sq.)	ASTM D6162	Composite reinforced modified membrane with a film surface. Applied by mechanical attachment.
Soprafix [S]	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix Base 612	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix [F]	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix Base 613	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix [X]	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Soprafix Base 614	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
Soprafix	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 4-inch or 5-inch wide side lap with a plastic burn-off film on the bottom and sanded on the top. Applied by mechanical attachment. Lap heat welded or sealed with an approved cold adhesive.
Soprafix Base 622	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 4-inch or 5-inch wide side lap with a plastic burn-off film on the bottom and sanded on the top. Applied by mechanical attachment. Lap heat welded or sealed with an approved cold adhesive.
Soprafix-e	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.
Soprafix Base 641	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.
Soprafix Cap FR-651	39" x 33' (1 sq.)	ASTM D6163	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Sopralene Flam 180	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 180	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced SBS modified

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
250			bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Colphene 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 180 Ultra FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Colphene 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene 250 Ultra FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
Sopralene 250 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 180 GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 GR 3.5	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 180 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR GR 3.5	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 Ultra FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
Sopralene Flam 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Colphene Flam 250 FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 250 Ultra FR GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 180 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam 250 FR+ GR	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
Sopralene Flam Antirock	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
Sopralast 50 TV Alu	various	ASTM D6298	Fiberglass reinforced modified bitumen sheeting faced with aluminum foil. Applied by heat welding of ribbon stripping (after removal of plastic burn-off film).
Sopralast 50 TV Alu Sanded	various	ASTM D6298	Fiberglass reinforced modified bitumen sheeting sanded on the bottom and faced with aluminum foil. Applied in hot asphalt, cold adhesive or ribbon stripping.
Soprarstar Flam	39" x 33' (1 sq.)	ASTM D6162	Polyester reinforced SBS modified bitumen membrane with a plastic burn-off film on the bottom side and a reflective white top surface. Applied by heat welding.

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Soprastar Sanded	39" x 33' (1 sq.)	ASTM D6162	Stabilized polyester mat reinforced SBS modified bitumen membrane with a sanded bottom side and a reflective white top surface. Applied by hot asphalt or cold adhesive.
UNILAY	39" x 33' (1 sq.)	ASTM D6164	Non-woven polyester reinforced modified bitumen membrane with fire retardants and surfaced with mineral granules. Applied by mechanical attachment, heat welding or ribbon stripping (after removal of plastic burn-off film).
Elastocol 500	various	ASTM D41	Asphalt primers.
Elastocol Stick	various	ASTM D41	Asphalt primers.
Elastocol Stick Zero	Various	ASTM D41	Asphalt primers.
ALSAN Flashing™	1.25 gallon pail or 3.75 gallon pail	Proprietary	One part polyurethane/bitumen resin, moisture cure compound.
ALSAN Polyfleece	4", 8" or 39" wide by 50' long	Proprietary	Non-woven polyester reinforcement used in the ALSAN Flashing system.
COLPLY Flashing Cement	5 gallon pail	Proprietary	Elastomeric bitumen based mastic compound.
Sopravap'r	45" x 133'	Various	A self-adhering air/vapor barrier membrane applied directly to deck for use in steel deck assemblies, composed of a SBS modified bitumen adhesive bottom layer and a tri-laminated woven polyethylene top layer.
Soprawalk	39" x 26' (3/4 sq.)	Proprietary	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and mineral granules on the top. Applied by hot asphalt, cold adhesive or ribbon stripping.
FM Adhesive	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Plastomeric bitumen based cold adhesive.
FM Adhesive (VOC)	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Elastomeric bitumen based cold adhesive.
COLPLY Adhesive	5 gallon pail or 55 gallon drum	Proprietary	Polymer modified cold process membrane adhesive.
COLPLY Modified Adhesive	5 gallon pail, 55 gallon drum or 350 gallon tote	Proprietary	Elastomeric bitumen based cold adhesive.

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
COLPLY EF Adhesive	5 gallon pail	Proprietary	Solvent free, polymeric adhesive.
Soprema PV Adhesive	5 gallon pail	Proprietary	A solvent free, two-component adhesive used in the application of PV laminates.
Soprastar Adhesive	5 gallon pail or 55 gallon drum	Proprietary	SBS modified bitumen based cold adhesive.

**APPROVED INSULATIONS:**

**TABLE 2**

<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
ACFoam-II, ACFoam-III	Polyisocyanurate foam insulation	Atlas Roofing Corporation
ISO 95+ GL	Polyisocyanurate foam insulation	Firestone Building Products Company, LLC
EPS	Type IX 1.8 pcf. Polystyrene Insulation	Generic
XPS	Type IV 1.6 pcf. Polystyrene Insulation	Generic
High Density Wood Fiberboard	Wood fiber insulation board	Generic
Perlite Insulation	Perlite insulation board	Generic
DensDeck, DensDeck Prime, DensDeck DuraGuard Fireguard, DensDeck DuraGuard Roof Board	Water resistant gypsum board	Georgia Pacific Gypsum LLC
M-Shield	Polyisocyanurate foam insulation	Soprema, Inc.
Sopra-ISO r, Sopra-ISO+ r	Polyisocyanurate foam insulation	Soprema, Inc.
H-Shield, H-Shield CG	Polyisocyanurate foam insulation	Hunter Panels LLC
ENRGY 3, ENRGY 3 25 PSI	Polyisocyanurate foam insulation	Johns Manville Corp.
ENRGY 3 CGF, ENRGY 3 FR, ENRGY 3 AGF	Polyisocyanurate foam insulation	Johns Manville Corp.
Multi-Max-3, Multi-Max FA-3	Polyisocyanurate foam insulation	RMax Operating, LLC
SECUROCK Gypsum-Fiber Roof Board	Gypsum board	USG Corp.
Structodek High Density Fiberboard Roof Insulation	High Density wood fiber insulation board	Blue Ridge Fiberboard, Inc.
Fesco Board	Expanded mineral fiber insulation	Johns Manville Corp.
Sopraboard	Mineral fortified asphaltic cored coverboard	Soprema, Inc.
Sopra-ISO s, Sopra-ISO+ s	Polyisocyanurate foam insulation	Soprema, Inc.
Sopra-ISO x	Polyisocyanurate foam insulation	Soprema, Inc.
Sopra-ISO r	Polyisocyanurate foam insulation	Soprema, Inc.
EnergyGuard Polyiso Insulation, EnergyGuard Ultra POLYISO Insulation	Polyisocyanurate foam insulation	GAF



**APPROVED INSULATIONS:**

<b>TABLE 2</b>		
<b>Product Name</b>	<b>Product Description</b>	<b>Manufacturer (With Current NOA)</b>
Fesco Board HD, Retro-Fit Board, DuraBoard	Expanded mineral fiberboard	Johns Manville
FiberBase HD Excel	wood fiber insulation board	Georgia-Pacific Panel Products, LLC
GreenGuard-PB6, GreenGuard-PB6W, GreenGuard-PB6 PLUS, GreenGuard-PB6FA, GreenGuard-PB38FA, GreenGuard-PB6FA90, GreenGuard-PB3890	Extruded polystyrene	Pactiv Building Products
Invinsa Roof Board, Invinsa FR Roof Board	High density Polyisocyanurate Board	Johns Manville

**APPROVED FASTENERS:**

<b>TABLE 3</b>				
<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
1.	Tri-Fix Fastening System	Fastening system for base sheet attachment to lightweight concrete, gypsum or cementitious wood fiber decks.	3” diameter plate with various length fasteners	Soprema, Inc.
2.	Soprema #12, #14 & #15 Fastener	Fasteners for membrane or insulation attachment to wood, steel or concrete decks.		Soprema, Inc.
3.	Dekfast 12, 14 & 15 HS Fastener	Insulation fastener		SFS Intec, Inc.
4.	Dekfast Galvalume Steel Hex	Galvalume AZ50 steel plate	2 7/8” x 3 1/4”	SFS Intec, Inc.
5.	AccuTrac Hextra	Insulation fastener for wood and steel.		OMG, Inc.
6.	AccuTrac Plate	Galvalume square stress plate	3” square	OMG, Inc.
7.	OMG 3” Galvalume Steel Plate	Galvalume stress plate.	3” round	OMG, Inc.
8.	#12 Standard Roofgrip, #14 Roofgrip & #15 Roofgrip	Insulation fastener.		OMG, Inc.
9.	3 in. Round Metal Plate	Galvalume AZ50 steel plate	3" round	OMG, Inc.
10.	Trufast TL Fastener	Insulation fastener for lightweight concrete, CWF and gypsum decks		Altenloh, Brinck & Co. U.S., Inc.
11.	Trufast #14 HD Fastener	Insulation fastener for wood, steel and concrete.		Altenloh, Brinck & Co. U.S., Inc.



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
12.	Trufast #15 EHD Fastener	Insulation fastener for wood, steel and concrete.		Altenloh, Brinck & Co. U.S., Inc.
13.	Trufast 3” Metal Insulation Plate	Galvalume AZ50 steel plate	3” round	Altenloh, Brinck & Co. U.S., Inc.
14.	Polymer Batten Strip	Modified polymer batten bar		OMG, Inc.
15.	Dekfast Galvalume Steel 3” Round	Galvalume AZ50 steel plate	3” round	SFS Intec, Inc.
16.	Dekfast Coiled Batten Strip	Batten bar		SFS Intec, Inc.
17.	Soprema 3” Round Insulation Plate	Stress plate	3” diameter	Soprema, Inc.
18.	Soprafix 2” SB Stress Plate	Stress plate	2” diameter	Soprema, Inc.
19.	Soprafix 2-3/8” SB Stress Plate	Stress plate	2-3/8” diameter	Soprema, Inc.
20.	Soprafix MBB-R	Metal Batten Bar		Soprema, Inc.
21.	Soprema #12 DP Fastener, Soprema #14 MP Fastener, Soprema #15 HD Fastener	Insulation and membrane fasteners		Soprema, Inc.
22.	Trufast Flat Batten Bar	Galvalume AZ55 steel batten bar		Altenloh, Brinck & Co. U.S., Inc.
23.	Trufast Recessed Batten Bar	Galvalume AZ55 steel batten bar with recessed holes		Altenloh, Brinck & Co. U.S., Inc.
24.	#15 Roofgrip Large Head	Carbon steel fasteners used in steel, wood and concrete decks.	Various	OMG, Inc.
25.	Dekfast IF-2-SB	Galvalume AZ55 steel plate	2” round	SFS Intec, Inc.
26.	Dekfast Galvalume Steel Round 2-3/8” 20 ga. Barbed Plate	Galvalume AZ55 steel barbed plate	2.37” Round	SFS Intec, Inc.
27.	Trufast 2” Barbed Metal Seam Plate	Galvalume steel stress plate	2” Round	Altenloh, Brinck & Co. U.S., Inc.
28.	Trufast 2.4” Barbed Metal Seam Plate	Galvalume steel stress plate	2.4” Round	Altenloh, Brinck & Co. U.S., Inc.
29.	Soprema 2” Seam Plate	Stress plate	2” diameter	Soprema, Inc.
30.	Soprema 3” Metal Insulation Plate	Stress plate	3” diameter	Soprema, Inc.
31.	Flat Bottom Metal Plate	Galvalume stress plate.	3” square	OMG, Inc.
32.	OMG 2” Barbed Plate	Galvalume stress plate	2” Round	OMG, Inc.
33.	Trufast 2.4” Scoop Seam Plate	Galvalume steel stress plate	2.4” Round	Altenloh, Brinck & Co. U.S., Inc.



**APPROVED FASTENERS:**

**TABLE 3**

<b>Fastener Number</b>	<b>Product Name</b>	<b>Product Description</b>	<b>Dimensions</b>	<b>Manufacturer (With Current NOA)</b>
34.	Soprema 2.4" Seam Plates	Galvalume steel stress plate	2.4" Round	Soprema, Inc.
35.	Soprema #15-EL	Fasteners for membrane or insulation attachment to wood, steel or concrete decks.		Soprema, Inc.
36.	OMG Heavy-Duty	Insulation fastener for wood, steel and concrete.		OMG, Inc.
37.	OMG 2-3/8" Round Barbed Same Plate	Galvalume stress plate	2-3/8" Round	OMG, Inc.
38.	AccuTrac Flat Bottom	Aluminized square stress plate	3" square	OMG, Inc.
39.	Trufast #12 DP Fastener	Insulation fastener for wood and steel.		Altenloh, Brinck & Co. U.S., Inc.

**APPROVED SURFACING/COATING OPTIONS:**

**TABLE 4**

**Chosen components must be applied according to manufacturer's application instructions. Any coating, listed below, used as a surfacing, must be listed within a current NOA.**

<b>System Number</b>	<b>Manufacturer</b>	<b>Application</b>
1.	Generic	Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.
2.	Soprema, Inc.	Gravel applied at 400 lbs./sq., adhered with FM Adhesive, FM Adhesive (VOC), COLPLY EF Adhesive, COLPLY Adhesive, COLPLY Modified Adhesive or Soprastar Adhesive at 4 gal./sq.
3.	Karnak Corporation	Karnak #97 Fibrated Aluminum Roof Coating applied at an application rate of 1.5 gal./sq.
4.	Soprema, Inc.	Cural Aluminizer applied at an application rate of 2 gal./sq.
5.	Thermo Manufacturing Systems, LLC	Super Prep Roof Coating applied in two coats at an application rate of 1.5 gal./sq./coat.
6.	Quest Construction Products LLC dba United Coatings	Roof Mate Coating, applied in one base coat at a rate of 1.5 gal./sq. and one finish coat at a rate of 1.5 gal./sq.
7.	Insulating Coatings Corporation	Astec 2000 Finish Coat applied in two base coats at a rate of 0.75 gal./sq./coat and two finish coats at a rate of 0.75 gal./sq./coat.
8.	Henry Company	HE280DC White Elastomeric Roof Coating applied in two coats at an application rate of 1 gal./sq./coat.
9.	National Coating Corp.	Acryshield® A500 applied in two coats at an application rate of 1 gal./sq./coat.
10.	Soprema, Inc.	R-Nova Roof Coating.
11.	Generic	Semi-ceramic coated colored granules.



**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Report</u>	<u>Name</u>	<u>Date</u>
Dynatech Engineering Corp.	2491-04.95	TAS 114	01/04/95
Factory Mutual Research Corp.	1Z3A6.AM	FM 4470	04/27/95
	1D4A3.AM	FM 4470	04/24/98
	3002351	FM 4470	02/28/03
	3017614	FM 4470	02/27/06
	3026028	FM 4470	05/25/06
	3023458	FM 4450	07/18/06
	3029098	FM 4470	10/25/07
	3032109	FM 4470	07/21/08
	3036182	FM 4470	07/31/09
	3001445	FM 4470	02/05/99
	3X3A7.AM	FM 4470	09/08/94
	3045101	FM 4470	11/05/12
	3049322	FM 4470	01/17/14
	3008441	FM 4470	10/17/00
	3044801	FM 4470	02/27/12
	3047439	FM 4470	07/22/13
	3028410	FM 4470	02/19/07
	3045734	FM 4470	04/04/12
	3046765	FM 4470	02/15/13
	3047351	FM 4470	10/09/14
Underwriters Laboratories	R11436	UL 790	06/18/13
Exterior Research & Design, LLC	2003.02.97-1	TAS 114	02/15/97
	2003-2.04.97-1	TAS 114	04/15/97
	2002.07.97-1	TAS 114	08/15/97
	2716.05.98-1	TAS 114	05/27/98
	2752.02LAB.05.02-1	TAS 114	05/24/02
	2109.09.02	TAS 114	09/19/02
	2764.09.03	TAS 114	09/16/03
	02843.02.05-2	TAS 117 & FM 4470	02/10/05
	2774.04 .05-R1	TAS 114	04/18/07
	2779.11.05-R1	TAS 114	04/18/07
Trinity   ERD	S12370.03.09-1	ASTM D6164	03/06/09
	S12370.03.09-2	ASTM D6164	03/06/09
	S12370.03.09-3	ASTM D6162	03/06/09
	S11440.06.10	ASTM D4798 & TAS 110	06/01/10
	S32840.06.10-R1	TAS 117 (B)	12/11/14
	02848.04.05-R1	TAS 114	10/19/10
	S11440.01.11-R1	ASTM D6164	06/07/12
	S11440.11.10-4	ASTM D2178	11/17/10
	S11440.11.10-3-R1	ASTM D4601	01/30/13
	S11440.12.10-1-R1	ASTM D6163	06/07/12
	S30440.03.10-2-R2	FM 4470 & TAS 114	06/01/10
	S35860.12.11-1-R1	ASTM D2178	12/12/14
	S35860.12.11-2	ASTM D4601	12/12/11



**EVIDENCE SUBMITTED: (CONTINUED)**

<u>Test Agency/Identifier</u>	<u>Report</u>	<u>Name</u>	<u>Date</u>	
Trinity   ERD	S35860.05.12-1-R2	ASTM D6163	02/14/13	
	S35860.05.12-2-R3	ASTM D6164	08/28/14	
	S35860.05.12-3	ASTM D6164	05/08/12	
	S35860.09.12-R2	ASTM D6163	12/12/14	
	S39320.01.12-R1	FM 4474 & TAS 114	05/24/12	
	S39970.07.12-2	ASTM D6164	07/12/12	
	S43400.08.14-6	ASTM D6164	08/26/14	
	S45520.11.13-R2	Physical Properties	03/26/14	
	S32700.12.10-R2	ASTM D6162	07/07/14	
	S43210.11.14	ASTM D1876	11/10/14	
	S43400.08.14-5	ASTM D6163	08/26/14	
	S45340.10.13	FM 4474 & TAS 114	10/02/13	
	S39970.07.12-R1	ASTM D6162	12/12/14	
	S47160.01.14-R1	FM 4470 & TAS 114 (H)	12/11/14	
	S45010.02.14	ASTM D6506	02/07/14	
	S43400.08.14-7-R1	ASTM D6164	11/20/14	
	S43400.09.14-9	ASTM D6164	09/02/14	
	S43400.09.14-10	ASTM D6298	09/08/14	
	S43400.08.14-4-R1	ASTM D6163	10/24/14	
	S44110.09.14-3	ASTM D6163	09/08/14	
	S44110.09.14-7C	ASTM D6164	09/02/14	
	S44220.09.14-1	ASTM D6162	09/08/14	
	S44220.09.14-7A	ASTM D4601	09/08/14	
	S11440.11.10-3-R2	ASTM D4601 & TAS 117(B)	08/26/14	
	PRI Construction Materials Technologies, LLC	SOP-049-02-01	ASTM D1644 /D2196	05/31/12
		SOP-043-02-01	ASTM D4601	02/27/12
		SOP-042-02-01	ASTM D4601	02/27/12
		SOP-041-02-01	ASTM D2178	02/27/12
		SOP-040-02-01	ASTM D2178	02/27/12
		SOP-010-02-01.03	TAS-138	07/26/11
		SOP-050-02-01	ASTM D3019	07/12/12
		SOP-033-02-01	FM 4474 & TAS 114	05/10/12
SOP-056-02-01	Various	09/12/12		



**APPROVED ASSEMBLIES:**

- Membrane:** SBS
- Deck Type 2I:** Steel, Insulated
- Deck Description:** Min. 22 ga., type B, 33 ksi steel fastened with puddle welds spaced 6” o.c. to supports spaced maximum 6’ o.c. Deck side laps are fastened max. 24” o.c. with Tek/1 fasteners.
- System Type B(1):** Optional vapor barrier followed by base layer of insulation mechanically attached, top layer adhered with approved adhesive, roof cover fully adhered.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap<sup>r</sup>, self-adhered to the top flanges of the steel deck.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISOs or ENRGY 3 Minimum 2” thick</b>	<b>8 (#12 or #14) with 38, 8 (#12) or 36 with 7, 3 (#12 or #14) with 15, 39, 21 (#12) or 11 or 21 (#14) with 13 or 17 or 2 (#12 or #14) with 30</b>	<b>1:2 ft<sup>2</sup></b>

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board Minimum 3/8” thick</b>	<b>N/A</b>	<b>N/A</b>

**Note:** All insulations shall be adhered with hot asphalt full mop applied at a rate of 25 lbs./sq. or with High Velocity<sup>®</sup> Insulation Adhesive III (HVIA-III), High Velocity<sup>®</sup> Insulation Adhesive III – Green, High Velocity Insulation Adhesive PG, Duotack, Duotack Neo, Millennium One Step Foamable Adhesive, Millennium One Step Green Foamable Adhesive, Millennium PG-1 Low Viscosity Insulation Adhesive applied in continuous ribbons maximum spacing of 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

**Base Sheet:** Elastophene Flam HS\*, Elastophene Flam 2.2\*, Elastophene Flam\*, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\* Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5 or Sopralene 250 SP, torch-applied.  
 \*Requires torch-applied Ply or Cap.



- Ply Sheet:** Elastophene HS 62, Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Sopralene 180 Sanded 2.2, Colphene 180 Sanded, Sopralene 180 Sanded, Sopralene 250 Sanded, Elastophene PS\*, Elastophene PS 3.0\*, Sopralene 180 PS 2.2\*, Colphene 180 PS\* or Sopralene 180 PS\* applied in hot asphalt at 25 lbs/sq.
- Or
- Elastophene Flam HS\*, Elastophene Flam 2.2\*, Elastophene Flam\*, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5 or Sopralene 250 SP, torch-applied.  
\*Requires torch-applied Cap.
- Membrane:** SopraStar Sanded, Elastophene GR, Elastophene LS FR GR, Elastophene FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR or Sopralast 50 TV Alu Sanded, applied in hot asphalt at 25 lbs/sq.
- Or
- SopraStar Flam, Elastophene Flam GR, Elastophene Flam LS FR GR, Elastophene Flam FR GR, Elastophene Flam FR+ GR, Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** -60 psf. (See General Limitation #7.)

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel fastened to structural supports spaced 6' o.c. with #12-24 x 1-1/4" HWH self-drilling metal screws with 1/4" washers in every flute. Deck side laps fastened with #1/4-14 x 7/8" HWH self-drilling metal screws with 1/4" washers spaced at 12" o.c.

**System Type B(2):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
(Optional)

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>H-Shield, M-Shield, Sopra-ISO r Minimum 2" thick</b>	<b>11, 21 (#14 MP) with 13, 30</b>	<b>1:1.78 ft<sup>2</sup></b>

**Note:** Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board Minimum 3/4" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note:** Top layer of insulation shall be adhered with ASTM D312 Type IV mopping asphalt within the EVT range and at a rate of 25 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

**Base Sheet:** One layer of Sopra G, Modified Sopra G, Sopra IV, Sopra VI, Soprabase, Soprabase S, Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Ply Sheet:** **(Base sheet required for use of torch-applied ply sheets)** One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, torch-applied.



Or

One or more layers of Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 PS\*, Sopralene 180 Sanded, Sopralene 250 Sanded or one or more plies of Type IV or Type VI ply sheets adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

\*Requires torch-applied cap membrane.

**Membrane:**

Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam FR+ GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Elastophene FR GR, Elastophene FR+ GR, Elastophene LS FR GR, Elastophene GR, Soprastar Sanded, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.

**Surfacing:**

Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes.

Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:**

-67.5 psf. (See General Limitation #7)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. steel Grade 80 steel fastened 6" o.c. with Traxx/5 fasteners to steel supports spaced maximum 5 ft. o.c. Deck side laps fastened with Traxx/1 fasteners spaced at 20" o.c.

**System Type B(3):** Base layer of insulation mechanically fastened, top layer adhered with approved asphalt.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
(Optional)

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, ENRGY 3, ENRGY 3 25 PSI, H-Shield, M-Shield, Sopra-ISO r (flat or tapered) Minimum 1.5" thick</b>	<b>2, 3, 5, 8, 10 with approved plates</b>	<b>1:1.33 ft<sup>2</sup></b>

**Note:** Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard, Structodek High Density Fiberboard Roof Insulation Minimum ½" thick</b>	<b>N/A</b>	<b>N/A</b>
<b>Fesco Board Minimum ¾" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note:** Top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.

**Base Sheet:** One or more layers of Sopra G, Modified Sopra G, Sopra IV, Sopra VI, or  
(Optional) Soprabase adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.



**Ply Sheet:  
(Optional)**

**(Required if no base sheet used)** One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, torch-applied.

Or

One or more layers of Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 PS\*, Sopralene 180 Sanded, Sopralene 250 Sanded or one or more plies of Type IV or Type VI ply sheets, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

\*Requires torch-applied cap membrane.

**Membrane:**

Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam FR+ GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR or Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Soprastar Sanded, Elastophene FR GR, Elastophene FR+ GR, Elastophene LS FR GR, Elastophene GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.

**Surfacing:**

Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design  
Pressure:**

-67.5 psf. (For Fesco Board) (See General Limitation #7)

-75 psf. (For High Density Wood Fiberboard) (See General Limitation #7)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., 1.5 in. (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners into steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with Traxx/1 fasteners spaced max. 30" o.c.

**System Type B(4):** Base layer of insulation mechanically attached, top layer adhered with approved asphalt

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, H-Shield, M-Shield, Sopra-ISO r (flat or tapered) Minimum 2" thick</b>	<b>11 or 21 (min #14)</b>	<b>1:1.6 ft<sup>2</sup></b>

**Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note: Top layer of insulation shall be adhered with approved hot asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as the base layer shall only be used as the base layer with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq.,  
**(Optional)** to top surface of any insulation, base or ply sheet prior to application of next layer.

**Base Sheet:** One or more layers of Sopra G, Modified Sopra G, Sopra IV, Sopra VI, Soprabase, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.  
\*Requires torch-applied ply or cap membrane.



**Ply Sheet:  
(Optional)** One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622. Sopralene Flam 250\*, Sopralene 250 SP, torch-applied.

Or

Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq. to sand surfaced base membrane.

\*Requires torch-applied cap membrane.

**Membrane:** Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Soprastar Sanded, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -75 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., type B, 33 ksi steel fastened with Tek/5 screws spaced 6" o.c. to supports spaced maximum 6' o.c. Deck side laps are fastened max. 24" o.c. with Tek/1 fasteners.

**System Type B(5):** Insulation layer mechanically attached followed by vapor barrier, fully adhered and insulation layers adhered with approved adhesive, roof cover fully adhered.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board</b>		
<b>Min. 0.625-inch thick</b>	<b>11 with 13 or 21 (#14) with 30</b>	<b>1:2 ft<sup>2</sup></b>

**Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.**

**Vapor Barrier:** Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, torch-applied.

<b>Middle Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam III, Sopra-ISO+ s</b>		
<b>Minimum 2" thick</b>	<b>N/A</b>	<b>N/A</b>

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board</b>		
<b>Minimum 0.25" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note: Middle and Top insulations shall be adhered with High Velocity Insulation Adhesive PG (HVIA-PG) applied in continuous ribbons maximum spacing of 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Base Sheet:** One layer of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Elastophene Flam HS\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\* or Sopralene 250 SP, torch-applied.  
Or



**Base Sheet:  
(Continued)** Elastophene Sanded, Colphene Sanded, Elastophene PS\*, Elastophene PS 3.0, Elastophene HS, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded adhered in COLPLY Adhesive, COLPLY Modified Adhesive, COLPLY EF Adhesive, FM Adhesive (VOC) or Soprastar Adhesive at a rate of 1.5 gal./sq. or adhered in hot asphalt at 25 lbs./sq. or Sopra-G, Modified Sopra-G, Sopra IV, Sopra VI or Soprabase applied in hot asphalt at 25 lbs/sq  
\*Requires torch-applied cap membrane

**Ply Sheet:  
(Optional)** One layer of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Elastophene Flam HS\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\* or Sopralene 250 SP, torch-applied.

Or

Elastophene Sanded, Colphene Sanded, Elastophene PS\*, Elastophene PS 3.0, Elastophene HS, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded adhered in COLPLY Adhesive, COLPLY Modified Adhesive, COLPLY EF Adhesive, FM Adhesive (VOC) or Soprastar Adhesive at a rate of 1.5 gal./sq. or adhered in hot asphalt at 25 lbs./sq. or Sopra-G, Modified Sopra-G, Sopra IV, Sopra VI or Soprabase applied in hot asphalt at 25 lbs/sq

\*Requires torch-applied cap membrane

**Membrane:** Elastophene Flam GR, Elastophene Flam LS FR GR, Elastophene Flam FR GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Soprastar Flam, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied with minimum 3" wide lap.

Or

Soprastar Sanded, Elastophene FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR or Sopralene 250 Ultra FR GR, applied in hot asphalt at 25 lbs/sq.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design  
Pressure:** -75 psf. (See General Limitation #7.)



- Membrane Type:** SBS
- Deck Type 2I:** Steel, Insulated
- Deck Description:** Min. 22 ga., Type B, Grade 33 steel fastened to structural supports spaced 6' o.c. with Tek/5 screws in every flute spaced 6" o.c. Deck side laps are fastened max. 24" o.c. with Tek/1 fasteners.
- System Type B(6):** Insulation layer mechanically attached followed by vapor barrier, fully adhered and insulation layers adhered with approved adhesive, roof cover fully adhered.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

**Separation Sheet:** Sopravap'r, self-adhered.  
(Optional)

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
<b>Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board</b> Min. 0.625-inch thick	<b>11 with 13 or 21 (#14) with 30</b>	<b>1:2 ft<sup>2</sup></b>

**Note: Base layer shall be mechanically attached with fasteners and density described above. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density. See Roofing Application Standard RAS 117 for fastening details.**

**Vapor Barrier:** Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, torch-applied.

Middle Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
<b>EnergyGuard POLYISO Insulation or ENRGY 3 CGF</b> Minimum 2" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
<b>Dens Deck Prime or SECUROCK Gypsum-Fiber Roof Board</b> Minimum 0.25" thick	N/A	N/A

**Note: Middle and Top insulation shall be adhered with High Velocity Insulation Adhesive PG, Millennium PG-1 Low Viscosity Insulation Adhesive, Duotack or Duotack Neo applied in continuous 3/4" to 1" wide ribbons at a maximum spacing of 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate**

**Base Sheet:** One layer of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Elastophene Flam HS\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\* or Sopralene 250 SP, torch-applied.



**Base Sheet:  
(Continued)**

Or  
Elastophene Sanded, Colphene Sanded, Elastophene PS\*, Elastophene PS 3.0, Elastophene HS, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded adhered in COLPLY Adhesive, COLPLY Modified Adhesive, COLPLY EF Adhesive, FM Adhesive (VOC) or Soprastar Adhesive at a rate of 1.5 gal./sq. or adhered in hot asphalt at 25 lbs./sq. or Sopra-G, Modified Sopra-G, Sopra IV, Sopra VI or Soprabase applied in hot asphalt at 25 lbs/sq  
\*Requires torch-applied cap membrane

**Ply Sheet:  
(Optional)**

One layer of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Elastophene Flam HS\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\* or Sopralene 250 SP, torch-applied.

Or  
Elastophene Sanded, Colphene Sanded, Elastophene PS\*, Elastophene PS 3.0, Elastophene HS, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded adhered in COLPLY Adhesive, COLPLY Modified Adhesive, COLPLY EF Adhesive, FM Adhesive (VOC) or Soprastar Adhesive at a rate of 1.5 gal./sq. or adhered in hot asphalt at 25 lbs./sq. or Sopra-G, Modified Sopra-G, Sopra IV, Sopra VI or Soprabase applied in hot asphalt at 25 lbs/sq  
\*Requires torch-applied cap membrane

**Membrane:**

Elastophene Flam GR, Elastophene Flam LS FR GR, Elastophene Flam FR GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Soprastar Flam, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied with minimum 3” wide lap.

Or  
Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 Ultra FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 Ultra FR GR, Sopralene 250 FR+ GR, Soprastar Sanded adhered in COLPLY Adhesive, COLPLY Modified Adhesive, COLPLY EF Adhesive, FM Adhesive (VOC) or Soprastar Adhesive at a rate of 1.5 gal./sq. or adhered in hot asphalt at 25 lbs./sq.

**Surfacing:**

Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design  
Pressure:**

-75 psf. (See General Limitation #7)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. Type B, Grade 33 steel fastened 6" o.c. with Traxx/5 fasteners to supports spaced 5 ft. o.c. Deck side laps fastened with Traxx/1 fasteners spaced at 20" o.c.

**System Type C(1):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, ENRGY 3, ENRGY 3 25 PSI, Multi-Max FA-3, Sopra-ISO x, H-Shield, M-Shield, Sopra-ISO r (flat or tapered) Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck Minimum ¼" thick</b>	<b>2, 3, 5, 8, or 10</b>	<b>1:2 ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard Minimum ½" thick</b>	<b>2, 3, 5, 8, or 10</b>	<b>1:2 ft<sup>2</sup></b>

**Note:** All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

**Base Sheet:** One or more layers of Sopra G, Modified Sopra G, Sopra IV, Sopra VI, Soprabase, adhered in CIM 162 Adhesive or Soprema PV Adhesive applied at a rate of 1.5 gal./sq.  
**(Optional)**

**Ply Sheet:** **(Required if no base sheet used)** One or more layers of Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded, Sopralene 250 Sanded, or one or more plies of Type IV or Type VI ply sheets adhered in CIM 162 Adhesive or Soprema PV Adhesive applied at a rate of 1.5 gal./sq.  
**(Optional)**

**Membrane:** Soprastar Sanded, Elastophene FR GR, Elastophene FR+ GR, Elastophene LS FR GR, Elastophene GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR adhered in CIM 162 Adhesive or Soprema PV Adhesive applied at a rate of 1.5 gal./sq.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -52.5 psf. (See General Limitation #7)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. ASTM A1008, Grade 80 steel decking over ¼” thick steel supports spaced at maximum 6 ft. o.c. attached with Traxx/5 fasteners at a spacing of 6” o.c. Deck side laps are attached 30” o.c. using Traxx/1 fasteners.

**System Type C(2):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**  
**Vapor Barrier:** Soprapap<sup>r</sup>, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, ENRGY 3, ENRGY 3 25 PSI, Multi-Max FA-3, Sopra-ISO x, H-Shield, M-Shield, Sopra-ISO r (flat or tapered) Minimum 1.5” thick	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
DensDeck Minimum ¼” thick	8	1:1.78 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** One or more layers of Sopra G, Modified Sopra G, Sopra IV, Sopra VI, Soprabase, adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.  
**(Optional)** \*Requires torch-applied ply or cap membrane.

**Ply Sheet:** **(Required if no base sheet used)** One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, torch-applied.

Or

One or more layers of Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 PS\*, Sopralene 180 Sanded, Sopralene 250 Sanded or one or more plies of Type IV or Type VI ply sheets, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

\*Requires torch-applied cap membrane.



**Membrane:** Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam FR+ GR, Elastophene Flam LS FR GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Soprastar Sanded, Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -52.5 psf. (See General Limitation #7)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., 1.5 in. (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners into steel supports spaced maximum 6 ft. o.c. Deck side laps are attached with Traxx/1 fasteners spaced max. 30" o.c.

**System Type C(3):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, ACFoam-III, Sopra-ISO s, Sopra-ISO+ s, ENRGY 3, H-Shield, M-Shield, Sopra-ISO r, Multi-Max FA-3, Sopra-ISO x (flat or tapered) Minimum 1.4" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck Minimum ¼" thick</b>	<b>2(#14)</b>	<b>1:1.78 ft<sup>2</sup></b>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq.,  
**(Optional)** to top surface of any insulation, base or ply sheet prior to application of next layer.

**Base Sheet:** One or two layers of Sopra G, Modified Sopra G, Sopra IV, Sopra VI, Soprabase,  
**(Optional)** adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or in FM Adhesive, FM Adhesive (VOC), COLPLY Adhesive, COLPLY Modified Adhesive or Soprastar Adhesive at 1.5 – 2.0 gallons/square.

**Ply Sheet:** **(Required if no base sheet used)** Elastophene Flam\*, Elastophene Flam 2.2\*,  
**(Optional)** Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250\*, Sopralene 250 SP, torch-applied.



Or

Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, or one to three plies of Sopra IV or Sopra VI ply sheet, adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or in FM Adhesive, FM Adhesive (VOC), COLPLY Adhesive, COLPLY Modified Adhesive or Soprastar Adhesive at 1.5 – 2.0 gallons/square.

\*Requires torch-applied cap membrane.

**Membrane:**

Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Soprastar Sanded, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. or in FM Adhesive, FM Adhesive (VOC), COLPLY Adhesive, COLPLY Modified Adhesive or Soprastar Adhesive at 1.5 – 2.0 gallons/square to sand surfaced base or ply membrane.

**Surfacing:**

Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes.

Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design**

**Pressure:**

-60 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(4):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered to the top flanges of the steel deck.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ACFoam-III, Sopra-ISO+ s, EnergyGuard POLYISO Insulation, EnergyGuard Ultra POLYISO Insulation, ENRGY 3, ENRGY 3 FR, ENRGY 3 AGF, ENRGY 3 CGF, H-Shield, Sopra-ISO r, M-Shield, H-Shield CG, Sopra-ISO+ r, Multi-Max FA-3, Sopra-ISO x (flat or tapered)</b>		
<b>Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board</b>		
<b>Minimum 0.5" thick</b>	<b>8 (#12 or #14) with 38, 8 (#12) or 36 with 7, 3 (#12 or #14) with 15, 39 21 (#12) or 11 or 21 (#14) with 13 or 17 or 2 (#12 or #14) with 30</b>	<b>1:1.78 ft<sup>2</sup></b>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer:** Coverboard is primed with an approved ASTM D41 asphalt primer at a rate of 100-150 ft<sup>2</sup>/gal.  
**(Optional)**

**Base Sheet:** Elastophene Flam HS\*, Elastophene Flam 2.2\*, Elastophene Flam\*, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5 or Sopralene 250 SP, torch-applied.  
\*Requires torch-applied Ply or Cap.

**Ply Sheet:** Elastophene HS 62, Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Sopralene 180 Sanded 2.2, Colphene 180 Sanded, Sopralene 180 Sanded, Sopralene 250 Sanded, Elastophene PS\*, Elastophene PS 3.0\*, Sopralene 180 PS 2.2\*, Colphene 180 PS\* or Sopralene 180 PS\* applied in hot asphalt at 25 lbs/sq.

Or



**Ply Sheet:  
(Optional)  
Continued** Elastophene Flam HS\*, Elastophene Flam 2.2\*, Elastophene Flam\*, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5 or Sopralene 250 SP, torch-applied.  
\*Requires torch-applied Cap.

**Membrane:** SopraStar Sanded, Elastophene GR, Elastophene LS FR GR, Elastophene FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR or Sopralast 50 TV Alu Sanded, applied in hot asphalt at 25 lbs/sq.

Or

Elastophene Flam GR, Elastophene Flam LS FR GR, Elastophene Flam FR GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, SopraStar Flam, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design  
Pressure:** -52.5 psf. (See General Limitation #7.)

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., ASTM A653 or A1008 Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(5):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
ACFoam-II, Sopra-ISO s, H-Shield, M-Shield, Sopra-ISO r, ISO 95+ GL, ENRGY 3 Minimum 2" thick	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick (4'x8')	3, 7, 11, 12	1:1.78 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq.,  
**(Optional)** to top surface of any insulation, base or ply sheet prior to application of next layer.

**Base Sheet:** One or more layers of Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq.

\*Requires torch-applied ply or cap membrane.



**Ply Sheet:  
(Optional)** One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250\*, Sopralene 250 SP, torch-applied.

Or

Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq. to sand surfaced base membrane.

\*Requires torch-applied cap membrane.

**Membrane:** Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Soprastar Sanded, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -60 psf. (See General Limitation #7.)

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(6):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved polyisocyanurate or EPS or XPS listed in Table 2</b>		
<b>Minimum 1" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard</b>		
<b>Minimum 1/8" thick</b>	<b>2, 3, 8, 11, 12</b>	<b>1:2 ft<sup>2</sup></b>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq.,  
**(Optional)** to top surface of any insulation, base or ply sheet prior to application of next layer.

**Base Sheet:** One or more layers of Sopra G, Modified Sopra G, Soprabase, Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq.

Or

One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 250\*, Sopralene 250 SP, Colvent TG, Colvent 180 TG, Colvent Flam TG\*, Colvent Flam 180 TG\*, torch-applied.

\*Requires torch-applied ply or cap membrane.



**Ply Sheet:  
(Optional)** One or more layers of Sopra IV, Sopra VI, Soprabase, Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq. to sand surfaced base membrane.

Or

Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 250\*, Sopralene 250 SP, torch-applied.  
\*Requires torch-applied cap membrane.

**Membrane:** Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

Or

Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Soprastar Sanded, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -60 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(7):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any approved polyisocyanurate or EPS or XPS listed in Table 2</b>		
<b>Minimum 1" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard</b>		
<b>Minimum 1/8" thick</b>	<b>2, 3, 8, 11, 12</b>	<b>1:2 ft<sup>2</sup></b>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq.,  
**(Optional)** to top surface of any insulation, base or ply sheet prior to application of next layer.

**Base Sheet:** One or more layers of Sopralene 180 Sanded, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq.

Or

Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 250\*, Sopralene 250 SP, Colvent 180 TG, Colvent Flam 180 TG\*, torch-applied.

\*Requires torch-applied ply or cap membrane.



**Ply Sheet:  
(Optional)** Sopralene 180 Sanded, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Elastophene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in hot asphalt at 25 lbs./sq. to sand surfaced base membrane.

Or

Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 250\*, Sopralene 250 SP, torch-applied.

\*Requires torch-applied cap membrane.

**Membrane:** Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralene Flam Antirock, torch-applied.

Or

Soprastar Sanded, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -67.5 psf. (See General Limitation #7.)

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(8):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick</b>	11 with 13 or 21 (#14) with 30	1:1.33 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** Sopralene 180 SP 3.0, torch-applied.

**Membrane:** Soprapap'r Sanded adhered in Soprema PV Adhesive at a rate of 2 gal./sq. to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
 Surfacing is Required for smooth or sanded surfaced field cap membranes.  
 Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
 Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -67.5 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(9):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered to the top flanges of the steel deck.

**(Optional)**

One or more layers of any of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam-II, Sopra-ISO s, ACFoam-III, Sopra-ISO+ s, EnergyGuard POLYISO Insulation, EnergyGuard Ultra POLYISO Insulation, ENRGY 3, ENRGY 3 FR, ENRGY 3 AGF, ENRGY 3 CGF, H-Shield, Sopra-ISO r, M-Shield, H-Shield CG, Sopra-ISO+ r, Multi-Max FA-3, Sopra-ISO x (flat or tapered)		
Minimum 1.5" thick	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
Dens Deck Prime		
Minimum 0.5" thick	36 with 7, 11 or 21 (#14) with 13 or 30	1:1.6 ft <sup>2</sup>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** Two or three plies of Sopra IV, Sopra VI or two plies of Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** Sopraplast Sanded, Elastophene GR, Elastophene LS FR GR, Elastophene FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR or Sopralast 50 TV Alu Sanded applied in hot asphalt at 25 lbs/sq.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
 Surfacing is Required for smooth or sanded surfaced field cap membranes.  
 Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
 Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -67.5 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(10):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board Minimum 1/2" thick</b>	<b>12 with 13 or 21 (#15) with 30</b>	<b>1:1.33 ft<sup>2</sup></b>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** Sopralene 180 SP 3.0, torch-applied.

**Membrane:** Soprapstar Sanded adhered in Soprapstar Adhesive, FM Adhesive (VOC), COLPLY EF Adhesive, COLPLY Adhesive or COLPLY Modified Adhesive at a rate of 1.5 gal./sq. to sanded surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
 Surfacing is Required for smooth or sanded surfaced field cap membranes.  
 Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
 Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -75 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 24" o.c.

**System Type C(11):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered to the top flanges of the steel deck.

**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ACFoam-III, Sopra-ISO+ s, EnergyGuard POLYISO Insulation, EnergyGuard Ultra POLYISO Insulation, ENRGY 3, ENRGY 3 FR, ENRGY 3 AGF, ENRGY 3 CGF, H-Shield, Sopra-ISO r, M-Shield, H-Shield CG, Sopra-ISO+ r, Multi-Max FA-3, Sopra-ISO x (flat or tapered)</b>	N/A	N/A
<b>Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board</b>	<b>12 or 21(#15) with 13 or 30</b>	<b>1:1.33 ft<sup>2</sup></b>
<b>Minimum 0.375" thick</b>		

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** Elastophene Flam HS\*, Elastophene Flam 2.2\*, Elastophene Flam\*, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5 or Sopralene 250 SP, torch-applied.  
\*Requires torch-applied Ply or Cap.

**Ply Sheet:** Elastophene Flam HS\*, Elastophene Flam 2.2\*, Elastophene Flam\*, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5 or Sopralene 250 SP, torch-applied.  
or  
Elastophene HS 62, Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Sopralene 180 Sanded 2.2, Colphene 180 Sanded, Sopralene 180 Sanded, Sopralene 250 Sanded, Elastophene PS\*, Elastophene PS 3.0\*, Sopralene 180 PS 2.2\*, Colphene 180 PS\* or Sopralene 180 PS\* applied in hot asphalt at 25 lbs/square.  
\*Requires torch-applied Cap.



**Membrane:**

SopraStar Flam, Elastophene Flam GR, Elastophene Flam LS FR GR, Elastophene Flam FR GR, Elastophene Flam FR+ GR, Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

or

SopraStar Sanded, Elastophene GR, Elastophene LS FR GR, Elastophene FR GR, Elastophene FR+ GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR or Sopralast 50 TV Alu Sanded, applied in COLPLY Adhesive or SopraStar Adhesive at 1.5-2.0 gal/square or applied in hot asphalt at 25 lbs/square.

or

SopraStar Sanded, Elastophene GR, Elastophene LS FR GR or Sopralast 50 TV Alu Sanded, applied in COLPLY Modified Adhesive or SopraStar Adhesive at 1.5-2.0 gal/square.

or

Elastophene GR, Elastophene LS FR GR, Elastophene FR GR or Elastophene FR+ GR, applied in COLPLY Modified Adhesive or SopraStar Adhesive at 1.5-2.0 gal/square.

**Surfacing:**

Surfacing is Optional on granular surfaced field cap membranes.

Surfacing is Required for smooth or sanded surfaced field cap membranes.

Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design**

**Pressure:**

-75 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. Type B, Grade 80 steel fastened 6" o.c. with Traxx/5 fasteners to steel supports spaced maximum 5 ft. o.c. Deck side laps fastened with Traxx/1 fasteners spaced at 20" o.c.

**System Type C(12):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
------------------------------	---	--

Any Approved insulation listed in Table 2 (flat or tapered) loose laid.

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
-----------------------------	---	--

**Sopraboard**

<b>Minimum 1/8" thick</b>	<b>3, 8, 12 (#15) or 21 (#15)</b>	<b>1:1.25 ft<sup>2</sup></b>
---------------------------	-----------------------------------	------------------------------

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Primer:** Elastocol 500, Elastocol Stick, Elastocol Stick Zero applied at a rate of 1 gal./sq.,  
**(Optional)** to top surface of any insulation, base or ply sheet prior to application of next layer.

**Base Sheet:** One or more layers of Sopra G, Modified Sopra G, Sopra IV, Sopra VI, Soprabase, Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, adhered in a full mopping of approved asphalt, applied within the EVT range and at a rate of 20-40 lbs./sq.

Or

Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250\*, Sopralene 250 SP, Colvent TG, Colvent 180 TG, Colvent Flam TG\*, Colvent Flam 180 TG\*, torch-applied.

\*Requires torch-applied ply or cap membrane.



**Ply Sheet:  
(Optional)** One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Elastophene Flam HS\*, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250\*, Sopralene 250 SP, torch-applied.

Or

Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene PS\*, Elastophene PS 3.0\*, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene 180 PS\*, Colphene 180 PS\*, Sopralene 180 PS 2.2\*, Sopralene 180 Sanded, Sopralene 180 PS\*, Sopralene 250 Sanded, or one to three plies of Sopra IV or Sopra VI, adhered in a full mopping of approved asphalt, applied within the EVT range and at a rate of 20-40 lbs./sq. to sand surfaced base membrane.

\*Requires torch-applied cap membrane.

**Membrane:** Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam FR+ GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied..

Or

Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Elastophene FR+ GR, Soprastar Sanded, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in hot asphalt at 25 lbs./sq. or in FM Adhesive, FM Adhesive (VOC), COLPLY Adhesive, COLPLY Modified Adhesive or Soprastar Adhesive at 1.5 – 2.0 gallons/square to sand surfaced base or ply membrane.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -90 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** Min. 22 ga., Type B, Grade 80 steel deck secured to min. ¼” thick supports spaced a max. 6’ o.c. with Traxx/5 fasteners spaced a max. 6” o.c. Deck side laps are attached with Traxx/1 screws spaced 24” o.c.

**System Type C(13):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap’r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck or DensDeck Prime Minimum .25” thick</b>	N/A	N/A
<b>Middle Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>H-Shield, M-Shield, Sopra-ISO r, ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max FA-3, Sopra-ISO x, ENRGY 3 Minimum 1.5” thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum .5” thick</b>	<b>11, 12 with 13; 21 (#14 or #15) with 30</b>	<b>1:1.33</b>

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** Elastophene Sanded, Colphene Sanded, Elastophene PS, Elastophene PS 3.0, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene 180 PS, Colphene 180 PS, Sopralene 180 PS 2.2, Sopralene 180 Sanded, Sopralene 180 PS, Sopralene 250 Sanded adhered in COLPLY Adhesive, COLPLY Modified Adhesive, COLPLY EF Adhesive, FM Adhesive (VOC) or Soprapstar Adhesive at a rate of 1.5 gal./sq. or adhered in hot asphalt at 25 lbs./sq.

Or

Elastophene Flam, Elastophene Flam 2.2, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Elastophene Flam HS, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene Flam 180, Colphene Flam 180, Sopralene Flam 250, Sopralene 250 SP, Colvent TG, Colvent 180 TG, Colvent Flam TG\*, Colvent Flam 180 TG\*, torch-applied.



**Membrane:** Elastophene FR GR, Elastophene LS FR GR, Elastophene GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 Ultra FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 Ultra FR GR, Sopralene 250 FR+ GR, Soprastar Sanded, Sopralast 50 TV Alu Sanded adhered in COLPLY Adhesive, COLPLY Modified Adhesive, COLPLY EF Adhesive, FM Adhesive (VOC) or Soprastar Adhesive at a rate of 1.5 gal./sq. or adhered in hot asphalt at 25 lbs./sq.

Or

Elastophene Flam FR GR, Elastophene Flam LS FR GR, Elastophene Flam GR, Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -90 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga., ASTM A1008 SS Grade 33 steel deck fastened to min. ¼” thick steel structural supports spaced a maximum 6 ft. o.c. with Traxx/5 screws and ¾” diameter washers spaced maximum 6 in. o.c. Side laps are fastened with Traxx/1 screws spaced maximum 12 in. o.c.

**System Type C(14):** All layers of insulation simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap’r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer:</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
-------------------------------	---	--

<b>H-Shield, ACFoam-II, M-Shield, Sopra-ISO r, Sopra-ISO s Minimum 1.5” thick</b>	N/A	N/A
---	-----	-----

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer:</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
------------------------------	---	--

<b>SECUROCK Gypsum-Fiber Roof Board</b>		
---	--	--

<b>Minimum ½” thick</b>	<b>11 with 13; 21 (#14) with 30</b>	<b>1:1.33 ft<sup>2</sup></b>
-------------------------	-------------------------------------	------------------------------

<b>Minimum ½” thick</b>	<b>11 with 13; 21 (#14) with 30</b>	<b>1:1 ft<sup>2</sup></b>
-------------------------	-------------------------------------	---------------------------

**Note: All layers of insulation shall be mechanically attached using the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Base Sheet:** Two or three plies of Sopra IV, Sopra VI or two plies of Elastophene Sanded, Colphene Sanded, Elastophene Sanded 3.0, Elastophene HS, Elastophene HS 62, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** SopraStar Sanded, Elastophene GR, Elastophene FR GR, Elastophene FR+ GR, Elastophene LS FR GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 180 FR+ GR, Sopralene 250 Ultra FR GR, Sopralast 50 TV Alu Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -157.5 psf. (fastener density of 1:1.33 ft<sup>2</sup>) (See General Limitation #7)  
 -172.5 psf. (fastener density of 1:1 ft<sup>2</sup>) (See General Limitation #7)



- Membrane:** SBS
- Deck Type 2I:** Steel, Insulated
- Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened to structural supports spaced a maximum of 6' o.c. with Tek/5 screws and spaced a maximum 6" o.c. at the supports. Side laps are fastened with Traxx/1 screws spaced maximum 24 in. o.c.
- System Type D(1):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

- Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**
- Fire Barrier:** Minimum ¼" thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>H-Shield, M-Shield, Sopra-ISO r Minimum 1.5" thick</b>	N/A	N/A

**Note:** Base layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

- Base Sheet:** One layer of Soprafix Base 611, Soprafix, Soprafix Base 622, Soprafix-e, Soprafix Base 641, Soprafix [F], Soprafix Base 613, Soprafix [S], Soprafix Base 612, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:
- Fastening #1:** Attach Soprafix Base 611 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates with row spacing at a maximum 70.75" o.c. The fasteners are spaced 6" o.c. in a 5" wide heat-welded base sheet side laps.
- Fastening #2:** Attach Soprafix or Soprafix Base 622 using Trufast #15 EHD Fasteners or Soprema #15 HD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2-3/8" Barbed XHD Plates with row spacing at a maximum 70.75" o.c. The fasteners are spaced 6" o.c. in a 4" or 5" wide heat-welded base sheet side laps.
- Fastening #3:** Attach Soprafix-e or Soprafix Base 641 using OMG Heavy-Duty fasteners with OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 70.75" o.c. The fasteners are spaced 6" o.c. in a 4" or 5" wide heat-welded base sheet side laps.



**Fastening #4:** Attach Soprafix [F] or Soprafix Base 613 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates or Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 70.75" o.c. The fasteners are spaced 6" o.c. in a 5" wide heat-welded base sheet side laps.

**Fastening #5:** Attach Soprafix [S] or Soprafix Base 612 using Trufast #15 EHD Fasteners or Soprema #15 HD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 70.75" o.c. The fasteners are spaced 6" o.c. in a 4" wide heat-welded base sheet side laps.

**Fastening #6:** Attach Soprafix [X] or Soprafix Base 614 using Dekfast 14 fasteners with Dekfast 2" Round Barbed Seam Plates, Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2" SB Stress Plates, Soprafix 2-3/8" SB Stress Plates or Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or OMG Heavy-Duty fasteners with OMG 2-3/8" Round Barbed Seam Plates or OMG 2" Barbed Plates with row spacing at a maximum 70.75" o.c. The fasteners are spaced 6" o.c. in a 6" wide heat-welded base sheet side laps.

**Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -60 psf. (See General Limitation #7)



**Membrane Type:** SBS

**Deck Type II:** Steel, Insulated

**Deck Description:** 18-22 ga., ASTM A1008/A1008M-01a SS Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum deck spans of 6 ft. o.c. Deck side laps are attached with Traxx/1 screws spaced 30" o.c.

**System Type D(2):** All layers of insulation and membrane simultaneously attached.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer:</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam II, Sopra-ISO s, ACFoam III, Sopra-ISO+ s, EnergyGuard POLYISO Insulation, EnergyGuard Ultra POLYISO Insulation, ENRGY 3, ENRGY 3 FR, ENRGY 3 AGF, ENRGY 3 CGF, H-Shield, Sopra-ISO r, M-Shield, H-Shield CG, Sopra-ISO+ r, Multi-Max FA-3, Sopra-ISO x (flat or tapered)</b>		
<b>Min. 1.5-inch</b>	N/A	N/A
<b>Top Insulation Layer (Optional):</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Fesco Board (flat or tapered)</b>		
<b>Homogeneous: Minimum 0.75" thick</b>	N/A	N/A
<b>Laminated: Minimum 1.5" thick</b>		
<b>Retro-Fit Board, DuraBoard, Structodek High Density Fiberboard Roof Insulation, FiberBase HD Excel, EnergyGuard HD POLYISO Insulation, EnergyGuard HD Plus POLYISO Insulation</b>		
<b>Minimum 0.5" thick</b>	N/A	N/A
<b>GreenGuard-PB6, GreenGuard-PB6W, GreenGuard-PB6 PLUS, GreenGuard-PB6FA, GreenGuard-PB38FA, GreenGuard-PB6FA90, GreenGuard-PB3890</b>		
<b>Minimum 0.375" thick</b>	N/A	N/A
<b>Dens Deck, Dens Deck Prime, SECUROCK Gypsum-Fiber Roof Board, Invinsa Roof Board, Invinsa FR Roof Board</b>		
<b>Minimum 0.25" thick</b>	N/A	N/A
<b>Sopraboard</b>		
<b>Minimum 0.125" thick</b>	N/A	N/A

**Note:** Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.



**Membrane:** One ply of Unilay fastened to the deck as described below:

**Fastening:** Soprema #14 MP with Soprafix 2 3/8 in SB Stress Plates spaced 12" o.c. within the minimum 5" wide, hot-air welded side laps.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -60 psf. (See General Limitation #7)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened to structural supports spaced a maximum of 6' o.c. with Tek/5 screws and spaced a maximum 6" o.c. at the supports. Side laps are fastened with Traxx/1 screws spaced maximum 24 in. o.c.

**System Type D(3):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum ¼" thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
H-Shield, M-Shield, Sopra-ISO r Minimum 1.5" thick	N/A	N/A

**Note:** Base layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix Base 611, Soprafix Base 610, Soprafix Base 630, Soprafix, Soprafix Base 622, Soprafix-e, Soprafix Base 641, Soprafix [F], Soprafix Base 613, Soprafix [S], Soprafix Base 612, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening #1:** Attach Soprafix Base 611 or Soprafix Base 630 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 4" wide heat-welded base sheet side laps.

**Fastening #2:** Attach Soprafix Base 611 or Soprafix Base 630 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 5" wide heat-welded base sheet side laps.

**Fastening #3:** Attach Soprafix Base 630 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 5" wide heat-welded base sheet side laps.



- Fastening #4:** Attach Soprafix Base 610 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates, Trufast 2" Barbed Metal Seam Plates or Soprema #15 HD Fasteners Soprema 2.4" Seam Plates, Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 4" wide heat-welded base sheet side laps.
- Fastening #5:** Attach Soprafix Base 610 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 5" wide heat-welded base sheet side laps.
- Fastening #6:** Attach Soprafix, Soprafix Base 622, Soprafix-e, Soprafix Base 641 using Trufast #15 EHD Fasteners or Soprema #15 HD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 4" or 5" wide heat-welded base sheet side laps.
- Fastening #7:** Attach Soprafix [F] or Soprafix Base 613 using Trufast #15 EHD Fasteners or Soprema #15 HD Fasteners with Trufast 2.4" Barbed Metal Seam Plates, Trufast 2" Barbed Metal Seam Plates, Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates, Dekfast 2" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates, Soprafix 2" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 5" wide heat-welded base sheet side laps.
- Fastening #8:** Attach Soprafix [S] or Soprafix Base 612 using Trufast #15 EHD Fasteners or Soprema #15 HD Fasteners with Trufast 2.4" Barbed Metal Seam Plates, Trufast 2" Barbed Metal Seam Plates, Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or OMG Heavy Duty fasteners with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 4" wide heat-welded base sheet side laps.
- Fastening #9:** Attach Soprafix [X] or Soprafix Base 614 using Trufast #15 EHD Fasteners or Soprema #15 HD Fasteners with Trufast 2.4" Barbed Metal Seam Plates, Trufast 2" Barbed Metal Seam Plates, Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates, Dekfast 2" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates, Soprafix 2" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 6" wide heat-welded base sheet side laps.

**Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -67.5 psf. (See General Limitation #7)

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., A1008 SS Grade 33, Type B steel deck fastened to ¼” thick steel structural supports spaced a maximum of 6’ o.c. with Traxx/5 fasteners and ¾” diameter steel washers spaced a maximum 6” o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 24 in. o.c.

**System Type D(4):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap’r, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum ¼” thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5” thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 1/8” thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix Base 611, Soprafix Base 610, Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening #1:** Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. in a 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -67.5 psf. See General Limitation #7.)*

**Fastening #2:** Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2.4” Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. in a 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -75 psf. See General Limitation #7.)*



**Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied. The 3” wide side laps of the cap sheets are torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** See Fastening Requirements above.



- Membrane:** SBS
- Deck Type 2I:** Steel, Insulated
- Deck Description:** 18-22 ga. (see fastening options), Type B, Grade 33 ksi steel deck fastened to ¼” thick steel structural supports spaced a maximum of 62”- 72” o.c. (see fastening options) with Traxx/5 fasteners and ¾” diameter steel washers spaced a maximum 6” o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 24 in. o.c.
- System Type D(5):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

- Fire Barrier:** Minimum ¼” thick DensDeck or DensDeck Prime, loose-laid. Minimum ½” thickness required if applying a vapor barrier.
- (Optional)**
- Vapor Barrier:** An FM approved vapor barrier approved for use with torch-adhered, self-adhered, hot asphalt or cold applied may be applied to the deck or over the base insulation layer.
- (Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5” thick	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
Sopraboard Minimum 1/8” thick	N/A	N/A
DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

- Base Sheet:** One layer of Soprafix Base 621, Soprafix, Soprafix Base 622, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 Sanded or Sopralene 250 SP fastened to the deck as described below:
- Fastening #1:** *(Min. 22 ga. Steel in max. 72” support span)*  
Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. and centered inside the 4” wide, torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -67.5 psf. See General Limitation #7.)*



**Fastening #2:** *(Min. 22 ga. Steel in max. 72" support span)*  
Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates with row spacing at a maximum 35.5" o.c. The fasteners are spaced 12" o.c. and centered inside the 4" wide, torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -75 psf. See General Limitation #7.)*

**Fastening #3:** *(Min. 18 ga. Steel in max. 72" support span; Min. 20 ga. Steel in max. 69" support span; Min. 22 ga. steel in max. 62" support span.)*  
Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates or Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Soprema 2.4" Seam Plates with row spacing at a maximum 35.5" o.c. The fasteners are spaced 6" o.c. and centered inside the 4" wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -112.5 psf. See General Limitation #7.)*

**Membrane:** Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 Ultra FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded or Soprastar Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or in COLPLY EF Adhesive, COLPLY Adhesive, COLPLY Modified Adhesive, FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square. The 3" wide side laps are adhered with the same adhesive or torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** See Fastening Requirements above.

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 80 ksi steel deck fastened to ¼” thick steel structural supports spaced a maximum of 6’ o.c. with Traxx/5 fasteners and ¾” diameter steel washers spaced a maximum 6” o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 12 in. o.c.

**System Type D(6):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Fire Barrier:** Minimum ¼” thick DensDeck or DensDeck Prime, loose-laid. Minimum ½” thickness required if applying a vapor barrier.

**(Optional)**

**Vapor Barrier:** An FM approved vapor barrier approved for use with torch-adhered, self-adhered, hot asphalt or cold applied may be applied to the deck or over the base insulation layer.

**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5” thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 1/8” thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix Base 621, Soprafix, Soprafix Base 622, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 Sanded or Sopralene 250 SP fastened to the deck as described below:

**Fastening #1:** Attach base sheet using Trufast #14 HD Fasteners with Trufast 2” Barbed Metal Seam Plates or Soprema #14 MP Fasteners with Soprema 2” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -67.5 psf. See General Limitation #7.)*



- Fastening #2:** Attach base sheet using Trufast #14 HD Fasteners with Trufast 2.4” Scoop Seam Plates or Soprema #14 MP Fasteners with Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -75 psf. See General Limitation #7.)*
- Fastening #3** Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2.4” Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -97.5 psf. See General Limitation #7.)*
- Fastening #4:** Attach base sheet using Trufast #14 HD or Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Seam Plates or Trufast 2.4” Scoop Seam Plates or Soprema #14 MP or Soprema #15 HD Fasteners with Soprema 2” Seam Plates or Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 6” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -120 psf. See General Limitation #7.)*
- Membrane:** Elastophene GR, Elastophene FR GR, Elastophene LS FR GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 FR+ GR, Sopralene 180 Ultra FR GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 Ultra FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded or Soprastar Sanded adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. or in COLPLY EF Adhesive, COLPLY Adhesive, COLPLY Modified Adhesive, FM Adhesive or FM Adhesive (VOC) at 1.5 – 2.0 gallons/square. The 3” wide side laps are adhered with the same adhesive or torch-applied.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** See Fastening Requirements above.

- Membrane:** SBS
- Deck Type 2I:** Steel, Insulated
- Deck Description:** 18-22 ga., A1008 or A653 Grade 80, Type B steel deck fastened to ¼” thick steel structural supports spaced a maximum of 6’ o.c. with Traxx/5 fasteners and ¾” diameter steel washers spaced a maximum 6” o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 12 in. o.c.
- System Type D(7):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

- Vapor Barrier:** Soprapap’r, self-adhered.  
**(Optional)**
- Fire Barrier:** Minimum ¼” thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5” thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 0.125” thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25” thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

- Base Sheet:** One layer of Soprafix Base 611, Soprafix Base 610, Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:
- Fastening #1:** Attach base sheet using Trufast #14 HD Fasteners with Trufast 2” Barbed Metal Seam Plates or Soprema #14 MP Fasteners with Soprema 2” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -67.5 psf. See General Limitation #7.)*
- Fastening #2:** Attach base sheet using Trufast #14 HD Fasteners with Trufast 2.4” Scoop Seam Plates or Soprema #14 MP Fasteners with Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -75 psf. See General Limitation #7.)*



- Fastening #3:** Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 6” o.c. in a 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -120 psf. See General Limitation #7.)*
- Fastening #4:** Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2.4” Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 6” o.c. in a 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -142.5 psf. See General Limitation #7.)*
- Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied. The 3” wide side laps of the cap sheets are torch-applied.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** See Fastening Requirements above.

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened to structural supports spaced a maximum of 6' o.c. with Tek/5 screws and spaced a maximum 6" o.c. at the supports. Side laps are fastened with Traxx/1 screws spaced maximum 24 in. o.c.

**System Type D(8):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap<sup>®</sup>, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum ¼" thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
H-Shield, M-Shield, Sopra-ISO r Minimum 1.5" thick	N/A	N/A

**Note:** Base layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X], Soprafix Base 614 fastened to the deck as described below:

**Fastening #1:** Attach using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 4" wide heat-welded base sheet side laps.

**Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -75 psf. (See General Limitation #7)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened to structural supports spaced a maximum of 6' o.c. with Tek/5 screws and spaced a maximum 6" o.c. at the supports. Side laps are fastened with Traxx/1 screws spaced maximum 24 in. o.c.

**System Type D(9):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum 1/4" thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
H-Shield, M-Shield, Sopra-ISO r Minimum 1.5" thick	N/A	N/A

**Note:** Base layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix Base 611, Soprafix Base 610, Soprafix, Soprafix Base 622, Soprafix-e, Soprafix Base 641, Soprafix [F], Soprafix Base 613, Soprafix [S], Soprafix Base 612, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening #1:** Attach Soprafix Base 611 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 4" or 5" wide heat-welded base sheet side laps. Or with Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 5" wide heat-welded base sheet side laps



- Fastening #2:** Attach Soprafix Base 610 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates, Soprema 2.4" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 4" wide heat-welded base sheet side laps. Or with Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates, or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 5" wide heat-welded base sheet side laps.
- Fastening #3:** Attach Soprafix or Soprafix Base 622 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 4" or 5" wide heat-welded base sheet side laps.
- Fastening #4:** Attach Soprafix-e or Soprafix Base 641 using Trufast #15 EHD Fasteners or Soprema #15 HD Fasteners with Trufast 2.4" Barbed Metal Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 4" or 5" wide heat-welded base sheet side laps.
- Fastening #5:** Attach Soprafix [F] or Soprafix Base 613 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates, Dekfast 2" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates, Soprafix 2" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 5" wide heat-welded base sheet side laps.
- Fastening #6:** Attach Soprafix [X] or Soprafix Base 614 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates, Dekfast 2" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates, Soprafix 2" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 6" wide heat-welded base sheet side laps.

- Fastening #7:** Attach Soprafix [S] and Soprafix Base 612 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or OMG Heavy-Duty fasteners with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 4" wide heat-welded base sheet side laps.
- Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** -82.5 psf. (See General Limitation #7)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga., 1.5 in. (38mm) deep, ASTM A653 or A1008 Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners at supports spaced maximum 6 ft. o.c. Side laps are fastened with Traxx/1 fasteners spaced 24" o.c.

**System Type D(10):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam-II, Sopra-ISO s, H-Shield, M-Shield, Sopra-ISO r (flat or tapered) Minimum 1.5" thick	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X], Soprafix Base 614, Soprafix-e or Soprafix Base 641, mechanically attached with OMG Polymer Batten Strip and OMG #15 Roofgrip Large Head fasteners, Trufast Recessed Batten Bar or Trufast Recessed Batten Bar and Trufast #15 EHD Fasteners or Soprafix MBB-R with Soprema #15 HD Fasteners, spaced 12" o.c. in the min. 5" lap.

\*Requires torch-applied ply or cap membrane.

**Ply Sheet:** One or more layers of Sopralene Flam 180, Colphene Flam 180, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250, Sopralene 250 SP, torch-applied.  
**(Optional)**

**Membrane:** SopraStar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -75 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. ASTM A653 or A1008 Grade 80 Steel decking fastened 6" o.c. with Traxx/5 fasteners to supports spaced maximum 6' o.c. Deck side laps are fastened 24" o.c. with Traxx/1 fasteners.

**System Type D(11):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam-II, Sopra-ISO s, H-Shield, M-Shield, Sopra-ISO r (flat or tapered) Minimum 1.5" thick	N/A	N/A
Fesco Board, Approved Perlite Insulation Minimum 0.75" thick	N/A	N/A

**Note:** Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix Base [X], Soprafix Base 614, Soprafix-e or Soprafix Base 641, fastened to the deck as described below:

**Fastening:** Attach base sheet using Trufast Recessed Batten Bar with Trufast #14 HD Fasteners or Soprafix MBB-R with Soprema #14 MP Fasteners spaced 12" o.c. in the minimum 5" wide lap.

**Ply Sheet:** One or more layers of Elastophene Flam\*, Elastophene Flam 2.2\*, Sopralene Flam 180\*, Colphene Flam 180\*, Sopralene Flam 250\*, Sopralene 180 SP 3.0, Sopralene 250 SP, torch-applied.  
 \*Requires torch-applied cap membrane.

**Membrane:** Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam FR+ GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -75 psf. (General Limitation #7)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga., Type B, ASTM A1008 SS Grade 80 steel deck with maximum deck spans of 6' o.c. secured with Traxx/5 screws spaced at every corrugation. Deck side laps are secured with two Traxx/1 fasteners evenly spaced between supports.

**System Type D(12):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Any Approved Insulation Listed in Table 2. Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Approved High Density Wood Fiberboard, Structodek High Density Fiberboard Roof Insulation Minimum ½" thick</b>	N/A	N/A
<b>DensDeck Minimum ¼" thick</b>	N/A	N/A
<b>Sopraboard Minimum 1/8" thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet (Optional):** Sopra G, Sopra IV or Sopra VI presecured to the deck with approved fasteners and plates spaced 24" o.c. in the minimum 3" wide lap

**Membrane:** One ply of UNILAY membrane fastened through the insulation to the deck using Dekfast 15 HS Fasteners with Dekfast Isofast IF-2.375-AT Plates, Dekfast Galvalume Steel Round 2-3/8" 20 ga. Barbed Plates or Soprema #15 Fasteners with Soprafix 2 3/8 in SB Stress Plates spaced 12" o.c. in a 5" wide lap. The side lap fastener row is encapsulated in the torch-applied lap.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -82.5 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., ASTM A1008 Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced 6 ft. o.c. Side laps are fastened with Traxx/1 fasteners spaced 30 in. o.c.

**System Type D(13):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
Any insulation listed in Table 2, flat or tapered.	N/A	N/A

**Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**

**Base Sheet:** Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X], Soprafix Base 614, Soprafix-e or Soprafix Base 641, mechanically attached with OMG Polymer Batten Strip and OMG #15 Roofgrip Large Head fasteners, Trufast Flat Batten Bar and Trufast #15 EHD Fasteners, Soprafix MBB-R and Soprema #15 Fasteners or Soprema #15 HD Fasteners, or SFS Dekfast Coiled Batten Bar and #15 Dekfast fasteners, spaced 12" o.c. in the min. 5" lap.

**Ply Sheet:** One or more layers of Sopralene Flam 180, Colphene Flam 180, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250, Sopralene 250 SP, torch-applied.  
**(Optional)**

**Membrane:** SopraStar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -97.5 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., ASTM A1008 Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced 6 ft. o.c. Side laps are fastened with Traxx/1 fasteners spaced 30 in. o.c.

**System Type D(14):** Membrane fastened over preliminarily fastened insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
Any insulation listed in Table 2, flat or tapered.	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X] or Soprafix Base 614, mechanically attached with OMG Polymer Batten Strip and OMG #15 Roofgrip Large Head fasteners, Trufast Flat Batten Bar and Trufast #15 EHD Fasteners, Soprema MBB-R batten bar and Soprema #15 Fasteners or Soprema #15 HD Fasteners, or SFS Dekfast Coiled Batten Bar and Dekfast 15 HS fasteners, spaced 12" o.c. in the min. 4" torch-applied lap.

**Ply Sheet:** One or more layers of Sopralene Flam 180, Colphene Flam 180, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250, Sopralene 250 SP, torch-applied.  
**(Optional)**

**Membrane:** SopraStar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -105 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18 ga. Type 3N, Grade 80 steel decking attached to minimum ½” thick, W14 x 43 purlins with an 8” wide top flange spaced maximum 9 ft. o.c. using ¾” puddle welds spaced 8” o.c. (every bottom flute). Two welds per attachment point, spaced 4” apart. Steel deck side laps are attached 24” o.c. with Traxx/1 fasteners.  
**System Type D(15):** Membrane fastened over preliminary fastened insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap<sup>®</sup>, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
ACFoam-II, Sopra-ISO s Minimum 1.5” thick	N/A	N/A

**Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**

**Base Sheet:** One layer of Soprafix [X], Soprafix Base 614 or Sopralene 250 Flam fastened through the insulation to the structural deck using Dekfast 15 HS fasteners or Soprema #15 Fasteners and 70-mm round plates spaced 16” o.c. in a 5” wide lap and 16” o.c. in one center row. The side lap fastener row is encapsulated in the torch-applied lap and the center row is stripped-in with an 8” wide strip of torch-applied membrane.

**Ply Sheet:**  
**(Optional)** One or more layers of Elastophene Flam, Elastophene Flam 2.2, Sopralene Flam 180, Colphene Flam 180, Sopralene Flam 250, Sopralene 180 SP 3.0, Sopralene 250 SP, torch-applied.

**Membrane:** Elastophene Flam GR, Elastophene Flam FR GR, Elastophene Flam FR+ GR, Elastophene Flam LS FR GR, SopraStar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
 Surfacing is Required for smooth or sanded surfaced field cap membranes.  
 Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
 Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -112.5 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., A1008 SS Grade 33, Type B steel deck fastened to ¼” thick steel structural supports spaced a maximum of 6’ o.c. with Traxx/5 fasteners and ¾” diameter steel washers spaced a maximum 6” o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 12 in. o.c.

**System Type D(16):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap’r, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum ¼” thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5” thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 1/8” thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix Base 611, Soprafix Base 610, Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening:** Attach base sheet using Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Seam Plates or Trufast 2.4” Scoop Seam Plates or Soprema #15 HD Fasteners with Soprema 2” Seam Plates or Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 6” o.c. in a 4” wide torch-applied base sheet side laps.



**Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied. The 3" wide side laps of the cap sheets are torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -112.5 psf. (See General Limitation #7.)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. ASTM A1008 Grade 80 steel deck fastened 6" o.c. with Traxx/5 fasteners to supports spaced 6 ft. o.c. Side laps are fastened with Traxx/1 fasteners spaced 30 in. o.c.  
**System Type D(17):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft <sup>2</sup>
Any insulation listed in Table 2, flat or tapered.	N/A	N/A

**Note: Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**

**Base Sheet:** One layer of Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X] or Soprafix Base 614, mechanically attached with OMG Polymer Batten Strip and OMG #15 Roofgrip Large Head fasteners, Trufast Flat Batten Bar and Trufast #15 EHD Fasteners, Soprema MBB-R Batten Bar and Soprema #15 Fasteners or Soprema #15 HD Fasteners, or SFS Dekfast Coiled Batten Bar and Dekfast 15 HS fasteners, spaced 6" o.c. in every other minimum 4" torch-applied lap. Intermediate, non-fastened laps are 3" wide and torch-applied.

**Ply Sheet:** One or more layers of Sopralene Flam 180, Colphene Flam 180, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Soprafix, Soprafix Base 622, Sopralene Flam 250, Sopralene 250 SP, torch-applied.  
**(Optional)**

**Membrane:** SopraStar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -120 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., A1008 or A653 Grade 80 ksi steel deck fastened to ¼” thick steel structural supports spaced a maximum of 6’ o.c. with Traxx/5 fasteners spaced a maximum 6” o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 12 in. o.c.

**System Type D(18):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap’r, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum ¼” thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5” thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 0.125” thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25” thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix Base 611, Soprafix Base 610, Soprafix, Soprafix Base 622, Soprafix [S], Soprafix Base 612, Soprafix [F], Soprafix Base 613, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening #1:** Attach base sheet using Trufast #14 HD Fasteners and Soprema #14 MP Fasteners with Trufast 2” Barbed Metal Seam Plates and Soprema 2” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 6” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -120 psf. See General Limitation #7.)*



- Fastening #2:** Attach base sheet using Trufast #14 HD Fasteners with Trufast 2.4” Scoop Seam Plates or Soprema #14 MP Fasteners with Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 6” o.c. and centered inside the 4” wide torch-applied base sheet side laps.  
*(Meets Maximum Design Pressure of -135 psf. See General Limitation #7.)*
- Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, SopraStar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied. The 3” wide side laps of the cap sheets are torch-applied.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** See Fastening Requirements above.

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., Type B, Grade 33 steel deck fastened to structural supports spaced a maximum of 6' o.c. with Tek/5 screws and spaced a maximum 6" o.c. at the supports. Side laps are fastened with Traxx/1 screws spaced maximum 24 in. o.c.

**System Type D(19):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum 1/4" thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>H-Shield, M-Shield, Sopra-ISO r Minimum 1.5" thick</b>	N/A	N/A

**Note:** Base layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix [F], Soprafix Base 613, Soprafix [S], Soprafix Base 612, Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening #1:** Attach Soprafix [F] or Soprafix Base 613 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or OMG Heavy-Duty fasteners with OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 5" wide heat-welded base sheet side laps.

**Fastening #2:** Attach Soprafix [S] or Soprafix Base 612 using Trufast #15 EHD Fasteners with Trufast 2" Barbed Metal Seam Plates, Trufast 2.4" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2" Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates or OMG Heavy-Duty fasteners with OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 34" o.c. The fasteners are spaced 6" o.c. in a 4" wide heat-welded base sheet side laps.



- Fastening #3:** Attach Soprafix [X] or Soprafix Base 614 using Trufast #15 EHD Fasteners with Trufast 2.4" Scoop Seam Plates, Trufast 2" Barbed Metal Seam Plates or Soprema #15 HD Fasteners with Soprema 2.4" Seam Plates, Soprema 2" Seam Plates or Dekfast 14 fasteners with Dekfast 2-3/8" Round Barbed Seam Plates, Dekfast 2" Round Barbed Seam Plates or Soprema #14 Fasteners with Soprafix 2-3/8" SB Stress Plates, Soprafix 2" SB Stress Plates or OMG Heavy-Duty with OMG 2" Barbed Plates or OMG 2-3/8" Round Barbed Seam Plates with row spacing at a maximum 35" o.c. The fasteners are spaced 12" o.c. in a 5" or 6" wide heat-welded base sheet side laps.
- Membrane:** Soprafix Cap FR-651, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, torch-applied.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** -142.5 psf. (See General Limitation #7)

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. A653 or A1008 Grade 33 Steel decking fastened 6" o.c. with two Traxx/5 fasteners and 0.75" diameter washers to supports spaced maximum 6" o.c. Deck side laps are fastened maximum 13" o.c. with Traxx/1 fasteners.

**System Type D(20):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap'r, self-adhered.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, H-Shield, M-Shield, Sopra-ISO r, ENRGY 3, ISO 95+ GL, Multi-Max-3 (flat or tapered) Minimum 1.5" thick</b>	N/A	N/A
<b>Middle Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>DensDeck (staggered from base layer) Minimum 0.5" thick</b>	N/A	N/A
<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 0.25" thick</b>	1 (#14)	1:4 ft <sup>2</sup>

**Note: Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**

**Base Sheet:** One layer of Soprafix [X], Soprafix Base 614 or Sopralene Flam 250, torch-applied to insulation with a minimum 6" wide lap, then fastened to the deck as described below:

**Fastening #1:** Attach base sheet using Dekfast 15 HS and Soprema #15 Fasteners with Dekfast 2-3/8" Round Barbed Seam Plates and Soprafix 2-3/8" SB Stress Plates in rows spaced maximum 18" o.c., with fasteners spaced maximum 6" o.c. within each row.

**Fastening #2:** Attach base sheet using Dekfast 15 HS and Soprema #15 Fasteners with Dekfast 2-3/8" Round Barbed Seam Plates and Soprafix 2-3/8" SB Stress Plates in rows spaced maximum 12" o.c., with fasteners spaced maximum 12" o.c. within each row.

**Ply Sheet:** Sopralene Flam 180, Colphene Flam 180, Sopralene Flam 250, torch-applied with minimum 3" wide lap.

**Membrane:** Soprastar Flam, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied with minimum 3” wide lap.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system

**Maximum Design Pressure:** -157.5 psf. (See General Limitation #7)



**Membrane:** SBS  
**Deck Type 2I:** Steel, Insulated  
**Deck Description:** 18-22 ga. ASTM A653/A653-01a SS Grade 33 Steel decking fastened maximum 6" o.c. with two Traxx/5 fasteners and 0.75" diameter washers to supports spaced maximum 6" o.c. Deck side laps are fastened maximum 12" o.c. with Traxx/1 fasteners.  
**System Type D(21):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Fire Barrier:** Minimum 5/8" thick SECUROCK Gypsum-Fiber Roof Board, DensDeck, (Optional) DensDeck Prime or DensDeck DuraGuard Roof Board, pre-secured with a maximum contributory area of 1:4 ft<sup>2</sup>

**Vapor Barrier:** One or more layers of Elastophene Sanded, Colphene Sanded, Elastophene (Optional) Sanded 3.0, Elastophene HS, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded, Sopralene 250 Sanded, Elastophene PS, Elastophene 180 PS, Colphene 180 PS, Sopralene 180 PS 2.2, adhered in hot asphalt at 25 lbs./sq. or applied in FM Adhesive, FM Adhesive (VOC), COLPLY Adhesive, COLPLY Modified Adhesive or Sopraprstar Adhesive at a rate of 1.5 gal./sq.  
 Or  
 One or two layers of Sopra IV or Sopra VI adhered in hot asphalt at 25 lbs./sq.  
 Or  
 Soprapr, self-adhered.  
 Or  
 Elastophene Flam, Elastophene Flam 2.2, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Elastophene Flam HS, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, Sopralene Flam 180, Colphene Flam 180 or Sopralene Flam 250, torch-applied.

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
ACFoam-II, Sopra-ISO s, ISO 95+ GL, H-Shield, ENRGY 3, Multi-Max-3, M-Shield, Sopra-ISO r Minimum 1.5" thick	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
SECUROCK Gypsum-Fiber Roof Board, DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board Minimum 0.5" thick	2, 3, 10, 46, 47	1:4 ft <sup>2</sup>

**Note: Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**

**Primer:** Coverboard is primed with an approved ASTM D41 asphalt primer at a rate of (Optional) 100-150 ft<sup>2</sup>/gal.



- Base Sheet:** One layer of Sopralene Flam 180, Colphene Flam 180, Sopralene Flam 250, Soprafix, Soprafix Base 622, Soprafix [F], Soprafix Base 613, Soprafix [S], Soprafix Base 612, Soprafix [X], Soprafix Base 614, Soprafix-e, Soprafix Base 641, Soprafix Base 610\*, Soprafix Base 611\* fastened as specified below.  
\*For use only when using 2 in. diameter plates.
- Fastening #1:** Torch-applied base membrane to the coverboard with minimum 3” laps. Mechanically attach torch-applied base sheet with Soprema #14 fasteners or Soprema #15 fasteners and Soprema Soprafix 2” SB Stress Plates or Soprafix 2-3/8 in. SB Stress Plates, Dekfast 14 or Dekfast 15 HS fasteners with Dekfast IF-2-SB or Dekfast Galvalume Steel Round 2-3/8” 20 ga. Barbed plates, Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Stress Plates or Trufast 2.4” Barbed Metal Seam Plates, Soprema #15 HD Fasteners with Soprema 2” Seam Plates spaced maximum 12” o.c. through the side laps and two equally spaced staggered rows in the field of the membrane.  
*(Maximum Design Pressures –165 psf. See General Limitation #7.)*
- Fastening #2** Mechanically attach base sheet with Soprema #14 fasteners or Soprema #15 fasteners and Soprema Soprafix 2” SB Stress Plates or Soprafix 2-3/8 in. SB Stress Plates, Dekfast 14 or Dekfast 15 HS fasteners with Dekfast IF-2-SB, Dekfast Galvalume Steel Round 2-3/8” 20 ga. Barbed plates, Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Stress Plates or Trufast 2.4” Barbed Metal Seam Plates, Soprema #15 HD Fasteners with Soprema 2” Seam Plates, spaced maximum 12” o.c. through the minimum 3” wide side lap and two equally spaced staggered rows in the field of the membrane.  
*(Maximum Design Pressures –150 psf. See General Limitation #7.)*
- Ply Sheet:** Elastophene Flam, Elastophene Flam 2.2, Elastophene Flam HS, Sopralene Flam 180, Colphene Flam 180, Sopralene Flam 250, torch-applied.
- Membrane:** Elastophene Flam FR GR, Elastophene Flam GR, Elastophene Flam LS FR GR, Sopralast 50 TV Alu, SopraStar Flam, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR+ GR, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** See Fastening Options Above

**Membrane:** SBS

**Deck Type 2I:** Steel Insulated

**Deck Description:** 18-22 ga. ASTM A653/A653-01a SS Grade 33 Steel decking fastened maximum 6" o.c. with two Traxx/5 fasteners and 0.75" diameter washers to supports spaced maximum 6" o.c. Deck side laps are fastened maximum 12" o.c. with Traxx/1 fasteners.

**System Type D(22):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Fire Barrier:** Minimum 5/8" thick SECUROCK Gypsum-Fiber Roof Board, DensDeck, (Optional) DensDeck Prime or DensDeck DuraGuard Roof Board, pre-secured with a maximum contributory area of 1:4 ft<sup>2</sup>

**Vapor Barrier:** One or more layers of Elastophene Sanded, Colphene Sanded, Elastophene (Optional) Sanded 3.0, Elastophene HS, Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Sopralene 180 Sanded, Sopralene 250 Sanded, Elastophene PS, Elastophene 180 PS, Colphene 180 PS, Sopralene 180 PS 2.2, adhered in hot asphalt at 25 lbs./sq. or applied in FM Adhesive, FM Adhesive (VOC), COLPLY Adhesive, COLPLY Modified Adhesive or Soprarstar Adhesive at a rate of 1.5 gal./sq.  
 Or  
 One or two layers of Sopra IV or Sopra VI adhered in hot asphalt at 25 lbs./sq.  
 Or  
 Sopravap'r, self-adhered.  
 Or  
 Elastophene Flam, Elastophene Flam 2.2, Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Elastophene Flam HS, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, Sopralene Flam 180, Colphene Flam 180 or Sopralene Flam 250, torch-applied.

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, H-Shield, ENRGY 3, Multi-Max-3, M-Shield, Sopra-ISO r</b>		
<b>Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>SECUROCK Gypsum-Fiber Roof Board, DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board</b>		
<b>Minimum 0.5" thick</b>	2, 21, 3, 11 or 12	1:4 ft <sup>2</sup>

**Note: Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**



- Primer:** Coverboard is primed with an approved ASTM D41 asphalt primer at a rate of 100-150 ft<sup>2</sup>/gal.  
**(Optional)**
- Base Sheet:** One Layer of Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, fastened as specified below:
- Fastening #1:** Torch-applied base sheet to coverboard with minimum 3” wide side lap. Mechanically attach torch-applied base sheet with Soprema #14 or Soprema #15 fasteners and Soprema Soprafix 2” SB Stress plates, Dekfast 14 or Dekfast 15 HS fasteners with Dekfast IF-2-SB, Dekfast Galvalume Steel Round 2-3/8” 20 ga. Barbed plates, Trufast#15 EHD Fasteners with Trufast 2” Barbed Metal Stress Plates or Trufast 2.4” Barbed Metal Seam Plates, Soprema #15 HD Fasteners with Soprema 2” Seam Plates or Soprafix 2-3/8” –SB Stress Plates, spaced maximum 12” o.c. through the side laps and two equally spaced staggered rows in the field of the membrane.  
*(Maximum Design Pressures –165 psf. See General Limitation #7.)*
- Fastening #2** Mechanically attach torch-applied base sheet with Soprema #14 or Soprema #15 fasteners and Soprema Soprafix 2” SB Stress plates, Dekfast 14 or Dekfast 15 HS fasteners with Dekfast IF-2-SB, Dekfast Galvalume Steel Round 2-3/8” 20 ga. Barbed plates, Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Stress Plates or Trufast 2.4” Barbed Metal Seam Plates, Soprema #15 HD Fasteners with Soprema 2” Seam Plates or Soprafix 2-3/8” –SB Stress Plates, spaced maximum 12” o.c. through the minimum 3” wide side lap and two equally spaced staggered rows in the field of the membrane.  
*(Maximum Design Pressures –150 psf. See General Limitation #7.)*
- Ply Sheet:** Elastophene 180 PS, Colphene 180 PS, Sopralene 180 PS 2.2, Elastophene PS, Elastophene PS 3.0, adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.
- Membrane:** Elastophene Flam FR GR, Elastophene Flam GR, Elastophene Flam LS FR GR, Sopralast 50 TV Alu, Soprastar Flam, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Sopralene Flam Antirock, torch-applied with minimum 3” wide side lap.
- Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications. Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.
- Maximum Design Pressure:** See Fastening Options Above

**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga. ASTM A653/A653-01a SS Grade 33 Steel decking fastened maximum 6" o.c. with two Traxx/5 fasteners and 0.75" diameter washers to supports spaced maximum 6' o.c. Deck side laps are fastened maximum 12" o.c. with Traxx/1 fasteners.

**System Type D(23):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
(Optional)

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
ACFoam-II, Sopra-ISO s, ISO 95+ GL, H-Shield, ENRGY 3, Multi-Max-3, M-Shield, Sopra-ISO r Minimum 1.5" thick	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density.**

<b>Top Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
SECUROCK Gypsum-Fiber Roof Board, DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board Minimum 0.5" thick	2, 21, 3, 11, 12	1:4 ft <sup>2</sup>

**Note: Insulation layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.**

**Primer:** Coverboard is primed with an approved ASTM D41 asphalt primer at a rate of 100-150 ft<sup>2</sup>/gal.  
(Optional)

**Base Sheet:** One layer of Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, Soprafix [F]\*, Soprafix Base 613\*, Soprafix [S]\*, Soprafix Base 612\*, Soprafix [X]\*, Soprafix Base 614\*, Soprafix\*, Soprafix Base 622\*, Soprafix-e, Soprafix Base 641, Soprafix Base 610\*\*, Soprafix Base 611\*\*, Soprafix Base 630\*\* torch-applied to coverboard.  
\*Requires torch-applied cap membrane.  
\*\* For use only when using 2 in. diameter plates and requires torch-applied cap membrane.



**Fastening #1:** Torch-applied base sheet to coverboard with minimum 3” wide side lap. Mechanically attach torch-applied base sheet with Soprema #14 fasteners or Soprema #15 fasteners and Soprema Soprafix 2” SB Stress Plates or Soprafix 2-3/8 in. SB Stress Plates, Dekfast 14 or Dekfast 15 HS fasteners with Dekfast IF-2-SB, Dekfast Galvalume Steel Round 2-3/8” 20 ga. Barbed plates, Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Stress Plates or Trufast 2.4” Barbed Metal Seam Plates, Soprema #15 HD Fasteners with Soprema 2” Seam Plates, spaced maximum 12” o.c. through the side laps and two equally spaced staggered rows in the field of the membrane.  
*(Maximum Design Pressures –165 psf. See General Limitation #7.)*

**Fastening #2** Mechanically attach base sheet with Soprema #14 fasteners or Soprema #15 fasteners and Soprema Soprafix 2” SB Stress Plates or Soprafix 2-3/8 in. SB Stress Plates, Dekfast 14 Dekfast 15 HS fasteners with Dekfast IF-2-SB, Dekfast Galvalume Steel Round 2-3/8” 20 ga. Barbed plates, Trufast #15 EHD Fasteners with Trufast 2” Barbed Metal Stress Plates or Trufast 2.4” Barbed Metal Seam Plates, Soprema #15 HD Fasteners with Soprema 2” Seam Plates spaced maximum 12” o.c. through the minimum 3” wide side lap and two equally spaced staggered rows in the field of the membrane.  
*(Maximum Design Pressures –150 psf. See General Limitation #7.)*

**Ply Sheet:** Elastophene SP 2.2, Colphene SP 2.2, Elastophene SP 3.0, Colphene SP 3.0, Sopralene 180 SP 3.0, Sopralene 180 SP 3.5, Colphene 180 SP 3.5, Sopralene 250 SP, torch-applied.

Or

Elastophene 180 Sanded, Colphene 180 Sanded, Sopralene 180 Sanded 2.2, Soprabase, Elastophene HS, Elastophene Sanded, Elastophene Sanded 3.0, Elastophene HS 62, Colphene Sanded, Sopralene 180 Sanded, Sopralene 250 Sanded, or 1-2 plies of Sopra IV or Sopra VI, adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Membrane:** Elastophene FR GR, Elastophene GR, Elastophene LS FR GR, Sopralene 180 FR GR, Colphene 180 FR GR, Sopralene 180 Ultra FR GR, Sopralene 180 FR+ GR, Sopralene 250 FR GR, Colphene 250 FR GR, Sopralene 250 Ultra FR GR, Sopralene 250 FR+ GR, Sopralast 50 TV Alu Sanded or Soprastar Sanded adhered in full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes. Surfacing is Required for smooth or sanded surfaced field cap membranes. Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.

Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** See Fastening Options Above



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., A1008 or A653 Grade 80 ksi steel deck fastened to ¼” thick steel structural supports spaced a maximum of 6’ o.c. with Traxx/5 fasteners spaced a maximum 6” o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 12 in. o.c.

**System Type D(24):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Soprapap’r, self-adhered.  
(Optional)

**Fire Barrier:** Minimum ¼” thick DensDeck or DensDeck Prime, loose-laid.  
(Optional)

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5” thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 1/8” thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum ¼” thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening:** Attach base sheet using Trufast #15 EHD Fasteners and Soprema #15 HD Fasteners with Trufast 2.4” Scoop Seam Plates and Soprema 2.4” Seam Plates with row spacing at a maximum 35.5” o.c. The fasteners are spaced 12” o.c. and centered inside the 4” wide torch-applied base sheet side laps.

**Membrane:** Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, Soprastar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied. The 3” wide side laps of the cap sheets are torch-applied.



**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -97.5 psf. (See General Limitation #7.)



**Membrane:** SBS

**Deck Type 2I:** Steel, Insulated

**Deck Description:** 18-22 ga., A1008 or A653 Grade 80, Type B steel deck fastened to 1/4" thick steel structural supports spaced a maximum of 6' o.c. with Traxx/5 fasteners and 3/4" diameter steel washers spaced a maximum 6" o.c. at the supports. Side laps are fastened with Traxx/1 fasteners spaced 12 in. o.c.

**System Type D(25):** Membrane fastened over preliminarily secured insulation.

**All General and System Limitations apply.**

**Vapor Barrier:** Sopravap'r, self-adhered.  
**(Optional)**

**Fire Barrier:** Minimum 1/4" thick DensDeck or DensDeck Prime, loose-laid.  
**(Optional)**

One or more layers of any of the following insulations.

<b>Base Insulation Layer</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>ACFoam-II, Sopra-ISO s, ISO 95+ GL, Multi-Max-3, H-Shield, M-Shield, Sopra-ISO r Minimum 1.5" thick</b>	N/A	N/A
<b>Top Insulation Layer (Optional)</b>	<b>Insulation Fasteners (Table 3)</b>	<b>Fastener Density/ft<sup>2</sup></b>
<b>Sopraboard Minimum 1/8" thick</b>	N/A	N/A
<b>DensDeck, DensDeck Prime, DensDeck DuraGuard Roof Board, SECUROCK Gypsum-Fiber Roof Board Minimum 1/4" thick</b>	N/A	N/A

**Note:** Top layer shall have preliminary attachment, prior to the installation of the base/anchor sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See base/anchor sheet below for fasteners and density.

**Base Sheet:** One layer of Soprafix [X] or Soprafix Base 614 fastened to the deck as described below:

**Fastening:** Attach base sheet using Trufast #15 EHD Fasteners and Soprema #15 HD Fasteners with Trufast 2.4" Scoop Seam Plates and Soprema 2.4" Seam Plates with row spacing at a maximum 35.5" o.c. The fasteners are spaced 6" o.c. and centered inside the 4" wide torch-applied base sheet side laps.

**Membrane:** Sopralene Flam 180 GR, Colphene Flam 180 GR, Sopralene Flam 180 GR 3.5, Sopralene Flam 180 FR GR, Colphene Flam 180 FR GR, Sopralene Flam 180 FR GR 3.5, Sopralene Flam 180 Ultra FR GR, Sopralene Flam 180 FR+ GR, Sopralene Flam 250 FR GR, Colphene Flam 250 FR GR, Sopralene Flam 250 Ultra FR GR, Sopralene Flam 250 FR+ GR, SopraStar Flam, Sopralast 50 TV Alu, Sopralene Flam Antirock, Soprafix Cap FR-651, torch-applied. The 3" wide side laps of the cap sheets are torch-applied.



**Surfacing:** Surfacing is Optional on granular surfaced field cap membranes.  
Surfacing is Required for smooth or sanded surfaced field cap membranes.  
Refer to Underwriters Laboratories or Intertek Testing Services listings for applicable fire classifications.  
Apply any coating listed in Table 4 above, or any Miami-Dade approved coating system.

**Maximum Design Pressure:** -172.5 psf. (See General Limitation #7.)



## STEEL DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.
2. For steel deck application where specific deck construction is not referenced: The deck shall be a minimum 22 gage attached with 5/8" puddle welds with weld washers at every flute with maximum deck spans of 5 ft. o.c.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.: 14-0603.08  
Expiration Date: 03/01/16  
Approval Date: 12/31/14  
Page 97 of 97