



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/economy

GAF
1 Campus Drive
Parsippany, NJ 07054

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: EverGuard® 1121 Bonding Adhesive

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 13-0603.14 and consists of pages 1 through 3.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 15-0128.04
Expiration Date: 05/10/15
Approval Date: 03/19/15
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cements, Adhesives and Coatings
Material: Various

SCOPE:

This approves **EverGuard® 1121 Bonding Adhesives**, as described in this Notice of Acceptance. The use of this acceptance is limited to those roof assemblies where EverGuard® 1121 Bonding Adhesive is specifically listed as an accepted component.

PRODUCT DESCRIPTION:

Property	Standard	Result
EverGuard® 1121 Bonding Adhesive		
Peel Adhesion	ASTM D 903	1.556 lbf/in
Tensile	ASTM D 412	256.4 psi.
Shear Strength	ASTM D 6383	53.82 lb/in.
Water Absorption	ASTM D 570	0.25%

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Specification</u>	<u>Date</u>
Momentum Technologies, Inc.	EX15F4A	ASTM D 903 ASTM D 412 ASTM D 6383 ASTM D 570	07/07/04

MANUFACTURING LOCATION:

1. Ashland, OH.

LIMITATIONS:

1. EverGuard® 1121 Bonding Adhesive shall have a quality control testing program by an approved independent listing agency having unannounced follow-up visits. Follow up test results shall be made available to Miami-Dade County Product Control upon request.
2. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 9N-3 of the Florida Administrative Code.

INSTALLATION:

EverGuard® 1121 Bonding Adhesive shall be installed in strict compliance with the roof assembly's assemblies Notice of Acceptance, and manufacturer's published literature.



NOA No.: 15-0128.04
Expiration Date: 05/10/15
Approval Date: 03/19/15
Page 2 of 3

BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or the applicable Building Code in order to properly evaluate the installation of this system. This Notice of Acceptance on its own cannot be used to obtain a building permit.

LABELING:

EverGuard® 1121 Bonding Adhesive shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE

