



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

GAF
1 Campus Drive
Parsippany, NJ 07054

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: GAF EverGuard® TPO Single Ply Roofing Systems over Cementitious Wood Fiber Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 13-0603.06 and consists of pages 1 through 7.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 15-0203.18
Expiration Date: 09/14/15
Approval Date: 05/07/15
Page 1 of 7

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Single Ply Roofing
Material:	TPO
Deck Type:	Cementitious Wood Fiber
Maximum Design Pressure	-375 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard® TPO	Various	ASTM D 6878	Thermoplastic Olefin reinforced membrane.
EverGuard® Extreme™ TPO	Various	ASTM D 6878	Thermoplastic Olefin reinforced membrane.
EverGuard® Coated Metal	4' x 10' sheets	Proprietary	24 guage steel with 25 mil thick TPO membrane film.
EverGuard® TPO Cover Tape	6" x 100'	Proprietary	30 mil TPO membrane laminated to white butyl tape.
EverGuard® TPO Detailing Membrane	24" x 50'	Proprietary	55 mil thick reinforced TPO membrane.
EverGuard® TPO Flashing Membrane	Various	Proprietary	Reinforced flashing membrane.
EverGuard® TPO Pourable Sealer Pocket	9" x 6" x 4" oval with 3" base flange	Proprietary	Pourable sealer pocket is molded with TPO compound to a nominal 70 mil thickness.
EverGuard® TPO RTA (Roof Transition Anchor) Strip™	6" x 100' roll	Proprietary	Reinforced TPO membrane with pressure sensitive adhesive.
EverGuard® TPO Split Pipe Boot	Various	Proprietary	45 mil thick reinforced TPO membrane split to accommodate most common pipes and conduits.
EverGuard® TPO Square Tube Wrap	Various	Proprietary	Square tube wraps are fabricated from 45 mil thick reinforced TPO membrane.
EverGuard® TPO Corner Curb Wrap	Various	Proprietary	Corners are fabricated from 45 mil thick reinforced TPO membrane.
EverGuard® TPO Scupper	4" x 6" x 12" 8" x 10" x 12"	Proprietary	TPO coated metal 55 mil unreinforced membrane.
EverGuard® TPO T-Joint Cover Patch	100 patches per box	Proprietary	55 mil thick unreinforced membrane.
EverGuard® TPO Vent	2 vents per carton	Proprietary	Vent manufactured out of reinforced 45 mil TPO membrane and galvanized steel.



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
EverGuard® TPO T-Top Vent	4" or 6"	Proprietary	Vent manufactured out of reinforced 45 mil TPO membrane and galvanized steel.
EverGuard® TPO Walkway Rolls	Rolls 1/8"x30"x50'	Proprietary	Standard duty walkway rolls with herringbone traction.
EverGuard® TPO Inside Corner	6" x 6" x 5¼"	Proprietary	Inside corners of base and curb flashings.
EverGuard® TPO Universal Corner	Various	Proprietary	Universal corner accommodates both inside and outside corners of bas and curb flashings.
EverGuard® TPO Vent Boot	1" - 6" o.d. 6 pcs. Crtn.	Proprietary	Vent pipe boots.
EverGuard® TPO Expansion Joint Cover	Various	Proprietary	60 mil thick TPO reinforced membrane, heat weldable, joint cover.
EverGuard® TPO Standing Seam Tape	6"	Proprietary	TPO white cover tape.
EverGuard® TPO Cut Edge Sealant	1 quart squeeze tube	Proprietary	Solvent based sealant for TPO cut edges.
EverGuard® TPO Drain	Various	Proprietary	Spun aluminum drain preflashed with 55 mil. unreinforced TPO membrane.
EverGuard® TPO Fluted Corner	8" diameter nominal .05" non-reinforced	Proprietary	Flashing outside corners of base and curb flashing.
EverGuard® TPO Seam Cleaner	1 gallon	Proprietary	Solvent-based seam cleaner.
EverGuard® WB181 Bonding Adhesive	5 gallons	Proprietary	Water-based rubberized adhesive for fully adhered systems and membrane flashing.
EverGuard® 1121 Bonding Adhesive	5 gallons	Proprietary	Adhesive for fully adhered systems and membrane flashing.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
EnergyGuard™ RA Polyiso Insulation	Polyisocyanurate foam insulation	GAF

APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	N/A	N/A	N/A	N/A

EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Underwriters Laboratory, Inc.	03CA38009	UL 790	01/21/04
	09CA55838	R1306	11/04/10
IRT-ARCON, Inc.	02-026	TAS 114	07/26/02
	04-019	TAS 114	04/26/04
Factory Mutual Research Corp.	FMRC 4470	3020588	03/24/04
		3031350	09/27/07
Factory Mutual Research Corp.	FMRC 4470	3013788	01/10/03
Exterior Research & Design, LLC	01881.11.03-2	TAS 114	11/26/03
	18029.12.02-1	TAS 131	12/16/02
Atlantic & Caribbean Roof Consulting, LLC	11-016	TAS -114-95	04/07/11
	11-017		04/07/11
PRI Construction Technologies Materials LLC	GAF-289-02-01	ASTM D 6878 TAS 131	09/07/11



APPROVED ASSEMBLIES:

Membrane Type: TPO

Deck Type 5: Cementitious Wood Fiber Deck, Insulated

Deck Description: Cementitious Wood Fiber Deck (Tectum)

System Type A(1): Membrane adhered to adhered insulation

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers each of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
EnergyGuard™ RA Polyiso Insulation Minimum 1" thick	N/A	N/A

Note: Insulation layers shall be adhered to the deck using Olybond 500® or Olybond 500® Green applied in 1" wide beads spaced 12" o.c. Insulation panels listed are minimum sizes and dimensions. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: One ply of EverGuard® TPO or EverGuard® Extreme™ TPO fully adhered to the insulation with EverGuard® #1121 Bonding Adhesive applied at a total rate of 1.67 gal. /sq. Apply half to the insulation and half to the underside of the membrane, roll with a weighted roller. Apply a minimum of 1½" wide heat weld in the side lap of the sheets.

Maximum Design

Pressure: -375 psf. (See General limitation #9)



Membrane Type: TPO

Deck Type 5: Cementitious Wood Fiber Deck, Insulated

Deck Description: Cementitious Wood Fiber Deck (Tectum)

System Type A(2): Membrane adhered to adhered insulation

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers each of the following insulations.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
EnergyGuard™ RA Polyiso Insulation Minimum 1" thick	N/A	N/A

Note: Insulation layers shall be adhered to the deck using Olybond 500® or Olybond 500® Green applied in 1" wide beads spaced 12" o.c . Insulation panels listed are minimum sizes and dimensions. Please refer to Roofing Application Standard RAS 117 for insulation attachment requirements.

Membrane: One ply of EverGuard® TPO or EverGuard® Extreme™ TPO adhered to the insulation with EverGuard® WB181 Bonding Adhesive applied at a total rate of 0.84 gal./sq. half applied to the insulation and half applied to the underside of the membrane. Allow it to become tacky to the touch before applying the roof cover to the substrate. Roll with a weighted roller. Apply a minimum of 1½" wide heat weld in the side lap of the sheets.

Maximum Design Pressure: -187.5 psf. (See General limitation #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

