



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

Sika Sarnafil, A Division of Sika Corp.  
100 Dan Road  
Canton, MA 02021

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Sika Sarnafil PVC Single Ply Roofing over Concrete Deck

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 14-0624.12 and consists of pages 1 through 98.  
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 15-0731.11  
Expiration Date: 07/05/21  
Approval Date: 06/30/16  
Page 1 of 98

## ROOFING SYSTEM APPROVAL

|                                 |            |
|---------------------------------|------------|
| <b>Category:</b>                | Roofing    |
| <b>Sub-Category:</b>            | Single Ply |
| <b>Material:</b>                | PVC        |
| <b>Deck Type:</b>               | Concrete   |
| <b>Maximum Design Pressure:</b> | -615 psf.  |

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

| <u>Product</u>                         | <u>Dimensions</u>      | <u>Test Specification</u> | <u>Product Description</u>  |
|--|------------------------|---------------------------|---|
| G410                                   | 48, 60, 72 and 80 mils | ASTM D4434                | Fiberglass reinforced PVC roofing membrane.                               |
| Textured G410                          | 48, 60, 72 and 80 mils | ASTM D4434                | Fiberglass reinforced PVC roofing membrane.                               |
| G410 Felt                              | 48, 60, 72 and 80 mils | ASTM D4434                | Fiberglass reinforced PVC roofing membrane with a non-woven felt backing. |
| Textured G410 Felt                     | 48, 60, 72 and 80 mils | ASTM D4434                | Fiberglass reinforced PVC roofing membrane with a non-woven felt backing. |
| G459                                   | 48, 60, 72 and 80 mils | ASTM D4434                | Fiberglass reinforced PVC Alloy asphalt compatible flashing membrane.     |
| S327                                   | 48, 60, 72 and 80 mils | ASTM D4434                | Polyester reinforced PVC roofing membrane.                                |
| S327 (10 ft)                           | 48, 60, 72 and 80 mils | ASTM D4434                | Polyester reinforced PVC roofing membrane.                                |
| S327 Felt                              | 48, 60, 72 and 80 mils | ASTM D4434                | Polyester reinforced PVC roofing membrane with a non-woven felt backing.  |
| Sikaplan Fastened                      | 45 mils or 60 mils     | ASTM D4434                | White polyester reinforced PVC roofing membrane.                          |
| Sikaplan Fastened Feltback             | 45 mils or 60 mils     | ASTM D4434                | White polyester reinforced PVC roofing membrane.                          |
| Sikaplan Adhered                       | 60 mils                | ASTM D4434                | White polyester reinforced PVC roofing membrane.                          |
| Sarnatape                              | Various                | Proprietary               | Air flow barrier tape   |
| Sarnacol 2170                          | 5 gallons              | Proprietary               | Solvent based bonding adhesive.   |
| Sarnacol 2121                          | 5 gallons              | Proprietary               | Water based bonding adhesive.   |
| Sarnacol 2163                          |                        | Proprietary               | Insulation adhesive.  |
| Sarnacol AD Feltback Membrane Adhesive | 5 gallons              | Proprietary               | Two-component foamable polyurethane membrane or insulation adhesive.      |
| Sarnacol AD Board Adhesive             | 5 gallons              | Proprietary               | Two-component foamable polyurethane insulation adhesive.                  |
| Sikaplan Water Based Membrane Adhesive | 5 gallons              | Proprietary               | Water-based dispersion membrane adhesive.                                 |



**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**

**TABLE 1**

| <u>Product</u>                         | <u>Dimensions</u> | <u>Test Specification</u> | <u>Product Description</u>                               |
|--|-------------------|---------------------------|--|
| Sarnacol OM Feltback Membrane Adhesive | 5 gallons         | Proprietary               | Two-component foamable polyurethane membrane adhesive.   |
| Sarnacol OM Board Adhesive             | 5 gallons         | Proprietary               | Two-component foamable polyurethane insulation adhesive. |
| OlyBond 500                            | 5 gallons         | Proprietary               | Two-component foamable polyurethane insulation adhesive. |
| Sarnacol 2170 VC                       | Various           | Proprietary               | Solvent-based, VOC compliant adhesive.                   |
| Sarnatred                              | 3.25' x 32.8'     | Proprietary               | PVC walkway protection sheet.                            |
| Sarnastack                             | Various           | Proprietary               | Prefabricated cone flashing.                             |
| Sarnaclad                              | Various           | Proprietary               | Heat weldable PVC/galvanized steel flashing              |

**APPROVED INSULATIONS:**

**TABLE 2**

| <u>Product Name</u> | <u>Product Description</u>   | <u>Manufacturer (With Current NOA)</u>  |
|---------------------|--|---|
| Sarnatherm          | Isocyanurate Insulation with fiber reinforced felt paper facer     | Sika Sarnafil, A Division of Sika Corp. |
| Sarnatherm-25 PSI   | Polyisocyanurate insulation with fiber reinforced felt paper facer | Sika Sarnafil, A Division of Sika Corp. |
| Sarnatherm (a)      | Isocyanurate Insulation with fiber reinforced felt paper facer     | Sika Sarnafil, A Division of Sika Corp. |
| ACFoam-II           | Isocyanurate Insulation with fiber reinforced felt paper facer     | Atlas Roofing Corp.                     |
| ACFoam-III          | Isocyanurate Insulation with coated glass facer                    | Atlas Roofing Corp.                     |
| ACFoam-IV           | Isocyanurate Insulation with heavy weight coated glass facer       | Atlas Roofing Corp.                     |
| ACFoam Supreme      | Isocyanurate Insulation with foil facer                            | Atlas Roofing Corp.                     |
| DensDeck            | Silicon treated gypsum with fiberglass mat facer                   | Georgia Pacific Gypsum LLC              |
| DensDeck Prime      | Silicon treated gypsum with an enhanced fiberglass mat facer       | Georgia Pacific Gypsum LLC              |
| ENRGY 3             | Isocyanurate Insulation with fiber reinforced felt paper facer     | Johns Manville Corp.                    |
| JM ISO 3            | Isocyanurate Insulation with fiber reinforced felt paper facer     | Johns Manville Corp.                    |
| ENRGY 3 25 PSI      | Isocyanurate Insulation with fiber reinforced felt paper facer     | Johns Manville Corp.                    |
| Type X Gypsum       | Gypsum Wallboard   | Generic                                 |



**APPROVED INSULATIONS:**

**TABLE 2**

| <u>Product Name</u>                                | <u>Product Description</u>  | <u>Manufacturer (With Current NOA)</u>   |
|--|---|--|
| XPS  | Type IV Extruded polystyrene with a minimum density of 1.6 pcf      | Generic                                  |
| EPS  | Type IX Expanded polystyrene with a minimum density of 1.8 pcf      | Generic                                  |
| H-Shield   | Isocyanurate Insulation with fiber reinforced felt paper facer      | Hunter Panels, LLC                       |
| H-Shield-WF  | Isocyanurate Insulation with fiber reinforced felt paper facer      | Hunter Panels, LLC                       |
| H-Shield HD  | High density polyisocyanurate cover board with a coated glass facer | Hunter Panels, LLC                       |
| ISO 95+ GL   | Isocyanurate Insulation with fiber reinforced felt paper facer      | Firestone Building Products Company, LLC |
| Structodek High Density Fiberboard Roof Insulation | High density wood fiber insulation board                            | Blue Ridge Fiberboard, Inc.              |
| SECUROCK Gypsum-Fiber Roof Board                   | Gypsum-fiber cover board  | United States Gypsum Corp.               |
| SECUROCK Glass-Mat Roof Board                      | Gypsum cover board with a glass mat facer                           | United States Gypsum Corp.               |
| Invinsa Roof Board                                 | High density polyisocyanurate cover board with a coated glass facer | Johns Manville Corp.                     |

**APPROVED FASTENERS:**

**TABLE 3**

| <u>Fastener Number</u> | <u>Product Name</u>              | <u>Product Description</u>          | <u>Dimensions</u> | <u>Manufacturer (With Current NOA)</u>  |
|------------------------|----------------------------------|-------------------------------------|-------------------|---|
| 1.                     | #14 Roofgrip, #15 Roofgrip       | Insulation and membrane fastener    | Various           | OMG, Inc.                               |
| 2.                     | CD-10                            | Insulation and membrane fastener    | Various           | OMG, Inc.                               |
| 3.                     | 3 in. Ribbed Galvalume Plate     | Galvalume steel stress plate        | 3” round          | OMG, Inc.                               |
| 4.                     | OMG 3” Galvalume Steel Plate     | Galvalume coated steel stress plate | 3” round          | OMG, Inc.                               |
| 5.                     | Dekfast 14, Dekfast 15 HS        | Insulation and membrane fasteners   | Various           | SFS Intec, Inc.                         |
| 6.                     | Dekfast Galvalume Steel 3” Round | Galvalume AZ50 stress plate         | 3” round          | SFS Intec, Inc.                         |
| 7.                     | Sarnafastener                    | Insulation and membrane fastener    | Various           | Sika Sarnafil, A Division of Sika Corp. |
| 8.                     | Sarnaplate                       | Insulation fastening plate.         | 3” round          | Sika Sarnafil, A Division of Sika Corp. |



|     |                                |   |              |   |
|-----|--------------------------------|---|--------------|---|
| 9.  | Sarnarail Polymer Batten Strip | Polymer Batten Bar                                    | 1" x 250'    | Sika Sarnafil, A Division of Sika Corp. |
| 10. | Sarnafastener-XP               | Insulation and membrane fastener                      | Various      | Sika Sarnafil, A Division of Sika Corp. |
| 11. | Sarnadisc-XP                   | Insulation and membrane fastener                      | 1.5" x 3.75" | Sika Sarnafil, A Division of Sika Corp. |
| 12. | Sarnafastener Concrete         | Insulation and membrane fastener                      | Various      | Sika Sarnafil, A Division of Sika Corp. |
| 13. | Sarnabar                       | Galvanized or stainless steel membrane fastening bar. | Various      | Sika Sarnafil, A Division of Sika Corp. |
| 14. | OMG Heavy Duty                 | Insulation and membrane fastener                      | Various      | OMG, Inc.                               |
| 15. | Sarnafastener #12, #14         | Insulation and membrane fastener                      | Various      | Sika Sarnafil, A Division of Sika Corp. |
| 16. | Flat Bottom Metal Plate        | Insulation fastening plate.                           | 3" Round     | OMG, Inc.                               |
| 17. | Sikaplan Fastener #14          | Insulation and membrane fastener                      | Various      | Sika Sarnafil, A Division of Sika Corp. |
| 18. | Sikaplan Board Plate           | Round galvalume plated steel stress plate             | 3" Round     | Sika Sarnafil, A Division of Sika Corp. |
| 19. | RhinoBond Insulation Plate     | Black primer coated plate for use with PVC membranes  | 3" Round     | OMG, Inc.                               |
| 20. | Sarnadisc RhinoBond            | Black primer coated plate for use with PVC membranes  | 3" Round     | Sika Sarnafil, A Division of Sika Corp. |
| 21. | Sikaplan RhinoBond Disc        | Black primer coated plate for use with PVC membranes  | 3" Round     | Sika Sarnafil, A Division of Sika Corp. |



**EVIDENCE SUBMITTED:**

| <u>Test Agency</u>                  | <u>Test Identifier</u> | <u>Description</u>  | <u>Date</u> |
|-------------------------------------|------------------------|---------------------|-------------|
| Celotex Technical Center            | MTS Job No. 258215     | TAS 114             | 09/09/97    |
| Exterior Research & Design          | 02767.02.06            | TAS 114             | 02/08/06    |
| Factory Mutual Research Corporation | 0X3A3.AM               | FM 4470             | 07/31/94    |
|                                     | 0P6A6.AM               | FM 4470             | 03/03/94    |
|                                     | 2X2A5.AM               | FM 4470             | 07/31/94    |
|                                     | 0B9A0.AM               | FM 4470             | 10/22/96    |
|                                     | 4B3A2.AM               | FM 4470             | 06/19/97    |
|                                     | 3D8A1.AM               | FM 4470             | 12/23/97    |
|                                     | 0B9A0.AM               | FM 4470             | 05/31/96    |
|                                     | 2D0A8.AM               | FM 4470             | 12/23/97    |
|                                     | 2B6A9.AM               | FM 4470             | 08/25/98    |
|                                     | 3001396                | FM 4470             | 05/28/99    |
|                                     | 3012964                | FM 4470             | 06/11/02    |
|                                     | 3015643                | FM 4470             | 12/06/02    |
|                                     | 3016201                | FM 4470             | 01/28/03    |
|                                     | 3006785                | FM 4470             | 05/06/04    |
|                                     | 3017292                | FM 4470             | 09/03/04    |
|                                     | 3021131                | FM 4470             | 07/07/05    |
|                                     | 3014692                | FM 4470             | 08/05/03    |
|                                     | 3009610                | FM 4450             | 10/22/01    |
|                                     | 3020703                | FM 4470             | 07/30/04    |
|                                     | 3012321                | FM 4470             | 07/29/02    |
|                                     | 3014751                | FM 4470             | 08/27/03    |
|                                     | 3024311                | FM 4470             | 11/01/06    |
|                                     | 3024229                | FM 4470             | 11/16/05    |
|                                     | 3028309                | FM 4470             | 03/30/07    |
|                                     | 3041256                | FM 4470             | 07/12/11    |
|                                     | 3000858                | FM 4470             | 05/14/99    |
|                                     | 3008869                | FM 4470             | 03/19/01    |
| 3039809                             | FM 4470                | 07/06/11            |             |
| 3030053                             | FM 4470                | 09/12/07            |             |
| 3043459                             | FM 4470                | 05/11/12            |             |
| 3036355                             | FM 4470                | 11/10/09            |             |
| 3035670                             | FM 4470                | 05/13/09            |             |
| Underwriters Laboratories, Inc.     | R8992                  | UL 790              | 05/15/13    |
| Trinity   ERD                       | 4740.04.98-1           |                     |             |
|                                     | S44790.06.13           | ASTM D4434          | 06/05/13    |
|                                     | S42480.08.12           | Physical Properties | 08/20/12    |
|                                     | S44790.08.13           | ASTM D4434          | 08/26/13    |
|                                     | S44790.07.14-R2        | ASTM D4434          | 06/01/15    |
|                                     | S45990.06.14           | ASTM D4434          | 06/02/14    |
|                                     | S36600.03.14           | FM 4474 & TAS 114   | 03/04/14    |

**APPROVED ASSEMBLIES**

- Membrane Type:** Single Ply, PVC
- Deck Type 3I:** Concrete, Insulated
- Deck Description:** Min. 2500 psi structural concrete or concrete plank
- System Type A(1):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved vapor barrier may be installed over the deck.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, Sarnatherm, ACFoam-II, ACFoam-III, JM ISO 3, ISO 95+GL, H-Shield<br>Minimum 1.5” thick              | N/A                                       | N/A  |
| DensDeck Prime<br>Minimum 0.5” thick   | N/A                                       | N/A  |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
| Sarnatherm (a), Sarnatherm-25 PSI, Sarnatherm, ACFoam-II, ACFoam-III, JM ISO 3, ISO 95+GL, H-Shield<br>(Tapered)<br>Minimum 0.5” thick | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck in 3-3.5” wide beads spaced 12” o.c. of ICP Adhesives CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or



Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.

Or

Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq or with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5" wide ribbons spaced 12" o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.

**Maximum Design  
Pressure:**

-45 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(2):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved vapor barrier may be installed over the deck.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, Sarnatherm, ACFoam-II, ACFoam-III, JM ISO 3, ISO 95+GL, H-Shield<br>Minimum 1.5” thick              | N/A                                       | N/A  |
| DensDeck Prime<br>Minimum 0.5” thick   | N/A                                       | N/A  |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
| Sarnatherm (a), Sarnatherm-25 PSI, Sarnatherm, ACFoam-II, ACFoam-III, JM ISO 3, ISO 95+GL, H-Shield<br>(Tapered)<br>Minimum 0.5” thick | N/A                                       | N/A  |

**Note:** All insulation shall be adhered to the deck in 3-3.5” wide beads spaced 12” o.c. of ICP Adhesives CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -45 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(3):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**

- Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.
- Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet.
- Torch-applied: Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional torch-applied sheet.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>  | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, AC Foam-II, AC Foam-III, ENRGY 3, H-Shield<br>Minimum 1.5" thick | N/A                                       | N/A  |

| <u>Top Insulation Layer:</u>  | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, AC Foam-II, AC Foam-III, ENRGY 3, H-Shield (Tapered)<br>Minimum 1.5" thick | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at a rate of 0.75-2gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.

Or



Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

*(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

Or

*(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq or with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure:**

- 97.5 psf; with Sarnacol 2170 VC adhesive (See General Limitation #9)
- 112.5 psf; Felt membranes with Sarnacol 2121 adhesive (See General Limitation #9)
- 117.5 psf; with all other applications (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(4):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**

- Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.
- Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet.
- Torch-applied: Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional torch-applied sheet.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield<br>Minimum 1.5" thick | N/A   | N/A  |

| <u>Top Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield (Tapered)<br>Minimum 1.5" thick | N/A   | N/A  |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.

**Maximum Design Pressure:** -117.5 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(5):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Approved EPS (Not used with Sarnacol 2170 or Sarnacol 2170 VC)<br>Minimum 2” thick | N/A                                       | N/A                                    |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25” thick  | N/A                                       | N/A                                    |

**Note: All insulation shall be adhered to the deck in ¾” – 1” wide beads 12” o.c. of Sarnacol OM Board Adhesive, OlyBond 500 or Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighed roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation or with Sarnacol 2170 VC adhesive roller applied at 0.75-2gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane; The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

Or



Or

Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. or with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5" wide ribbons spaced 12" o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.

**Maximum Design  
Pressure:**

-112.5 psf; Felt membranes with Sarnacol 2121 adhesive (See General Limitation #9)  
-120 psf; with all other applications (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(6):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u>     | <u>Fastener Density/ft<sup>2</sup></u>     |
|--|---|--|
| Approved EPS (Not used with Sarnacol 2170 or Sarnacol 2170 VC)<br>Minimum 2” thick | N/A   | N/A  |
| <br><u>Top Insulation Layer:</u>   | <br><u>Insulation Fasteners<br/>(Table 3)</u> | <br><u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25” thick  | N/A   | N/A  |

**Note: All insulation shall be adhered to the deck in ¾” – 1” wide beads 12” o.c. of Sarnacol OM Board Adhesive, OlyBond 500 or Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure:** -120 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(7):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Torch-applied: Torch-applied base membrane approved for use with roof cover followed by an additional torch-applied sheet.  
 Asphalt-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield<br>Minimum: 1.5" thick | N/A   | N/A                                    |

| <u>Top Insulation Layer (Optional):</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield<br>Minimum: 1.5 " thick | N/A   | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410 S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410 S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** *(With Vapor Barrier)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -169.0 psf. (See General Limitation #9)**



**Attachment #3:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** (With Vapor Barrier) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -169.0 psf. (See General Limitation #9)**

**Maximum Design Pressures:** See Attachments. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(8):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Torch-applied: Torch-applied base membrane approved for use with roof cover followed by an additional torch-applied sheet.  
 Asphalt-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, AC Foam-II, AC Foam-III, ENRGY 3, H-Shield<br>Minimum: 1.5" thick  | N/A   | N/A                                    |
| <u>Top Insulation Layer (Optional):</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, AC Foam-II, AC Foam-III, ENRGY 3, H-Shield<br>Minimum: 1.5 " thick | N/A   | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered to the insulation layers as specified below.

**Attachment #1:** *(With Vapor Barrier)* Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -169.0 psf. (See General Limitation #9)**

**Attachment #2:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Maximum Design Pressures:** See Attachments. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(9):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved asphaltic vapor barrier may be installed over the deck or the base layer of insulation

One or more layers of any of the following insulations:

| <b><u>Base Insulation Layer:</u></b>  | <b><u>Insulation Fasteners</u></b><br><b><u>(Table 3)</u></b> | <b><u>Fastener Density/ft<sup>2</sup></u></b> |
|---|---|---|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3<br>Minimum 1.5” thick | N/A   | N/A   |
| Sarnatherm, H-Shield (Requires top layer of approved insulation)<br>Minimum 1.5” thick  | N/A   | N/A   |
| <b><u>Top Insulation Layer (Optional):</u></b>  | <b><u>Insulation Fasteners</u></b><br><b><u>(Table 3)</u></b> | <b><u>Fastener Density/ft<sup>2</sup></u></b> |
| DensDeck Prime<br>Minimum 0.25” thick   | N/A   | N/A   |

**Note:** All insulation shall be adhered to the deck in ½” to ¾” wide beads 12” o.c. of Sarnacol 2163, Sarnacol AD Board Adhesive, Sarnacol AD Feltback Membrane Adhesive, Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** (With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** (With DensDeck Prime) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**



**Attachment #3:** (*With DensDeck Prime*) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -157.5 psf; with asphaltic vapor Barrier (See General Limitation #9)**

**Attachment #4:** (*With ISO*) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure -232.5 psf; without vapor Barrier (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** (*With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (*With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI or DensDeck Prime*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** (*With DensDeck Prime*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #5:** (*With DensDeck Prime*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -157.5 psf; with asphaltic vapor Barrier (See General Limitation #9)**

**Maximum Design Pressures:**

See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(10):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved asphaltic vapor barrier may be installed over the deck or the base layer of insulation

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3<br>Minimum 1.5” thick | N/A                                       | N/A                                    |
| Sarnatherm, H-Shield (Requires top layer of approved insulation)<br>Minimum 1.5” thick  | N/A                                       | N/A                                    |
| <u>Top Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25” thick   | N/A                                       | N/A                                    |

**Note: All insulation shall be adhered to the deck in ½” to ¾” wide beads 12” o.c. of Sarnacol 2163, Sarnacol AD Board Adhesive, Sarnacol AD Feltback Membrane Adhesive, Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** (*With ISO*) Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressures:** -232.5 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank  
**System Type A(11):** One or more layers of insulation fully adhered with approved asphalt.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered | N/A                                       | N/A                                    |
| Sarnatherm, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered            | N/A                                       | N/A                                    |
| H-Shield-WF<br>Minimum 1.9” thick or tapered  | N/A                                       | N/A                                    |
| <u>Top Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum ¼” thick  | N/A                                       | N/A                                    |

**Note:** Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** (With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** (With DensDeck Prime) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**



**Attachment #3:** (With AC Foam-II, AC Foam-III, ENRGY 3 and H-Shield) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Attachment #4:** (With DensDeck Prime) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Attachment #5:** (With H-Shield-WF) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -255.0 psf. (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI or DensDeck Prime) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5" wide ribbons spaced 12" o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** (*With DensDeck Prime*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure:** *-127.5 psf. (See General Limitation #9)*

**Maximum Design Pressures:**

See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank  
**System Type A(12):** One or more layers of insulation fully adhered with approved asphalt.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered | N/A                                       | N/A                                    |
| Sarnatherm, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered            | N/A                                       | N/A                                    |
| H-Shield-WF<br>Minimum 1.9” thick or tapered  | N/A                                       | N/A                                    |
| <u>Top Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum ¼” thick  | N/A                                       | N/A                                    |

**Note:** Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.

**Membrane:** Sikaplan Adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, ENRGY 3 and H-Shield)* Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Attachment #2:** *(With DensDeck Prime)* Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**



**Attachment #3:** (*With H-Shield-WF*) Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -255.0 psf. (See General Limitation #9)**

**Maximum Design Pressures:**

See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(13):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved asphaltic vapor barrier may be installed over the deck or the base layer of insulation

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---------------------------------------|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ISO 95+ GL, H-Shield Minimum 1.5” thick | N/A                                   | N/A                                    |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime Minimum 0.25” thick   | N/A                                   | N/A                                    |

**Note: All insulation shall be adhered to the deck in ¾” – 1” wide beads 12” o.c. of Sarnacol OM Board Adhesive, OlyBond 500 or Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -150.0 psf; with asphaltic vapor barrier (See General Limitation #9)**



- Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.
- Attachment #1:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure: -112.5 psf. (See General Limitation #9)*
- Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
*Maximum Design Pressure: -120.0 psf. (See General Limitation #9)*
- Attachment #3:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
*Maximum Design Pressure: -127.5 psf. (See General Limitation #9)*
- Attachment #4:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure: -150.0 psf; with asphaltic vapor barrier (See General Limitation #9)*

**Maximum Design Pressures:** See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(14):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered  
**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**  
**Vapor Barrier (Optional):** Any UL or FM approved asphaltic vapor barrier may be installed over the deck or the base layer of insulation

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---------------------------------------|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ISO 95+ GL, ENRGY 3, H-Shield<br>Minimum 1.5” thick | N/A                                   | N/A                                    |
| DensDeck Prime<br>Minimum 0.25” thick   | N/A                                   | N/A                                    |
| <u>Top Insulation Layer (Optional):</u>   | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25” thick   | N/A                                   | N/A                                    |

**Note: All insulation shall be adhered to the deck in ¾" – 1" wide beads 12" o.c. of Sarnacol OM Board Adhesive, OlyBond 500 or Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** *(With DensDeck Prime)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**



**Attachment #3:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -150.0 psf; with asphaltic vapor barrier (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI or DensDeck Prime) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** (With DensDeck Prime) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #5:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -150.0 psf; with asphaltic vapor barrier (See General Limitation #9)**

**Maximum Design Pressures;**

See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(15):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>                 | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| ENRGY 3, ENRGY 3 25 PSI<br>Minimum 1.5" thick | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck with hot asphalt at a rate of 25 lb/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.

**Maximum Design Pressure:** -210.0 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(16):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered  
**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>                 | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| ENRGY 3, ENRGY 3 25 PSI<br>Minimum 1.5” thick | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck with hot asphalt at a rate of 25 lb/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -210.0 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(17):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>                 | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| ENRGY 3, ENRGY 3 25 PSI<br>Minimum 1.5” thick | N/A                                       | N/A  |
| <u>Top Insulation Layer (Optional):</u>       | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
| ENRGY 3 25 PSI<br>Minimum 1.5” thick          | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck with hot asphalt at a rate of 25 lb/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied to substrate at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive roller applied as a primer at a rate of 1.0-1.25 gal/sq. and allowed to dry. Following a second coat application of Sarnacol 2170 adhesive roller applied to substrate at a rate of 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -112.5 psf; Felt membranes with Sarnacol 2121 adhesive (See General Limitation #9)  
-232.5 psf; Felt membranes with Sarnacol 2170 adhesive (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(18):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield<br>Minimum 1.5" thick | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck with hot asphalt at a rate of 25 lb/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75gal/sq. or with Sarnacol 2170 adhesive applied to substrate at a rate of 0.75-2 gal/sq. and allowed to dry. Following a second coat application of Sarnacol 2170 adhesive roller applied to substrate at a rate of 0.5 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**



**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** (With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive roller applied as a primer at a rate of 1.0-1.25 gal/sq. and allowed to dry. Following a second coat application of Sarnacol 2170 adhesive roller applied to substrate at a rate of 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -240.0 psf. (See General Limitation #9)**

**Attachment #5:** (With H-Shield and ENRGY 3) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive roller applied as a primer at a rate of 1.0-1.25 gal/sq. and allowed to dry. Following a second coat application of Sarnacol 2170 adhesive roller applied to substrate at a rate of 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -255.0 psf. (See General Limitation #9)**

**Maximum Design Pressures:**

See Attachments. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(19):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>              | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm, H-Shield<br>Minimum 1.5" thick | N/A                                       | N/A  |
| <u>Top Insulation Layer (Optional):</u>    | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
| H-Shield-WF<br>Minimum 1.5" thick          | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck with hot asphalt at a rate of 25 lb/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.

**Maximum Design Pressure:** -255 psf (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(20):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>               | <u>Insulation Fasteners<br/>(Table 3)</u>     | <u>Fastener<br/>Density/ft<sup>2</sup></u>     |
|---|---|--|
| Sarnatherm, H-Shield<br>Minimum 1.5" thick  | N/A   | N/A  |
| <br><u>Top Insulation Layer (Optional):</u> | <br><u>Insulation Fasteners<br/>(Table 3)</u> | <br><u>Fastener<br/>Density/ft<sup>2</sup></u> |
| H-Shield-WF<br>Minimum 1.5" thick           | N/A   | N/A  |

**Note: All insulation shall be adhered to the deck with hot asphalt at a rate of 25 lb/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.

**Maximum Design Pressure:** -255 psf (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank  
**System Type A(21):** One or more layers of insulation fully adhered with approved asphalt.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered | N/A                                       | N/A  |
| Sarnatherm, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered            | N/A                                       | N/A  |
| H-Shield-WF<br>Minimum 1.9” thick or tapered  | N/A                                       | N/A  |

**Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** *(With ENRGY 3 Plus)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**

**Attachment #3:** *(With H-Shield-WF)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**



**Attachment #4:** (With AC Foam-II, AC Foam-III, Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ENRGY 3, ENRGY 3 25 PSI and H-Shield) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5" wide ribbons spaced 12" o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Maximum Design Pressures:** See Attachments. (See General Limitation #9)

**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank  
**System Type A(22):** One or more layers of insulation fully adhered with approved asphalt.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered | N/A                                       | N/A  |
| Sarnatherm, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered            | N/A                                       | N/A  |
| H-Shield-WF<br>Minimum 1.9” thick or tapered  | N/A                                       | N/A  |

**Note: Concrete deck shall be primed with ASTM D 41 asphalt primer and allowed to dry prior to application of base sheet. All insulation shall be adhered to the deck in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels used as a top layer shall be placed with the polyisocyanurate side facing down.**

**Membrane:** Sikaplan Adhered to the insulation layers as specified below.

**Attachment #1:** *(With ENRGY 3 Plus)* Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**

**Attachment #2:** *(With H-Shield-WF)* Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**



**Attachment #3:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ENRGY 3, ENRGY 3 25 PSI and H-Shield)* Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -232.5 psf. (See General Limitation #9)**

**Maximum Design Pressures:**

See Attachments. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(23):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**

- Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.
- Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet
- Torch-applied: Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional torch-applied sheet

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield<br>Minimum: 1.5” thick | N/A   | N/A                                    |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| Structodek High Density Fiberboard Roof Insulation<br>Minimum: 0.5” thick                                      | N/A   | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -112.5 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(24):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**

- Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.
- Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet
- Torch-applied: Hot asphalt-applied base and/or ply sheets or optional torch-applied base membrane approved for use with roof cover followed by an additional torch-applied sheet

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield<br>Minimum: 1.5” thick | N/A   | N/A                                    |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| Structodek High Density Fiberboard Roof Insulation<br>Minimum: 0.5” thick                                      | N/A   | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -112.5 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(25):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Torch-applied: Torch-applied base membrane approved for use with roof cover followed by an approved torch-applied sheet.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>   | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---------------------------------------|--|
| Sarnatherm (a), Sarnartherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, H-Shield or Approved XPS or EPS (Not used with Sarnacol 2170 or Sarnacol 2170 VC)<br>Minimum: 1.5” thick | N/A                                   | N/A                                    |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum: 0.25” thick   | N/A                                   | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #2:** (With Vapor Barrier) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -169.0 psf. (See General Limitation #9)**



**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #3:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #4:** (*With Vapor Barrier*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -169.0 psf. (See General Limitation #9)**

**Maximum Design Pressures:**

See Attachments, (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(26):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.  
 Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>              | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|--|---|--|
| Approved XPS or EPS<br>Minimum: 1.5" thick | N/A                                       | N/A  |
| <u>Top Insulation Layer:</u>               | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum: 0.25" thick     | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With Vapor Barrier)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -180.0 psf. (See General Limitation #9)**



- Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.
- Attachment #1:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure: -112.5 psf. (See General Limitation #9)*
- Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
*Maximum Design Pressure: -120.0 psf. (See General Limitation #9)*
- Attachment #3** (*With Vapor Barrier*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure: -180.0 psf. (See General Limitation #9)*

**Maximum Design Pressures:** See Attachments. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(27):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, AC Foam-II, AC Foam-III, ENRGY 3, ISO 95+GL, H-Shield<br>Minimum 1.5” thick | N/A   | N/A                                    |
| DensDeck Prime<br>Minimum 0.25” thick  | N/A   | N/A                                    |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25” thick  | N/A   | N/A                                    |

**Note: All insulation shall be adhered to the deck in full coating of OlyBond Adhesive Fastener at a rate of 1 gal/sq. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -150.0 psf. (See General Limitation #9)**



**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #3:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #4:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -150.0 psf. (See General Limitation #9)**

**Maximum Design Pressures:** See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(28):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>         | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---------------------------------------|---|--|
| Approved XPS<br>Minimum 1” thick      | N/A                                       | N/A                                    |
| <u>Top Insulation Layer:</u>          | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25” thick | N/A                                       | N/A                                    |

**Note: All insulation shall be adhered to the deck in ¾” – 1” wide beads 12” o.c. of Sarnacol OM Board Adhesive, OlyBond 500 or Spot Shot Adhesive Fastener. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment 1:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**



**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #3:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Maximum Design Pressure:**

See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(29):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.  
 Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet

One or more layers of any of the following insulations:

| <u>Base Insulation Layer (Optional):</u>  | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, AC Foam-II, AC Foam-III, ENRGY 3, H-Shield or Minimum 2.0 pcf Approved XPS or EPS (Not used with Sarnacol 2170 or Sarnacol 2170 VC)<br>Minimum: 1.5” thick | N/A                                       | N/A  |
| <u>Top Insulation Layer:</u>  | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum: 0.25” thick  | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

- Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.
- Attachment #1:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
*Maximum Design Pressure: -127.5 psf. (See General Limitation #9)*
- Attachment #2:** (With Vapor Barrier) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure: -202.5 psf. (See General Limitation #9)*



**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #3:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #4:** (*With Vapor Barrier*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -202.5 psf. (See General Limitation #9)**

**Maximum Design Pressures:**

See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(30):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved vapor barrier may be installed over the deck.  
 One or more layers of any of the following insulations:

| <u>Insulation Layer:</u>  | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---------------------------------------|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, JM ISO 1, ISO 95+GL, H-Shield<br>Minimum 1.5” thick | N/A                                   | N/A                                    |
| DensDeck Prime<br>Minimum 0.5” thick  | N/A                                   | N/A                                    |

**Note: All insulation shall be adhered to the deck in 3-3.5” wide beads spaced 12” o.c. of ICP Adhesives CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** *(With DensDeck Prime)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #3:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -232.5 psf; with asphaltic vapor barrier (See General Limitation #9)**



- Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.
- Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**
- Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**
- Attachment #3:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI or DensDeck Prime)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**
- Attachment #4:** *(With DensDeck Prime)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**
- Attachment #5:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -232.5 psf; with asphaltic vapor barrier (See General Limitation #9)**

**Maximum Design Pressures:** See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(31):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved asphaltic vapor barrier may be installed over the deck or the base layer of insulation.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>         | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---------------------------------------|---------------------------------------|--|
| Approved EPS<br>Minimum 1.5" thick    | N/A                                   | N/A                                    |
| Approved XPS<br>Minimum 1" thick      | N/A                                   | N/A                                    |
| <u>Top Insulation Layer:</u>          | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25" thick | N/A                                   | N/A                                    |

**Note: All insulation shall be adhered to the deck in ½" to ¾" wide beads 12" o.c. of Saranacol 2163, Sarnacol AD Board Adhesive, Sarnacol AD Feltback Membrane Adhesive, Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.  
**Maximum Design Pressure: -202.5 psf; with asphaltic vapor barrier (See General Limitation #9)**



- Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.
- Attachment #1:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure: -112.5 psf. (See General Limitation #9)*
- Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
*Maximum Design Pressure: -120.0 psf. (See General Limitation #9)*
- Attachment #3** (*With Vapor Barrier*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure: -202.5 psf; with asphaltic vapor barrier (See General Limitation #9)*
- Maximum Design Pressures:** See Attachments. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(32):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.  
 Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum: 1.5” thick  | N/A                                       | N/A                                    |
| <u>Top Insulation Layer (Optional):</u>  | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum: 1.5 ” thick | N/A                                       | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** (With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attahment #2:** (With Vapor Barrier) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**



**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** *(With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** *(With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** *(With Vapor Barrier)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**

**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(33):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.  
 Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet.

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners<br/>(Table 3)</u>     | <u>Fastener Density/ft<sup>2</sup></u>     |
|--|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum: 1.5” thick  | N/A   | N/A  |
| <br><u>Top Insulation Layer (Optional):</u>                                      | <br><u>Insulation Fasteners<br/>(Table 3)</u> | <br><u>Fastener Density/ft<sup>2</sup></u> |
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum: 1.5 ” thick | N/A   | N/A  |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** (With Vapor Barrier) Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressures:** -210.0 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(34):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Insulation Layer:</u>  | <u>Insulation Fasteners</u><br>(Table 3) | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
|---|--|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ISO 95+GL, H-Shield<br>Minimum 1.5” thick | N/A                                      | N/A  |

**Note: All insulation shall be adhered to the deck in 3-3.5” wide beads spaced 12” o.c. of ICP Adhesives CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Option 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** *(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**



**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure: -210.0 psf. (See General Limitation #9)**

**Maximum Design Pressures:**

See Attachments. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(35):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener</u><br><u>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ISO 95+GL, H-Shield<br>Minimum 1.5” thick | N/A   | N/A  |

**Note: All insulation shall be adhered to the deck in 3-3.5” wide beads spaced 12” o.c. of ICP Adhesives CR-20. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressures:** -210.0 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type A(36):** One or more layers of insulation adhered with approved adhesive, membrane fully adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved asphaltic vapor barrier may be installed over the deck or the base layer of insulation

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, AC Foam-II, AC Foam-III, ENRGY 3, H-Shield<br>Minimum 1.5" thick | N/A                                       | N/A  |
| DensDeck Prime<br>Minimum 0.25" thick   | N/A                                       | N/A  |
| <u>Top Insulation Layer (Optional):</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener<br/>Density/ft<sup>2</sup></u> |
| DensDeck Prime<br>Minimum 0.25" thick   | N/A                                       | N/A  |

**Note: All insulation shall be adhered to the deck in 1/2" to 3/4" wide beads 12" o.c. of Sarnacol 2163, Sarnacol AD Board Adhesive, Sarnacol AD Feltback Membrane Adhesive, Millennium One Step Foamable Adhesive or Millennium PG-1 Low Viscosity Insulation Adhesive. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane (Options 1):** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered to the insulation layers as specified below.

**Attachment #1:** *(With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** *(With DensDeck Prime)* Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**



**Attachment #3:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -157.5 psf; with asphaltic vapor barrier (See General Limitation #9)**

**Attachment #4:** Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -232.5 psf; with no vapor barrier (See General Limitation #9)**

**Membrane (Option 2):** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered to the insulation layers as specified below.

**Attachment #1:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -97.5 psf. (See General Limitation #9)**

**Attachment #2:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
**Maximum Design Pressure: -112.5 psf. (See General Limitation #9)**

**Attachment #3:** (With AC Foam-II, AC Foam-III, Sarnatherm (a) and Sarnatherm-25 PSI or DensDeck Prime) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -120.0 psf. (See General Limitation #9)**

**Attachment #4:** (With DensDeck Prime) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.  
**Maximum Design Pressure: -127.5 psf. (See General Limitation #9)**

**Attachment #5:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

***Maximum Design Pressure: -157.5 psf; with asphaltic vapor barrier (See General Limitation #9)***

**Attachment #6:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or with Sarnacol 2121 adhesive roller applied at 0.75ga./sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

***Maximum Design Pressure: -232.5 psf; with no vapor barrier (See General Limitation #9)***

**Maximum Design Pressures:**

See Attachment. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(37):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.  
 Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>                         | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm, ENRGY 3, H-Shield<br>Minimum: 1.5” thick  | N/A                                       | N/A                                    |
| <u>Top Insulation Layer (Optional):</u>               | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| Sarnatherm, ENRGY 3, H-Shield<br>Minimum: 1.5 ” thick | N/A                                       | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation using a ¼” x ¼” notched squeegee or with Sarnacol 2170 adhesive rolled applied as a primer at a rate 1.0-1.25 gal/sq. to the insulation allowed to dry. Following a second coat roller applied of adhesive at 1.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the insulation using a ¼” x ¼” notched squeegee or with Sarnacol 2170 adhesive applied at 0.75-1.25gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -112.5 psf; Felt membranes with Sarnacol 2121 adhesive or Sikaplan Water Based Membrane Adhesive (See General Limitation #9)  
 -225.0 psf; with all other applications. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** 2500 psi structural concrete or concrete plank  
**System Type A(38):** One or more layers of insulation adhered with approved adhesive

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):**  
 Hot-applied: Hot asphalt-applied base and/or ply sheets approved for use with roof cover followed by an additional asphalt-applied sheet.  
 Self-Adhered: Self-adhered base membrane approved for use with roof cover followed by an additional self-adhered sheet

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>                         | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Sarnatherm, ENRGY 3, H-Shield<br>Minimum: 1.5” thick  | N/A                                       | N/A                                    |
| <br>  |   |  |
| <u>Top Insulation Layer (Optional):</u>               | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| Sarnatherm, ENRGY 3, H-Shield<br>Minimum: 1.5 ” thick | N/A                                       | N/A                                    |

**Note: All insulation shall be adhered to the deck or vapor barrier in ICP Adhesives CR-20 applied in continuous 3-inch ribbons spaced 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at a rate of 0.75 gal/sq. to the insulation using a ¼” x ¼” notched squeegee. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -225.0 psf. (See General Limitation #9)



|                          |  |
|--------------------------|--|
| <b>Membrane Type:</b>    | Single Ply, PVC  |
| <b>Deck Type 3I:</b>     | Concrete, Insulated  |
| <b>Deck Description:</b> | Minimum 2500 psi structural concrete or concrete plank   |
| <b>System Type B(1):</b> | Base Layer of insulation mechanically attached, optional top insulation layer fully adhered with approved asphalt, membrane adhered. |

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved vapor barrier approved for use with hot asphalt may be applied to the deck.

**Fire Barrier (Optional):** Minimum ¼” Type X Gypsum or DensDeck

One or more layers of any of the following insulations:

| <b><u>Base Insulation Layer:</u></b>   | <b><u>Insulation Fasteners<br/>(Table 3)</u></b> | <b><u>Fastener Density/ft<sup>2</sup></u></b> |
|--|--|---|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, H-Shield<br>Minimum 1.3” thick or tapered                          | 1, 5, 7, 8 & 16                                  | 1:2 ft <sup>2</sup>                           |
| Minimum 2” thick or tapered  | 1, 5, 7, 8 & 16                                  | 1:4 ft <sup>2</sup>                           |
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered | 1, 5, 7, 8 & 16                                  | 1:3 ft <sup>2</sup>                           |
| Minimum 2” thick or tapered  | 1, 5, 7, 8 & 16                                  | 1:4 ft <sup>2</sup>                           |
| DensDeck Prime<br>Minimum ¼” thick   | 1, 5, 7, 8 & 16                                  | 1:1.2 ft <sup>2</sup>                         |
| Minimum ½” thick   | 1, 5, 7, 8 & 16                                  | 1:1.7 ft <sup>2</sup>                         |

**Note:** Base layers of insulation shall be mechanically attached with fasteners and density described above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

| <b><u>Top Insulation Layer (Optional):</u></b>   | <b><u>Insulation Fasteners<br/>(Table 3)</u></b> | <b><u>Fastener Density/ft<sup>2</sup></u></b> |
|--|--|---|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered  | N/A  | N/A   |
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered | N/A  | N/A   |
| DensDeck Prime<br>Minimum ¼” thick   | N/A  | N/A   |



**Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive rolled applied as a primer at a rate of 1.0-1.25gal/sq. to the substrate allowed to dry. Following a second coat roller applied of adhesive at a rate 1.0 gal/sq. or with Sarnacol 2121 adhesive roller applied at 0.75 gal./sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

(*With ISO*) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

(*With DensDeck Prime*) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

(*With ACFoam-II, ACFoam-III, Sarnatherm (a), Sarnatherm-25 PSI or DensDeck Prime*) Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

Or

(*With ACFoam-II, ACFoam-III, Sarnatherm (a), Sarnatherm-25 PSI or DensDeck Prime*) Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq or with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure:**

-45 psf. (See General Limitation #9)



|                          |  |
|--------------------------|--|
| <b>Membrane Type:</b>    | Single Ply, PVC  |
| <b>Deck Type 3I:</b>     | Concrete, Insulated  |
| <b>Deck Description:</b> | Minimum 2500 psi structural concrete or concrete plank   |
| <b>System Type B(2):</b> | Base Layer of insulation mechanically attached, optional top insulation layer fully adhered with approved asphalt, membrane adhered. |

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved vapor barrier approved for use with hot asphalt may be applied to the deck.

**Fire Barrier (Optional):** Minimum ¼” Type X Gypsum or DensDeck

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, H-Shield<br>Minimum 1.3” thick or tapered                          | 3, 17 & 18                                      | 1:2 ft <sup>2</sup>                    |
| Minimum 2” thick or tapered  | 3, 17 & 18                                      | 1:4 ft <sup>2</sup>                    |
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered | 3, 17 & 18                                      | 1:3 ft <sup>2</sup>                    |
| Minimum 2” thick or tapered  | 3, 17 & 18                                      | 1:4 ft <sup>2</sup>                    |
| DensDeck Prime<br>Minimum ¼” thick   | 3, 17 & 18                                      | 1:1.2 ft <sup>2</sup>                  |
| Minimum ½” thick   | 3, 17 & 18                                      | 1:1.7 ft <sup>2</sup>                  |

**Note:** Base layers of insulation shall be mechanically attached with fasteners and density described above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

| <u>Top Insulation Layer (Optional):</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered  | N/A   | N/A                                    |
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, H-Shield<br>Minimum 1.4” thick or tapered | N/A   | N/A                                    |
| DensDeck Prime<br>Minimum ¼” thick   | N/A   | N/A                                    |



**Note: Optional top layer of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation boards used as a top layer shall be installed with the polyisocyanurate face down.**

**Membrane:** (With *ISO*) Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

(With *DensDeck Prime*) Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -45 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank  
**System Type C(1):** All layers of insulation simultaneously fastened; membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved vapor barrier approved for use with hot asphalt may be applied to the deck.

**Fire Barrier (Optional):** Minimum ¼” Type X Gypsum or DensDeck

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ACFoam Supreme, H-Shield<br>Minimum 1.3” thick or tapered                      | N/A                                       | N/A                                    |
| Sarnatherm, Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, ISO 95+ GL, H-Shield<br>Minimum 1.4” thick or tapered | N/A                                       | N/A                                    |
| DensDeck Prime<br>Minimum ¼” thick   | N/A                                       | N/A                                    |

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered  | 1, 5, 7, 8 & 16                           | 1:2 ft <sup>2</sup>                    |
| Minimum 2” thick or tapered  | 1, 5, 7, 8 & 16                           | 1:4 ft <sup>2</sup>                    |
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, ISO 95+ GL, H-Shield<br>Minimum 1.4” thick or tapered | 1, 5, 7, 8 & 16                           | 1:3 ft <sup>2</sup>                    |
| Minimum 2” thick or tapered  | 1, 5, 7, 8 & 16                           | 1:4 ft <sup>2</sup>                    |



**DensDeck, DensDeck Prime**

**Minimum ¼” thick**

**1, 5, 7, 8 & 16**

**1:1.2 ft<sup>2</sup>**

**Minimum ½” thick**

**1, 5, 7, 8 & 16**

**1:1.7 ft<sup>2</sup>**

**Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:**

Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive rolled applied as a primer at a rate of 1.0-1.25gal/sq. to the substrate allowed to dry. Following a second coat roller applied of adhesive at a rate of 1.0 gal/sq. or with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal./sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

Or

*(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI or DensDeck Prime)*  
Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.25” wide heat weld.

Or

*(With ACFoam-II, ACFoam-III, Sarnatherm (a) and Sarnatherm-25 PSI or DensDeck Prime)*  
Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq or with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.25” wide heat weld.

**Maximum Design**

**Pressure:**

-45 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank  
**System Type C(2):** All layers of insulation simultaneously fastened; membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Any UL or FM approved vapor barrier approved for use with hot asphalt may be applied to the deck.

**Fire Barrier (Optional):** Minimum ¼” Type X Gypsum or DensDeck

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---------------------------------------|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ACFoam Supreme, H-Shield<br>Minimum 1.3” thick or tapered                      | N/A                                   | N/A                                    |
| Sarnatherm, Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, ISO 95+ GL, H-Shield<br>Minimum 1.4” thick or tapered | N/A                                   | N/A                                    |
| DensDeck Prime<br>Minimum ¼” thick   | N/A                                   | N/A                                    |

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---------------------------------------|--|
| Sarnatherm (a), Sarnatherm-25 PSI, ACFoam-II, ACFoam-III<br>Minimum 1.3” thick or tapered  | 3, 17 & 18                            | 1:2 ft <sup>2</sup>                    |
| Minimum 2” thick or tapered  | 3, 17 & 18                            | 1:4 ft <sup>2</sup>                    |
| Sarnatherm (a), Sarnatherm, Sarnatherm-25 PSI, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, ISO 95+ GL, H-Shield<br>Minimum 1.4” thick or tapered | 3, 17 & 18                            | 1:3 ft <sup>2</sup>                    |
| Minimum 2” thick or tapered  | 3, 17 & 18                            | 1:4 ft <sup>2</sup>                    |



**DensDeck, DensDeck Prime**

**Minimum ¼” thick**

**3, 17 & 18**

**1:1.2 ft<sup>2</sup>**

**Minimum ½” thick**

**3, 17 & 18**

**1:1.7 ft<sup>2</sup>**

**Note: All layers shall be simultaneously fastened; see top layer for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:**

Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design**

**Pressure:**

-45 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type C(3):** All layers of insulation simultaneously fastened; membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Any approved polyisocyanurate listed in Table 2<br>Minimum 1.5" thick | N/A                                       | N/A                                    |

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

| <u>Top Insulation Layer:</u>         | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--------------------------------------|---|--|
| DensDeck Prime<br>Minimum 5/8" thick | 7 & 8                                     | 1:2 ft <sup>2</sup>                    |

**Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive roller applied at a rate of 0.75 gal/sq. to the substrate or adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. or with Sarnacol AD or Sarnacol OM Feltback Membrane Adhesive in 0.5" wide ribbons spaced 12" o.c. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.

Or

Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2121 adhesive roller applied at 0.75 gal/sq. to the insulation or with Sarnacol 2170 adhesive applied at 0.75-2 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.

Or



Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied to the substrate at a rate of 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.

**Maximum Design Pressures:**

-52.5 psf; with Felt membranes (See General Limitation #7)

-60.0 psf; with Non-Felt membranes (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type C(4):** All layers of insulation simultaneously fastened; membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>   | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Any approved polyisocyanurate listed in Table 2<br>Minimum 1.5" thick | N/A                                       | N/A                                    |

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

| <u>Top Insulation Layer:</u>         | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--------------------------------------|---|--|
| DensDeck Prime<br>Minimum 5/8" thick | 7 & 8                                     | 1:2 ft <sup>2</sup>                    |

**Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** Sikaplan Adhered with Sikaplan Water Based Membrane Adhesive roller applied at 0.75 gal/sq. to the insulation. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a minimum 1.25" wide heat weld.

**Maximum Design Pressures:** -60.0 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank.  
**System Type C(5):** All layers of insulation simultaneously fastened; membrane adhered using RhinoBond plate bonding tool.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>              | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm, H-Shield<br>Minimum 1.5" thick | N/A                                       | N/A                                    |

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

| <u>Top Insulation Layer (Optional):</u>                           | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Any approved cover board listed in Table 2<br>Minimum 0.25" thick | 10, 14 & 15 (#14)                         | See Design Pressure                    |

**Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** Sarnafil S327 or S327 (10 ft) bonded to RhinoBond Insulation Plates with RhinoBond Plate bonding tool at 6 seconds per plate so the tool reaches 400°F. Minimum 3" wide side lap is sealed with a minimum 3/4" wide heat weld.

|                                  | <b>Maximum Pressure</b>                | <b>Fastener Spacing</b> | <b>Fastener Row Spacing</b> |
|----------------------------------|--|-------------------------|-----------------------------|
| <b>Maximum Design Pressures:</b> | -45 psf<br>(See General Limitation #7) | 2 ft.                   | 3 ft.                       |
|                                  | -60 psf<br>(See General Limitation #7) | 2 ft.                   | 2 ft.                       |



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank.  
**System Type C(6):** All layers of insulation simultaneously fastened; membrane adhered using RhinoBond plate bonding tool.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>              | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm, H-Shield<br>Minimum 1.5" thick | N/A                                       | N/A                                    |

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

| <u>Top Insulation Layer (Optional):</u>                           | <u>Insulation Fasteners<br/>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| Any approved cover board listed in Table 2<br>Minimum 0.25" thick | 10, 14 & 17                               | See Design Pressure                    |

**Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** Sikaplan Fastened or Sikaplan Fastened Feltback bonded to Sikaplan RhinoBond Disc, Sarnadisc RhinoBond with RhinoBond Plate bonding tool at 6 seconds per plate so the tool reaches 400°F. Minimum 3" wide side lap is sealed with a minimum 3/4" wide heat weld.

|                                  | <b>Maximum Pressure</b>                | <b>Fastener Spacing</b> | <b>Fastener Row Spacing</b> |
|----------------------------------|--|-------------------------|-----------------------------|
| <b>Maximum Design Pressures:</b> | -45 psf<br>(See General Limitation #7) | 2 ft.                   | 3 ft.                       |
|                                  | -60 psf<br>(See General Limitation #7) | 2 ft.                   | 2 ft.                       |



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type C(7):** All layers of insulation simultaneously fastened; membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

| <u>Base Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, ACFoam-II, ACFoam-III, ACFoam-IV, H-Shield<br>Minimum: 1.5” thick                       | N/A   | N/A                                    |
| <u>Top Insulation Layer:</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
| DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board, SECUROCK Glass-Mat Roof Board, Invinsa Roof Board, H-Shield HD<br>Minimum 0.5” thick | 8 with 15 (#12)                                 | 1:1 ft <sup>2</sup>                    |

**Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** Sarnafil S327 Felt, G410 Felt or Textured G410 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive applied in four rows of 0.5” wide ribbons spaced 12” o.c. and rolled with a weighted roller. Minimum 1.5” wide side lap heat weld.  
 Or  
 Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 VC adhesive applied at 0.75 gal/sq. to the substrate and 0.5 gal/sq. to the back of the membrane or Sarnafil G410 Felt or S327 Felt adhered with Sarnacol 2170 VC adhesive applied to the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure:** -120.0 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi concrete or concrete plank  
**System Type D(1):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8” Type X Gypsum or 1/4” DensDeck secured with Miami-Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4’ and not less than four fasteners for any board with any greater dimension than 4’.

|                                 |   |   |
|---------------------------------|---|---|
| <b><u>Insulation Layer:</u></b> | <b><u>Insulation Fasteners</u></b><br><b><u>(Table 3)</u></b> | <b><u>Fastener Density/ft<sup>2</sup></u></b> |
|---------------------------------|---|---|

**Any approved cover board listed in Table 2**  
**Minimum 1.5” thick**

**N/A**

**N/A**

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sikaplan Fastened or Sikaplan Fastened Feltback attached to deck as specified below.  
  
 Sarnafastener-XP, Sarnafastener Concrete or Sikaplan #14 fasteners with Sarnadisc XPN plates spaced 6” o.c. within 5.5” wide side laps spaced maximum 114.5” o.c. Laps are sealed with a minimum 0.5” wide outside edge heat weld.

**Maximum Design Pressures:** -45.0 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type D(2):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8" Type X Gypsum, 1/4" DensDeck secured with Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4' and not less than four fasteners for any board with any greater dimension than 4'.

| <u>Insulation Layer:</u>   | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---|--|
| <u>Any approved cover board listed in Table 2</u><br><u>Minimum 1.3" thick</u> | <u>N/A</u>                                      | <u>N/A</u>                             |

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sikaplan Fastened or Sikaplan Fastened Feltback attached to deck as specified below with Sarnarail Polymer Batten Strips spaced at 14.5" o.c. within a 5.5" wide lap.  
  
Sarnafastener-XP, Sarnafastener Concrete or Sikaplan #14 fasteners spaced 6" o.c. through batten strip. Batten strip is lapped 8" and sealed with a 1.25" wide heat weld on outside edge and a 0.75" wide heat weld on inside edge.

**Maximum Design Pressures:** -52.5 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type D(3):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8" Type X Gypsum, 1/4" DensDeck secured with Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4' and not less than four fasteners for any board with any greater dimension than 4'.

| <u>Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| <b>Any approved cover board listed in Table 2</b><br><b><u>Minimum 1.3" thick</u></b> | <u>N/A</u>                                      | <u>N/A</u>                             |

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sikaplan Fastened or Sikaplan Fastened Feltback attached to deck as specified below.  
 Sarnafastener-XP, Sarnafastener Concrete or Sikaplan #14 fasteners with Sarnadisc-XP plates spaced 6" o.c. within 5.5" wide laps spaced 14.5" o.c. Laps are sealed with a 1.75" wide heat weld on outside edge of lap.

**Maximum Design Pressures:** -60.0 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 2I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type D(4):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8" Type X Gypsum, 1/4" DensDeck secured with Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4' and not less than four fasteners for any board with any greater dimension than 4'.

| <u>Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| <b>Any approved cover board listed in Table 2</b><br><b><u>Minimum 1.5" thick</u></b> | <u>N/A</u>                                      | <u>N/A</u>                             |

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sarnafil S327 or S327 (10 ft) attached to deck as specified below with Sarnarail Polymer Batten Strips.

Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners spaced 6" o.c. through batten strip spaced maximum 144" o.c. within the 5.5" wide side lap. Batten strip splice joints are made by overlapping the batten 12" and securing with two Sarnafastener XP screws spaced 6" o.c. Laps are sealed with at 1.5" wide heat weld on the outside edge and 1.0" wide heat weld on the inside edge.

**Maximum Design Pressures:** -60.0 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 2I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type D(5):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8” Type X Gypsum, 1/4” DensDeck secured with Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4’ and not less than four fasteners for any board with any greater dimension than 4’.

| <u>Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| <b>Any approved cover board listed in Table 2</b><br><b><u>Minimum 1.5” thick</u></b> | <u>N/A</u>                                      | <u>N/A</u>                             |

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sikaplan Fastened or Sikaplan Fastened Feltback attached to deck as specified below with Sarnarail Polymer Batten Strips.

Sarnafastener-XP, Sarnafastener Concrete or Sikaplan #14 fasteners spaced 6” o.c. through batten strip spaced maximum 144” o.c. within the 5.5” wide side lap. Batten strip splice joints are made by overlapping the batten 12” and securing with two Sarnafastener XP screws spaced 6” o.c. Laps are sealed with at 1.5” wide heat weld on the outside edge and 1.0” wide heat weld on the inside edge.

**Maximum Design Pressures:** -60.0 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Min. 2500 psi structural concrete or concrete plank  
**System Type D(6):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8" Type X Gypsum, 1/4" DensDeck secured with Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4' and not less than four fasteners for any board with any greater dimension than 4'.

| <u>Insulation Layer:</u>  | <u>Insulation Fasteners</u><br><u>(Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|---|---|--|
| <b>Any approved cover board listed in Table 2</b><br><b><u>Minimum 1.5" thick</u></b> | <u>N/A</u>                                      | <u>N/A</u>                             |

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sikaplan Fastened or Sikaplan Fastened Feltback attached to deck as specified below.  
 Sarnafastener-XP, Sarnafastener Concrete, Sikaplan #14 fasteners or OMG Large Head #15 Roofgrip fasteners with 3/4" wide Sarnarail Polymer Batten Strip spaced 6" o.c. within 5.5" wide side laps spaced maximum 114.5" o.c. Batten Strip is lapped 8" within lap to provide a minimum 2 screw securement in lap. Laps are sealed with a minimum 1.25" wide outside edge heat weld and minimum 0.75" wide inside edge heat weld.

**Maximum Design Pressures:** -60.0 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type D(7):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnvap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8" Type X Gypsum or 1/4" DensDeck secured with Miami-Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4' and not less than four fasteners for any board with any greater dimension than 4'.

One or more layers of the following insulations:

| <u>Insulation Layer:</u>   | <u>Insulation Fasteners (Table 3)</u> | <u>Fastener Density/ft<sup>2</sup></u> |
|--|---------------------------------------|--|
| Any approved Polyisocyanurate insulation board listed in Table 2<br>Minimum 1.5" thick | N/A                                   | N/A                                    |

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sarnafil S327 attached to deck as specified below with Sarnarail Polymer Batten Strips.

**Fastening #1:** Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners spaced 12" o.c. through batten strip spaced maximum 73.25" o.c. within the 5.5" wide side lap. Batten strip splice joints are made by overlapping the batten 18" and securing with two Sarnafastener XP, Sarnafastener Concrete or Sarnafastener #14 fasteners spaced 12" o.c. Laps are sealed with at 1.5" wide heat weld on the outside edge and 1.0" wide heat weld on the inside edge.  
**Maximum Design Pressure -45.0 psf. (See General Limitation #7)**

**Fastening #2:** Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners spaced 6" o.c. through batten strip spaced maximum 73.25" o.c. within the 5.5" wide side lap. Batten strip splice joints are made by overlapping the batten 12" and securing with two Sarnafastener XP, Sarnafastener Concrete or Sarnafastener #14 fasteners spaced 6" o.c. Laps are sealed with at 1.5" wide heat weld on the outside edge and 1.0" wide heat weld on the inside edge.  
**Maximum Design Pressure -75.0 psf. (See General Limitation #7)**

**Maximum Design Pressures:** See Fastening Pattern. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank  
**System Type D(8):** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8" Type X Gypsum, 1/4" DensDeck, secured with Miami-Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4' and not less than four fasteners for any board with any greater dimension than 4'.

| <u>Base Insulation Layer</u>  | <u>Fastener Density/ft<sup>2</sup></u> | <u>Fastener Type</u> |
|---|--|----------------------|
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, ACFoam-II, ACFoam-III, ACFoam Composite (bottom layer only), ACFoam Supreme, H-Shield<br>Minimum 1.3" thick or tapered | N/A                                    | N/A                  |
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, ACFoam-II, ACFoam-III, ENRGY-3, ENRGY 3 25 PSI, ISO 95+ GL, H-Shield<br>Minimum 1.4" thick or tapered                  | N/A                                    | N/A                  |
| DensDeck, DensDeck Prime<br>Minimum 1/4" thick  | N/A                                    | N/A                  |

**Note: All insulation shall have preliminary attachment prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft. and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sarnafil S327, S327 (10 ft), Sikaplan Fastened or Sikaplan Fastened Feltback attached to deck as specified below.

**Fastening #1:** *(Not with S327 (10 ft), Sikaplan Fastened or Sikaplan Fastened Feltback)* SFS Dekfast 14, Dekfast 15 HS, Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners with approved discs spaced 6" o.c. within the minimum 5.5" side lap spaced maximum 73" o.c. and sealed a minimum 1.5" weld on each side of the sheet.  
**Maximum Design Pressure: -52.5 psf. (See General Limitation #7)**

**Fastening #2:** *(With S327 (10 ft), Sikaplan Fastened and Sikaplan Fastened Feltback)* Sarnafastener with Sarnabars spaced 12' o.c. maximum fastened with Sarnafastener spaced 6" o.c. through the field of the membrane and covered with a 7" minimum width cover strip with minimum 1.5" welds on each side of the sheet.  
**Maximum Design Pressure: -52.5 psf. (See General Limitation #7)**



- Fastening #3:** *(Not with S327 (10 ft), Sikaplan Fastened or Sikaplan Fastened Feltback)* Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners with approved plates spaced maximum 6" o.c. within the minimum 5.5" wide side laps. Laps spaced maximum 73.5" apart and sealed with minimum 1.5" wide heat weld.  
**Maximum Design Pressure:** *-75 psf. (See General Limitation #7)*
- Fastening #4:** *(Not with S327 (10 ft), Sikaplan Fastened or Sikaplan Fastened Feltback)* Sarnabar spaced maximum 4.5' o.c. secured to deck with Sarnafastener-Concrete or CD-10 fasteners spaced maximum 12" o.c. A 9" wide cover strip was heat welded over the batten bars using 1.5" wide heat weld on the edges of each strip.  
**Maximum Design Pressure:** *-120 psf. (See General Limitation #7)*
- Fastening #5:** *(Not with S327 (10 ft), Sikaplan Fastened or Sikaplan Fastened Feltback)* Sarnabar spaced maximum 4.5' o.c. secured to deck with Sarnafastener-Concrete or CD-10 fasteners spaced maximum 6" o.c. A 9" wide cover strip was heat welded over the batten bars using 1.5" wide heat weld on the edges of each strip.  
**Maximum Design Pressure:** *-232.5 psf. (See General Limitation #7)*
- Maximum Design Pressure:** See Above for fastening



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type D(9):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.  
**Fire Barrier (Optional):** Minimum 5/8" Type X Gypsum, 1/4" DensDeck secured with Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4' and not less than four fasteners for any board with any greater dimension than 4'.

|                                 |   |   |
|---------------------------------|---|---|
| <b><u>Insulation Layer:</u></b> | <b><u>Insulation Fasteners</u></b><br><b><u>(Table 3)</u></b> | <b><u>Fastener Density/ft<sup>2</sup></u></b> |
|---------------------------------|---|---|

Any approved cover board listed in Table 2

|                                  |                   |                   |
|----------------------------------|-------------------|-------------------|
| <b><u>Minimum 1.5" thick</u></b> | <b><u>N/A</u></b> | <b><u>N/A</u></b> |
|----------------------------------|-------------------|-------------------|

**Note: All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.**

**Membrane:** Sarnafil S327 attached to deck as specified below.

**Fastening #1:** Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners and Sarnarail Polymer Batten Strip spaced 12" o.c. within 5.5" wide side laps spaced maximum 54" o.c. Laps are sealed with a minimum 1" wide outside heat weld and a minimum 5/8" wide inside heat weld.  
**Maximum Design Pressure -52.5 psf. (See General Limitation #7)**

**Fastening #2:** Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners and Sarnadisc XPN plates spaced 12" o.c. within 5.5" wide side laps spaced maximum 54" o.c. Laps are sealed with a minimum 1.6" wide outside heat weld.  
**Maximum Design Pressure -60.0 psf. (See General Limitation #7)**

**Fastening #3:** Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners and Sarnadisc XPN plates spaced 6" o.c. within 5.5" wide side laps spaced maximum 54" o.c. Laps are sealed with a minimum 1.6" wide outside heat weld.  
**Maximum Design Pressure -90.0 psf. (See General Limitation #7)**

**Maximum Design Pressures:** See Fastening Pattern. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3I:** Concrete, Insulated  
**Deck Description:** Minimum 2500 psi concrete or concrete plank  
**System Type D(10):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Vapor Barrier (Optional):** Sarnavap-10 or a FM approved vapor barrier applied directly to the deck or over the base insulation layer.

**Fire Barrier (Optional):** Minimum 5/8” Type X Gypsum or 1/4” DensDeck, secured with Miami-Dade County approved insulation fasteners at not less than 2 fasteners for a board with no dimension greater than 4’ and not less than four fasteners for any board with any greater dimension than 4’.

**One or more of the following.**

| <u>Base Insulation Layer</u>  | <u>Fastener Density/ft<sup>2</sup></u> | <u>Fastener Type</u> |
|---|--|----------------------|
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, ACFoam-II, ACFoam-III, ACFoam Composite (bottom layer only), ACFoam Supreme, H-Shield<br>Minimum 1.3” thick or tapered | N/A                                    | N/A                  |
| Sarnatherm (a), Sarnatherm, Sarnatherm 25 PSI, ACFoam-II, ACFoam-III, ENRGY-3, ENRGY 3 25 PSI, ISO 95+ GL, H-Shield<br>Minimum 1.4” thick or tapered                  | N/A                                    | N/A                  |
| DensDeck, DensDeck Prime<br>Minimum 1/4” thick  | N/A                                    | N/A                  |

**Note:** All insulation shall have preliminary attachment, prior to the installation of the roofing membrane at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft.

**Membrane:** Sarnafil S327 attached to deck as specified below.

**Fastening #1:** Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners and plates spaced 12” o.c. within 5.5” wide side laps. Laps spaced 72.5” o.c. and sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure -45 psf. (See General Limitations # 7)*

**Fastening #2:** Sarnafastener-XP, Sarnafastener Concrete or Sarnafastener #14 fasteners and plates spaced 6” o.c. within 5.25” wide side laps. Laps spaced 73.5” o.c. and sealed with a 1.5” wide heat weld.  
*Maximum Design Pressure -60 psf. (See General Limitations # 7)*



**Fastening #3:**

Sarnabars spaced 3' o.c. maximum fastened with Sarnafasteners-XP spaced 6" o.c. through the field of the membrane and covered with a 7" minimum width cover strip with 1.5" welds on each side.

***Maximum Design Pressure -112.5 psf. (See General Limitations # 7)***

**Maximum Design Pressures:**

See Fastening Pattern. (See General Limitations # 7)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3:** Concrete, Non-Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank.  
**System Type F(1):** Membrane fully adhered to deck.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive in 0.5” wide ribbons spaced 12” o.c. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.  
Or  
Sarnafil G410, Textured G410, S327 or S327 (10 ft) adhered with Sarnacol 2170 adhesive roller applied to the substrate at a rate of 2 to 2.5 gal./sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -390 psf. (See General Limitation #9)

**Membrane Type:** Single Ply, PVC  
**Deck Type 3:** Concrete, Non-Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank.  
**System Type F(2):** Membrane fully adhered to deck.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** Sarnafil S327 Felt, G410 Felt or Textured G410 Felt adhered with Sarnacol AD Feltback Membrane Adhesive or Sarnacol OM Feltback Membrane Adhesive applied in four rows of 0.5” wide ribbons spaced 4” o.c. and rolled with a weighted roller. The adhesive will spread out after foaming to produce full coverage.  
Or  
Sarnafil G410 Felt or Textured G410 Felt adhered with Sarnacol 2170 VC adhesive applied to only the substrate in two coats with a total application rate of 2.0 gal/sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a minimum 1.25” wide heat weld.

**Maximum Design Pressure:** -495.0 psf. (See General Limitation #9)



**Membrane Type:** Single Ply, PVC  
**Deck Type 3:** Concrete, Non-Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank.  
**System Type F(3):** Membrane fully adhered to deck

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2170 adhesive roller applied to the substrate at a rate of 2.0 gal./sq. Roof cover immediately placed into adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -547.5 psf. (See General Limitation #9)

**Membrane Type:** Single Ply, PVC  
**Deck Type 3:** Concrete, Non-Insulated  
**Deck Description:** Minimum 2500 psi structural concrete or concrete plank.  
**System Type F(4):** Membrane fully adhered to deck.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Membrane:** Sarnafil G410 Felt, Textured G410 Felt or S327 Felt adhered with Sarnacol 2121 adhesive squeegee applied to the substrate at a rate of 2 to 2.5 gal./sq. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3” wide side lap is sealed with a 1.5” wide heat weld.

**Maximum Design Pressure:** -615 psf. (See General Limitation #9)



## CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117 and/or RAS 137, calculations shall be signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**