



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY, FLORIDA
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
T (786) 315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/economy

Continental Glass Systems, Inc.
325 West 74th Place
Hialeah FL, 33014

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/ or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "2000" Aluminum Sliding Glass Door – S.M.I.

APPROVAL DOCUMENT: Drawing No. **S.G.D-2000-SM**, titled "Series 2000 Sliding Glass Door Small Missile", sheets 1 through 10 of 10, dated 11/30/05, with revision "3" dated 07/12/16, prepared by manufacturer, dated 09/07/16, signed and sealed by Hermes F. Norero, P.E., bearing the Miami-Dade County Product Control Section Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **revises and renews** NOA No. **12-1120.10** and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Jorge M. Plasencia, P. E.**



[Signature]
11/08/2016

NOA No. 15-0827.18
Expiration Date: March 30, 2021
Approval Date: November 17, 2016
Page 1

Continental Glass Systems, Inc.

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
(Submitted under NOA No. 05-1220.19)
2. Drawing No. **S.G.D-2000-SM**, titled "Series 2000 Sliding Glass Door Small Missile", sheets 01 through 10 of 10, dated 11/30/05, with revision "3" dated 07/12/16, prepared by manufacturer, dated 09/07/16, signed and sealed by Hermes F. Norero, P.E.

B. TESTS

1. Test reports on:
 - 1) Air Infiltration Test, per FBC, TAS 202-94
 - 2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
 - 3) Water Resistance Test, per FBC, TAS 202-94
 - 4) Small Missile Impact Test per FBC, TAS 201-94
 - 5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
 - 6) Forced Entry Test, per FBC 2411.3.2.1, and TAS 202-94along with marked-up drawings and installation diagram of an aluminum sliding glass door, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-4724** dated 11/10/05, signed and sealed by Edmundo J. Largaespada, P.E.
(Submitted under NOA No. 05-1220.19)

C. CALCULATIONS

1. Anchor verification calculations and structural analysis, complying with **FBC 5th Edition (2014)**, dated 02/15/15 revised on 08/02/16, prepared by Building Drops, Inc., signed and sealed by Hermes F. Norero, P.E.
2. **Glazing complies with ASTM E1300-09**

D. QUALITY ASSURANCE


1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **14-0423.15** issued to **Eastman Chemical Company (MA)** for their "**Saflex CP - Saflex and Saflex HP Composite Glass Interlayers with PET Core**" dated 06/19/14, expiring on 12/11/18.

F. STATEMENTS

1. Statement letter of no financial interest, conformance and complying with **FBC 5th Edition (2014)**, issued by Building Drops, Inc., signed, sealed and dated 02/15/16 by Hermes F. Norero, P.E.



Jorge M. Plasencia, P. E.
Product Control Unit Supervisor
NOA No. 15-0827.18
Expiration Date: March 30, 2021
Approval Date: November 17, 2016

Continental Glass Systems, Inc.


NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

F. STATEMENTS (CONTINUED)

2. Notification of Successor Engineer for manufacturer's NOA document per **Section 61G15-27.001** of the **Florida Administrative Code**, notifying original engineer that the successor engineer is assuming full professional and legal responsibility for all engineering documents pertaining to this NOA, dated 02/15/15, signed and sealed by Hermes F. Norero, P.E.
3. Laboratory compliance letter for Test Report No. **FTL-4724**, issued by Fenestration Testing Laboratory, Inc., dated 11/10/05, signed and sealed by Edmundo J. Largaespada, P.E.
(Submitted under NOA No. 05-1220.19)

G. OTHERS


1. Notice of Acceptance No. **12-1120.10**, issued to Continental Glass Systems, Inc. for their Series "2000" Aluminum Sliding Glass Door – SMI, approved on 02/14/13 and expiring on 03/30/16.



Jorge M. Plasencia, P. E.
Product Control Unit Supervisor
NOA No. 15-0827.18
Expiration Date: March 30, 2021
Approval Date: November 17, 2016

DOORS ELEVATION / EXTERIOR VIEW

HEAD RECEPTOR




DESIGN LOAD CAPACITY (P.S.F.)					
DOOR HEIGHT	POSITIVE	NEGATIVE	SECTION	JAMB	REINFORCING
120"	53	53	SHEET 5	NOT REQUIRED	
120"	80	80	SHEET 5	YES, 3/8"x4" AL. BAR	
120"	110	110	SHEET 6	YES, 1/4"x4" STEEL BAR	
120"	140	140	SHEET 7	YES, 3/8"x4" STEEL BAR	
108"	80	80	SHEET 5	NOT REQUIRED	
108"	110	110	SHEET 6	YES, 3/8"x4" AL. BAR	
108"	140	140	SHEET 7	YES, 1/4"x4" STEEL BAR	

SERIES 2000 ALUMINUM SLIDING GLASS DOOR.

NOTES:

1. THIS SLIDING GLASS DOOR SYSTEM IS DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE 5TH EDITION (2014) FLORIDA BUILDING CODE (FBC) CHAPTERS 16 AND 24, UNDER THE SPECIFIC CONDITION SHOWN ON THIS DRAWING. REF. FTL No. 4724 DATE 10th NOV. 2005
2. ALL EXTRUSIONS ARE ALUMINUM, 6005-T5 WITH A MINIMUM Fy OF 35.000 P.S.I. U.O.N.
3. SMALL MISSILE IMPACT: INSTALLATION UP TO 30 FT ABOVE GRADE WILL REQUIRE A HURRICANE PROTECTION SYSTEM. BUT FOR INSTALLATION ABOVE 30FT ABOVE GRADE WILL NOT REQUIRE A HURRICANE PROTECTION SYSTEM.
4. ALL ANCHORS ARE 5/16" ELCO ULTRACONS WITH 1 3/4" MIN. EMBEDMENT INTO 3515 PSI CONCRETE OR BETTER.
5. SHIMS. USE HARD PLASTIC.
6. ADD ANCHORS SHOWN AT SILL WHEN DESIGN LOAD IS 140 P.S.F.
7. APPROVED STRUCTURAL SILICONE:

- A) 795 DOW CORNING
- B) SCS 2000 BY GE
- C) PROGLAZE SSG BY TREMCO
- D) DOW CORNING CONTRACTORS WEATHERPROOFING SEALANT
- 8. APPROVED PERIMETER SILICONE SEALANT: 790 & 795 DOW CORNING



GLAZING DETAIL

Continental Glass Systems LLC.
325 West 74 Place
Hialeah Florida, 33014
Phone 305-231-1101 Fax 305-231-1109

Series 2000
Sliding Glass Door
SMALL MISSILE


Revision		Description	
No	Date	By	Rev
1	01-01-2013	R.P.	INITIAL
2	01-14-2013	M.R.P.	PRODUCT CONTROL
3	07-18-2016	S.M.	2014 CODE CHANGE

Date: 06.27.2019
Scale:
Design by: G.S.
Drawing by: RICHARD
Checked by: G.S.
Drawing No. S.G.D-2000-SM
Sheet 1 of 10



APPROVED

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. 15-0827.18
Expiration Date 03/30/2021

By: *[Signature]*
Miami-Dade Product Control



HEAD STANDARD FRAME



DOORS ELEVATION / EXTERIOR VIEW

DOOR HEIGHT	DESIGN LOAD CAPACITY (P.S.F.)		SECTION	JAMB REINFORCING
	POSITIVE	NEGATIVE		
120"	53	53	SHEET 5	NOT REQUIRED
120"	80	80	SHEET 5	YES, 3/8"x4" AL. BAR
120"	110	110	SHEET 6	YES, 1/4"x4" STEEL BAR
108"	80	80	SHEET 5	NOT REQUIRED
108"	110	110	SHEET 6	YES, 3/8"x4" AL. BAR

Continental Glass Systems LLC.
325 West 74 Place
Hialeah Florida, 33014
Phone 305-231-1101 Fax 305-231-1103

Series 2000
Sliding Glass Door
SMALL MISSILE


REVISION		Date	Description
No.	By		
A	01-01-2011	R. F.	RENEWAL
B	11-14-2012	M.E.P.	PRODUCT CONTROL
C	07-12-2016	S.I.M.	2014 CODE CHANGE

Date: 08.27.2013
Scale:
Design by: |G. S.
Drawing by: |RICHARD
Checked by: |G. S.
Drawing No.: S.G.D-2000-SM
Sheet 2 of 10

APPROVED


PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. **15-0827.18**
Expiration Date **03/30/2021**

By: *[Signature]*
Miami-Dade Product Control



HEAD RECEPTOR

5/16 ϕ ELCO ULTRACONS
1 3/4" MIN. EMBEDMENT TYP.




5/16 ϕ ELCO ULTRACON
1 3/4" MIN. EMBEDMENT
TYP.

APPROVED

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **15-0827.18**
Expiration Date **03/30/2021**

By *[Signature]*
Miami-Dade Product Control



Revision			
No	Date	By	Description
A	01-01-2011	R.F.	RENEWAL
A	11-14-2012	M.E.P.	PRODUCT CONTROL
A	07-18-2016	S.L.M.	2014 CODE CHANGE

Date: 08.27.2019
Scale:
Design by: G. E.
Drawing by: RICHARD
Checked by: G. E.
Drawing No.: S.G.D-2000-SM
Sheet 3 of 10


Series 2000
Sliding Glass Door
SMALL MISSILE

Continental Glass Systems LLC.
325 West 74 Place
Hialeah Florida, 33014
Phone 305-231-1101 Fax 305-231-1103

HEAD STANDARD FRAME

5/16 ϕ ELCO ULTRACONS
1 3/4" MIN. EMBEDMENT TYP.

CONCRETE (3515 PSI)
OR BETTER



5/16 ϕ ELCO ULTRACON
1 3/4" MIN. EMBEDMENT
TYP.

PERIMETER
SEALANT

PAD

C

B1

INTERIOR

EXTERIOR

1/4" MAX.

MASONRY OPENING
120"


DOOR HEIGHT
119 1/2"

116 13/16" PANEL HEIGHT (MAX.)

APPROVED

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **15-0827.18**
Expiration Date **03/30/2021**

By *[Signature]*
Miami-Dade Product Control



Revision			
No	Date	By	Description
1	03-01-2011	R.F.	REVISION
2	11-14-2012	M.E.P.	PRODUCT CONTROL
3	07-19-2018	S.L.M.	2014 CODE CHANGE

Date: 08.27.2015
Scale:
Design by: G.S.
Drawing by: RICHARD
Checked by: G.S.
Drawing No.: S.G.D-2000-SM
Sheet 4 of 10

Series 2000
Sliding Glass Door
SMALL MISSILE


Continental Glass Systems LLC.
325 West 74 Place
Hialeah Florida, 33014
Phone 305-231-1101 Fax 305-231-1103

Continental Glass Systems LLC.
 325 West 74 Place
 Hialeah Florida, 33014
 Phone 305-231-1101 Fax 305-231-1103

Series 2000
 Sliding Glass Door
 SMALL, MISSILE



Revision	
No	Description
A	01-01-2011 R.F. INITIAL
B	11-14-2018 M.R.P. PRODUCT CONTROL
C	07-12-2016 E.L.M. 2014 CODE CHANGE

Date: 08.27.2015
 Scale:
 Design by: G.S.
 Drawing by: RICHARD
 Checked by: G.S.
 Drawing No.: S.G.D-2000-SM
 Sheet 5 of 10




EXTERIOR



MAX DESIGN LOAD
 80 PSF POSITIVE
 80 PSF NEGATIVE
 (SEE TABLES ON SHEETS 1&2 FOR ALLOWABLE LOADS DEPENDENT ON HEIGHT AND JAMB REINFORCING)



NOTES:
 1. BACKER ROD DIAMETER EQUALS SEAL WIDTH x 120%
 2. SEALANT DEPTH IS :
 1/2" FOR WIDTHS UP TO 1" AND
 5/8" FOR WIDTHS OVER 1"

APPROVED
PRODUCT REVISED
 as complying with the Florida Building Code
 NOA-No. **15-0827.18**
 Expiration Date **03/30/2021**
 By _____
 Miami-Dade Product Control





EXTERIOR

MAX DESIGN LOAD
 110 PSF POSITIVE
 110 PSF NEGATIVE
 (SEE TABLES ON SHEETS 1&2 FOR ALLOWABLE LOADS DEPENDENT ON HEIGHT AND JAMB REINFORCING)

NOTES:
 1. BACKER ROD DIAMETER EQUALS SEAL WIDTH x 120%
 2. SEALANT WIDTH TO DEPTH RATIO SHALL BE 2:1 FOR WIDTHS UP TO 1" FOR WIDTHS OVER 1" USE 1/2" DEPTH.

Continental Glass Systems LLC.
 325 West 74 Place
 Hialeah Florida, 33014
 Phone 305-231-1101 Fax 305-231-1103

Series 2000
 Sliding Glass Door
 SMALL MISSILE


Revision	
No	Description
1	REVISION
2	PRODUCT CONTROL
3	2014 CODE CHANGE

Date: 08.27.2015
 Scale:
 Design by: G. S.
 Drawing by: RICHARD
 Checked by: G. S.
 Drawing No.: S.G.D-2000-SM
 Sheet 6 of 10

APPROVED

PRODUCT REVISED
 as complying with the Florida Building Code
 NOA-No. 15-0827.18
 Expiration Date 03/30/2021

By: *[Signature]*
 Miami-Dade Product Control





Continental Glass Systems LLC.
325 West 74 Place
Hialeah Florida, 33014
Phone 305-231-1101 Fax 305-231-1103

Series 2000
Sliding Glass Door
SMALL MISSILE

Revision	
No	Description
1	REVISION
2	PRODUCT CONTROL
3	2014 CODE CHANGE


Date: 08/27/2013
Scale:
Design by: G. S.
Drawing by: RICHARD
Checked by: G. S.
Drawing No.: S.G.D-2000-SM
Sheet 7 of 10



EXTERIOR

ALUM. ANGLE AT FRONT OF LOCKSTILE & ASTRAGAL ATTACHED WITH (2) GR.5 #14 X 1\"/>

- NOTES:**
1. BACKER ROD DIAMETER EQUALS SEAL WIDTH x 120%
 2. SEALANT WIDTH TO DEPTH RATIO SHALL BE 2:1 FOR WIDTHS UP TO 1\"/>







MAX DESIGN LOAD
140 PSF POSITIVE
140 PSF NEGATIVE
(SEE TABLE ON SHEET 1 FOR ALLOWABLE LOADS DEPENDENT ON HEIGHT AND JAMB REINFORCING)

APPROVED

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. **15-0827.18**
Expiration Date **03/30/2021**

By: *[Signature]*
Miami-Dade Product Control





Continental Glass Systems LLC.
 325 West 74 Place
 Hialeah Florida, 33014
 Phone 305-231-1101 Fax 305-231-1103

Series 2000
 Sliding Glass Door
 SMALL MISSILE

Revision	
No	Date
A	01-01-2011
A	11-14-2012
A	07-18-2016

Date	06.27.2013
Scale	
Design by	G. S.
Drawing by	RICHARD
Checked by	G. S.
Drawing No.	S.G.D-2000-SM
Sheet	8 of 10


APPROVED

PRODUCT REVISED
 as complying with the Florida
 Building Code
 NOA-No. 15-0827.18
 Expiration Date 03/30/2021


By [Signature]
 Miami-Date Product Control

ELEVATION


HERMES F. NORERO
 LICENSE
 No. 73778
 STATE OF
 FLORIDA
 9-7-2016
 HERMES F. NORERO, P.E.
 390 S. DANA BEACH BLVD #308
 DANA BEACH FL 33404
 P.E. CERT. # 29578




② HEAD RECEPTOR




⑤ TOP AND BOTTOM PANEL STILE




⑧ THRESHOLD




⑨ SILL




⑩ REINFORCING




⑪ RECEPTOR




⑫ BOTTOM MOVING PANEL STILE




⑬ SILLTRACK




⑭ SCREEN TRACK




⑮ STANDARD HEAD




⑯ FIXED STILE




⑰ INTERLOCK




⑱ LEFT INTERLOCK




⑲ HEAVY ASTRAGAL




⑳ LOCK STILE




㉑ ASTRAGAL




㉒ JAMB




㉓ HEAVY INTERLOCK




㉔ BAR




㉕ ANGLE




㉖ ALUM. BAR




㉗ STEEL BAR



㉘ STEEL BAR



㉙ ANGLE



㉕ ANGLE

APPROVED

PRODUCT REVISED
as complying with the Florida Building Code
NOA-No. **15-0827.18**
Expiration Date **03/30/2021**

By *[Signature]*
Miami-Dade Product Control

Revision Table:

No	Date	By	Description
A	01-01-2011	R.P.	REVISION
A	11-14-2011	M.F.P.	PRODUCT CONTROL
A	07-18-2014	J.M.	2014 CODE CHANGE

Date: 08/27/2015
Scale:
Design by: G.S.
Drawing by: RICHARD
Checked by: G.S.
Drawing No.: S.G.D-2000-SM
Sheet 8 of 10


HERMES E. NOREÑO, P.E.
398 S. DANIA BEACH BLVD., #200
DANIA BEACH, FL 33004
FBPE/CPRE # 139378

Continental Glass Systems LLC.
325 West 74 Place
Hialeah Florida, 33014
Phone 305-231-1101 Fax 305-231-1103

Series 2000
Sliding Glass Door
SMALL MISSILE

SLIDING GLASS DOOR

ITEM NUMBER	PART NUMBER	PART NAME	REMARKS	ALLOY & TEMPERED
1	P 10009 AFK	HEAD PAD	ULTRAFAB	
2	2000 - 01	HEAD	FRAME	6005-T5
3	FP-448-V	VINYL BULB	PROTOTYPE PLASTIC EXTRUSION	
4		FIN-SEAL .370 x .187	ULTRAFAB	
5	2000-08	TOP & BOTTOM PANEL STILE	PANEL	6005-T5
6	P 7509 AFK	INTERLOCK PAD	ULTRAFAB	
7	CGS-01	GLASS SPACING	PROTOTYPE PLASTIC EXTRUSION	
8	2000-06	THRESHOLD		6005-T5
9	2000-03	SILL	FRAME	6005-T5
10	2000-16	REINFORCING		6005-T5
11	2000-07	HEAD RECEPTOR		6005-T5
12	2000-09	BOTTOM MOVING PANEL PANEL	PANEL	6005-T5
14	AR-50A	WHEEL	DOOR & WINDOW HARDWARE	
15		FIN-SEAL .250 x .187	ULTRAFAB	
16	2000-05	SILL TRACK	FRAME	6005-T5
17	2000-15	SCREEN TRACK		6005-T5
18	2000-02	HEAD	FRAME	6005-T5
19	2000-13	FIXED STILE	PANEL	6005-T5
20	2000-11	INSIDE INTERLOCK	PANEL	6005-T5
21	D-60 C	LOCK	DOOR & WINDOW HARDWARE	
22	KP-50	KEEPER	DOOR & WINDOW HARDWARE	
23	2000-04	JAMB	FRAME	6005-T5
24	2000-12	HEAVY INTERLOCK	PANEL	6005-T5
25	2000-10	LOCK STILE	PANEL	6005-T5
26	2000-14	HEAVY ASTRAGAL	PANEL	6005-T5
27	2000-17	OUTSIDE INTERLOCK	PANEL	6005-T5
28	2000-18	ASTRAGAL	PANEL	6005-T5
29		ALUM. ANGLE 3/16" x 1" x 1 1/2" x 5 1/4"	ONLY AT 140 P.S.F.	6063-T5
30		BAR 1/4" x 1 1/2" x 2 1/2"	ONLY AT 140 P.S.F.	6063-T5
31		ANGLE 1/4" x 2" x 3" x 1 1/2"	ONLY AT 140 P.S.F.	6063-T5
32	CGI-02	FIXED PANEL SUPPORT - HARD PLASTIC	TWO PER PANEL- AT EACH END	
33		REINFORCING ALUMINUM BAR	3/8" x 4" x 60"	6063-T5
34		REINFORCING STEEL BAR	1/4" x 4" x 60"	A36
35		REINFORCING STEEL BAR	3/8" x 4" x 60"	A36



Continental Glass Systems LLC.
 325 West 74 Place
 Hialeah, Florida, 33014
 Phone 305-831-1101 Fax 305-231-1103

Series 2000
 Sliding Glass Door
 SMALL MISSILE

Revision		Description
No	Date	By
1	01-01-2011	R. P. RENEWAL
2	11-14-2012	M.L.P. PRODUCT CONTROL
3	07-18-2016	B.L.M. 2014 CODE CHANGE

Date: 06.27.2019
 Scale:
 Design by: [signature]
 Drawing by: [signature]
 Checked by: [signature]
 Drawing No.: S.G.D-2000-SM
 Sheet 10 of 10

APPROVED

PRODUCT REVISED
 as complying with the Florida Building Code
 NOA-No. **15-0827.18**
 Expiration Date **03/30/2021**

By *[Signature]*
 Miami-Dade Product Control

