



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

**NOTICE OF ACCEPTANCE (NOA)**

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**IB Roof Systems**  
**8181 Jetstar Drive, Suite 150**  
**Irving, TX 75063**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: IB PVC Single Ply Roof Systems over Wood Decks.**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 11-0118.06 and consists of pages 1 through 6.  
The submitted documentation was reviewed by Jorge L. Acebo



NOA No.: 15-0928.12  
Expiration Date: 04/28/21  
Approval Date: 04/21/16  
Page 1 of 6

## ROOFING SYSTEM APPROVAL

|                                 |                    |
|---------------------------------|--------------------|
| <b>Category:</b>                | Roofing            |
| <b>Sub-Category:</b>            | Single Ply Roofing |
| <b>Material:</b>                | PVC                |
| <b>Deck Type:</b>               | Wood               |
| <b>Maximum Design Pressure:</b> | -45 psf.           |

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

| <u>Product</u>               | <u>Dimensions</u>        | <u>Test Specification</u> | <u>Product Description</u>  |
|------------------------------|--------------------------|---------------------------|---|
| IB PVC Single Ply            | 50, 60, 80 mil thickness | ASTM D4434                | Polyester reinforced PVC membrane.  |
| IB PVC Single Ply Fleeceback | 50, 60, 80 mil thickness | ASTM D4434                | Polyester reinforced PVC membrane with a non-woven polyester fleeceback.                          |
| IB Water Borne Adhesive      | 3 gal.                   | Proprietary               | Adhesive for bonding IB membranes to wood, concrete and glass faced polyisocyanurate insulations. |

### APPROVED INSULATIONS:

TABLE 2

| <u>Product Name</u>              | <u>Product Description</u>                               | <u>Manufacturer (With Current NOA)</u>         |
|----------------------------------|--|--|
| ACFoam-II                        | Polyisocyanurate Insulation                              | Atlas Roofing Corp.                            |
| ACFoam-III                       | Polyisocyanurate Insulation                              | Atlas Roofing Corp.                            |
| DensDeck                         | Gypsum insulation  | Georgia Pacific Gypsum LLC                     |
| DensDeck Prime                   | Gypsum insulation  | Georgia Pacific Gypsum LLC                     |
| ENRGY 3                          | Polyisocyanurate Insulation                              | Johns Manville                                 |
| SECUROCK Gypsum-Fiber Roof Board | Gypsum insulation  | US Gypsum                                      |
| Multi-Max FA-3                   | Polyisocyanurate Insulation                              | Rmax Operating, LLC                            |
| H-Shield                         | Polyisocyanurate insulation                              | Hunter Panels, LLC                             |
| Insulfoam EPS                    | Closed-cell, Type IX (min 1.8 pcf) expanded polystyrene. | Insulfoam, a Div. of Carlisle Const. Materials |
| ISO 95+ GL                       | Polyisocyanurate foam insulation                         | Firestone Building Products Company, LLC       |

**APPROVED FASTENERS:**

**TABLE 3**

| <b>Fastener Number</b> | <b>Product Name</b>                | <b>Product Description</b>                    | <b>Dimensions</b> | <b>Manufacturer (With Current NOA)</b> |
|------------------------|------------------------------------|---|-------------------|--|
| 1.                     | IB #14 Heavy Duty Roofing Fastener | #14 membrane fastener                         | Various           | IB Roof Systems                        |
| 2.                     | IB 2" Barbed Seam Plates           | 2" round barbed membrane plate                | 2" round          | IB Roof Systems                        |
| 3.                     | IB #12 Standard Roofing Fastener   | #12 insulation fastener                       | Various           | IB Roof Systems                        |
| 4.                     | OMG #14 Roofgrip Fastener          | #14 carbon steel fastener with CR-10 coating. | Various           | OMG, Inc.                              |
| 5.                     | OMG 2" Barbed Plate                | 2" round barbed membrane plate                | 2" round          | OMG, Inc.                              |

**EVIDENCE SUBMITTED:**

| <b><u>Test Agency/Identifier</u></b> | <b><u>Name</u></b> | <b><u>Report</u></b> | <b><u>Date</u></b> |
|--------------------------------------|--------------------|----------------------|--------------------|
| Factory Mutual Research Corp.        | 3029864            | FM 4470              | 02/18/08           |
|                                      | 3014692            | FM 4470              | 08/05/03           |
|                                      | 2D5A9.AM           | FM 4450              | 06/22/99           |
|                                      | 3014751            | FM 4450              | 08/27/03           |
|                                      | 3012321            | FM 4470              | 07/29/02           |
|                                      | 3009502            | FM 4470              | 12/21/00           |
|                                      | 3015444            | FM 4450              | 07/11/03           |
| Underwriters Laboratories Inc.       | 02NK18635          | CGSB-37.54-95        | 11/12/03           |
| Exterior Research & Design, LLC      | 03900.05.05        | TAS 114-D            | 05/19/05           |
|                                      | 03903.05.06-2      | TAS 114-J            | 05/10/06           |
| Trinity   ERD                        | 02762.03.05-R1     | TAS 114-D/TAS 114-J  | 12/10/07           |
|                                      | 02642.01.05-1-R1   | TAS 114-J            | 07/13/09           |
|                                      | 111110.02.09       | TAS 114-J            | 02/05/09           |
|                                      | 03903.05.06-2-R1   | TAS 114-J            | 07/13/09           |
|                                      | 131580.10.10       | ASTM D4434           | 10/18/10           |



**APPROVED ASSEMBLIES**

- Membrane Type:** Single Ply, PVC, Insulated
- Deck Type 1I:** Wood, Insulated
- Deck Description:** Min. 15/32-inch plywood or wood plank
- System Type C:** All layers of insulation simultaneously attached; membrane fully adhered.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following.

| <b>Insulation Layer</b>  | <b>Insulation Fasteners<br/>(Table 3)</b> | <b>Fastener<br/>Density/ft<sup>2</sup></b> |
|--|---|--|
| <b>Multi-Max FA-3<br/>Minimum 1.5” thick</b>                   | <b>3</b>                                  | <b>1:1.6 ft<sup>2</sup></b>                |
| <b>SECUROCK Gypsum-Fiber Roof Board<br/>Minimum 0.5” thick</b> | <b>3</b>                                  | <b>1:1.6 ft<sup>2</sup></b>                |

**Note: All layers shall be simultaneously fastened; see above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** IB PVC Single Ply or IB PVC Single Ply Fleeceback roof cover adhered using IB Water Borne Adhesive at a rate of 1 gal/200 ft<sup>2</sup> (substrate only). Side laps are min. 3-inch wide sealed with min. 1- 1/2” heat weld.

**Maximum Design Pressure:** -45 psf. (See General Limitation #7)



**Membrane Type:** Single Ply, PVC, Insulated  
**Deck Type II:** Wood  
**Deck Description:** Min. 19/32-inch plywood or wood plank  
**System Type D:** Membrane mechanically attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of the following.

| Insulation Layer  | Insulation Fasteners | Fastener Density |
|---|----------------------|------------------|
| <b>Any Approved Polyisocyanurate Insulation listed in Table 2<br/>Minimum 1.5” thick</b>                | N/A                  | N/A              |
| <b>Any approved Expanded Polystyrene Type IX (min 1.8 pcf) listed in Table 2<br/>Minimum 1.0” thick</b> | N/A                  | N/A              |
| <b>DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board<br/>Minimum 0.25” thick</b>               | N/A                  | N/A              |

**Note: All layers of insulation and membrane sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** IB PVC Single Ply or IB PVC Single Ply Fleeceback secured through the preliminarily attached insulation as specified below:  
 IB #14 Heavy Duty Roofing Fasteners with IB 2” Barbed Seam Plates or OMG #14 Roofgrip Fasteners with OMG 2” Barbed Plates, spaced 6” o.c. in minimum 5” side laps spaced maximum 67” apart. Outside 1.5” of seam is heat welded.

**Maximum Design Pressure:** -45 psf. (See General Limitation #7)



## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**

