



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

AWP Windows and Doors, LLC
8130 NW 74th Avenue
Medley, FL 33166

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "Exterior Glazed" Aluminum Fixed Window – L.M.I.

APPROVAL DOCUMENT: Drawing No. **W06-84**, titled "Exterior Glazed Aluminum Fixed Window (L.M.I.)", sheets 1 through 5 of 5, dated 12/11/06, with revision **D** dated 04/22/15, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA **renews and revises** NOA# **11-1213.08** and consists of this page 1 and evidence pages E-1, E-2, and E-3, as well as approval document mentioned above.

The submitted documentation was reviewed by **Jorge M. Plasencia, P.E.**



Jorge M. Plasencia

NOA No. 16-0126.01
Expiration Date: December 13, 2021
Approval Date: June 16, 2016
Page 1


NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
2. Drawing No. **W06-84**, titled "Exterior Glazed Aluminum Fixed Window (L.M.I.)", sheets 1 through 5 of 5, dated 12/11/06, with revision **D** dated 04/22/15, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E.

B. TESTS

1. Test reports on: 1) Large Missile Impact Test per FBC, TAS 201-94
2) Cyclic Wind Pressure Loading per FBC, TAS 203-94
along with marked-up drawings and installation diagram of 2 mulled fixed frame windows, O-O configuration, prepared by Fenestration Testing Laboratory, Inc., Test Report No. **FTL-6600**, dated 08/30/11, signed and sealed by Marlin D. Brinson, P.E.
(Submitted under previous NOA #11-1213.08)
(All test reports below submitted under previous NOA #01-0102.05)
2. Test reports on: 1) Air Infiltration Test, per PA 202-94
2) Uniform Static Air Pressure Test, Loading per PA 202-94
3) Water Resistance Test, per PA 202-94
along with installation diagram of an aluminum arch fixed window (3/16" temp), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-1174A**, dated 10/19/00, signed and sealed by Arshad Viqar, P.E.
3. Test reports on: 1) Air Infiltration Test, per PA 202-94
2) Uniform Static Air Pressure Test, Loading per PA 202-94
3) Water Resistance Test, per PA 202-94
along with installation diagram of an aluminum rectangular fixed window (3/16" ann), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-1174B**, dated 10/19/00, signed and sealed by Arshad Viqar, P.E.
4. Test reports on: 1) Air Infiltration Test, per PA 202-94
2) Uniform Static Air Pressure Test, Loading per PA 202-94
3) Water Resistance Test, per PA 202-94
along with installation diagram of an aluminum rectangular fixed window (3/16" temp), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-1174C**, dated 10/19/00, signed and sealed by Arshad Viqar, P.E.
5. Test reports on: 1) Air Infiltration Test, per PA 202-94
2) Uniform Static Air Pressure Test, Loading per PA 202-94
3) Water Resistance Test, per PA 202-94
along with installation diagram of an aluminum rectangular fixed window (3/16" temp), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-1174D**, dated 10/19/00, signed and sealed by Arshad Viqar, P.E.



Jorge M. Plasencia, P.E.
Product Control Unit Supervisor
NOA No. 16-0126.01
Expiration Date: December 13, 2021
Approval Date: June 16, 2016

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

B. TESTS (CONTINUED)

(All test reports below submitted under previous NOA #01-0102.05)

6. Test reports on: 1) Large Missile Impact Test per SFBC, PA 201-94
2) Cyclic Wind Pressure Loading per SFBC, PA 203-94
along with installation diagram of an aluminum rectangular fixed window (1am 3/16” HS), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-907A**, dated 12/06/00, signed and sealed by Arshad Viqar, P.E.
7. Test reports on: 1) Air Infiltration Test, per PA 202-94
2) Uniform Static Air Pressure Test, Loading per PA 202-94
3) Water Resistance Test, per PA 202-94
along with installation diagram of an aluminum fixed rectangular window (1am 3/16” HS), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-1162**, dated 12/6/00, signed and sealed by Arshad Viqar, P.E.
8. Test reports on: 1) Large Missile Impact Test per SFBC, PA 201-94
2) Cyclic Wind Pressure Loading per SFBC, PA 203-94
along with installation diagram of an aluminum fixed rectangular window (1am 3/16” HS), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-907B**, dated 12/6/00, signed and sealed by Arshad Viqar, P.E.
9. Test reports on: 1) Large Missile Impact Test per SFBC, PA 201-94
2) Cyclic Wind Pressure Loading per SFBC, PA 203-94
along with installation diagram of an aluminum fixed arch window (1am 3/16” HS), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-916**, dated 12/6/00, signed and sealed by Arshad Viqar, P.E.
10. Test reports on: 1) Air Infiltration Test, per PA 202-94
2) Uniform Static Air Pressure Test, Loading per PA 202-94
3) Water Resistance Test, per PA 202-94
along with installation diagram of an aluminum fixed rectangular window (3/16” ann), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-1163**, dated 12/6/00, signed and sealed by Arshad Viqar, P.E.
(Submitted under previous NOA #01-0102.05)
11. Test reports on: 1) Large Missile Impact Test per SFBC, PA 201-94
2) Cyclic Wind Pressure Loading per SFBC, PA 203-94
along with installation diagram of an aluminum fixed arch window (1am 3/16” HS), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-917**, dated 12/6/00, signed and sealed by Arshad Viqar, P.E.
12. Test reports on: 1) Uniform Static Air Pressure Test, Loading per PA 202-94
along with installation diagram of an aluminum fixed rectangular window (1/8” ann), prepared by Hurricane Engineering & Testing Inc., Report No. **HETI-00-915**, dated 12/6/00, signed and sealed by Arshad Viqar, P.E.



Jorge M. Plasencia, P.E.
Product Control Unit Supervisor
NOA No. 16-0126.01
Expiration Date: December 13, 2021
Approval Date: June 16, 2016

AWP Windows and Doors, LLC

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

C. CALCULATIONS:

1. Anchor verification calculations and structural analysis, complying with FBC–2014, 5th edition, prepared by Al–Farooq Corporation, dated 04/20/15, signed and sealed by Javad Ahmad, P.E.
2. Glazing complies with ASTM E1300-09

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **15-1201.11** issued to **Eastman Chemical Company (MA)** for their “**Saflex Clear and Color Glass Interlayers**” dated 03/17/16, expiring on 05/21/21.

F. STATEMENTS











1. Statement letter of conformance, complying with **FBC–2014**, and of no financial interest, dated 04/20/15, signed and sealed by Javad Ahmad, P.E.
2. Sales agreement between AWP, LLC (Acquiror) and Arch Aluminum & Glass Enterprise, a Delaware Corp (Asset Seller) dated MAR 20, 2014, signed by Paul Schmitz, President and Tim Morris Jr., President, respectively.
3. Statement letter dated April 20, 2015, issued by Trulite Window & Door Solution, LLC, stating Trulite has legally sold to AWP Windows and Doors, LLC, all the NOA(s) per schedule A and gave-up all rights to NOA(s) and request to rescind all NOA(s) under Trulite, signed by Kevin Barret, CFO (Trulite).
4. Statement letter dated July 15, 2014 requesting name change from Trulite windows and doors solution, LLC to AWP windows and Doors, LLC, signed by Gerardo Beros, Director of Engineering (AWP).

G. OTHERS


1. Notice of Acceptance No. **11-1213.08**, issued to Trulite Window & Door Solutions, LLC for their Exterior Glazed Fixed Window – L.M.I., approved on 02/02/12 and expiring on 12/13/16.



Jorge M. Plasencia, P.E.
Product Control Unit Supervisor
NOA No. 16-0126.01
Expiration Date: December 13, 2021
Approval Date: June 16, 2016



ALLOWABLE LOADS FOR ALTERNATE SHAPES AS SHOWN ABOVE OR SIMILAR CAN BE VERIFIED BY INSCRIBING PICTURE WINDOW SHAPE WITHIN SQUARE OR RECTANGLE AS SHOWN IN DOTTED LINES AND OBTAINING ALLOWABLE LOADS FROM THOSE SHAPES.



TYPICAL ELEVATION

EXTERIOR GLAZED ALUMINUM FIXED WINDOW

APPROVAL APPLIES TO SINGLE UNITS OR SIDE BY SIDE COMBINATIONS OF FIXED/FIXED OR FIXED WITH OTHER MIAMI-DADE COUNTY APPR'D WINDOWS USING MIAMI-DADE COUNTY APPROVED MULLIONS IN BETWEEN. LOWER DESIGN PRESSURE FROM WINDOWS OR MULLION APPROVAL WILL APPLY TO ENTIRE SYSTEM.

DESIGN LOAD RATING FOR THESE WINDOWS TO BE AS PER CHARTS SHOWN ON SHEET 2.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).

WOOD BUCKS BY OTHERS, MUST BE ANCHORED PROPERLY TO TRANSFER LOADS TO THE STRUCTURE.

ANCHORS SHALL BE AS LISTED, SPACED AS SHOWN ON DETAILS, ANCHORS EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO.

ANCHORING OR LOADING CONDITIONS NOT SHOWN IN THESE DETAILS ARE NOT PART OF THIS APPROVAL.

A LOAD DURATION INCREASE IS USED IN DESIGN OF ANCHORS INTO WOOD ONLY.

ALL SHIMS TO BE HIGH IMPACT, NON-METALLIC AND NON-COMPRESSIBLE.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE.

THESE WINDOWS ARE RATED FOR LARGE & SMALL MISSILE IMPACT. SHUTTERS ARE NOT REQUIRED.

Engr: JAVAD AHMAD
 CIVIL
 FLA. PE. # 70592
 C.A.N. 3638
 APR 24 2021

PRODUCT REVISED
 as complying with the Florida Building Code
 NOA-No. 16-0126.01

Expiration Date 12/13/2021

By *[Signature]*
 Miami-Dade Product Control

EXTERIOR GLAZED ALUM FIXED WINDOW (L.M.I.)
AWP WINDOWS AND DOORS, LLC
 8130 N.W. 74TH AVE.
 MEDLEY, FL. 33166
 TEL. (305) 887-2646 FAX (305) 883-1309

no.	date	description
A	03.25.09	NOTES REV., MANF. NAME CHANGE
B	05.27.10	MANUF. NAME REVISED
C	11.18.11	UPDATED TO 2010 FBC, NAME REV
D	04.22.15	UPDATED TO 2014 FBC

date: 12-11-08
 scale: 1/2"=1'-0"
 dr. by: HAMID
 chk. by:


drawing no.
W06-84

sheet 1 of 5

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 12335 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W06-84YO

DESIGN LOAD CAPACITY - PSF							
WINDOW DIMS.		GLASS TYPE 'A'		GLASS TYPE 'B'			
		ANCHORS TYPE 'A'		ANCHORS TYPE 'A'		ANCHORS TYPE 'B'	
WIDTH	LENGTH	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)
19-1/8"	26"	70.0	70.0	65.0	65.0	65.0	65.0
26-1/2"		70.0	70.0	65.0	65.0	65.0	65.0
37"		70.0	70.0	65.0	65.0	65.0	65.0
53-1/8"		70.0	70.0	65.0	65.0	65.0	65.0
19-1/8"	38-3/8"	70.0	70.0	65.0	65.0	65.0	65.0
26-1/2"		70.0	70.0	65.0	65.0	65.0	65.0
37"		63.7	63.7	65.0	65.0	65.0	65.0
53-1/8"		61.5	61.5	65.0	65.0	65.0	65.0
19-1/8"	59"	70.0	70.0	65.0	65.0	65.0	65.0
26-1/2"		70.0	70.0	65.0	65.0	65.0	65.0
37"		63.7	63.7	65.0	65.0	65.0	65.0
53-1/8"		-	-	60.2	60.2	65.0	65.0
19-1/8"	63"	70.0	70.0	65.0	65.0	65.0	65.0
26-1/2"		70.0	70.0	65.0	65.0	65.0	65.0
37"		60.7	60.7	65.0	65.0	65.0	65.0
53-1/8"		-	-	64.3	64.3	65.0	65.0
19-1/8"	74-1/4"	70.0	70.0	65.0	65.0	65.0	65.0
26-1/2"		69.8	69.8	65.0	65.0	65.0	65.0
37"		47.5	47.5	65.0	65.0	65.0	65.0
53-1/8"		-	-	57.3	57.3	65.0	65.0


NOTE:
GLASS CAPACITIES ON THIS SHEET ARE
BASED ON ASTM E1300-09 (3 SEC. GUSTS).



GLAZING OPTIONS

DESIGN LOAD CAPACITY - PSF								
WINDOW DIMS.		GLASS TYPE 'A'		GLASS TYPE 'B'				
		ANCHORS TYPE 'A'		ANCHORS TYPE 'A'		ANCHORS TYPE 'B'		
WIDTH	LENGTH	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	
18"	24"	70.0	70.0	65.0	65.0	65.0	65.0	
24"		70.0	70.0	65.0	65.0	65.0	65.0	
30"		70.0	70.0	65.0	65.0	65.0	65.0	
36"		70.0	70.0	65.0	65.0	65.0	65.0	
42"		70.0	70.0	65.0	65.0	65.0	65.0	
48"		70.0	70.0	65.0	65.0	65.0	65.0	
54"		70.0	70.0	65.0	65.0	65.0	65.0	
60"		70.0	70.0	65.0	65.0	65.0	65.0	
66"		70.0	70.0	65.0	65.0	65.0	65.0	
72"		70.0	70.0	65.0	65.0	65.0	65.0	
18"		36"	70.0	70.0	65.0	65.0	65.0	65.0
24"			70.0	70.0	65.0	65.0	65.0	65.0
30"	70.0		70.0	65.0	65.0	65.0	65.0	
36"	65.5		65.5	65.0	65.0	65.0	65.0	
42"	65.5		65.5	65.0	65.0	65.0	65.0	
48"	65.5		65.5	65.0	65.0	65.0	65.0	
54"	65.5		65.5	65.0	65.0	65.0	65.0	
60"	65.5		65.5	65.0	65.0	65.0	65.0	
66"	58.4		58.4	65.0	65.0	65.0	65.0	
72"	49.7		49.7	64.0	64.0	65.0	65.0	
18"	48"		70.0	70.0	65.0	65.0	65.0	65.0
24"			70.0	70.0	65.0	65.0	65.0	65.0
30"		70.0	70.0	65.0	65.0	65.0	65.0	
36"		65.5	65.5	65.0	65.0	65.0	65.0	
42"		56.2	56.2	65.0	65.0	65.0	65.0	
48"		49.1	49.1	65.0	65.0	65.0	65.0	
54"		49.1	49.1	65.0	65.0	65.0	65.0	
60"		49.1	49.1	60.0	60.0	65.0	65.0	
66"		-	-	61.7	61.7	65.0	65.0	
72"		-	-	54.0	54.0	65.0	65.0	
18"		60"	70.0	70.0	65.0	65.0	65.0	65.0
24"			70.0	70.0	65.0	65.0	65.0	65.0
30"	70.0		70.0	65.0	65.0	65.0	65.0	
36"	65.5		65.5	65.0	65.0	65.0	65.0	
42"	56.2		56.2	63.3	63.3	65.0	65.0	
48"	49.1		49.1	60.0	60.0	65.0	65.0	
54"	-		-	58.2	58.2	65.0	65.0	
60"	-		-	57.6	57.6	60.4	60.4	
66"	-		-	57.6	57.6	60.4	60.4	
72"	-		-	49.4	49.4	60.4	60.4	
18"	72"		70.0	70.0	65.0	65.0	65.0	65.0
24"			70.0	70.0	65.0	65.0	65.0	65.0
30"		62.0	62.0	65.0	65.0	65.0	65.0	
36"		49.7	49.7	64.0	64.0	65.0	65.0	
42"		-	-	58.1	58.1	65.0	65.0	
48"		-	-	54.0	54.0	65.0	65.0	
54"		-	-	51.2	51.2	65.0	65.0	
60"		-	-	49.4	49.4	60.4	60.4	
18"		84"	70.0	70.0	65.0	65.0	65.0	65.0
24"			70.0	70.0	65.0	65.0	65.0	65.0
30"			50.9	50.9	65.0	65.0	65.0	65.0
36"			-	-	61.1	61.1	65.0	65.0
42"	-		-	54.9	54.9	65.0	65.0	
48"	-		-	50.4	50.4	65.0	65.0	
54"	-		-	47.2	47.2	65.0	65.0	

DESIGN LOAD CAPACITY - PSF							
WINDOW DIMS.		GLASS TYPE 'A'		GLASS TYPE 'B'			
		ANCHORS TYPE 'A'		ANCHORS TYPE 'A'		ANCHORS TYPE 'B'	
WIDTH	LENGTH	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)	EXT. (+)	INT. (-)
18"	96"	70.0	70.0	65.0	65.0	65.0	65.0
24"		66.8	66.8	65.0	65.0	65.0	65.0
30"		47.2	47.2	65.0	65.0	65.0	65.0
36"		-	-	59.1	59.1	65.0	65.0
42"		-	-	52.7	52.7	65.0	65.0
48"		-	-	48.0	48.0	65.0	65.0
18"	108"	70.0	70.0	65.0	65.0	65.0	65.0
24"		70.0	70.0	65.0	65.0	65.0	65.0
30"		-	-	65.0	65.0	65.0	65.0
36"		-	-	57.6	57.6	65.0	65.0
42"	-	-	51.1	51.1	65.0	65.0	
18"	114"	62.2	62.2	65.0	65.0	65.0	65.0
24"		62.2	62.2	65.0	65.0	65.0	65.0
30"		-	-	65.0	65.0	65.0	65.0
36"		-	-	60.0	60.0	65.0	65.0
18"	120"	55.6	55.6	65.0	65.0	65.0	65.0
24"		55.6	55.6	65.0	65.0	65.0	65.0
30"		-	-	65.0	65.0	65.0	65.0
36"		-	-	56.5	56.5	65.0	65.0
18"	132"	44.6	44.6	65.0	65.0	65.0	65.0
24"		-	-	65.0	65.0	65.0	65.0
30"		-	-	65.0	65.0	65.0	65.0
18"	144"	39.2	39.2	65.0	65.0	65.0	65.0
24"		-	-	65.0	65.0	65.0	65.0
30"		-	-	64.3	64.3	65.0	65.0



NOTE:
WIDTH AND LENGTH DIMENSIONS CAN BE ORIENTED
VERTICALLY OR HORIZONTALLY AS SHOWN ABOVE.

Engr: JAVAD AHMAD
CIVIL
FLA. PE # 70592
C.A.N. 3538
APR 24 2015

PRODUCT REVISED
as complying with the Florida
Building Code
NOA-No. **16-0126.01**
Expiration Date **12/13/2021**
By *[Signature]*
Miami-Dade Product Control



af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
1235 S.W. 87 AVE
MIAMI, FLORIDA 33174
TEL. (305) 264-8100 FAX (305) 262-6978
COMP-ANL\W06-84YO

EXTERIOR GLAZED ALUM FIXED WINDOW (L.M.I.)
AWP WINDOWS AND DOORS, LLC
8130 N.W. 74TH AVE.
MEDLEY, FL. 33166
TEL. (305) 887-2646 FAX (305) 883-1309

no	date	description	by
A	03.25.09	NOTES REV., MANF. NAME CHANGE	
B	05.27.10	MANUF. NAME REVISED	
C	11.16.11	MANUF. NAME REVISED	
D	04.22.15	UPDATED TO 2014 FBC	

date: 12-11-06
scale: -
dr. by: HAMID
chk. by:

drawing no.
W06-84
sheet 2 of 5



WOOD BUCKS AND METAL STRUCTURE NOT BY AWP WINDOWS MUST SUSTAIN LOADS IMPOSED BY GLAZING SYSTEM AND TRANSFER THEM TO THE BUILDING STRUCTURE.

TYPICAL ANCHORS: SEE ELEV. FOR SPACING

TYPE 'A'— 3/16" DIA. ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)
 INTO 2BY WOOD BUCKS OR WOOD STRUCTURES
 1-1/8" MIN. PENETRATION INTO WOOD (HEAD/SILL/JAMBS)
 THRU 1BY BUCKS INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONCRETE (HEAD/SILL)
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY (JAMBS)
 DIRECTLY INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONCRETE (HEAD/SILL)
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY (JAMBS)

TYPE 'B'— 1/4" DIA. ULTRACON BY 'ELCO' (Fu=177 KSI, Fy=155 KSI)
1/4" DIA. TAPCON BY 'ITW' (Fu=125 KSI, Fy=100 KSI)
 INTO 2BY WOOD BUCKS OR WOOD STRUCTURES
 1-1/2" MIN. PENETRATION INTO WOOD (HEAD/SILL/JAMBS)
 THRU 1BY BUCKS INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONCRETE (HEAD/SILL)
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY (JAMBS)
 DIRECTLY INTO CONC. OR MASONRY
 1-1/4" MIN. EMBED INTO CONCRETE (HEAD/SILL)
 1-1/4" MIN. EMBED INTO CONC. OR MASONRY (JAMBS)

3/16" DIA. TEKS OR SELF DRILLING SCREWS (GRADE 5 CRS)
 INTO METAL STRUCTURES
 STEEL : 1/8" THK. MIN. (Fy = 36 KSI MIN.)
 ALUMINUM : 1/8" THK. MIN. (6063-T5 MIN.)
 (STEEL IN CONTACT WITH ALUMINUM TO BE PLATED OR PAINTED)

#10 SMS OR SELF DRILLING SCREWS (GRADE 2 CRS)
 INTO MIAMI-DADE COUNTY APPROVED MULLIONS (MIN. THK. = 1/8")
 (NO SHIM SPACE)

Ed = ANCHOR EDGE DISTANCE
 INTO CONCRETE AND MASONRY = 1-1/4" MIN.
 INTO WOOD STRUCTURE = 9/16" MIN.
 INTO METAL STRUCTURE = 1/2" MIN.

WOOD AT HEAD, SILL OR JAMBS SG = 0.55 MIN.
 CONCRETE AT HEAD, SILL OR JAMBS f'c = 3000 PSI MIN.
 C-90 HOLLOW/FILLED BLOCK AT JAMBS f'm = 2000 PSI MIN.

SEALANTS:
 FRAME CORNERS AND INSTALLATION SCREWS SEALED WITH SILICONE SEALANT.

Engr: JAWAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A.N. 13538
 APR 24 2015

PRODUCT REVISED
 as complying with the Florida
 Building Code
 NOA-No. **16-0126.01**
 Expiration Date **12/13/2021**
 By *[Signature]*
 Miami-Dade Product Control




af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W06-84YO

EXTERIOR GLAZED ALUM FIXED WINDOW (L.M.I.)
AWP WINDOWS AND DOORS, LLC
 8130 N.W. 74TH AVE.
 MEDLEY, FL. 33166
 TEL. (305) 887-2646 FAX (305) 883-1309

Revisions:

no	date	description
A	03.25.09	MANUF. NAME CHANGE
B	05.27.10	MANUF. NAME REVISED
C	11.18.11	ANCHORS, MANUF. NAME REVISED
D	04.22.15	UPDATED TO 2014 FBC

date: 12-11-08
 scale: 1/2" = 1"
 dr. by: HAMID
 chg. by:
 drawing no. **W06-84**
 sheet 3 of 5



Engr: JAVAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A.N. 3538

APR 24 2015

PRODUCT REVISED
 as complying with the Florida
 Building Code
 NOA-No. **16-0126.01**
 Expiration Date **12/13/2021**
 By *[Signature]*
 Miami-Dade Product Control


af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W06-84YO

EXTERIOR GLAZED ALUM FIXED WINDOW (L.M.I.)
AWP WINDOWS AND DOORS, LLC
 8130 N.W. 74TH AVE.
 MEDLEY, FL. 33166
 TEL. (305) 887-2646 FAX (305) 883-1309

revisions:




no	date	description
A	03.25.09	MANUF. NAME CHANGE
B	05.27.10	MANUF. NAME REVISED
C	11.18.11	MANUF. NAME REVISED
D	04.22.15	UPDATED TO 2014 FBC

date: 12-11-08
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:
 drawing no.
W06-84
 sheet 4 of 5



WINDOW FRAME

ITEM NO.	PART NUMBER	QUANTITY	DESCRIPTION	MATERIAL	MANF./SUPLIER/REMARKS
1	YE-60	4	WINDOW FRAME	ALUMINUM	6063-T6
3	-	AS REQD.	GLAZING COMPOUND	SILICONE	GE-2800
4	#8 X 1"	2/ CORNER	FRAME ASSEMBLY SCREWS	-	-
5	-	AS REQD.	SETTING BLOCKS	EPDM	DUROMETER 80±5 SHORE A



RECT. OR SQUARE WINDOWS

TYP. CORNER DETAILS

af c
AL-FAROOQ CORPORATION
 ENGINEERS & PRODUCT DEVELOPMENT
 1235 S.W. 87 AVE
 MIAMI, FLORIDA 33174
 TEL. (305) 264-8100 FAX. (305) 262-6978
 COMP-ANL\W06-84YO

EXTERIOR GLAZED ALUM FIXED WINDOW (L.M.I.)
AWP WINDOWS AND DOORS, LLC
 8130 N.W. 74TH AVE.
 MEDLEY, FL. 33166
 TEL. (305) 887-2646 FAX (305) 883-1309

no	date	by	description
A	03.25.09		MANUF. NAME CHANGE
B	05.27.10		MANUF. NAME REVISED
C	11.18.11		MANUF. NAME REVISED
D	04.22.15		UPDATED TO 2014 FBC

Engr: JAVAD AHMAD
 CIVIL
 FLA. PE # 70592
 C.A.N. 3538
 APR 24 2015

PRODUCT REVISED
 as complying with the Florida
 Building Code
 NOA-No. **16-0126.01**
 Expiration Date **12/13/2021**
 By *[Signature]*
 Miami-Dade Product Control

date: 12-11-06
 scale: 1/2" = 1"
 dr. by: HAMID
 chk. by:
 drawing no.
W06-84
 sheet 5 of 5