



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

Covestro, LLC
2400 Spring Stuebner Rd
Spring, TX 77389

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Bayseal SPF over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 13-0809.01 and consists of pages 1 through 5.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 16-0203.04
Expiration Date: 08/10/18
Approval Date: 04/21/16
Page 1 of 5

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Spray Applied Polyurethane Foam
Material: Polyurethane Foam
Deck Type: Concrete
Maximum Design Pressure: -495 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
Bayseal 3.0	N/A	TAS 110	Polyurethane spray applied foam that utilizes an HFC blowing agent intended for roofing applications.

TRADE NAMES OF PRODUCTS MANUFACTURED BY OTHERS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>	<u>Manufacturer</u>
Any Miami-Dade County Approved Roof Coating	N/A	As Required by Miami-Dade County Product Control Office	Roof coating for application over polyurethane spray applied foam.	Generic (with current Notice of Acceptance)

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Underwriters Laboratories Inc.	R12134	UL 790	02/11/14
FM Approvals	3016938	FM 4470	01/13/05
	3022954	FM 4470	03/24/05
	3026505	FM 4470	03/21/06
R&D Services, Inc.	RD14384	ASTM D2842	04/02/14
		ASTM D2126	
		ASTM E96	
		ASTM D1621	
		ASTM D1623	
NTA, Inc.	R&DS050714-53	ASTM C273	07/23/14



AMBIENT HUMIDITY APPLICATION LIMITS SPRAYED POLYURETHANE FOAM:

TABLE 1

Maximum Wet Bulb and Relative Humidity for a Given Dry Bulb Reading						
Dry Bulb Temp. (°F)	Wet Bulb Temp. (°F)	R.H. (%)		Dry Bulb Temp. (°F)	Wet Bulb Temp. (°F)	R.H. (%)
45	43	81		73	69	82
46	44	81		74	70	82
47	45	81		75	71	82
48	46	81		76	72	82
49	47	81		77	73	82
50	48	81		78	73	82
51	48	81		79	74	82
52	49	81		80	75	82
53	50	81		81	76	82
54	51	81		82	77	82
55	52	81		83	78	82
56	52	81		84	79	82
57	53	81		85	80	82
58	54	81		86	81	82
59	55	81		87	82	82
60	56	81		88	83	82
61	57	81		89	84	82
62	58	82		90	85	82
63	59	82		91	86	82
64	60	82		92	87	82
65	61	82		93	88	82
66	62	82		94	89	82
67	63	82		95	90	82
68	64	82		96	91	82
69	65	82		97	92	82
70	66	82		98	93	82
71	67	82		99	94	82
72	68	82		100	95	82

Note: Bayseal SPF shall not be sprayed when environmental conditions are beyond the temperature and relative humidity limits listed in this table. (See System Limitations #1)



APPROVED SYSTEMS:

Deck Type 3: Concrete

Deck Description: 2500 psi structural concrete or concrete plank

System Type A: Sprayed polyurethane foam covered with an approved Miami-Dade County roof coating.

All General and System Limitations apply.

Deck Requirements: Concrete decks shall be in compliance with the Florida Building Code Roofing Application Standard RAS 109.

Surface Preparation: Deck shall be free of loose dirt, grease, oil or other contaminants prior to priming or foam application. Remove loose dirt or debris by use of compressed air, vacuum or brooming. No washing shall be permitted. Oil, grease, release agents or other contaminants shall be removed with proper cleaning solutions.

Primers shall be applied in accordance with the manufacturer’s instructions. All primers must be thoroughly dry and cured prior to foam application.

All joint openings in concrete decks that exceed 1/8 inch shall be grouted or caulked.

Polyurethane Foam Application: The Bayseal SPF shall be applied uniformly over the entire surface at the specified thickness in compliance with the requirements set forth in the Florida Building Code Roofing Application Standard RAS 109 but in no case shall it be less than 2” thick. The Bayseal SPF shall be feathered at the edges to produce a smooth transition.

Protective Coating Application: (Choose One) Apply a Miami-Dade County approved roof coating with a current Notice of Acceptance (NOA) that is compatible with this system and is applied in accordance with the guidelines listed in the product’s NOA.

Bayseal SPF surface shall be free of moisture, dust, debris, oils, tars, grease or other materials that will impair adhesion of the protective coverings. Any damage or defects to the Bayseal SPF surface shall be repaired prior to the coating application. The base coat shall be applied the same day as the foam when possible. If more than 72 hours elapse prior to the application of the base coat, the polyurethane foam shall be inspected for UV degradation.

Maximum Design Pressure: -495 psf. (See General Limitation #4)



CONCRETE DECK SYSTEM LIMITATIONS:

1. Bayseal SPF shall not be sprayed when environmental conditions are beyond the temperature and relative humidity limits listed in Table 1 of this approval. Contractor shall monitor and record environmental conditions in job log in compliance with Florida Building Code Roofing Application Standard RAS 109. Job log shall be maintained at the job site and accessible to the Building Official.
2. Adhesion testing of foam to substrate and coating to foam shall be performed in compliance with Florida Building Code Roofing Application Standard RAS 109.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. All work shall performed by a Covestro, LLC’s trained and approved applicator familiar with the details and specifications published by Covestro, LLC.
3. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
4. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
5. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
6. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE

