



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/pera

NOTICE OF ACCEPTANCE (NOA)

Flex Membrane International, Corp.
2670 Leisch's Bridge Road, Suite 400
Leesport, PA 19533

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Flex Single Ply PVC Roof Systems over Recover Decks

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 12-0914.09 and consists of pages 1 through 15.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 16-0224.10
Expiration Date: 02/12/19
Approval Date: 07/21/16
Page 1 of 15

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Single Ply
Material:	PVC
Deck Type:	Recover
Maximum Design Pressure:	See specific deck assemblies.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Flex Tripolymer MF/R	45, 50, 60, 120 mils	ASTM D 4434 TAS 110	Polyester reinforced PVC membrane for mechanical attachment or adhered application.
Flex Tripolymer FB	45, 60, 80, 120 mils	ASTM D 4434	Polyester felt-backed PVC membrane for application in hot asphalt or adhesive.
Flex MFR PVC	50, 60, 80 mils	ASTM D 4434	PVC membrane for mechanical attachment.
Flex Substrate Adhesive	5 gallon	Proprietary	Adhesive used to bond Flex Tripolymer FB membrane to substrate.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
EnergyGuard Polyiso Insulation	Polyisocyanurate foam insulation	GAF Material Corporation
Dens Deck	Silicon treated gypsum	Georgia-Pacific Gypsum LLC
ENRGY 3, ENRGY 25 PSI	Isocyanurate Insulation	Johns Manville
Fesco Foam	Isocyanurate Insulation with perlite facer	Johns Manville
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic
Type X Gypsum	Gypsum Wallboard	Generic
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax Operating LLC.
ACFoam-II	Polyisocyanurate foam insulation	Atlas Roofing Corp.
ACFoam-III	Polyisocyanurate foam insulation	Atlas Roofing Corp.
Flex ISO II	Polyisocyanurate foam insulation	Atlas Roofing Corp.
Flex ISO III	Polyisocyanurate foam insulation	Atlas Roofing Corp.



APPROVED FASTENERS:

TABLE 3

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Dekfast 12, Dekfast 12 Hex	Insulation and membrane fastener	Various	SFS Intec, Inc.
2.	Dekfast 14	Insulation and membrane fastener	Various	SFS Intec, Inc.
3.	Dekfast Galvalume Steel Hex Plate	Insulation and membrane fastener	Various	SFS Intec, Inc.
4.	#14 Roofgrip	Insulation and membrane fastener	Various	OMG, Inc.
5.	Recessed Metal Plate	Galvalume stress plate	3" square	OMG, Inc.
6.	3 in. Round Metal Plate	Galvalume stress plate	3" round	OMG, Inc.
7.	OMG 3" Galvalume Steel Plate	Galvalume stress plate	3" round	OMG, Inc.
8.	OMG Plastic Plate	Plastic plates for fasteners.	3" round	OMG, Inc.
9.	Dekfast 15 HS	Insulation fastener for use in concrete, wood and steel decks	Various	SFS Intec, Inc.
10.	Dekfast Galvalume Steel 3" Round	Galvalume AZ55 stress plate	3" round	SFS Intec, Inc.
11.	RhinoBond Insulation Plate	Metal plate with an adhesive top	3" round	OMG, Inc.
12.	OMG Super XHD	Truss head, self-drilling, pinch point, high thread fastener	#21 x 16" max. length	OMG, Inc.
13.	Isoweld F1-P-6.8-PVC Plate	Round, coated galvalume plate (Silver and Gold) used for PVC membranes	3" round	SFS Intec, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	2X4A1.AM	FM 4470	06/29/94
	2W5A3.AM	FM 4470	12/22/93
	3033126	FM 4470	07/11/08
	3044073	FM 4470	06/20/12
Underwriters Laboratories, Inc.	R9228	UL 790	01/01/96
Trinity ERD	F42130.06.13	ASTM D4434	06/05/13
	F42130.06.13-1	ASTM D4434	06/05/13
	F42130.09.13	ASTM D4434	09/13/13
	SFS-SC10010.02.16	FM 4474/UL1897/TAS 114	02/29/16

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies:</u>	<u>Date</u>
Robert Nieminen, P.E.	Letter	C(3), C(4), C(5), C(8), C(9)	07/06/16
FM Approval Deck Limitation	RoofNav Listing	C(2), C(6), C(7), D	07/11/16



APPROVED ASSEMBLIES

- Membrane Type:** Single Ply, PVC
- Deck Type 7I:** Recover
- Deck Description:** Concrete/Lightweight Concrete/Cementitious Wood Fiber/Wood/Steel
- System Type C(1):** All layers of insulation simultaneously attached; membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Retarder: Any UL or FM approved vapor retarder may be installed on the deck or over the base layer of insulation.

One or more layers of the following.

<u>Base Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
EnergyGuard Polyiso Insulation Minimum 1.3” thick	N/A	N/A
ENRGY 3, ENRGY 3 25 PSI Minimum 1.4” thick	N/A	N/A

Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<u>Top Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
EnergyGuard Polyiso Insulation, Fesco Foam Minimum 1.3” thick	Approved Fastener for Deck Type	1:2 ft ²
ENRGY 3 Minimum 1.4” thick	Approved Fastener for Deck Type	1:2 ft ²

Membrane: Flex Tripolymer MF/R or Flex Tripolymer FB membrane adhered to the insulation substrate with Flex Substrate Adhesive at a rate of 1.66 gal./sq. applied to the insulation, or the Flex Tripolymer FB membrane may be set in hot asphalt adhesive applied at the rate of 20-40 lbs/sq.

Maximum Design Pressure: -45 psf. (See General Limitation #9.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Min. 22 ga., Type B, Grade 33 steel deck secured 6" o.c. with ITW Buildex ICH TRAXX/5 screws to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 24" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(2): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, AC Foam-II, AC Foam-III, ENRGY 3, ENRGY 3 25 PSI, Multi-Max FA-3 Minimum 1.5" thick	11 & 12	1:6 ft ²

Note: All layers of insulation shall be mechanically attached using RhinoBond Insulation Plates, with a 2 ft x 2 ft grid pattern, and the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density.

Membrane: Flex Tripolymer MF/R heat welded to insulation layer with RhinoBond Insulation Plate bonding tool at a rate of 6 sec per plate so the tool reaches 400°F (204°C). Side laps are sealed with a minimum 2.0" heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Structural concrete or min. 22 ga., Type B, Grade 80 steel deck secured 6" o.c. with ITW Buildex ICH TRAXX/5 screws to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 36" o.c. *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 450 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(3): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, ACFoam-II, ACFoam-III Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation shall have preliminary attachment prior to the application of Isoweld plates and fasteners as outline below. See membrane description for fastener details. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Flex MFR PVC (50-mil) roof cover shall be heat welded to bonding plates as specified below:

Fastening: Insulation shall be mechanically attached with Dekfast 12, Dekfast 14 and Dekfast 15 HS fasteners and Isoweld F1-P-6.8-PVC Plates spaced 12" o.c. in fastener rows spaced 60" o.c. Membrane shall be bonding to plates with SFS Isoweld 3000 stand-up bonding tool. Side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Structural concrete or min. 22 ga., Type B, Grade 40 steel deck secured 6" o.c. with 5/8" diameter puddle welds to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 36" o.c. *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 420 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(4): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, ACFoam-II, ACFoam-III Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation shall have preliminary attachment prior to the application of Isoweld plates and fasteners as outline below. See membrane description for fastener details. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Flex MFR PVC (50-mil) roof cover shall be heat welded to bonding plates as specified below:

Fastening: Insulation shall be mechanically attached with Dekfast 15 HS fasteners and Isoweld F1-P-6.8-PVC Plates spaced 2' o.c. in staggered fastener rows spaced 2' o.c (grid pattern). Membrane shall be bonding to plates with SFS Isoweld 3000 stand-up bonding tool. Side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Structural concrete or min. 22 ga., Type B, Grade 40 steel deck secured 6" o.c. with ITW buildex ICH TRAXX/5 screws to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 36" o.c. *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 630 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(5): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, ACFoam-II, ACFoam-III Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation shall have preliminary attachment prior to the application of Isoweld plates and fasteners as outline below. See membrane description for fastener details. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Flex MFR PVC (50-mil) roof cover shall be heat welded to bonding plates as specified below:

Fastening: Insulation shall be mechanically attached with Dekfast 15 HS fasteners and Isoweld F1-P-6.8-PVC Plates spaced 2' o.c. in staggered fastener rows spaced 3' o.c (grid pattern). Membrane shall be bonding to plates with SFS Isoweld 3000 stand-up bonding tool. Side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressure: -52.5 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Min. 22 ga., Type B, Grade 33 steel deck secured 6" o.c. with ITW Buildex ICH TRAXX/5 screws to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 24" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(6): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, Multi-Max FA-3 Minimum 1.5" thick	11 & 12	1:4 ft ²

Note: All layers of insulation shall be mechanically attached using RhinoBond Insulation Plates, with a 2 ft x 2 ft grid pattern, and the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density.

Membrane: Flex Tripolymer MF/R heat welded to insulation layer with RhinoBond Insulation Plate bonding tool at a rate of 6 sec per plate so the tool reaches 400°F (204°C). Side laps are sealed with a minimum 2.0" heat weld.

Maximum Design Pressure: -60 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Min. 22 ga., Type B, Grade 33 steel deck secured 6" o.c. with ITW Buildex ICH TRAXX/5 screws to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 24" o.c.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(7): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, ACFoam-II, ACFoam-III, ENRGY 3, ENRGY 3 25 PSI, Multi-Max FA-3 Minimum 1.5" thick	11 & 12	1:4 ft ²

Note: All layers of insulation shall be mechanically attached using RhinoBond Insulation Plates, with a 2 ft x 2 ft grid pattern, and the fastener density listed above. The insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density.

Membrane: Flex Tripolymer MF/R heat welded to insulation layer with RhinoBond Insulation Plate bonding tool at a rate of 6 sec per plate so the tool reaches 400°F (204°C). Side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressure: -75 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Structural concrete or min. 22 ga., Type B, Grade 40 steel deck secured 6" o.c. with 5/8" diameter puddle welds to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 36" o.c. *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 495 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(8): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, ACFoam-II, ACFoam-III Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation shall have preliminary attachment prior to the application of Isoweld plates and fasteners as outline below. See membrane description for fastener details. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Flex MFR PVC (50-mil) roof cover shall be heat welded to bonding plates as specified below:

Fastening: Insulation shall be mechanically attached with Dekfast 15 HS fasteners and Isoweld F1-P-6.8-PVC Plates spaced 1.5' o.c. in staggered fastener rows spaced 3' o.c (grid pattern). Membrane shall be bonding to plates with SFS Isoweld 3000 stand-up bonding tool. Side laps are sealed with a minimum 1.5" heat weld.

Maximum Design Pressure: -82.5 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC

Deck Type 7I: Recover

Deck Description: Structural concrete or min. 22 ga., Type B, Grade 80 steel deck secured 6” o.c. with ITW Buildex ICH TRAXX/5 screws to supports spaced max. 5 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 30” o.c. *The deck shall record a Minimum Characteristic Resistance Force (MCRF) of 450 lbf when tested with fasteners, listed in this assembly, installed through to the deck in accordance with TAS 105.

This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type C(9): Membrane heat welded to fastener plates mechanically attaching insulation layer.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
Flex ISO II, Flex ISO III, ACFoam-II, ACFoam-III Minimum 1.5” thick	N/A	N/A

Note: All layers of insulation shall have preliminary attachment prior to the application of Isoweld plates and fasteners as outline below. See membrane description for fastener details. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: Flex MFR PVC (50-mil) roof cover shall be heat welded to bonding plates as specified below:

Fastening: Insulation shall be mechanically attached with Dekfast 15 HS fasteners and Isoweld F1-P-6.8-PVC Plates spaced 6” o.c. in fastener rows spaced 60” o.c. Membrane shall be bonding to plates with SFS Isoweld 3000 stand-up bonding tool. Side laps are sealed with a minimum 1.5” heat weld.

Maximum Design Pressure: -90 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC
Deck Type 7I: Recover
Deck Description: Min. 16-22 ga., Type B, Grade 33 steel deck secured 6" o.c. with ITW Buildex ICH TRAXX/5 screws to supports spaced max. 6 ft o.c. Side laps secured with ITW Buildex ICH TRAXX/1 screws spaced max 24" o.c.
This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.
System Type D: Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

Vapor Retarder: Any UL or FM approved vapor retarder may be installed on the deck or over the base layer of insulation.

One or more layers of the following.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft²</u>
EnergyGuard Polyiso Insulation, Multi Max FA-3 Minimum 1.3" thick	N/A	N/A
ENRGY 3, ENRGY 3 25 PSI Minimum 1.4" thick	N/A	N/A

Note: Top layer shall have preliminary attachment, prior to the installation of the membrane sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density.

Membrane: Flex Tripolymer MF/R or Flex MFR PVC attached through preliminary attached insulation to the deck as described below.
Fastening: OMG 2" Barbed Plates and approved fasteners placed 6" o.c. in the membrane lap seams not more than 55" o.c.
Maximum Design Pressure: -45 psf; See General Limitation #7



RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant
(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE