



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**NOTICE OF ACCEPTANCE (NOA)**

**Cooley, Inc.**  
**50 Esten Avenue**  
**Pawtucket, RI 02860**

**SCOPE:**

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

**DESCRIPTION: Cooley C3, C3FB and C3Plus PVC Single Ply Roof Systems over Gypsum Decks**

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 14-0527.09 and consists of pages 1 through 7.  
The submitted documentation was reviewed by Alex Tigera.



**NOA No.:16-0322.01**  
**Expiration Date: 08/03/21**  
**Approval Date: 07/21/16**  
**Page 1 of 7**

## ROOFING SYSTEM APPROVAL

<b>Category:</b>	Roofing
<b>Sub-Category:</b>	Single Ply
<b>Material:</b>	PVC
<b>Deck Type:</b>	Gypsum
<b>Maximum Design Pressure:</b>	-45 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Cooley Standard Perimeter Sheet 50 – 80 mil	Various	ASTM D 4434	A single ply non-elvaloy membrane perimeter sheet
Cooley C-3 40-100 Mil Membrane	78" x 108" 702 sf. roll	ASTMD 4434	40-100 mil thermoplastic alloy membrane field membrane.
Cooley C-3 40-100 Mil Perimeter Sheet	39" x 108' 351 sf. roll	ASTM D 4434	40-100 mil thermoplastic alloy membrane perimeter sheet.
Cooley C-3 Plus 40-100 Mil Membrane	78" x 100' 650 ft. <sup>2</sup> roll	ASTMD 4434	40-100 mil thermoplastic alloy membrane field membrane.
Cooley C-3 Plus 40-100 Mil Perimeter Sheet	39" x 100' 325 ft. <sup>2</sup> roll	ASTMD 4434	40-100 mil thermoplastic alloy membrane perimeter sheet.
Cooley C-3 Reinforced Flashing Membrane	6", 8", 12", 18" & 24" variable length rolls	ASTM D 4434	40-100 mil thermoplastic flashing membrane.
Cooley Standard Roofing reinforced Flashing	Various	ASTM D 4434	Single Ply PVC flashing material
Cooley Standard Roofing Coated Metal	Various	ASTM D 4434	Single Ply PVC membrane laminated 24 Ga. galvanized steel.
Cooley Standard Roofing RAM Flashing	Various	ASTM D 4434	Single Ply PVC membrane flashing material
Cooley Standard Roofing RAM Universal Corners	Various	ASTM D 4434	Single ply PVC membrane
Cooley C-3 Fleece backed Membrane	Various	ASTM D 4434	Thermoplastic fleece back membrane
Cooley C-3 Coated Metal	4' x 8' 4' x 10' sheets	US Commercial Standard CS- 245-62	C-3 membrane laminated 24 Ga. galvanized steel.
Cooley C-3 Fleece Back RAM	76" x 100' 39" x 100' 325 ft. <sup>2</sup> roll	ASTM D 4434	Thermoplastic fleece back membrane. Adhered applications.
Cooley C-3 Fleece Back RAM Flashing	12" x 100' 100 ft. <sup>2</sup> roll 24" x 100' 200 ft. <sup>2</sup> roll	ASTM D 4434	Thermoplastic fleece back membrane flashing material.



**TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:**

**TABLE 1**

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Cooley C-3 Fleece Back RAM Universal Corners	14" x 14"	ASTM D 4434	Thermoplastic fleece back membrane. Adhered applications.
Cooley C3 Bonding Adhesive	5 gallon pails	proprietary	Solvent based adhesive for fully adhered RAM systems and C3PLUS roofing membrane.
Cooley WB Bonding Adhesive	N/A	proprietary	Water Based adhesive for fully adhered C3PLUS Roofing Membrane.
Cooley Coolgrip Walkway	0.072" x 36" x 60'	proprietary	Walkway pad (roll configuration)
Cooley Coolgrip Heavy Duty Walkway	0.150" x 36" x 60'	proprietary	Walkway pad (roll configuration)

**APPROVED INSULATIONS:**

**TABLE 2**

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
ACFoam II, III	Isocyanurate Insulation	Atlas Roofing Corp.
Styrofoam	Extruded Polystyrene.	Dow Chemical
ISO 95+ GL	Polyisocyanurate foam insulation	Firestone
EnergyGuard Perlite	Perlite insulation board.	GAF Materials Corp.
Dens Deck, Dens Deck Prime	Silicon treated gypsum	G-P Products
High Density Wood Fiberboard	High Density Wood Fiber insulation board.	Generic
Perlite Insulation Board	Perlite Insulation	Generic
Type X Gypsum, Gypsum	Gypsum Wallboard	Generic
EPS or XPS Insulation	Expanded or Extruded Polystyrene.	Generic
H-Shield	Isocyanurate Insulation	Hunter Panels
ENRGY 2, ENERGY 3, PSI-25 UltraGuard	Isocyanurate Insulation	Johns Manville
Fesco Foam, DuraFoam	Isocyanurate Insulation with perlite facer	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
Ultra-Max, Multi-Max FA, Thermarroof Composite	Polyisocyanurate foam insulation	Rmax Operating, LLC
Structodeck	High Density Wood Fiber insulation board.	Wood Fiber Industries



**APPROVED FASTENERS:**

**TABLE 3**

<u>Fastener Number</u>	<u>Product Name</u>	<u>Product Description</u>	<u>Dimensions</u>	<u>Manufacturer (With Current NOA)</u>
1.	Trufast Twin Loc-Nail Assembled Fastener	Base sheet fastener with integrated Plate.	Length: 1.8" Plate Dia.: 2.7"	Altenloh, Brinck & Co. U.S., Inc.
2.	Strap Toggle Fasteners	Insulation and membrane fastener	Various	OMG, Inc
3.	Polymer Gyptec	Glass reinforced nylon fastener	1" dia. Head up to 12" length	OMG, Inc
4.	Polymer GypTec Insulation Plate	AZ-55 Galvalume plate for use with Polymer GypTec fastener	3" round	OMG, Inc

**EVIDENCE SUBMITTED:**

<u>Test Agency/Identifier</u>	<u>Report</u>	<u>Name</u>	<u>Date</u>
Factory Mutual Corp.	3025170	4470	02/07/06
	3021133	4470	02/07/06
	3047298	4470	10/08/15
	J.I. 0X2A9.AM	4470	06/26/93
	J.I. 3W1A1.AM	4470	03/29/93
	J.I. 1W1A9.AM	4470	09/11/93
	J.I. 1X3A6.AM	4470	10/03/93
	J.I. 1W9A2.AM	4470	06/15/93
	J.I. 1W2A0.AM	4470	08/24/93
	J.I. 1T2A6.AM	4470	02/22/93
	J.I. 3W3A4.AM	4470	03/26/93
	J.I. 0X8A9.AM	4470	06/25/93
	J.I. 1X6A5.AM	4470	10/12/93
	J.I. 2W5A6.AM	4470	06/01/93
Underwriters Laboratories, Inc.	File R9834 (N)	UL 790	04/06/93
Momentum Technologies, Inc.	NX21J0A	ASTM D 4434	06/01/11
	NX21J0B	ASTM D 4434	07/20/11
	NX21J0C	ASTM D 4434	06/01/11



**Membrane Type:** Single Ply, PVC  
**Deck Type 6I:** Poured Gypsum, Insulated  
**Deck Description:** Poured Gypsum  
**System Type C(1):** All layers of insulation simultaneously attached; C3 Plus membrane fully adhered.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
ISO 95+ GL, ENRGY 3 PSI 25, ValuTherm Minimum 2” thick	See Note below	1: 2 ft <sup>2</sup>
ACFoam II, ACFoam III, Minimum 1.5” thick	See Note below	1: 2 ft <sup>2</sup>
High Density Wood Fiberboard Minimum 1” thick	See Note below	1: 2 ft <sup>2</sup>

**Note: All layers shall be simultaneously fastened with Strap Toggle fasteners or Polymer Gyptec fastener and plate all with minimum 1.5” deck penetration. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation.**

**Vapor Retarder:** (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

**Fire Barrier:** (Optional) Minimum 1/4” Dens Deck secured to the deck with the insulation.

**Membrane:** C3 Plus Membrane fully adhered to the insulation with Cooley C3 Bonding Adhesive applied at the rate of 0.83 gal./sq. on both the membrane and the substrate for a total of 1.67 gal./sq., and a heat welded seam minimum 1½” wide at the laps or Cooley WB Bonding Adhesive applied at the rate of 0.67 gal/sq to the substrate.

**Maximum Design Pressure:** -45 psf; (See General Limitation #9.)



**Membrane Type:** Single Ply, PVC  
**Deck Type 6I:** Poured Gypsum, Insulated  
**Deck Description:** Poured Gypsum  
**System Type C(2):** All layers of insulation simultaneously attached; C3 Plus membrane fully adhered.

**All General and System Limitations apply.**

One or more layers of any of the following insulations.

<u>Insulation Layer</u>	<u>Insulation Fasteners (Table 3)</u>	<u>Fastener Density/ft<sup>2</sup></u>
<b>ENRGY 3 PSI 25, ValuTherm, ISO 95+ GL Minimum 2” thick</b>	<b>1</b>	<b>1: 33 ft<sup>2</sup></b>
<b>ACFoam II, ACFoam III Minimum 1.5” thick</b>	<b>1</b>	<b>1: 33 ft<sup>2</sup></b>
<b>High Density Wood Fiberboard Minimum 1” thick</b>	<b>1</b>	<b>1: 33 ft<sup>2</sup></b>

**Note: All layers shall be simultaneously fastened with minimum 1” deck penetration. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Vapor Retarder:** (Optional) Any UL or FM approved vapor retarder applied to the roof deck or over a base layer of insulation.

**Fire Barrier:** (Optional) Minimum 1/4” Dens Deck secured to the deck with the insulation.

**Membrane:** C3 Plus Membrane fully adhered to the insulation with Cooley C3 Bonding Adhesive applied at the rate of 0.83 gal./sq. on both the membrane and the substrate for a total of 1.67 gal./sq., and a heat welded seam minimum 1½” wide at the laps or Cooley WB Bonding Adhesive applied at the rate of 0.67 gal/sq to the substrate.

**Maximum Design Pressure:** -45 psf; (See General Limitation #9.)



## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**



NOA No.:16-0322.01  
Expiration Date: 08/03/21  
Approval Date: 07/21/16  
Page 7 of 7