



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

IB Roof Systems
8181 Jetstar Drive, Suite 150
Irving, TX 75063

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: IB PVC Single Ply Roof Systems over Wood Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No. 15-0928.12 and consists of pages 1 through 11.
The submitted documentation was reviewed by Jorge L. Acebo



NOA No.: 16-0412.04
Expiration Date: 04/28/21
Approval Date: 07/06/17
Page 1 of 11

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Single Ply Roofing
Material:	PVC
Deck Type:	Wood
Maximum Design Pressure:	-45 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
IB PVC Single Ply	50, 60, 80 mil thickness	ASTM D4434	Polyester reinforced PVC membrane.
IB PVC Single Ply Fleeceback	50, 60, 80 mil thickness	ASTM D4434	Polyester reinforced PVC membrane with a non-woven polyester fleeceback.
IB PVC-GR 60	60 mil	ASTM D4434	Fiberglass reinforced PVC membrane.
IB Water Borne Adhesive	3 gal.	Proprietary	Adhesive for bonding IB membranes to wood, concrete and glass faced polyisocyanurate insulations.
IB Vertibond PVC Bonding Adhesive	5 gal.	Proprietary	Adhesive for bonding IB membranes to metal, wood, concrete and certain insulation boards.
IB Rapid Set Insulation Adhesive	Various	Proprietary	Elastomeric, one-step, all-purpose, foamable adhesive.
Sopravap'r	45" x 133'	Various	Self-adhering air/vapor barrier membrane.

APPROVED INSULATIONS:

TABLE 2

<u>Product Name</u>	<u>Product Description</u>	<u>Manufacturer (With Current NOA)</u>
IB EnergyBoard II, IB EnergyBoard III	Polyisocyanurate Insulation	IB Roof Systems
ACFoam-II, ACFoam-III	Polyisocyanurate Insulation	Atlas Roofing Corp.
DensDeck, DensDeck Prime	Gypsum insulation	Georgia Pacific Gypsum LLC
ENRGY 3	Polyisocyanurate Insulation	Johns Manville
Multi-Max FA-3	Polyisocyanurate Insulation	Rmax Operating, LLC
H-Shield, H-Shield CG	Polyisocyanurate insulation	Hunter Panels, LLC
Insulfoam EPS	Closed-cell, Type IX (min 1.8 pcf) expanded polystyrene.	Insulfoam, a Div. of Carlisle Const. Materials
ISO 95+ GL	Polyisocyanurate foam insulation	Firestone Building Products Company, LLC
SECUROCK Gypsum-Fiber Roof Board	Gypsum insulation	US Gypsum

APPROVED FASTENERS / ADHESIVES:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	IB #14 Heavy Duty Roofing Fastener	#14 membrane fastener	Various	IB Roof Systems
2.	IB 2" Barbed Seam Plates	2" round barbed membrane plate	2" round	IB Roof Systems
3.	IB #12 Standard Roofing Fastener	#12 insulation fastener	Various	IB Roof Systems
4.	IB 3" Galvalume Insulation Plate	Galvalume coated steel plate	3" round	IB Roof Systems
5.	#12 Standard Roofgrip	#12 insulation fastener	Various	OMG, Inc.
6.	OMG #14 Roofgrip Fastener	#14 carbon steel fastener with CR-10 coating.	Various	OMG, Inc.
7.	OMG 2" Barbed Plate	2" round barbed membrane plate	2" round	OMG, Inc.
8.	OMG 3" Galvalume Steel Plate	Galvalume coated steel plate	3" round	OMG, Inc.
9.	IB 3" Insulation Plate	Galvalume stress plate	3" round	IB Roof Systems
10.	Dekfast Galvalume Steel 3" Round	Galvalume stress plate	3" round	SFS Intec, Inc.
11.	Millennium One Step Foamable Adhesive	Polyurethane two component high rise insulation adhesive	1.5 liters	Adco Products, Inc. d.b.a. Royal Adhesives & Sealants, Inc.
12.	OMG OlyBond 500 Adhesive	Spray polyurethane foam insulation adhesive	10 gal. bag-in-box set and 1.5 liters SpotShot cartridge	OMG, Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	2D5A9.AM	FM 4450	06/22/99
	3009502	FM 4470	12/21/00
	3012321	FM 4470	07/29/02
	3015444	FM 4450	07/11/03
	3014692	FM 4470	08/05/03
	3014751	FM 4450	08/27/03
	3029864	FM 4470	02/18/08
	Underwriters Laboratories Inc.	02NK18635	CGSB-37.54-95
Exterior Research & Design, LLC	03903.05.06-2	TAS 114-J	05/10/06
	03900.05.05-R1	TAS 114-D	03/23/10
Trinity ERD	02762.03.05-R1	TAS 114-D/TAS 114-J	12/10/07
	I11110.02.09	TAS 114-J	02/05/09
	03903.05.06-2-R1	TAS 114-J	07/13/09
	I31580.10.10	ASTM D4434	10/18/10
	I33030.03.11	TAS 114	03/11/11
	02642.01.05-1-R2	TAS 114-J	06/07/11
	SC5160.01.15-R1	TAS 114	02/03/15
	SC5160.02.15	TAS 114	02/12/15



APPROVED ASSEMBLIES

- Membrane Type:** Single Ply, PVC
- Deck Type II:** Wood, Insulated
- Deck Description:** Min. 15/32-inch plywood or wood plank
- System Type B(1):** Thermal barrier mechanically attached, vapor barrier, base and top layer of insulation adhered with approved adhesive, roof cover fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

Thermal Barrier	Thermal Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.5” thick	1, 3, 4, 5, 6, 8, 9, 10	1:1.6 ft²
Vapor Barrier: Soprapap’r, primed with Elastocol Stick Zero or Elastocol Stick applied at 1.0 gal./sq., adhered to the Thermal Barrier.		

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam-II, IB EnergyBoard II, ACFoam-III, IB EnergyBoard III, H-Shield, H-Shield CG Minimum 1.0” thick	N/A	N/A

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25” thick	N/A	N/A

Note: All insulations shall be adhered with OlyBond 500 applied in ¾” – 1” wide beads 12” o.c. or Millennium One Step Foamable Adhesive or IB Rapid Set Insulation Adhesive applied in ½” - ¾” wide beads 12” o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

- Membrane:** IB PVC-GR 60 or IB PVC Single Ply roof cover adhered to the insulation with IB Vertibond PVC Bonding Adhesive at 1 gal/50 – 70 ft2 (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- ½” heat weld.
Or
IB PVC Single Ply roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/125 – 175 ft2 (substrate only). Side laps are min. 3-inch wide sealed with min. 1- ½” heat weld.
Or
IB PVC Single Ply Fleeceback roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/100 – 160 ft2 (substrate only) or IB Vertibond PVC Bonding Adhesive at 1 gal/45 – 60 ft2 (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- ½” heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #9.)



Membrane Type: Single Ply, PVC
Deck Type 1I: Wood, Insulated
Deck Description: Min. 15/32-inch plywood or wood plank
System Type B(2): Base layer of insulation mechanically attached, top layer adhered with approved adhesive, roof cover fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam-II, IB EnergyBoard II, ACFoam-III, IB EnergyBoard III, H-Shield, H-Shield CG Minimum 2.0" thick	1, 3, 4, 5, 6, 8, 9, 10	1:1.6 ft²
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulations shall be adhered with OlyBond 500 applied in 3/4" – 1" wide beads 12" o.c. or Millennium One Step Foamable Adhesive or IB Rapid Set Insulation Adhesive applied in 1/2" – 3/4" wide beads 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: IB PVC-GR 60 or IB PVC Single Ply roof cover adhered to the insulation with IB Vertibond PVC Bonding Adhesive at 1 gal/50 – 70 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.
 Or
 IB PVC Single Ply roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/125 – 175 ft² (substrate only). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.
 Or
 IB PVC Single Ply Fleeceback roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/100 – 160 ft² (substrate only) or IB Vertibond PVC Bonding Adhesive at 1 gal/45 – 60 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #9.)



Membrane Type: Single Ply, PVC
Deck Type II: Wood, Insulated
Deck Description: Min. 15/32-inch plywood or wood plank
System Type B(3): Base layer of insulation mechanically attached, top layer adhered with approved adhesive, roof cover fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam-III, IB EnergyBoard III, H-Shield, H-Shield CG Minimum 1.5" thick	1, 3, 4, 5, 6, 8, 9, 10	1:1.6 ft ²
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	N/A	N/A

Note: All insulations shall be adhered with OlyBond 500 applied in 3/4" – 1" wide beads 12" o.c. or Millennium One Step Foamable Adhesive or IB Rapid Set Insulation Adhesive applied in 1/2" – 3/4" wide beads 12" o.c. Refer to Roofing Application Standard RAS 117 for insulation attachment. Insulations listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Membrane: IB PVC-GR 60 or IB PVC Single Ply roof cover adhered to the insulation with IB Vertibond PVC Bonding Adhesive at 1 gal/50 – 70 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.
 Or
 IB PVC Single Ply roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/125 – 175 ft² (substrate only). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.
 Or
 IB PVC Single Ply Fleeceback roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/100 – 160 ft² (substrate only) or IB Vertibond PVC Bonding Adhesive at 1 gal/45 – 60 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #9.)



Membrane Type: Single Ply, PVC
Deck Type II: Wood, Insulated
Deck Description: Min. 15/32-inch plywood or wood plank
System Type C(1): All layers of insulation simultaneously attached; membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
Multi-Max FA-3 Minimum 1.5" thick	3, 4, 5, 8	1:1.6 ft ²
SECUROCK Gypsum-Fiber Roof Board Minimum 0.5" thick	3, 4, 5, 8	1:1.6 ft ²

Note: All layers shall be simultaneously fastened; see above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: IB PVC Single Ply roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/125 – 175 ft² (substrate only). Side laps are min. 3-inch wide sealed with min. 1-1/2" heat weld.

Or

IB PVC-GR 60 or IB PVC Single Ply roof cover adhered to the insulation with IB Vertibond PVC Bonding Adhesive at 1 gal/50 – 70 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1-1/2" heat weld.

Or

IB PVC Single Ply Fleeceback roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/100 – 160 ft² (substrate only) or IB Vertibond PVC Bonding Adhesive at 1 gal/45 – 60 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1-1/2" heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



Membrane Type: Single Ply, PVC
Deck Type 1I: Wood, Insulated
Deck Description: Min. 15/32-inch plywood or wood plank
System Type C(2): All layers of insulation simultaneously attached; membrane fully adhered.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

Base Insulation Layer (Optional)	Insulation Fasteners (Table 3)	Fastener Density/ft²
Any Polyisocyanurate Insulation listed in Table 2. Any thickness	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam-II, IB EnergyBoard II, ACFoam-III, IB EnergyBoard III, H-Shield, H-Shield CG, Multi-Max FA-3 Minimum 1.5" thick	1, 3, 4, 5, 6, 8, 9, 10	1:1.6 ft²
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25" thick	1, 3, 4, 5, 6, 8, 9, 10	1:1.6 ft²

Note: All layers shall be simultaneously fastened; see above for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Membrane: IB PVC-GR 60 or IB PVC Single Ply roof cover adhered to the insulation with IB Vertibond PVC Bonding Adhesive at 1 gal/50 – 70 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.
 Or
 IB PVC Single Ply roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/125 – 175 ft² (substrate only). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.
 Or
 IB PVC Single Ply Fleeceback roof cover adhered to the insulation with IB Water Borne Adhesive at 1 gal/100 – 160 ft² (substrate only) or IB Vertibond PVC Bonding Adhesive at 1 gal/45 – 60 ft² (contact both sides). Side laps are min. 3-inch wide sealed with min. 1- 1/2" heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #9.)



Membrane Type: Single Ply, PVC
Deck Type II: Wood, Insulated
Deck Description: Min. 19/32-inch plywood or wood plank
System Type D: Membrane mechanically attached over preliminary fastened insulation.

All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.

One or more layers of the following.

Insulation Layer	Insulation Fasteners	Fastener Density
Any Polyisocyanurate Insulation listed in Table 2. Minimum 1.5” thick	N/A	N/A
Any approved Expanded Polystyrene Type IX (min 1.8 pcf) Insulation listed in Table 2. Minimum 1.0” thick	N/A	N/A
DensDeck, DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum 0.25” thick	N/A	N/A

Note: All layers of insulation shall have preliminary attachment, prior to the installation of the membrane sheet, at a minimum application rate of two fasteners per board for insulation boards having no dimension greater than 4 ft., and four fasteners for any insulation board having no dimension greater than 8 ft. All layers of insulation and base sheet shall be simultaneously fastened. See membrane sheet below for fasteners and density.

Membrane: IB PVC Single Ply or IB PVC Single Ply Fleeceback secured through the preliminarily attached insulation as specified below:
 Install maximum 72” wide sheets with a 5” overlap fastened 6” o.c. with IB #14 Heavy Duty Roofing Fasteners with IB 2” Barbed Seam Plates or OMG #14 Roofgrip Fasteners with OMG 2” Barbed Plates. Side laps are min. 5” wide sealed with min. 1.5” heat weld.

Maximum Design Pressure: -45 psf. (See General Limitation #7.)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

