



MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
 11805 SW 26 Street, Room 208
 Miami, Florida 33175-2474
 T (786)315-2590 F (786) 31525-99
www.miamidade.gov/economy

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
 BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

Johns Manville Corporation
 717 17th Street
 Denver, CO 80202

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Johns Manville Built-Up Roofing Systems over Recover Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 13-0529.12 and consists of pages 1 through 14.
 The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 16-0413.16
 Expiration Date: 07/19/21
 Approval Date: 06/16/16
 Page 1 of 14

ROOFING SYSTEM APPROVAL

Category:	Roofing
Sub-Category:	Built-up Roofing
Materials:	Fiberglass
Deck Type:	Recover
Maximum Design Pressure:	See Specific Deck Type

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
DynaBase	54'-10" x 36"	ASTM D6163 Type I Grade S	An SBS modified bitumen coated, fiber glass reinforced base sheet.
GlasBase Plus	36" x 108'	ASTM D4601	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
PermaPly 28	36" x 106'	ASTM D4601	Type II asphalt impregnated and coated glass fiber base sheet for use in conventional and modified bitumen built-up roofing.
GlasPly IV	36" x 180'	ASTM D2178 Type IV	Type IV asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
GlasPly Premier	36" x 180'	ASTM D2178 Type VI	Type VI asphalt impregnated glass felt for use in conventional and modified bitumen built-up roofing.
GlasKap	36" x 36	ASTM D3909	Asphalt impregnated and coated felt surfaced with mineral granules used as the top ply in conventional built-up roof membranes.
GlasKap CR	36" x 36'	ASTM D3909	White mineral surfaced, white acrylic coated, fiber glass cap sheet for use as the top ply in conventional built-up roof membranes
GlasKap Plus	39-3/8" x 34'	ASTM D3909	SBS Modified Asphaltic cap sheet used as the top ply in conventional built-up roof membranes.
Bestile Industrial Roof Cement	N/A	ASTM D 4586 Type II	General purpose medium trowel grade, cement cutback asphalt mastic reinforced with non-asbestos fibers and mineral stabilizers.
MBR Flashing Cement Activator	N/A	Proprietary	Activator component for use with MBR Flashing Cement Base



<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
MBR Flashing Cement Base	N/A	Proprietary	A two component elastomeric, cold application adhesive, consisting of a modified proprietary compound with an asphalt base.
MBR Bonding Adhesive	N/A	Proprietary	A two-part insulation and membrane adhesive
JM Urethane Insulation Adhesive	N/A	Proprietary	Urethane insulation adhesive.
Expand-O-Flash	Various	Proprietary	Expansion joint covers manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges. Available in various standard configurations and may be custom manufactured to specific dimensions.
Expand-O-Guard	Various	Proprietary	Elastomeric expansion joint cover for vertical expansion and seismic joints. Manufactured from non-reinforced, form-supported elastomeric bellows with a bifurcated waterproof attachment to metal flanges. Available in various standard configurations and may be custom manufactured to specific dimensions.
FP-10 Vents	10" deck flange, base diameter of 4" and a height of 6".	Proprietary	One-way roof vent, designed for use in various roof systems, for the release of pressure created by gases or moisture vapor trapped within the roofing system.
FesCant Plus Cant Strips, and Taper Edge.	Various	TAS 110	Factory pre-fabricated cant strips and taper edge, manufactured from expanded perlite insulation.
Flex-I-Drain	Various sizes from 3" to 6"	BOCA 76-61 SBCCI 89204 UBC 3236	Two piece flexible drain system composed of a Noryl deck flange, a flexible neoprene bellows and no hub connection. Available in various sizes and styles for most retro-fit applications.
Presto Lok Fascia and Flashing System	Various	TAS 114	A multi-piece fascia and flashing system for built-up and modified bitumen roofing systems manufactured from aluminum or steel. Extender plates available for wide fascia applications. This assembly meets the criteria of FMRC 1-49 for wind resistance perimeter flashing.



APPROVED INSULATIONS:

TABLE 2

Product Name	Product Description	Manufacturer (With Current NOA)
ENRGY 3, ENRGY 3 25 PSI, ValuTherm, ValuTherm 25 PSI, R-Panel, R-Panel 25 PSI	Isocyanurate Insulation.	Johns Manville
ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI	Isocyanurate Insulation with glass reinforced facers	Johns Manville
DuraBoard	High-density perlite roof insulation.	Johns Manville
Fesco Board	Rigid perlite roof insulation board.	Johns Manville
AC Foam II	Isocyanurate Insulation	Atlas Roofing Corp.
Structodek® High Density Fiber Board Roof Insulation	High density wood fiber insulation board	Blue Ridge Fiberboard, Inc.
DensDeck	Silicon treated gypsum	Georgia-Pacific Gypsum LLC
ISO 95+ GL	Polyisocyanurate foam insulation	Firestone Building Products Company, LLC
Multi-Max FA-3	Polyisocyanurate foam insulation	Rmax Operating, LLC

APPROVED FASTENERS:

TABLE 3

Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Trufast Twin Loc-Nail Assembled Fastener	Base sheet fastener with integrated Plate.	Min. 1.8” length	Altenloh, Brink & Co. U.S., Inc.



EVIDENCE SUBMITTED:

<u>Test Agency/Identifier</u>	<u>Name</u>	<u>Report</u>	<u>Date</u>
Factory Mutual Research Corp.	3001629	Class 4470	09/10/98
	3D4A4.AM	Class 4470	09/28/98
	3000949	Class 4470	06/05/98
	3001482	Class 4470	08/11/98
	OZ8A9.AM	Class 4470	09/10/98
	3009502	Class 4450	12/21/00
	3009499	Class 4470	04/04/01
	3014090	Class 4470	09/05/02
	3012974	Class 4450	06/03/02
	3011248	Class 4470	11/01/02
	3011057	Class 4470	08/10/01
	3015444	Class 4450	07/11/03
	3026130	Class 4470	04/26/06
	3037540	Class 4450	10/20/10
	Trinity ERD	10391.01.03	TAS 114-J
J7670.06.08		ASTM D3909	06/16/08
Underwriters Laboratories, Inc.	R10167	UL 790	05/27/13
IRT-ARCON, Inc.	02-026	TAS 114-J	07/26/02
	02-011	TAS 114-J	02/06/02
PRI Construction Materials Technologies, LLC	JMC-069-02-01.1	ASTM D3909	05/26/16
	JMC-070-02-01	ASTM D2178	04/17/12
	JMC-071-02-01	ASTM D2178	04/17/12
	JMC-072-02-02.1	ASTM D4601	05/25/16
	JMC-072-02-03	ASTM D4601	06/14/12
	JMC-074-02-01	ASTM D4897 Type II	04/17/12
	JMC-093-02-01	ASTM D4601 TYPE II	08/02/12
	JMC-171-02-01	ASTM D6163	01/10/14
	JMC-107-02-01 Rev 2	ASTM D903	08/19/13
		ASTM D1876	
		ASTM D5147	
		TAS 117(B)	
TAS 117(A)			
	TAS 114(C)		

DECK STRESS ANALYSIS CALCULATIONS/REPORTS

<u>Engineer/Agency</u>	<u>Identifier</u>	<u>Assemblies</u>	<u>Date</u>
Zachary R. Priest, P.E.	Signed/Sealed Calculations	E(1)	04/27/16



APPROVED ASSEMBLIES

Membrane Type: BUR

Deck Type 7I: Recover

Deck Description: Concrete

System Type A(1): All layer of insulation adhered to a primed roof membrane. Membrane is subsequently fully or partially adhered.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI Minimum 1.5 thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Fesco Board, DuraBoard Minimum 3/4" thick	N/A	N/A

Note: All layers of insulation shall be adhered with approved asphalt within the EVT range and at a rate of 20-40 lbs./100 ft² or MBR Bonding Adhesive in 1-1/2" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAs 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) One ply of GlasBase Plus, PermaPly 28, GlasPly Premier or GlasPly IV Base Sheet adhered to the insulated substrate in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier Ply VI adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -120 psf. (See General Limitation #9).



Membrane Type: BUR
Deck Type 7I: Recover, Insulated
Deck Description: Concrete
System Type A(2): All layers of insulation adhered.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI, AC Foam II, ISO 95+ GL, Multi Max FA-3 Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
Fesco Board Minimum 3/4" thick	N/A	N/A

Note: All layers of insulation shall be adhered with JM Urethane Insulation Adhesive in 1/2" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAs 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) PermaPly 28, GlasBase Plus, DynaBase, GlasPly Premier or GlasPly IV applied to the insulation in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier ply sheet adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -112.5 psf. (See General Limitation #9)



Membrane Type: BUR
Deck Type 7I: Recover, Insulated
Deck Description: Concrete
System Type A(3): All layers of insulation adhered.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI, AC Foam II, ISO 95+ GL, Multi Max FA-3 Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation shall be adhered with JM Urethane Insulation Adhesive in ½" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) PermaPly 28, GlasBase Plus, DynaBase, GlasPly Premier or GlasPly IV applied to the insulation in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; **See General Limitation #4 Maximum Design Pressure -45 psf. applies.**

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier ply sheet adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If ply sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; **See General Limitation #4 Maximum Design Pressure -45 psf. applies.**

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:
 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -157.5 psf. (See General Limitation #9)



Membrane Type: BUR
Deck Type 7I: Recover, Insulated
Deck Description: Concrete
System Type A(4): All layers of insulation adhered.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI, AC Foam II, ISO 95+ GL, Multi Max FA-3 Minimum 1.5" thick	N/A	N/A
Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck, Structodek High Density Fiber Board Roof Insulation Minimum 3/4" thick	N/A	N/A

Note: All layers of insulation shall be adhered with JM Urethane Insulation Adhesive in 1/2" wide beads at maximum spacing of 12" o.c. Please refer to Roofing Application Standard RAs 117 for insulation attachment. Insulation listed as base layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) PermaPly 28, GlasBase Plus, DynaBase, GlasPly Premier or GlasPly IV applied to the insulation in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier ply sheet adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -105 psf. (See General Limitation #9)



Membrane Type: BUR
Deck Type 7I: Recover, Insulated
Deck Description: Concrete with an existing mineral cap sheet
System Type A(5): All layers of insulation adhered.

All General and System limitations apply.

One or more layers of any of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft ²
ENRGY 3, ENRGY 3 25 PSI, ENRGY 3 CGF, ENRGY 3 CGF 25 PSI, ENRGY 3 AGF, ENRGY 3 AGF 25 PSI, ValuTherm, ValuTherm 25 PSI, ValuTherm CGF, ValuTherm CGF 25 PSI, ValuTherm AGF, ValuTherm AGF 25 PSI, R-Panel, R-Panel 25 PSI, AC Foam II, ISO 95+ GL, Multi Max FA-3 Minimum 1.5" thick	N/A	N/A

Note: All layers of insulation shall be adhered with JM Urethane Insulation Adhesive in ½" wide beads at maximum spacing of 6" o.c. Please refer to Roofing Application Standard RAs 117 for insulation attachment. Composite insulation panels may be used as a top layer placed with the polyisocyanurate side facing down.

Base Sheet: (Optional) PermaPly 28, GlasBase Plus, DynaBase, GlasPly Premier or GlasPly IV applied to the insulation in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If base sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; **See General Limitation #4 Maximum Design Pressure -45 psf. applies.**

Ply Sheet: Two or more plies (three plies required if neither a base sheet nor a cap sheet is used) of GlasPly IV or GlasPly Premier ply sheet adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq. If ply sheet is applied directly to polyisocyanurate insulation only a spot or strip mopped application as detailed in this approval is approved; **See General Limitation #4 Maximum Design Pressure -45 psf. applies.**

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:
 1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -172.5 psf. (See General Limitation #9)



Membrane Type: BUR

Deck Type 7: Recover

Deck Description: Lightweight concrete over structural concrete of minimum 22 ga., Grade 33 steel deck attached to supports spaced a maximum 5-ft o.c. *The deck should record a Minimum Characteristic Resistance Force (MCRF) of 111 lbf when tested with the Trufast Twin Loc-Nail Assembled Fasteners in accordance with TAS 105.
This Tested Assembly has been analyzed for allowable deck stress. See Evidence Submitted Table.

System Type E(1): Base sheet mechanically fastened.

Base Sheet: One ply of PermaPly 28, DynaBase, or GlasPly Premier fastened to the deck as described below:

Fastening Option 1: Fasten base sheet with minimum 1.8" Trufast Twin Loc-Nail Assembled Fasteners spaced 9" o.c. at the 4" side lap and two rows staggered 9" o.c. in the field.
(Maximum Design Pressure -60 psf. - See General Limitation #7.)

Fastening Option 2: DynaBase only fastened with minimum 1.8" Trufast Twin Loc-Nail Assembled Fasteners spaced 9" o.c. at the 4" side lap and two rows staggered 9" o.c. in the field.
(Maximum Design Pressure -75 psf. - See General Limitation #7.)

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

1. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: See Fastening Options Above



Membrane Type: BUR

Deck Type 7: Recover

Deck Description: Poured Gypsum. *The deck should record a Minimum Characteristic Resistance Force (MCRF) of 126 lbf when tested with the Trufast Twin Loc-Nail Assembled Fasteners in accordance with TAS 105.

System Type E(2): Base sheet mechanically fastened.

Base Sheet: One ply of GlasPly Premier fastened to the deck as described below:

Fastening: Fasten base sheet with 1.8" Trufast Twin Loc-Nail Assembled Fastener spaced 9" o.c. at the 3" side lap and two rows staggered 12" o.c. in the field.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

2. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -75 psf. (See General Limitation #7)



Membrane Type: BUR

Deck Type 7: Recover

Deck Description: Cementitious Wood Fiber. *The deck should record a Minimum Characteristic Resistance Force (MCRF) of 139 lbf when tested with the Trufast Twin Loc-Nail Assembled Fasteners in accordance with TAS 105.

System Type E(3): Base sheet mechanically fastened.

Base Sheet: One ply of GlasPly Premier fastened to the deck as described below:

Fastening: Fasten base sheet with 1.8" Trufast Twin Loc-Nail Assembled Fastener spaced 9" o.c. at the 3" side lap and two rows staggered 12" o.c. in the field.

Ply Sheet: Two or more plies of GlasPly IV or GlasPly Premier adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Cap Sheet: (Optional) One ply of GlasKap, GlasKap CR or GlasKap Plus adhered in a full mopping of hot asphalt applied within the EVT range and at a rate of 20-40 lbs./sq.

Surfacing: (Required if no cap sheet is used) Install the following:

3. Flood coat and gravel/slag with an application rate of 60 lbs./sq. & 400 lbs./sq., respectively.

Maximum Design Pressure: -82.5 psf. (See General Limitation #7)



RECOVER SYSTEM LIMITATIONS:

1. All System Limitations and General Limitations shall apply. See specific deck type Notice of Acceptance for deck type System Limitations.
2. All assemblies listed herein shall be installed in compliance with the applicable sections of FBC 1521. Uplift performance of assemblies bonded to existing roofing system shall be verified per 1521.10. Uplift performance of assemblies mechanically attached through existing roofing system shall be verified per 1521.11.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.
Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 16-0413.16
Expiration Date: 07/19/21
Approval Date: 06/16/16
Page 14 of 14