



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

US Ply, Inc.  
2000 E. Richmond Ave.  
Fort Worth, TX 76104

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: US Ply Built-Up Roofing Systems over Wood Decks

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by Alex Tigera.



NOA No.: 16-0425.02  
Expiration Date: 08/24/21  
Approval Date: 08/24/16  
Page 1 of 5

## ROOFING ASSEMBLY NOTICE OF ACCEPTANCE

**Category:** Roofing  
**Sub-Category:** Built Up Roofing  
**Material:** BUR  
**Deck Type:** Wood  
**Maximum Design Pressure:** - 60 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

| <b><u>Product</u></b> | <b><u>Dimensions</u></b> | <b><u>Test Specification</u></b> | <b><u>Product Description</u></b>  |
|-----------------------|--------------------------|----------------------------------|--|
| USP Base              | 36" x 108'               | ASTM D 4601                      | A non-porous 28 pound base sheet consisting of a heavyweight, fiberglass mat saturated with polymer modified asphalt with a sand surfacing. For use as a mechanically fastened or adhered base sheet in a wide variety of built-up roofing applications. |
| USP Type IV Felt      | 36" X 180'               | ASTM D 2178                      | A heavyweight fiberglass mat saturated with type IV asphalt, giving excellent strength and weathering characteristics. For use as a ply sheet in hot mopped built-up roofing applications  |
| USP Type VI Felt      | 36" X 180'               | ASTM D 2178                      | A heavyweight fiberglass mat saturated with type IV asphalt, giving excellent strength and weathering characteristics. For use as a ply sheet in hot mopped built-up roofing applications  |
| USP Mineral Cap Sheet | 36" x 36'                | ASTM D 3909                      | A high strength non-woven fiberglass carrier for added dimensional stability coated on both sides with premium grade asphalt. Mineral granule surfacing for superior weathering characteristics.   |

### APPROVED INSULATIONS:

TABLE 2

| <b><u>Product Name</u></b> | <b><u>Product Description</u></b> | <b><u>Manufacturer (With Current NOA)</u></b> |
|----------------------------|-----------------------------------|---|
| N/A                        | N/A                               | N/A   |

### APPROVED FASTENERS:

TABLE 3

| <b><u>Fastener Number</u></b> | <b><u>Product Name</u></b> | <b><u>Product Description</u></b> | <b><u>Dimensions</u></b> | <b><u>Manufacturer (With Current NOA)</u></b> |
|-------------------------------|----------------------------|-----------------------------------|--------------------------|---|
| 1.                            | N/A                        | N/A                               | N/A                      | N/A   |



NOA No.: 16-0425.02  
Expiration Date: 08/24/21  
Approval Date: 08/24/16  
Page 2 of 5

**EVIDENCE SUBMITTED:**

| <u>Test Agency</u>                        | <u>Test Identifier</u> | <u>Description</u> | <u>Date</u> |
|---|------------------------|--------------------|-------------|
| PRI Construction Material<br>Technologies | BWR-505-02-01 (rev)    | ASTM D 2178        | 01/23/09    |
|   | BWR-506-02-01 (rev)    | ASTM D 2178        | 01/23/09    |
|   | BWR-530-02-01          | ASTM D 4601        | 12/03/10    |
|   | BWR-539-02-01          | ASTM D 3909        | 07/24/13    |
|   | USPI-015-02-01         | TAS 114 J          | 01/30/16    |

## APPROVED ASSEMBLIES

|                          |   |
|--------------------------|---|
| <b>Membrane Type:</b>    | BUR   |
| <b>Deck Type II:</b>     | Wood, Non-Insulated   |
| <b>Deck Description:</b> | Min. 19/32" thick plywood attached to wood supports spaced a maximum 24-inch o.c attached with minimum 0.113" x 2-3/8" ring shank nails 6" o.c. at the perimeter and 6" o.c. in the field |
| <b>System Type E(1):</b> | Base sheet mechanically fastened.   |

### All General and System limitations apply.

|                                 |   |
|---------------------------------|---|
| <b>Base Sheet:</b>              | One ply of USP Base sheet shall be mechanically fastened to the deck with 32 ga x 1-5/8" diameter ring shank nails and 12 ga. x 1 1/4" ring shank nails spaced maximum 8" o.c. in the minimum 3" lap and maximum 8" o.c. in two, equally spaced, staggered center rows. |
| <b>Ply Sheet:</b>               | One or more layers of USP Type IV Felt or USP Type VI Felt with minimum 4" wide side laps, adhered in hot asphalt applied in EVT range at a rate of 20 - 40 lbs/sq.   |
| <b>Cap Sheet:</b>               | One ply of USP Mineral Cap Sheet with minimum 4" wide side laps, adhered in hot asphalt applied in EVT range at a rate of 20 - 40 lbs/sq.   |
| <b>Maximum Design Pressure:</b> | - 60 psf (See General Limitation #7).   |



## WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with USP Type IV Felt or USP Type VI Felt when used as a mechanically fastened base or anchor sheet.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

## END OF THIS ACCEPTANCE