



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

**Firestone Building Products Company, LLC.**  
250 W 96<sup>th</sup> Street  
Indianapolis, IN 46260

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: CLAD-GARD MA Roofing Underlayment

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA# 12-0229.01 and consists of pages 1 through 3.  
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 17-0221.03  
Expiration Date: 02/01/22  
Approval Date: 05/25/17  
Page 1 of 3

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Underlayment  
**Material:** Polypropylene

### SCOPE:

This acceptance is for **CLAD-GARD MA Roofing Underlayment**, as described in this Notice of Acceptance, for use with approved prepared roof assemblies where ASTM D 226 Type I or II underlayment is specified. (See Limitations Below). Designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
CLAD-GARD MA Roofing Underlayment	Width = 36", 38", up to 144" Length = min. 25'	ASTM D 226 Type I & Type II TAS 104	A hybrid underlayment composed of a woven-polypropylene core, coated on both sides with a polymer coating.

### MANUFACTURING LOCATION:

1. Truro, Nova Scotia, Canada

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
Intertek ETL SEMKO	3092073COQ-005A	TAS-104 / ASTM D 226	02/14/07

### INSTALLATION:

1. CLAD-GARD MA Roofing Underlayment and its components shall be installed in strict compliance with applicable Building Code.
2. CLAD-GARD MA Roofing Underlayment shall be installed with a minimum 4-inch head lap in a shingle layer fashion and a 6" end lap where required. Fastener spacing shall be a maximum of 4" o.c. on the head and end laps and 12" o.c. vertically and horizontally in the field of the membrane in compliance with Florida Building Code 1518.2 .
3. CLAD-GARD MA Roofing Underlayment may be used with Asphaltic shingles, Wood shakes and shingles, Non-structural metal roofing, and quarry slate.
4. CLAD-GARD MA Roofing Underlayment shall not be used as roof tile underlayment or anchor sheet within a roof tile underlayment system.
5. For fire classifications of specific roof assemblies using CLAD-GARD MA Roofing Underlayment refer to a current Approved Roofing Materials Directory for fire ratings of this product.



NOA No.: 17-0221.03  
Expiration Date: 02/01/22  
Approval Date: 05/25/17  
Page 2 of 3

## **LABELING:**

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



## **BUILDING PERMIT REQUIREMENTS:**

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

## **LIMITATIONS:**

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. CLAD-GARD MA Roofing Underlayment is a component used in roof assemblies. Roof assemblies are approved under specific assembly Notice of Acceptance.
4. CLAD-GARD MA Roofing Underlayment shall not be left exposed as a temporary roof for longer than 30 days of application. Firestone Building Products Company, LLC., reserves the right to revise or alter product exposure times; not to exceed the preceding maximum time limitations.
5. CLAD-GARD MA Roofing Underlayment can be used in any prepared roof assemblies were an ASTM D 226 Type I & II is required with the exception of Roof Tile Systems.
6. CLAD-GARD MA Roofing Underlayment may be used with any approved roof covering Notice of Acceptance listing CLAD-GARD MA Roofing Underlayment as a component part of an assembly in the Notice of Acceptance. If CLAD-GARD MA Roofing Underlayment is not listed, a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code

**END OF THIS ACCEPTANCE**



NOA No.: 17-0221.03  
Expiration Date: 02/01/22  
Approval Date: 05/25/17  
Page 3 of 3