



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

ReflectASeal, LLC.
10871 SW 188 St, #14
Miami, FL 33157

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: ReflectASeal Waterproofing System

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA #12-0919.01 and consists of pages 1 through 5.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 18-0220.15
Expiration Date: 03/14/23
Approval Date: 03/29/18
Page 1 of 5

WATERPROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Waterproofing
Materials: Elastomeric
Maximum Design Pressure -184 psf

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
ReflectASeal 100	1 & 5 gallon containers	ASTM D 6083	Two part epoxy elastomeric maintenance roof coating.
ReflectASeal 505 Concrete Primer	1 & 5 gallon containers	Adhesion-Pull-Off (D4541)	Two part epoxy primer

PRODUCTS MANUFACTURED BY OTHERS:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>	<u>Manufacturer</u>
Ceramic Tile	12"x 12" x 1/4" thick	ISO 13006	Clay exterior grade tiles.	Generic
Multi-Purpose Thin Set Mortar	Various	ANSI A108.5, A137.2, ISO 13007-2	A high performance dry set mortar.	Generic

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Specification</u>	<u>Date</u>
PRI Construction Materials Technologies	NRS-001-02-01	ASTM D6083	05/11/10
American Test Lab of South Florida	RT1116.01-11	TAS 114-D	01/02/12



NOA No.: 18-0220.15
Expiration Date: 03/14/23
Approval Date: 03/29/18
Page 2 of 5

APPROVED APPLICATIONS:

Deck Type 3:	Concrete Decks, Roof Plaza Decks, Parking Garage
Deck Description:	Min. 2500 psi concrete, and/or dual slab construction
System Type F(1):	ReflectASeal Waterproofing System
Substrate Preparation:	All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.
Primer:	Apply ReflectASeal 505 Concrete Primer: Mix the two component primer as per manufacturer's published instructions. Apply the primer to prepared concrete deck at a minimum rate of 250 ft ² /gallon.
Base Coat:	Apply ReflectASeal 100: Mix the two components as per the manufacturer's published installation instructions. Apply one coat of to the primed concrete deck at a minimum rate of 100 ft ² /gallon. Do not apply heavier than 16 wet mils per coat.
Finish Coat:	Apply a second coat of ReflectASeal 100FR at a minimum rate of 100 ft ² /gallon. Do not apply heavier than 16 wet mils per coat.
Integrity Test:	Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.
Inspection:	Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.
Maximum Design Pressure	-184 psf. (See General Limitaion #9)



Deck Type 3:	Concrete Decks, Roof Plaza Decks, Parking Garage
Deck Description:	Min. 2500 psi concrete
System Type F(2):	ReflectASeal Waterproofing System
Substrate Preparation:	All surfaces must be dry, smooth, free of depressions, voids, and protrusions, and clean and free of any non-compatible curing compounds, foam release agents and other surface contaminants. Substrate shall be smooth, free of voids, spalled areas, laitance, honeycombs, and sharp protrusions.
Primer:	Apply ReflectASeal 505 Concrete Primer: Mix the two component primer as per manufacturer's published instructions. Apply the primer to prepared concrete deck at a minimum rate of 250 ft ² /gallon.
Base Coat:	Apply ReflectASeal 100: Mix the two components as per the manufacturer's published installation instructions. Apply one coat of to the primed concrete deck at a minimum rate of 100 ft ² /gallon. Do not apply heavier than 16 wet mils per coat.
Finish Coat:	Apply a second coat of ReflectASeal 100 at a minimum rate of 100 ft ² /gallon. Do not apply heavier than 16 wet mils per coat. Broadcast fine silica sand over the finish coat at a rate specified in the manufacturer's published installation instructions while the finish coat is still wet.
Integrity Test:	Required, and shall be performed in accordance with ASTM D 5957. Water maybe maintained for a period longer than 24 hours if required.
Inspection:	Contractor and a representative of the membrane manufacturer shall inspect the waterproofing assembly and notify the contractor of any defects. All defects shall be corrected.
Surfacting:	Ceramic tile with minimum dimensions of 12" x 12" by 1/4" thick adhered in full bed of multi-purpose thin set mortar to the surfaced membrane.
Maximum Design Pressure	-103 psf. (See General Limitaion #9)



GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. A copy of the integrity test report described herein in accordance with ASTM D5957 shall be provided to the Building Official for review at time of final inspection.
3. Contractor shall submit to the Building Official for review the system specifications and details. Submission of these documents, as well as the proper application and installation of all materials shall be the sole responsibility of the contractor.
4. Flashings shall be installed according to the manufacturers published standard details, specific details, approved by ReflectASeal LLC and shall be submitted to the Building Official for review.
5. All work shall be performed by a Contractor licensed to do roofing/waterproofing and be a Manufacturer Trained 'Qualified Applicator' approved and licensed by ReflectASeal LLC. ReflectASeal LLC. shall supply a list of approved applicators to the authority having jurisdiction.
6. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform with Roofing Application Standard RAS 111 and the wind load requirements of applicable Building Code.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. A non-skid surfacing is required for all pedestrian areas, plaza decks or balconies.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below

MIAMI-DADE COUNTY
APPROVED

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY
APPROVED

NOA No.: 18-0220.15
Expiration Date: 03/14/23
Approval Date: 03/29/18
Page 5 of 5