



BUILDING AND NEIGHBORHOOD COMPLIANCE DEPARTMENT (BNC)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599

NOTICE OF ACCEPTANCE (NOA)

www.miamidade.gov/economy

Keter US, Inc.
6435 S. Scatterfield Road
Anderson, IN 46013

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER- Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: "Montfort" Extreme Weather Kit Storage Shed

APPROVAL DOCUMENT: Drawing No. 18-59D, titled "Montfort" Extreme Weather Kit Storage Shed, sheets 1 through 29 of 29, dated August 17, 2018, prepared by Keter US, Inc., signed and sealed by Javad Ahmad, P.E., on October 28, 2018, bearing the Miami-Dade County Product Control Approval stamp with the Notice of Acceptance number and the approval date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: None

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1, evidence submitted page E-1 as well as approval document mentioned above. The submitted documentation was reviewed by **Helmy A. Makar, P.E. M.S.**



Helmy A. Makar
03/28/2019

NOA No. 18-1120.04
Expiration Date: 03/28/2024
Approval Date: 03/28/2019
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. *Drawing No. 18-59D, titled "Montfort" Extreme Weather Kit Storage Shed, sheets 1 through 29 of 29, dated August 17, 2018, prepared by Keter US, Inc., signed and sealed by Javad Ahmad, P.E., on October 28, 2018.*

B. TESTS

1. *Test report on Uniform Static Air Pressure Test of "Utility Shed", prepared by Intertek, Report No. H6147.01-109-18, dated 02/21/18, signed and sealed by Joseph A. Reed, P.E.*

C. CALCULATIONS

1. *Calculation of "Montfort" Extreme Weather Kit Storage Shed and anchor calculations dated 10/15/2018, 19 pages, prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E., on 10/29/2018.*

D. QUALITY ASSURANCE

1. *By Miami-Dade County Department of Regulatory and Economic Resources (RER).*

E. MATERIAL CERTIFICATIONS

1. *None.*

F. STATEMENTS

1. *An FBC, 2017 Edition compliance letter prepared by Al-Farooq Corporation, signed and sealed by Javad Ahmad, P.E., on 10/29/2018.*



Helmy A. Makar, P.E., M.S.
Product Control Section Supervisor
NOA No. 18-1120.04
Expiration Date: 03/28/2024
Approval Date: 03/28/2019

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

STORAGE SHED CAN BE FIXED TO AN ENGINEERED CEMENT PAD WITH ANCHOR BOLTS.
SEE SHEET 18 FOR INSTALLATION FASTENERS.

THIS PRODUCT HAS BEEN DESIGNED AND TESTED TO COMPLY WITH THE
REQUIREMENTS OF THE 2017 (6TH EDITION) FLORIDA BUILDING CODE
INCLUDING HIGH VELOCITY HURRICANE ZONE (HVHZ).


THIS APPROVAL IS FOR THE STORAGE SHED AS SHOWN ON THESE
APPROVED DRAWINGS.
UPLIFT, OVERTURNING, FLOOR SLAB AND OTHER ELEMENTS SHALL BE
DESIGNED BY A REGISTERED PROFESSIONAL ENGINEER AND REVIEWED BY THE
STRUCTURAL PLANS EXAMINER OF THE CORRESPONDING BUILDING DEPARTMENT.

MATERIALS INCLUDING BUT NOT LIMITED TO STEEL/METAL SCREWS, THAT
COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE
REQUIREMENTS OF THE INTERNATIONAL BUILDING CODE WITH TEXAS REVISIONS.

DESIGN IS BASED ON TESTING IN ACCORDANCE WITH FLORIDA BUILDING CODE
CYCLIC WIND PRESSURE TEST, TAS 203-94.
STATIC AIR PRESSURE TEST, TAS 202.


THIS PRODUCT APPROVAL DOCUMENT IS GENERIC AND DOES NOT PROVIDE
INFORMATION FOR A SITE SPECIFIC PROJECT.

STORAGE SHED TO BE ASSEMBLED AND INSTALLED AS PER MANUFACTURER'S
INSTALLATION INSTRUCTIONS.



MAXIMUM DESIGN LOAD RATING = +15.0 PSF
-15.0 PSF
SHED MAX. LENGTH = 85"
SHED MAX. WIDTH = 79-7/8"
SHED MAX. HEIGHT = 99-3/8"

Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control
By Heidi A. Miller



'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.

6435 S Scatterfield Road
Anderson, IN 46013



Phone: (404) 803-7832 Fax: (-)

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

SHEDS\18-59D-KET

revisions:	
no	date by description

date: 08-17-18	scale: -	dr. by: TARIQ	chk. by:
drawing no. 18-59D			
sheet 1 of 29			



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By Heidi A. McLean





AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
(C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED


Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (404) 803-7832

Fax: (-)

date: 08-17-18		revisions:	
scale: -		no	date by description
dr. by: TARIQ			
chk. by:			
drawing no. 18-59D			
sheet 2 of 29			



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-120-04
Miami Dade Product Control
By He G. A. Mc



WALL ASSEMBLY



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED



Keter US, Inc.
6435 S Scatterfield Road

Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)


date: 08-17-18		revisions:	
scale: -	no	date	by description
dr. by: TARIQ			
chk. by:			
drawing no. 18-59D			
sheet 3 of 29			



WALL ASSEMBLY



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-120.04
Miami Dade Product Control
By *He G A Moh*





AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)


'MONIFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:		no date by description	
date:	08-17-18	no	date by description
scale:	-	dr.	by: TARIQ
chk.	by:	chk.	by:
drawing no.		18-59D	
sheet 4 of 29			

SHEDS\18-59D-KET



By H. G. A. M. W.



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 353B)
TEL. (305) 264-8100 FAX. (305) 262-6978

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.

6435 S Scatterfield
Anderson, IN 46013

Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:
no date by description

date: 08-17-18

scale: —



dr. by: TARIQ

chk. by:

drawing no.




18-59D

sheet 5 of 29






TOP ROOF CROSS SECTION BEAM
KP-01-0108
SECURED WITH
1/4" X 1" PH SCREWS
2 PER END




Front



ROOF ASSEMBLY




APEX CAP
SECURED WITH
(3) #8 X 1" FH SCREWS



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOAH 18-1126.04
Miami Dade Product Control

By *He G A. M. M.*




AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONIFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)


revisions:		date		by description	
no	date	no	date	no	date

date: 08-17-18
scale: -
dr. by: TARIQ
chk. by:
drawing no.
18-59D
sheet 6 of 29






SHEDS\18-59D-KET





(16) #8 X 5/8"
FH SCREWS



ROOF CONNECTORS
AT 9" FROM CORNERS
SECURED TO WALL PANEL WITH
(2) #10 X 3/4" FH SCREWS
AND TO ROOF PANEL WITH
(2) #10 X 1-3/4" FH SCREWS




WALL PANELS FASTENERS
(28) #8 X 1/2" PH SCREWS



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control

By He G A Moh



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)


revisions:
no date by description

date: 08-17-18
scale: --
dr. by: TARIQ
chk. by:


drawing no.
18-59D

sheet 7 of 29


SHEDS \ 18-59D-KET




SIDE WALL BEAM



SIDE + ROOF JOINT STIFFENER




SIDE WALL BEAM ASSEMBLY



ROOF BEAM ASSEMBLY

Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120.24
Miami Dade Product Control

By He G.A. 11/6/19





AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED




Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:		no		date		by		description	
date:	08-17-18	no		date		by		description	
scale:	-	no		date		by		description	
dr.	TARIQ	no		date		by		description	
chk.		no		date		by		description	
drawing no.		18-59D							
sheet		8 of 29							


SHEDS\18-59D-KET





(2) 1/4" X 1" PH SCREWS



(2) 1/4" X 1" PH SCREWS




ROOF BEAM
KP-01-0105
SECURED WITH
(6) 1/4" X 1" PH SCREWS





CROSS SECTION BEAM
KP-01-0124
SECURED WITH
1/4" X 1" PH SCREWS
2 PER END


PORTAL SLOPE BEAM
KP-01-0121
SECURED WITH
1/4" X 1" PH SCREWS
2 PER END



TOP ROOF CROSS SECTION BEAM
KP-01-0108
SECURED WITH
1/4" X 1" PH SCREWS
2 PER END



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control
By H. A. M. M.



ROOF BEAM ASSEMBLY

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)



'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)


Revisions:		date: 08-17-18		scale: -		dr. by: TARIQ		chk. by:	
no	date	no	date	no	date	no	date	no	date

drawing no.
18-59D
sheet 9 of 29

SHEDS\18-59D-KET



Approved as complying with the
Florida Building Code
Date 03/28/01
NOA# 18-1120-04
Miami Dade Product Control
By He G. A. Miller





AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED


Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax:

SHEDS\18-59D---KET


date: 08-17-18		revisions:	
scale: -	no	date	by description
dr. by: TARIQ			
chk. by:			
drawing no.			
18-59D			
sheet 10 of 29			




BOTTOM CORNER STIFFENER



TOP CORNER STIFFENER
KP-01-0110
KP-01-0111
— SECURED TO ROOF WITH
(8) #8 X 5/8" FH SCREWS
AND TO WALL WITH
(4) #8 X 5/8" FH SCREWS




TOP CORNER STIFFENER



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control

By H. G. A. Mich



'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.
6435 S Scatterfield Road

Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:	no	date	by	description

date: 08-17-18

scale: 1000000


dr. by: TARIQ

chk. by:

drawing no.


18-59D

sheet 11 of 29




CORNER BAR MIDDLE STIFFENER
KP-01-0152
SECURED WITH
(4) #8 X 5/8" FH SCREWS

CORNER BAR MIDDLE STIFFENER



CORNER STIFFENER OPPOSITE PLATE
KP-01-0155
SECURED WITH
1/4" X 1-1/2"
CARRIAGE BOLTS WITH NUTS




CORNER STIFFENER OPPOSITE PLATE
KP-01-0155
SECURED WITH
1/4" X 1-1/2"
CARRIAGE BOLTS WITH NUTS

CORNER STIFFENER OPPOSITE PLATE

Approved as complying with the
Florida Building Code
Date: 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control

By *Heb A. Moh*






AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONIFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)




revisions:		date		by description	
no	date	no	date	no	date

date: 08-17-18
scale: -
dr. by: TARIQ
chk. by:
drawing no.
18-59D
sheet 12 of 29

SHEDS\18-59D-KET




1/4" X 2"
CARRIAGE BOLTS WITH NUTS



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control

By H. G. A. M. W.



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.
6435 S Scatterfield Road

Phone: (404) 803-7832 Fax: (-)

revisions:
no date by description

date: 08-17-18

scale: 

dr. by: TARIQ

chk. by:




drawing no.

18-59D



sheet 13 of 29

SHEDS\18-59D-KET



HINGE ASSEMBLY




1/4" X 2"
CARRIAGE BOLTS WITH NUTS



1/4" X 2"
CARRIAGE BOLTS WITH NUTS



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control
By *He G. M. M.*






HINGE ASSEMBLY

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)


'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:		no date by description	
date:	08-17-18	scale:	-
dr. by:	TARIQ	chk. by:	
drawing no.	18-59D	sheet 14 of 29	


SHEDS \ 18-59D-KET




(2) #8 X 5/8"
FH SCREWS





(8) #8 X 5/8"
FH SCREWS




DOOR STIFFENER
KP-01-0005 (LEFT)
KP-01-0115 (RIGHT)



(8) #8 X 5/8"
FH SCREWS




#8 X 1/2"
PH SCREWS



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control

By *He G. A. M.*



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)





'MONTFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)


revisions:		by description	
no	date	no	date

date: 08-17-18
scale: -
dr. by: TARIQ
chk. by:
drawing no.
18-59D
sheet 15 of 29

SHEDS\18-59D-KET



Approved as complying with the
Florida Building Code
Date 03/29/2019
NOA# 18-1120-04
Miami Dade Product Control
By H. G. A. M. M.





a f c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)





'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:		no date by description	
date:	08-17-18	no	date by description
scale:	-	dr.	by: TARIQ
chk.	by:	chk.	by:
drawing no.		18-59D	
sheet 16 of 29			

SHEDS\18-59D-KET




Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control
By He G. A. Nelson



FLOOR
(POLYPROPYLENE)
(2 REQD.)

Approved as complying with the
Florida Building Code
Date: 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By: H. G. A. H. H.



revisions:			
no	date	by	description





date: 08-17-18
scale: 1/16" = 1"
dr. by: TARIQ
chk. by:

drawing no.
18-59D
sheet 19 of 29





'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

SHEDS\18-59D-KET




ROOF TILE DOWN
(POLYPROPYLENE)
(2 REQD.)



ROOF TILE UP
(POLYPROPYLENE)
(2 REQD.)

Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By Hedy A. Mohr









af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)


revisions:		date		by description	
no	date	no	date	no	date

date: 08-17-18
scale: 1/16" = 1"
dr. by: TARIQ
chk. by:
drawing no.
18-59D
sheet 20 of 29

SHEDS\18-59D-KET



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By He G. A. Mub



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978

a f c
SHEDS \ 18-59D-KET

'MONFORT' EXTREME WEATHER KIT STORAGE SHED

Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:	
no	date by description

date: 08-17-18

scale: 1/4" = 1"



dr. by: TARIQ

chk. by:


drawing no.

18-59D

sheet 21 of 29



Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control
By H. G. A. K. M.







AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978
SHEDS\ 18-59D-KET


'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:		date: 08-17-18		scale: 1/4" = 1"		dr. by: TARIQ		chk. by:	
no	date	by	description	no	date	by	description	no	date

drawing no.
18-59D
sheet 22 of 29



VENT
(POLYPROPYLENE)
(2 REQD.)



TILE SUPPORT
(GALV. STEEL)
(2 REQD.)

Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By H. G. A. Mohr




af c
AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONIFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)


revisions:		by description	
no	date	no	date

date: 08-17-18
scale: 1/4" = 1"
dr. by: TARIQ
chk. by:
drawing no.
18-59D
sheet 23 of 29


SHEDS\18-59D-KET




SIDE WALL BEAM
(KP-01-0101) (GALV. STEEL)
(3 REQD.)




SIDE + ROOF JOINT
(KP-01-0132) (GALV. STEEL)
(1 REQD.)




SIDE + ROOF JOINT
(KP-01-0104) (GALV. STEEL)
(2 REQD.)



ROOF BEAM
(KP-01-0105) (GALV. STEEL)
(3 REQD.)



PORTAL SLOPE BEAM BOTTOM BRACKET
(KP-01-0143) (GALV. STEEL)
(1 REQD.)



TOP ROOF CROSS SECTION BEAM
(KP-01-0108) (GALV. STEEL)
(1 REQD.)

Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By [Signature]





AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)


'MONFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:		date: 08-17-18		scale: 1/4" = 1"		dr. by: TARIQ		chk. by:	
no	date	no	date	no	date	no	date	no	date



drawing no.
18-59D
sheet 24 of 29




SIDE WALL BEAM EXTENSION
(PEM S 0420-1) (GALV. STEEL)
(1 REQD.)




REAR WALL OPPOSITE PLATE
(KP-01-0148) (GALV. STEEL)
(-)




REAR WALL BEAM
(KP-01-0131) (GALV. STEEL)
(1 REQD.)



CORNER STIFFENER COLLECTIVE WASHER
(KP-01-0145) (GALV. STEEL)
(-)




BOTTOM LATCH DRILLING JIG
(KP-01-0154) (GALV. STEEL)
(1 REQD.)



SIDE WALL BEAM BOTTOM BRACKET
(KP-01-0144) (GALV. STEEL)
(3 REQD.)

Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control
By Hege A. Khan






AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)




revisions:		date: 08-17-18		scale: 1/4" = 1"		dr. by: TARIQ		chk. by:	
no	date	no	date	no	date	no	date	no	date

drawing no.
18-59D
sheet 25 of 29


SHEDS\18-59D-KET








TOP CORNER STIFFENER
(KP-01-0110) (GALV. STEEL)
(2 REQD.)







TOP CORNER STIFFENER
(KP-01-0111) (GALV. STEEL)
(2 REQD.)



PORTAL SLOPE BEAM
(KP-01-0121) (GALV. STEEL)
(1 REQD.)




CORNER STIFFENER OPPOSITE PLATE
(KP-01-0155) (GALV. STEEL)
(12 REQD.)



CORNER BAR MIDDLE STIFFENER
(KP-01-0152) (GALV. STEEL)
(4 REQD.)

Approved as complying with the
Florida Building Code
Date: 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By: *H. G. A. M. M.*



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)


'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:	no	date	by	description


date: 08-17-18
scale: 1/4" = 1"
dr. by: TARIQ
chk. by:

drawing no.
18-59D
sheet 26 of 29

SHEDS\18-59D-KET




BOTTOM CORNER STIFFENER
(KP-01-0112) (GALV. STEEL)
(2 REQD.)



BOTTOM CORNER STIFFENER
(KP-01-0113) (GALV. STEEL)
(2 REQD.)

Approved as complying with the
Florida Building Code
Date: 03/28/2019
NOA# 18-1120.04
Miami Dade Product Control
By: *[Signature]*






revisions:			
no	date	by	description

date: 08-17-18
scale: 1/4" = 1"
dr. by: TARIQ
chk. by:





drawing no.
18-59D
sheet 27 of 29

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173 (C.A.N. 3538)
TEL. (305) 264-8100 FAX. (305) 262-6978
SHEDS\18-59D-KET



SIDE WALL OPPOSITE PLATE
(KP-01-0114) (GALV. STEEL)
(3 REQD.)



CROSS SECTION BEAM
(KP-01-0124) (GALV. STEEL)
(1 REQD.)

Approved as complying with the
Florida Building Code
Date 03/28/2019
NOA# 18-1120-04
Miami Dade Product Control

By H. G. A. K. K. K.





AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)



revisions:		no		date		by		description	

date: 08-17-18
scale: 1/4" = 1"
dr. by: TARIO
chk. by:
drawing no.
18-59D
sheet 28 of 29


SHEDS\18-59D-KET






RIGHT DOOR STIFFENER
(KP-01-0115) (GALV. STEEL)
(1 REQD.)





LEFT DOOR STIFFENER
(KP-01-0005)
(1 REQD.)





DOOR OVERLAP PLATE
(KP-01-0117) (GALV. STEEL)
(-)




DOOR MIDDLE AXIS BRACKET
(KP-01-0140) (GALV. STEEL)
(2 REQD.)




DOOR TOP LATCH OPPOSITE PART
(KP-01-0149) (GALV. STEEL)
(2 REQD.)





DOOR LATCH
(-)
(4 REQD.)



DOOR POST CONNECTOR
(GALV. STEEL)
(2 REQD.)



DOOR POST
(GALV. STEEL)
(2 REQD.)



UPPER DOOR POST
(GALV. STEEL)
(1 REQD.)

Approved as complying with the
Florida Building Code
Date 03/20/2019
NOA# 18-1120.04
Miami Dade Product Control
By Heidi H. Miller



AL-FAROOQ CORPORATION
ENGINEERS & PRODUCT DEVELOPMENT
9360 SUNSET DRIVE, SUITE 220
MIAMI, FLORIDA 33173
TEL. (305) 264-8100 FAX. (305) 262-6978
(C.A.N. 3538)

'MONTFORT' EXTREME WEATHER KIT STORAGE SHED
Keter US, Inc.
6435 S Scatterfield Road
Anderson, IN 46013
Phone: (404) 803-7832 Fax: (-)

revisions:		no date by description	
date:	08-17-18	scale:	1/4" = 1"
dr. by:	TARIQ	chk. by:	
drawing no.		18-59D	
sheet 29 of 29			

SHEDS\18-59D-KET