



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

US Ply, Inc.  
2000 E. Richmond Ave.  
Fort Worth, TX 76104

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: US Ply APP Modified Bitumen Roofing Systems Over Wood Decks

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA# 18-0109.07 and consists of pages 1 through 15.  
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 18-1218.15  
Expiration Date: 03/14/24  
Approval Date: 02/21/19  
Page 1 of 15

## ROOFING ASSEMBLY NOTICE OF ACCEPTANCE

**Category:** Roofing  
**Sub-Category:** Modified Bitumen  
**Material:** APP  
**Deck Type:** Wood  
**Maximum Design Pressure:** -75 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
USP Base	36" x 108'	ASTM D 4601	An asphaltic, fiberglass reinforced base sheet
USP Type IV Felt	36" x 180'	ASTM D 2178	An asphaltic, fiberglass reinforced, ASTM D2178 Type IV ply sheet.
USP Type VI Felt	36" x 180'	ASTM D 2178	An asphaltic, fiberglass reinforced, ASTM D2178 Type VI ply sheet.
USP Mineral Cap Sheet	36" x 36'	ASTM D 3909	A high strength non-woven fiberglass carrier for added dimensional stability coated on both sides with premium grade asphalt. Mineral granule surfacing for superior weathering characteristics.
USP APP 160S	39-3/8" x 32' 9"	ASTM D 6222 Type I, Grade S	Polyester reinforced, smooth surfaced, APP modified bitumen base / interply sheet.
USP APP 160M	39-3/8" x 32' 9"	ASTM D 6222 Type I, Grade M	Polyester reinforced, mineral granule surfaced, APP modified bitumen cap sheet.
SafeWeld 180S APP	39-3/8 x 32' 9"	ASTM D 6222 Type I, Grade S	Smooth surfaced, polyester reinforced APP modified bitumen membrane with talc underside.
SafeWeld 180M APP	39-3/8 x 32' 9"	ASTM D 6222 Type I, Grade G	Smooth surfaced, polyester reinforced APP modified bitumen membrane with slag underside.
SafeWeld 180FR APP	39-3/8" x 32' 9"	ASTM D 6222 Type I, Grade G	Granule surfaced, polyester reinforced, fire resistant, APP modified bitumen membrane with slag underside.
DuraWeld 4S APP	39-3/8" x 32' 9"	ASTM D 6222 Type I, Grade S	Smooth surfaced, polyester reinforced, APP modified bitumen base / interply sheet.
DuraWeld 4M APP	39-3/8" x 32' 9"	ASTM D 6222 Type I, Grade G	Polyester reinforced, granule surfaced APP modified bitumen cap sheet.

DuraWeld 4M FR APP	39-3/8" x 32' 9"	ASTM D 6222 Type I, Grade G	Polyester reinforced, mineral granule surfaced, fire resistant, APP modified bitumen cap sheet.
USP #442 Fibered Aluminum Roof Coating	5 gal	ASTM D 2824 Type III	A hydrocarbon protective coating.

## APPROVED INSULATIONS:

**TABLE 2**

<b><u>Product Name</u></b>	<b><u>Product Description</u></b>	<b><u>Manufacturer (With Current NOA)</u></b>
ACFoam-II, ACFoam-III	Polyisocyanurate Insulation	Atlas Roofing Corporation
Tapered ACFoam	Polyisocyanurate insulation with a coated glass mat.	Atlas Roofing Corporation
ENRGY 3	Polyisocyanurate Insulation	Johns Manville Corporation
FescoBoard	Rigid perlite roof insulation board	Johns Manville Corporation
ISO 95+ GL	Polyisocyanurate foam insulation	Firestone Building Products Company, LLC.
H-Shield, Tapered H-Shield, H-Shield-CG, H-Shield WF	Polyisocyanurate foam insulation	Hunter Panels, LLC.
Multi-Max FA-3	Polyisocyanurate Insulation	Rmax Operating, Inc.
DensDeck, DensDeck Prime	Water resistant gypsum board	Georgia-Pacific Gypsum LLC.
SECUROCK Gypsum-Fiber Roof Board	Gypsum board	United States Gypsum Corporation
Structodek High Density Fiberboard Roof Insulation	High Density Wood Fiber insulation board.	Blue Ridge Fiberboard, Inc.



**APPROVED FASTENERS:****TABLE 3**

<b><u>Fastener Number</u></b>	<b><u>Product Name</u></b>	<b><u>Product Description</u></b>	<b><u>Dimensions</u></b>	<b><u>Manufacturer (With Current NOA)</u></b>
1.	#12 Standard Roofgrip	Self drilling, carbon steel fastener with a CR-10 coating	Various	OMG, Inc.
2.	OMG 3" Galvalume Steel Plate	Galvalume coated steel plate	3" Round	OMG, Inc.
3.	Trufast 3" Metal Insulation Plate	Galvalume steel stress plate	3" Diameter	Altenloh, Brinck & CO. U.S., Inc.
4.	PlyFast 3" Metal Plate T	Galvalume steel stress plate	3" Diameter	U.S. Ply, Inc.
5.	OMG Heavy Duty	Self drilling fastener for steel used wood, steel or concrete decks	Various	OMG, Inc.
6.	Trufast SIP TP Fastener	Self-drilling carbon steel fastener used in steel and wood decks. Tru-Kote PC-3 coating.	Various	Altenloh, Brinck & CO. U.S., Inc.
7.	Trufast #15 EHD Fastener	Carbon steel fastener used in concrete, steel and wood decks. Tru-Kote PC-3 coating.	Various	Altenloh, Brinck & CO. U.S., Inc.
8.	PlyFast #15 Fastener T	Heavy duty corrosion resistant steel fastener.	Various	U.S. Ply, Inc.
9.	Trufast #14 HD Fastener	Self-drilling, carbon steel fastener used in concrete, steel and wood decks. Tru-Kote PC-3 coating.	Various	Altenloh, Brinck & CO. U.S., Inc.
10.	PlyFast #14 Fastener T	Fastener used in steel, concrete and wood decks.	Various	U.S. Ply, Inc.
11.	PlyFast #12 Fastener O	Self drilling, carbon steel fastener with a CR-10 coating	Various	U.S. Ply, Inc.
12.	PlyFast #14 Fastener O	Self drilling fastener for steel used wood, steel or concrete decks	Various	U.S. Ply, Inc.

**EVIDENCE SUBMITTED:**

<b><u>Test Agency</u></b>	<b><u>Test Identifier</u></b>	<b><u>Description</u></b>	<b><u>Date</u></b>
Factory Mutual Research Corp.	2D5A9.AM	FM 4450	06/22/99
	3014751	FM 4450	08/27/03
	3032172	FM 4470	06/12/09
	3024311	FM 4470	11/01/06
	3024973	FM 4470	11/10/06
	3014692	FM 4470	08/05/03
	3023458	FM 4450	07/18/06
PRI Construction Materials Technologies	GAPR-004-02-01	ASTM D 4897	05/19/11
	BWR-506-02-01.1	ASTM D 2178	01/23/09
	BWR-505-02-01.1	ASTM D 2178	01/23/09
	BWR-539-02-01	ASTM D 3909	07/24/13
Exterior Research & Design, LLC	USPI-014-02-01	TAS 114 D	1/30/16
	USPI-015-02-01	TAS 114 J	1/30/16
	2005.U0212.09.05-R1	FM 4470	03/31/10
	U0215.05.06-2-R2	ASTM D6222	08/02/10
	U0210.05.06-R1	FM 4470	03/31/10
	U11650.07.09	FM 4470	07/15/09
	02762.03.05-R2	FM 4470	04/01/10
	U41790.05.12-1	ASTM D6222 & TAS 110	05/30/12
	U41790.05.12-2	ASTM D6222 & TAS 110	05/30/12
	U35910.12.11-1	TAS 117	12/21/11
	U35910.12.11-3	ASTM D1878	12/21/11

## APPROVED ASSEMBLIES

<b>Membrane Type:</b>	APP
<b>Deck Type II:</b>	Wood, Insulated
<b>Deck Description:</b>	<sup>19</sup> / <sub>32</sub> " or greater plywood or wood plank mechanically attached at 24" spans with 8d ring shank nails spaced 6" o.c. at edges and intermediate supports.
<b>System Type A:</b>	Anchor sheet mechanically fastened, all layers of insulation adhered with approved asphalt.

All General and System limitations apply.

<b>Anchor Sheet:</b>	One ply of Miami-Dade approved ASTM D4601 sheet, mechanically fastened to the wood deck with Trufast SIP TP Fasteners or Trufast #15 EHD Fasteners with Trufast 3" Metal Insulation Plates, PlyFast #15 Fastener T with PlyFast 3" Metal Plate T, PlyFast #12 Fastener O or PlyFast #14 Fastener O or #12 Standard Roofgrip or OMG Heavy Duty fasteners with OMG 3" Galvalume Steel Plates spaced 6" o.c. in the 3" lap and 12" o.c. in two, equally spaced, staggered center rows.
----------------------	---

One or more layers of any of the following insulations:

<b><u>Base Insulation Layer</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>Multi-Max FA-3, ACFoam-II Minimum 1.5" thick</b>	N/A	N/A
<b><u>Top Insulation Layer</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>Structodek High Density Fiberboard Roof Insulation, SECUROCK Gypsum-Fiber Roof Board, DensDeck Prime Minimum ½" thick</b>	N/A	N/A
<b>FescoBoard Minimum ¾" thick</b>	N/A	N/A

**Note:** Insulation shall be adhered with approved asphalt within the EVT range and at a rate of 25 lbs/sq<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<b>Base Sheet:</b>	One ply of USP Type IV Felt or USP Base, hot asphalt applied. Or One ply of USP APP 160S, SafeWeld 180SAPP, or DuraWeld 4S APP, heat welded only when used over DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board.
--------------------	---



<b>Ply Sheet:</b>	<p>One or more plies of USP Type IV Felt, or USP VI Felt adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.</p> <p>Or</p> <p>One or more layers of USP APP 160S, SafeWeld 180S APP, or DuraWeld 4S APP, heat welded.</p>
<b>Membrane:</b>	<p>One ply of USP APP 160M, SafeWeld 180M APP, SafeWeld 180FR APP, DuraWeld 4M APP or DuraWeld 4M FR APP, heat welded.</p> <p>Or</p> <p>(Not for use with APP ply sheet) One ply of USP Mineral Cap Sheet adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.</p>
<b>Surfacing:</b>	<p>Only for use with USP APP 160M, SafeWeld 180M APP or DuraWeld 4M APP membranes: USP #442 Fibered Aluminum Roof Coating applied at a rate of 1.5 gal/sq.</p>
<b>Maximum Design Pressure:</b>	<p>- 75.0 psf (See General Limitation #7).</p>



<b>Membrane Type:</b>	APP
<b>Deck Type II:</b>	Wood, Insulated
<b>Deck Description:</b>	<sup>19</sup> / <sub>32</sub> " or greater plywood or wood plank mechanically attached at 24" spans with 8d ring shank nails spaced 6" o.c. at edges and intermediate supports.
<b>System Type B:</b>	Base layer of insulation mechanically fastened, optional top layer adhered with approved asphalt.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b><u>Base Insulation Layer</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>ISO 95+ GL, AC Foam-II, ENRGY 3, Multi-Max FA-3 Minimum 1.5" thick</b>	<b>12, 5 with 2</b>	<b>1: 1.33 ft<sup>2</sup></b>
<b>AC Foam-II, ENRGY 3 Minimum 1.5" thick</b>	<b>3 with 9 4 with 10</b>	<b>1: 1.33 ft<sup>2</sup></b>

**Note:** Base layer shall be mechanically attached with fasteners and density described. Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application Standard RAS 117 for fastening details).

<b><u>Top Insulation Layer</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>Structodek High Density Fiberboard Roof Insulation, SECUROCK Gypsum-Fiber Roof Board or DensDeck Prime, DensDeck Minimum ½" thick</b>	<b>N/A</b>	<b>N/A</b>
<b>FescoBoard Minimum ¾" thick</b>	<b>N/A</b>	<b>N/A</b>

**Note:** Top layer of insulation shall be adhered in full mopping of approved asphalt within the EVT range and at a rate of 20-40 lbs/100 ft<sup>2</sup>. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<b>Base Sheet:</b>	One ply of USP Type IV Felt or USP Base, hot asphalt applied. Or One ply of USP APP 160S, SafeWeld 180S APP, or DuraWeld 4S APP, heat welded only when applied over DensDeck, DensDeck Prime or SECUROCK Gypsum-Fiber Roof Board.
--------------------	---





<b>Ply Sheet:</b>	<p>One or more plies of USP Type IV Felt or USP VI Felt, adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.</p> <p>Or</p> <p>(Optional with APP Membrane) One or more layers of USP APP 160S, SafeWeld 180S APP, or DuraWeld 4S APP, heat welded.</p> <p>Or</p> <p>(Not for use with APP membrane) One or more plies of USP Type IV Felt or USP Type VI Felt adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.</p>
<b>Membrane:</b>	<p>One ply of USP APP 160M, SafeWeld 180M APP, SafeWeld 180FR APP, DuraWeld 4M APP or DuraWeld 4M FR APP, heat welded.</p> <p>(Not for use over USP Type IV or VI Felt) One ply of USP APP 160M, SafeWeld 180M APP, SafeWeld 180FR APP, DuraWeld 4M APP or DuraWeld 4M FR APP, heat welded.</p> <p>Or</p> <p>(Not for use with APP ply sheet) One ply of USP Mineral Cap Sheet adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.</p>
<b>Surfacing:</b>	<p>Only for use with USP APP 160M, SafeWeld 180M APP or DuraWeld 4M APP membranes: USP #442 Fibered Aluminum Roof Coating applied at a rate of 1.5 gal/sq.</p>
<b>Maximum Design Pressure:</b>	<p>-52.5 psf (See General Limitation #7).</p>



<b>Membrane Type:</b>	APP
<b>Deck Type II:</b>	Wood, Insulated
<b>Deck Description:</b>	<sup>19</sup> / <sub>32</sub> " or greater plywood or wood plank mechanically attached at 24" spans with 8d ring shank nails spaced 6" o.c. at edges and intermediate supports.
<b>System Type C:</b>	All layers of insulation simultaneously attached to roof deck. Membrane is subsequently fully or partially adhered to insulation.

**All General and System limitations apply.**

One or more layers of any of the following insulations:

<b><u>Base Insulation Layer</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>Any Approved Polyisocyanurate Listed in Table 1 Minimum 1.5" thick</b>	N/A	N/A

**Note:** All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

<b><u>Top Insulation Layer</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick</b>	3 with 6	1:1.33 ft <sup>2</sup>

<b>Base Sheet:</b>	One ply of USP Type IV Felt, hot asphalt applied. Or One ply of USP APP 160S, SafeWeld 180S APP, or DuraWeld 4S APP, heat welded.
<b>Ply Sheet:</b>	One or more plies of USP Type IV Felt or USP VI Felt adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq. Or (Optional with APP Membrane) One or more layers of USP APP 160S, SafeWeld 180S APP, or DuraWeld 4S APP, heat welded. Or (Not for use with APP membrane) One or more plies of USP Type IV Felt or USP Type VI Felt adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.
<b>Membrane:</b>	(Not for use over USP Type IV or VI Felt) One ply of USP APP 160M, SafeWeld 180M APP, SafeWeld 180FR APP, DuraWeld 4M APP or DuraWeld 4M FR APP, heat welded. Or (Not for use with APP ply sheet) One ply of USP Mineral Cap Sheet adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.



**Surfacing:** Only for use with USP APP 160M, SafeWeld 180M APP or DuraWeld 4M APP membranes:  
USP #442 Fibered Aluminum Roof Coating applied at a rate of 1.5 gal/sq.

**Maximum Design Pressure:** -52.5 psf (See General Limitation #7).



**Membrane Type:** APP  
**Deck Type 1I:** Wood, Insulated  
**Deck Description:** Min. 19/32" plywood or wood plank.  
**System Type E(1):** Base sheet mechanically fastened.

**All General and System limitations apply.**

**Base Sheet:** One ply of USP Base shall be mechanically fastened to the deck with 1-5/8" diameter Tin-Caps and 12 ga. ring shank nails spaced 8" o.c. in the 3" lap and 8" o.c. in three, equally spaced, staggered center rows.

**Ply Sheet:** (Optional) One or more layers of USP APP 160S, SafeWeld 180S APP, or DuraWeld 4S APP, heat welded.

**Membrane:** One ply of USP APP 160M, SafeWeld 180M APP, SafeWeld 180FR APP, DuraWeld 4M APP or DuraWeld 4MFR APP, heat welded.

**Surfacing:** For use on non FR membranes:  
USP #442 Fibered Aluminum Roof Coating applied at a rate of 1.5 gal/sq.

**Maximum Design Pressure:** -52.5 psf (See General Limitation #7).



**NOA No.: 18-1218.15**  
**Expiration Date: 03/14/24**  
**Approval Date: 02/21/19**  
**Page 12 of 15**

**Membrane Type:** APP  
**Deck Type 1I:** Wood, Insulated  
**Deck Description:** Min. 19/32" plywood or wood plank.  
**System Type E(2):** Base sheet mechanically fastened.

**All General and System limitations apply.**

**Base Sheet:** One ply of USP Base shall be mechanically fastened to the deck with 1-5/8" diameter Tin-Caps and 12 ga. ring shank nails spaced 6" o.c. in the 3" lap and 6" o.c. in three, equally spaced, staggered center rows

**Ply Sheet:** (Optional) One or more layers of USP APP 160S, SafeWeld 180S APP, or DuraWeld 4S APP, heat welded.  
Or  
(Required with use of USP Mineral Cap; not for use with APP membrane) One or more plies of USP Type IV Felt or USP VI Felt adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.

**Membrane:** (Not for use over USP Type IV or VI Felt) One ply of USP APP 160M, SafeWeld 180M APP, SafeWeld 180FR APP, DuraWeld 4M APP or DuraWeld 4M FR APP, heat welded.  
Or  
(Not for use with APP ply sheet) One ply of USP Mineral Cap Sheet adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq.

**Surfacing:** For use on non FR APP membranes only:  
USP #442 Fibered Aluminum Roof Coating applied at a rate of 1.5 gal/sq.

**Maximum Design Pressure:** -60 psf (See General Limitation #7).



**NOA No.:** 18-1218.15  
**Expiration Date:** 03/14/24  
**Approval Date:** 02/21/19  
**Page 13 of 15**

**Membrane Type:** APP  
**Deck Type 1I:** Wood, Non-Insulated  
**Deck Description:** Min. 19/32" plywood or wood plank.  
**System Type E(3):** Base sheet mechanically fastened.

**All General and System limitations apply.**

**Base Sheet:** One ply of USP Base shall be mechanically fastened to the deck with 1-5/8" diameter Tin-Caps and 12 ga. ring shank nails spaced 8" o.c. in the 4" lap and 8" o.c. in two, equally spaced, staggered rows in the field of the row.

**Ply Sheet:** One or more plies of USP Type IV Felt or USP VI Felt adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq. with minimum 4" wide side laps

**Membrane:** One ply of USP Mineral Cap Sheet adhered in hot asphalt applied in the EVT range at a rate of 20-40 lbs/sq. with minimum 3" wide side laps

**Maximum Design Pressure:** - 60.0 psf (See General Limitation #7).



**NOA No.:** 18-1218.15  
**Expiration Date:** 03/14/24  
**Approval Date:** 02/21/19  
**Page 14 of 15**

## WOOD DECK SYSTEM LIMITATIONS:

1. A slip sheet is required with USP Type IV Felt and USP Type VI Felt when used as a mechanically fastened base or anchor sheet.

## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq. **Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**

## END OF THIS ACCEPTANCE