



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

**GAF**  
1 Campus Drive  
Parsippany, NJ. 07054

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: GAF Cobra® Exhaust Vent for Roof Ridge

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 18-0619.02 and consists of pages 1 through 3.  
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No. 19-0123.05  
Expiration Date: 11/09/23  
Approval Date: 05/16/19  
Page 1 of 3

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Ventilation  
**Materials:** Plastic

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
<b>GAF Cobra® Exhaust Vent for Roof Ridge</b>	3/4" x 10 1/2" x 20'	TAS-100(A)	Low profile attic ridge vent for installation under ridge shingles.
<b>GAF Cobra® Exhaust Vent for Roof Ridge (For nail guns)</b>	5/8" x 10 1/2" x 20'	TAS-100(A)	Low profile attic ridge vent for installation under ridge shingles.

### EVIDENCE SUBMITTED:

1. Acworth, GA.

### EVIDENCE SUBMITTED:

<b><u>Test Agency/Identifier</u></b>	<b><u>Name</u></b>	<b><u>Report</u></b>	<b><u>Date</u></b>
Intertek - Architectural Testing	TAS 100(A)	I3223.01-109-18	06/06/18
	ASTM D 1929	I3223.02-106-18 R1	07/20/18
	ASTM D 635	I3223.02-106-18 R1	07/20/18
	ASTM D 2843	I3223.02-106-18 R1	07/20/18
Intertek	ASTM D 1929	J0478.01-106-18 R0	01/08/19
	ASTM D 635	J0478.01-106-18 R0	01/08/19
	ASTM D 2843	J0478.01-106-18 R0	01/08/19



NOA No. 19-0123.05  
Expiration Date: 11/09/23  
Approval Date: 05/16/19  
Page 2 of 3

## APPROVED APPLICATIONS

- Tradename:** GAF Cobra® Exhaust Vent for Roof Ridge
- System Type:** Mechanical attachment of static vent over asphalt shingle roof systems only.
- Cutout:** Cut a 2" slot along the ridge of the roof by cutting 1" on each side of the ridge. Leave uncut sheathing area of 6" at each end of the ridge. Cut through sheathing only, avoiding roof trusses. In buildings with a ridge board, cut 1-3/4" slot on each side.
- Installation:** Roll out ridge vent centered over the slot and secured 6" o.c. on each side of the ridge with included 2-1/2" corrosion resistant galvanized roofing nails or 1-3/4" collated corrosion resistant galvanized roofing nails (for nail guns) to hold it in place until ridge shingles can be installed. (Polyurethane sealant shall be used to seal the perimeter of the vent to the roof shingles.) Extend to the rake edge. Roll ends or cut joints shall be butted together and caulked with an approved polyurethane sealant.
- Ridge Shingle:** Install pre-manufactured or field-cut ridge shingles over the ridge vent in compliance with the shingle manufacturer's Notice of Acceptance (NOA) and the installation instructions. Ring shank nails shall be corrosion resistant and long enough to penetrate through the wood deck a minimum of 3/16". Apply a bead of polyurethane sealant in between adjacent cap shingles to seal the caps.
- Net Free Area:** Refer to manufacturers published literature.

## LIMITATIONS:

1. Refer to applicable building codes for required ventilation.
2. This acceptance is for installations over asphalt shingle roof systems only.
3. GAF Cobra® Exhaust Vent for Roof Ridge shall not be installed on roof mean heights greater than 33 feet.
4. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
5. All approved products listed herein shall be labeled and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



**END OF THIS ACCEPTANCE**



**NOA No. 19-0123.05**  
**Expiration Date: 11/09/23**  
**Approval Date: 05/16/19**  
**Page 3 of 3**