

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION 11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

Kantuta Corporation 12040 SW 32 Street Davie, FL 33330

#### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

#### **DESCRIPTION:** DMC 175 S – 24Ga. Steel Panel over Plywood deck

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 5.

The submitted documentation was reviewed by *Freddy Semino* 





NOA No.: 19-0207.13 Expiration Date: 03/28/2024 Approval Date: 03/28/2019 Page 1 of 5

## **ROOFING SYSTEM APPROVAL:**

Category:	Roofing
Sub-Category:	Metal, Panels (Non-Structural)
<u>Material:</u>	Steel
Deck Type:	Wood
Maximum Design Pressure	–121.75 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<b>Product</b>	Dimensions	Test <u>Specifications</u>	Produc <u>Descripti</u>	
DMC 175 S – 24Ga. Steel Panel	Length: various Height: 1 5/8" Width: 18" Thickness 24 ga Min Yield Strength: 49 ksi.	TAS 110	Corrosion resistant, galv galvalume metal panel.	
Snap–Lock Clip	Length: 3-3/4" Height: 1-7/8" Width: 2" Thickness 18 ga		Corrosion resistant, 18 gauge steel clip.	
<b>Evidence Submitte</b>	ED:			
Test Agency	<u>Test I</u>	<u>dentifier</u>	Test Name/Report	Date
Akzo Nobel Coatings, Inc.	Lab	Form	ASTM G 153	
PRI Asphalt Technologies,	AKZC- AKZC- AKZC-	001-02-01 001-02-02 001-02-03 001-02-04 001-02-05	ASTM B 117	10/08/02
PRI Asphalt Technologies,	Inc. DMC-0	002-02-01	TAS 100	07/23/07

 Hurricane Test Laboratory, Inc.
 0287-0706-07
 TAS 125
 09/28/07



NOA No.: 19-0207.13 Expiration Date: 03/28/2024 Approval Date: 03/28/2019 Page 2 of 5

#### **APPROVED ASSEMBLIES:**

System:	Snap–Lock Panel 24 gauge 18" wide		
Deck Type:	Wood, Non-insulated		
Deck Description:	New Construction $^{19}/_{32}$ " or greater plywood or wood plank. 2": 12" or greater		
Slope Range:			
Maximum Uplift Pressure:	See Table A below		
Deck Attachment:	In accordance with applicable Building Code, but in no case shall it be less than 8d annula ring shank nails spaced 6" o.c. In reroofing, where the deck is less than $\frac{19}{32}$ " thic (Minimum $\frac{15}{32}$ ") The above attachment method must be in addition to existing attachment.		
Underlayment:	Minimum underlayment shall be an ASTM D 226 Type II installed with a minimum 4 side-lap and 6" end-laps. Underlayment shall be fastened with corrosion resistant tin-cap and 12 gauge 1 <sup>1</sup> / <sub>4</sub> " annular ring-shank nails, spaced 6" o.c. at all laps and two staggere rows 12" o.c. in the field of the roll or any approved underlayment having a current NOA.		
Fire Barrier Board:	Any approved fire barrier having a current NOA. Refer to a current fire directory listing for fire ratings of this roofing system assembly as well as the location of the fire barrier within the assembly. See Limitation # 1.		
Valleys:	Valley construction shall be in compliance with Roofing Application Standard RAS 13 and with the current published installation instructions and details in DMC Association of Regional Manufacturers Installation Manual.		
Metal Panels and Accessories:	Install the "Snap–Lock 24 gauge Steel Metal Panel" panels including flashing penetrations valleys, end laps and accessories in compliance "DMC Association of Regiona Manufacturers" current, published installation instructions and in compliance with the minimum requirements detailed in Roofing Application Standard RAS 133.		
	Panels shall be secured along the male rib with approved clips and two corrosion resistar #10 pancake head fasteners of sufficient length to penetrate through the sheathing minimum of ${}^{3}/{}_{16}$ ". The panel clips were placed at a spacing listed in <b>Table A</b> below startin 3" from panel end. The female rib of panel is snapped over the male rib of panel.		

TABLE A				
MAXIMUM DESIGN PRESSURES				
Roof Areas	Field	Perimeter and Corner <sup>1</sup>		
Maximum Design Pressures	-84.25psf	-121.75psf		
Maximum Clip Spacing	16" o.c.	8" o.c.		

**1.** Extrapolation shall not be allowed



## LIMITATIONS

- 1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
- 2. The maximum designed pressure listed herein shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners).
- **3.** Panels may be rolls formed in continuous lengths from eave to ridge. Maximum lengths shall be as described in Roofing Application Standard RAS 133
- 4. All panels shall be permanently labeled with the manufacturer's name and/or logo, city and state, and the following statement: "Miami-Dade County Product Control Approved" or with the Miami-Dade County Product Control Seal as seen below. All clips shall be permanently labeled with the manufacturer's name and/or logo, and/or model.




- 5. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
- 6. Panels may be jobsite roll formed with machine model # <u>SSQ8591018</u> from DMC Association of Regional Manufacturers.



NOA No.: 19-0207.13 Expiration Date: 03/28/2024 Approval Date: 03/28/2019 Page 4 of 5

## **PROFILE DRAWINGS**



# END OF THIS ACCEPTANCE



NOA No.: 19-0207.13 Expiration Date: 03/28/2024 Approval Date: 03/28/2019 Page 5 of 5