



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidadecounty.gov/economy

Wayne Dalton a Div. of Overhead Door Corporation
3395 Addison Drive
Pensacola, FL 32514

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/ or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Models 4600 / 4650 / 6600 / 8300 / 8500 / 8650 / 5150 / 5200 / TM515 / TM525 Insulated Steel Sectional Garage Door up to 16'-2" Wide with Optional Impact Resistant Glazing

APPROVAL DOCUMENT: Drawing No. **D-363475**, titled "Windload Models 4600 / 4650 / 6600 / 8300 / 8500 / 8650 / 5150 / 5200 / TM515 / TM525, +46/-52 PSF Dade County, 16'2" Max. Width", sheets 1 through 4 of 4, dated 08/28/2018, prepared by Overhead Door Corporation, signed and sealed by Dwayne J. Kornish, P.E. on 09/24/2019, bearing the Miami-Dade County Product Control approval stamp with the NOA number and approval date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large & Small Missile Impact Resistant

LABELING: A permanent label with the manufacturer's name or logo, manufacturing address, model/ series number, the positive and negative design pressure rating, indicate impact rated if applicable, installation instruction drawing reference number, approval number (NOA), the applicable test standards, and the statement reading 'Miami-Dade County Product Control Approved' is to be located on the door's side track, bottom angle, or inner surface of a panel.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/ or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of this page 1, evidence page E-1, as well as approval document mentioned above.

The submitted documentation was reviewed by **Carlos M. Utrera, P.E.**



Signature
10/01/2019

NOA No: 19-0815.07
Expiration Date: October 10, 2024
Approval Date: October 10, 2019
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Drawing No. **D-363475**, titled "Windload Models 4600 / 4650 / 6600 / 8300 / 8500 / 8650 / 5150 / 5200 / TM515 / TM525, +46/-52 PSF Dade County, 16'2" Max. Width", sheets 1 through 4 of 4, dated 08/28/2018, prepared by Overhead Door Corporation, signed and sealed by Dwayne J. Kornish, P.E. on 09/24/2019.

B. TESTS

1. Test reports on 1) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
2) Large Missile Impact Test per FBC, TAS 201-94
3) Cyclic Wind Pressure Loading per FBC, TAS 203-94
4) Forced Entry Test, per FBC, TAS 202-94
5) Tensile Test per ASTM E8
along with marked-up drawings of a 16'-2" Wide, 8300 Series Sectional Garage Doors, prepared by Intertek, Test Report No. **J1626.02-801-18-R0**, dated 06/24/2019, signed and sealed by Tyler Westerling, P.E.
2. Test report on Standard Test Method for Evaluation of Painted of Coated Specimens Subjected to Corrosive Environments per ASTM D1654-08(2016)-e1 and Standard Practice for Operating Salt Spray (Fog) Apparatus per ASTM B117-16 and on garage door exterior steel, prepared by Intertek, Report No. **J4650.01-106-18 R0**, dated 05/24/2019, signed by Gary T. Hartman, P.E.

C. CALCULATIONS

1. Anchorage verification calculations prepared by Overhead Door Corp., dated 06/07/2019, signed and sealed by Dwayne J. Kornish, P.E.

D. MATERIAL CERTIFICATIONS


1. Test report on Ignition Temperatures of Plastic per ASTM D1929-16 on BASF Corp. Elastopor P19670R polyurethane foam insulation, prepared by QAI Laboratories, Inc., Test Report No. **RJ6431F-1**, dated 09/28/2018, signed by Bryan Ortega.
2. Test report on Surface Burning Characteristics of Building Materials per ASTM E84-18b on BASF Corp. Elastopor P19670R polyurethane foam insulation, prepared by QAI Laboratories, Inc., Test Report No. **RJ6648F-4**, dated 12/12/2018, signed by Bryan Ortega.
3. Notice of Acceptance No. **18-0918.06**, issued to Plaskolite, LLC, for their TUFFAK Polycarbonate Sheets, approved on 11/15/2018 and expiring on 08/27/2022.

E. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

F. STATEMENTS

1. Statement letter of code conformance to the 6th edition (2017) FBC issued by Overhead Door Corporation, dated 05/24/2019, signed and sealed by Dwayne J. Kornish, P.E.
2. No financial interest letter issued by Overhead Door Corporation, dated 08/07/2019, signed and sealed by Dwayne J. Kornish, P.E.


10/01/2019

Carlos M. Utrera, P.E.
Product Control Examiner
NOA No: 19-0815.07

Expiration Date: October 10, 2024
Approval Date: October 10, 2019

NOTES: (UNLESS OTHERWISE SPECIFIED)

1. RATED DESIGN LOAD +46/-52 PSF.
2. SECTION HEIGHTS MAY VARY TO CREATE VARIOUS DOOR HEIGHTS, 24" MAXIMUM SECTION HEIGHT.
3. MINIMUM 1" OVERLAP ON BOTH JAMBS REQUIRED TO MEET NEGATIVE DESIGN PRESSURES.
4. TESTED IN ACCORDANCE WITH DADE COUNTY PROTOCOLS TAS 201-94, TAS 202-94, & TAS 203-94.
5. DOOR SKIN MUST BE 30,000 PSI MIN. YIELD STRENGTH.
6. JAMB LOAD CALCULATIONS:
 $(1/2 \text{ DOOR WIDTH})(1 \text{ FT OF HEIGHT})(\text{DESIGN PRESSURE})$
 $(8.08)(1 \text{ FOOT})(46.00 \text{ AND } -52.00)(371.68/420.16) \text{ LB}$
7. JAMB FASTENER REQUIREMENTS:
 $F_x = (1/2 \text{ DOOR WIDTH})(1 \text{ FT OF HEIGHT})(\text{DESIGN PRESSURE})$
 $F_x = 371 \text{ LBS.}$
8. DOOR SKIN MATERIAL SHALL BE GALVANIZED ACCORDING TO ASTM A-525 TO G40 MIN, WITH BAKED-ON PRIMER, AND BAKED-ON POLYESTER PAINT TOP COAT.
9. FOR ANCHORING INTO WOOD, USE ONE 5/16" LAG SCREW PER TRACK BRACKET WITH 1-1/2" EMBEDMENT INTO SOUTHERN PINE (G=0.55) OR BETTER.
10. WELD SLOT ON ANGLE 3/32" X 1" LONG ON 12" CENTERS. "IF WELDING MOUNTING OPTION IS CHOSEN."
11. LIFT UP MECHANISM-MANUAL, CHAIN LIFT, OR OPERATOR IS NOT PART OF THIS APPROVAL.
12. STANDARD LIFT, HIGH LIFT, VERTICAL LIFT, AND LOW HEADROOM TRACK IS AVAILABLE. FOR LOW HEADROOM LIFT CONDITIONS TOP BRACKET SHALL BE 13 GA LHR 7/4 TOP BRACKET WITH A MIN OF (3) 1/4 - 14 X 7/8" SELF DRILLING CRIMPTITE SCREWS IN LIEU OF THE BRACKET SHOWN ON DRAWING. U-BAR ON TOP SECTION SHALL BE INSTALLED ON TOP OF LHR TOP BRACKETS.
13. ATTACH STRUTS WITH (2) 1/4-14x7/8" SELF DRILLING CRIMPTITE SCREWS AT ALL HINGE LOCATIONS AND (2) BETWEEN EACH INTERMEDIATE HINGE.
14. KEY LOCK, OR SIDE LOCK REQUIRED.
15. IMPACT RESISTANT GLAZING OPTION- IMPACT RESISTANT GLAZING SYSTEM MAY BE INSTALLED IN TOP OR INTERMEDIATE SECTIONS. GLAZING SHALL BE 1/4" POLYCARBONATE. FASTENED WITH # 8 X 1" SMS. SEE DETAIL F-F ON SHEET 2 FOR ASSEMBLY DETAILS. MAXIMUM OF ONE GLAZED SECTION.
16. THE DESIGN OF THE SUPPORTING STRUCTURAL ELEMENTS SHALL BE THE RESPONSIBILITY OF THE PROFESSIONAL OF RECORD FOR THE BUILDING OR STRUCTURE AND IN ACCORDANCE WITH CURRENT BUILDING CODES FOR THE LOADS LISTED ON THIS DRAWING.
17. A 2-1/4" X 6-3/8" X 22 GA BACKER PLATE IS TO BE LOCATED AT EVERY CENTER HINGE AND 3" X 3-3/4" X 22 GA BACKER PLATE AT EACH END HINGE LOCATION. EACH IS ADHERED TO THE INTERIOR OF THE SECTION BACKER STEEL.

REVISIONS				
ER	REV	DESCRIPTION	DATE	APVL
ER	P00	NEW DRAWING	8/28/18	ESC

1" OVERLAP REQUIRED

1" OVERLAP REQUIRED



DOOR JAMB

SECTION B-B
SCALE 1:12

PRODUCT APPROVED
as complying with the Florida
Building Code
NOA-No. **19-0815.07**

Approval Date **10/10/2019**

By *[Signature]*
Miami-Dade Product Control



DWAYNE J. KORNISH, PE
4576 COUNTY ROAD 160
MOUNT HOPE, OHIO
FL PE 77945 TX PE 117868

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR
VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

RETAINER
WEATHERSEAL
(ASTRAGAL)

SECTION C-C
SCALE 1:4

ANGLE
TRACK
2" TRACK - 13 GA
3" TRACK - 12 GA

SECTION D-D
SCALE 1:4



A DIVISION OF OVERHEAD
DOOR CORP
3395 ADDISON DRIVE
PENSACOLA, FLORIDA 32514
(850)-474-9890

INTERPRET DIMS & TOLS
PER ASME Y14.5M
ALL DIMS ARE IN
INCHES

DO NOT SCALE

DIMS CIRCLED WITH SYMBOL 'C'
ARE CRITICAL TO QUALITY DESIGN
FEATURES & MUST MEET APPLICABLE
IN-PROCESS INSPECTION STANDARDS.

UNLESS OTHERWISE SPECIFIED

TOLERANCES:

.X = ± .1
.XX = ± .03
.XXX = ± .010
ANGULAR = ± .5°

HOLES:

< Ø.251 = +.004/- .003
Ø.251-Ø.500 = +.006/- .003
> Ø.500 = +.008/- .003

ALL GEOMETRY GOVERNED BY 3D CAD DATABASE:

APPROVALS DATE

DRAWN E. CONRAD 8/28/18

CHECKED D. KORNISH

APPROVED

MATERIAL

FINISH

WINDLOAD SPECIFICATION
OPTION CODE 2341

Wayne Dalton
GARAGE DOORS

PENSACOLA, FLORIDA

DESCRIPTION
WINDLOAD MODELS 4600/4650/6600/8300/
8500/8650/5150/5200/TM515/TM525, +46/-52PSF
DADE COUNTY, 16'2" MAX WIDTH


SIZE DWG NO.
D D-363475

REV
P-00

SCALE 1:12


UOM = EA

SHEET 1 OF 4




WOOD MOUNTED TO #3 SOUTHERN PINE SUBSTRATE


3/8" DIA. SIMPSON TITEN HD FASTENER, MAX. OF 15" O.C., 2-3/4" MIN. EMBED INTO MIN. 1500 PSI GROUT FILLED CMU, MIN. 4" EDGE DISTANCE




WOOD MOUNTED TO GROUT FILLED MASONRY BLOCK DETAIL




WOOD MOUNTED TO 2000 PSI CONCRETE DETAIL




MOUNTING TO WOOD JAMB DETAIL



MOUNTING TO STEEL JAMB DETAIL




MOUNTING TO GROUT FILLED MASONRY BLOCK DETAIL




MOUNTING TO 2000 PSI CONCRETE DETAIL

SECTION E-E SCALE 1:4



SECTION F-F SCALE 1:4

Impact Frame Size	Daylight Opening (DLO)	Screw Qty
15-1/4 x 19-1/8	11-1/8 x 15	10
16-7/8 x 19-7/8	12-3/4 x 15-3/4	10
16-7/8 x 42-1/8	12-3/4 x 37-7/8	14
15-1/4 x 44-1/2	11-1/4 x 40-1/8	14
12-3/4 x 40	8-5/8 x 35-7/8	14
13 x 38	8-7/8 x 33-7/8	14




DETAIL J SCALE 1:4


INTERNAL STEEL BACKER PLATE ADHERED TO INTERIOR OF THE SECTION BACKER STEEL.

13 GA ROLLER SLIDE ATTACHED TO TOP FIXTURE WITH 5/16\"/>

INTERNAL STEEL BACKER PLATE ADHERED TO INTERIOR OF THE SECTION BACKER STEEL.




DETAIL H SCALE 1:4




DETAIL K SCALE 1:4

INTERNAL STEEL BACKER PLATE ADHERED TO INTERIOR OF THE SECTION BACKER STEEL.



DETAIL I SCALE 1:4



DWAYNE J. KORNISH, PE
4576 COUNTY ROAD 160
MOUNT HOPE, OHIO
FL PE 77945 TX PE 117868

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

THIRD ANGLE PROJECTION		UNLESS OTHERWISE SPECIFIED		APPROVALS DATE		Wayne Dalton PENSACOLA, FLORIDA	
A DIVISION OF OVERHEAD DOOR CORP 3395 ADDISON DRIVE PENSACOLA, FLORIDA 32514 (850)-474-9890	INTERPRET DIMS & TOLS PER ASME Y14.5M ALL DIMS ARE IN INCHES DO NOT SCALE DIM CIRCLED WITH SYMBOL 'D' ARE CRITICAL TO QUALITY DESIGN FEATURES & MUST MEET APPLICABLE IN-PROCESS INSPECTION STANDARDS.	TOLERANCES: X = ± .1 .XX = ± .03 .XXX = ± .010 ANGULAR = ± .5° HOLES: < Ø.251 = +.004/- .003 Ø.251-Ø.500 = +.006/- .003 > Ø.500 = +.008/- .003 ALL GEOMETRY GOVERNED BY 3D CAD DATABASE:	DRAWN E. CONRAD 8/28/18 CHECKED D. KORNISH - APPROVED - MATERIAL - FINISH - WINDLOAD SPECIFICATION OPTION CODE 2341	DESCRIPTION WINDLOAD MODELS 4600/4650/6600/8300/8500/8650/5150/5200/TM515/TM525, +46/-52PSF DADE COUNTY, 16"2" MAX WIDTH	SIZE DWG NO. D D-363475	REV P-00	SCALE 1:12 UOM = EA SHEET 2 OF 4

PRODUCT APPROVED
as complying with the Florida Building Code
NOA-No. 19-0815.07
Approval Date 10/10/2019
By *[Signature]*
Miami-Dade Product Control

NOTES: (UNLESS OTHERWISE SPECIFIED)

1. ONE 4" STRUT PER SECTION, AND ONE 3" STRUT PER BOTTOM SECTION, ATTACHED WITH 1/4-14X7/8" SELF DRILLING CRIMPTITE SCREWS.

PRODUCT APPROVED
as complying with the Florida
Building Code

NOA-No. **19-0815.07**

Approval Date **10/10/2019**

By *[Signature]*
Miami-Dade Product Control

(12) SECTION DOORS WITH
(12) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN

(11) SECTION DOORS WITH
(11) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN

(10) SECTION DOORS WITH
(10) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN

(9) SECTION DOORS WITH
(9) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN


(8) SECTION DOORS WITH
(8) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN

(7) SECTION DOORS WITH
(7) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN


(6) SECTION DOORS WITH
(6) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN

(5) SECTION DOORS WITH
(5) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN


(4) SECTION DOORS WITH
(4) 4" 16 GA 80 KSI U- BARS
(1) 3" 20 GA 80 KSI U- BARS
LOCATED AS SHOWN




TYPICAL TRACK CLIP
WELDING DETAIL



TYPICAL TRACK CLIP
BOLTING DETAIL




TYPICAL TRACK CLIP
RIVETING DETAIL




TYPICAL TRACK AND JAMB
FASTENERS DETAIL

OPTIONAL WALL ANGLE TRACK

DETAIL M
SCALE 1:4




STANDARD LIFT
TRACK DETAIL




LOW HEADROOM
TRACK DETAIL


TRACK DETAIL
SCALE 1:12




HIGH LIFT
TRACK DETAIL



VERTICAL LIFT
TRACK DETAIL




DETAIL N
SCALE 1:4



DETAIL O
SCALE 1:4

STRUT LOCATIONS
SCALE 1:20











DWAYNE J. KORNISH, PE
4576 COUNTY ROAD 160
MOUNT HOPE, OHIO
FL PE 77945 TX PE 117868

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR
VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

THIRD ANGLE PROJECTION		UNLESS OTHERWISE SPECIFIED INTERPRET DIMS & TOLS PER ASME Y14.5M ALL DIMS ARE IN INCHES DO NOT SCALE		TOLERANCES: X = ± .1 .XX = ± .03 .XXX = ± .010 ANGULAR = ± .5° HOLES: < Ø.251 = +.004/- .003 Ø.251-Ø.500 = +.006/- .003 > Ø.500 = +.008/- .003 ALL GEOMETRY GOVERNED BY 3D CAD DATABASE:		APPROVALS DATE DRAWN E. CONRAD 8/28/18 CHECKED D. KORNISH - APPROVED - - MATERIAL - FINISH - WINDLOAD SPECIFICATION OPTION CODE 2341		Wayne Dalton 854-463-7000 PENSACOLA, FLORIDA DESCRIPTION WINDLOAD MODELS 4600/4650/6600/8300/ 8500/8650/5150/5200/TM515/TM525, +46/-52PSF DADE COUNTY, 16'2" MAX WIDTH SIZE DWG NO. D D-363475 REV P-00	
A DIVISION OF OVERHEAD DOOR CORP 3395 ADDISON DRIVE PENSACOLA, FLORIDA 32514 (850)-474-9890		DIMS CIRCLED WITH SYMBOL 'O' ARE CRITICAL TO QUALITY DESIGN FEATURES & MUST MEET APPLICABLE IN-PROCESS INSPECTION STANDARDS.						SCALE 1:12 UOM = EA SHEET 3 OF 4	

NOTES: (UNLESS OTHERWISE SPECIFIED)
1. FOR DIMENSIONS AND NOTE REFERENCES, REFER TO INDIVIDUAL DRAWINGS.



7/24/2019 DWAYNE J. KORNISH, PE
4576 COUNTY ROAD 160
MOUNT HOPE, OHIO
FL PE 77945 TX PE 117868

PROFESSIONAL ENGINEER'S SEAL PROVIDED ONLY FOR VERIFICATION OF WINDLOAD CONSTRUCTION DETAILS.

PRODUCT APPROVED
as complying with the Florida Building Code
NOA-No. **19-0815.07**
Approval Date **10/10/2019**
By *[Signature]*
Miami-Dade Product Control

THIRD ANGLE PROJECTION

 A DIVISION OF OVERHEAD DOOR CORP
 3395 ADDISON DRIVE
 PENSACOLA, FLORIDA 32514
 (850)-474-9890

UNLESS OTHERWISE SPECIFIED
 INTERPRET DIMS & TOLS PER ASME Y14.5M
 ALL DIMS ARE IN INCHES
 DO NOT SCALE
 DIMS CIRCLED WITH SYMBOL 'C' ARE CRITICAL TO QUALITY DESIGN
 FEATURES & MUST MEET APPLICABLE IN-PROCESS INSPECTION STANDARDS.

TOLERANCES:
 .X = ± .1
 .XX = ± .03
 .XXX = ± .010
 ANGULAR = ± .5°

HOLES:
 < Ø.251 = +.004/- .003
 Ø.251-Ø.500 = +.006/- .003
 > Ø.500 = +.008/- .003

ALL GEOMETRY GOVERNED BY 3D CAD DATABASE:

APPROVALS DATE
 DRAWN E. CONRAD 8/28/18
 CHECKED D. KORNISH
 APPROVED
 MATERIAL
 FINISH
 WINDLOAD SPECIFICATION
 OPTION CODE 2341

Wayne Dalton PENSACOLA, FLORIDA
 DESCRIPTION
 WINDLOAD MODELS 4600/4650/6600/8300/
 8500/8650/5150/5200/TM515/TM525, +46/-52PSF
 DADE COUNTY, 16'2" MAX WIDTH
 SIZE DWG NO. REV
 D D-363475 P-00
 SCALE 1:12 UOM = SHEET 4 OF 4