



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786)315-2590 F (786) 31525-99

[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

**Icynene-Lapolla**  
**15402 Vantage Parkway East, Suite 322**  
**Houston, TX 77032**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: THERMO-SIL PRO 9600 High Solids Silicone Coating

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 6.

The submitted documentation was reviewed by ***Freddy Semino***



**NOA No.: 20-0127.03**  
**Expiration Date: 09/06/23**  
**Approval Date: 03/12/20**  
**Page 1 of 6**

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Cement-Adhesive-Coatings  
**Materials:** Silicone

### SCOPE:

This approves the roof maintenance and restoration coating system using **THERMO-SIL PRO 9600 High Solids Silicone Coating** to be used on existing roof assemblies as manufactured Tropical Roofing Products, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Materials Technologies LLC	TRS-145-02-01	ASTM D 6694	03/09/18
	TRA-162-02-01	ASTM D 2697 / ASTM D 1644 / ASTM D 2370 / ASTM D 624	04/24/18
	TRA-163-02-01	ASTM D 2697 / ASTM D 1644 / ASTM D 2370 / ASTM D 624	04/24/18
	TRA-178-02-01	ASTM D 2196 / ASTM D 1475 / ASTM D 1644 / ASTM D 4017 / ASTM D 3960	03/01/18
	TRA-227-02-01	ASTM D 6694	01/15/19



## TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
THERMO-SIL PRO 9600 High Solids Silicone Coating	1, 5, 55, and 275 gallons.	ASTM D6694	THERMO-SIL PRO 9600 High Solids Silicone Coating is a solvent-free, high solids, single-component, silicone moisture cured roof coating.
THERMO-SIL PRO Bleed Blocker	5 and 55 gallons.	Proprietary	THERMO-SIL PRO Bleed Blocker is an acrylic single component, water-based primer.
THERMO-SIL PRO Silicone Roof Patch	2 gallons.	Proprietary	THERMO-SIL PRO Silicone Roof Patch, a solvent-based, fibrated, single-component, silicone moisture cured roofing cement, mastic, and patch/repair product.
THERMO-SIL PRO 9600 Silicone Seam Sealer	2 gallons.	Proprietary	THERMO-SIL PRO 9600 Silicone Seam Sealer, a solvent-free, high solids, single-component, silicone moisture cured roofing cement, mastic, and seam sealer.

## MANUFACTURING LOCATIONS:

1. Hallandale, FL



## PHYSICAL PROPERTIES OF COMPONENTS

**Trade names:** THERMO-SIL PRO 9600 High Solids Silicone Coating  
**Thickness:** See scope of use below.  
**Specifications:** ASTM D 6694  
**Description:** A solvent-free, high solids, single-component, silicone moisture cured roof coating to be applied to the specified surfaces only as follows:

- **Asphalt Built-Up Roofing Granulated:** Prepare surface as per manufacturer's specification prior to application.

Option 1 – Apply THERMO-SIL PRO 9600 High Solids Silicone Coating directly to the substrate at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).

Option 2 – Apply THERMO-SIL PRO Bleed Blocker at a minimum rate of 1.0 gallon per 100 ft<sup>2</sup> or 7 mils Dry Film Thickness (DFT).  
Allow THERMO-SIL PRO Bleed Blocker to fully cure, then apply THERMO-SIL PRO 9600 High Solids Silicone Coating at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).

- **SBS Modified Bitumen Granulated:** Prepare surface as per manufacturer's specification prior to application.

Option 1 – Apply THERMO-SIL PRO 9600 High Solids Silicone Coating directly to the substrate at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT)

Option 2 – Apply THERMO-SIL PRO Bleed Blocker at a minimum rate of 1.0 gallon per 100 ft<sup>2</sup> or 7 mils Dry Film Thickness (DFT). Allow THERMO-SIL PRO Bleed Blocker to fully cure, then apply THERMO-SIL PRO 9600 High Solids Silicone Coating at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT)

- **SBS Modified Bitumen Smooth:** Prepare surface as per manufacturer's specification prior to application. Apply THERMO-SIL PRO Bleed Blocker at a minimum rate of 1.0 gallon per 100 ft<sup>2</sup> or 7 mils Dry Film Thickness (DFT). Allow THERMO-SIL PRO Bleed Blocker to fully cure, then apply THERMO-SIL PRO 9600 High Solids Silicone Coating at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).
- **APP Modified Bitumen Granulated:** Prepare surface as per manufacturer's specification prior to application. Apply THERMO-SIL PRO Bleed Blocker at a minimum rate of 1.0 gallon per 100 ft<sup>2</sup> or 7 mils Dry Film Thickness (DFT). Allow THERMO-SIL PRO Bleed Blocker to fully cure, then apply THERMO-SIL PRO 9600 High Solids Silicone Coating at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).

- **Spray Polyurethane Foam:** Prepare surface as per manufacturer's specification prior to application. Then apply THERMO-SIL PRO 9600 High Solids Silicone Coating directly to the substrate at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).
- **PVC Single Ply Membrane:** Prepare surface as per manufacturer's specification prior to application. Apply THERMO-SIL PRO 9600 High Solids Silicone Coating directly to the substrate at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).
- **EPDM Single Ply Membrane:** Prepare surface as per manufacturer's specification prior to application. Apply THERMO-SIL PRO 9600 High Solids Silicone Coating directly to the substrate at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).
- **Galvanized Steel:** Prepare surface as per manufacturer's specification prior to application. Then apply THERMO-SIL PRO 9600 High Solids Silicone Coating directly to the substrate at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).
- **Concrete:** Prepare surface as per manufacturer's specification prior to application. Then apply THERMO-SIL PRO 9600 High Solids Silicone Coating directly to the substrate at a minimum rate of 1.20 gallons per 100 ft<sup>2</sup> or 18 mils Dry Film Thickness (DFT).

**Container Size:** 1, 5, 55, and 275 gallons. Note all precautions on container.

**Trade names:** **THERMO-SIL PRO 9600 Silicone Seam Sealer**  
**Application Rate:** This material is applied by trowel or brush at a coverage rate of 80-120 linear feet.  
**Specifications:** ASTM D 2697 / ASTM D 1644 / ASTM D 2370 / ASTM D 624  
**Description:** A solvent-free, high solids, single-component, silicone moisture cured roofing cement, mastic, and seam sealer.

**Container Size:** 2 gallons. Note all precautions on container.

**Trade names:** **THERMO-SIL PRO Silicone Roof Patch**  
**Application Rate:** This material is applied by trowel or brush at a coverage rate of 80-120 linear feet.  
**Specifications:** ASTM D 2697 / ASTM D 1644 / ASTM D 2370 / ASTM D 624  
**Description:** A solvent-based, fibrated, single-component, silicone moisture cured roofing cement, mastic, and patch/repair product.

**Container Size:** 2 gallons. Note all precautions on container.



## **BUILDING PERMIT REQUIREMENTS:**

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable Building Code in order to properly evaluate the installation of this system.

## **GENERAL LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. Icynene-Lapolla's, THERMO-SIL PRO 9600 High Solid Silicone Coating, THERMO-SIL PRO 9600 Silicone Seam Sealer, THERMO-SIL PRO Silicone Roof Patch and THERMO-SIL PRO Bleed Blocker shall not be applied in inclement weather conditions.
3. Icynene-Lapolla's, THERMO-SIL PRO 9600 High Solid Silicone Coating, THERMO-SIL PRO 9600 Silicone Seam Sealer, THERMO-SIL PRO Silicone Roof Patch and THERMO-SIL PRO Bleed Blocker, shall not be applied over asphaltic shingles, metal shingles, fiber-cement shingles, quarry slate, cement or clay roofing tile, or wood shingles or shakes.
4. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their Roof Assembly's Notice of Acceptance.
5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



6. Icynene-Lapolla's, THERMO-SIL PRO 9600 High Solid Silicone Coating, THERMO-SIL PRO 9600 Silicone Seam Sealer, THERMO-SIL PRO Silicone Roof Patch and THERMO-SIL PRO Bleed Blocker shall only be applied by a factory trained and certified applicators and in accordance with manufacturer's published application instructions.
7. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade Product Control upon request.
8. Change in materials use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code

**END OF THIS ACCEPTANCE**



NOA No.: 20-0127.03  
Expiration Date: 09/06/23  
Approval Date: 03/12/20  
Page 6 of 6