



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

## NOTICE OF ACCEPTANCE (NOA)

**Henry Company LLC**  
**999 N. Sepulveda Blvd, Suite 800**  
**El Segundo, CA 90245**

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Henry Company Roofing Cements, Adhesives and Coatings

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA No.16-0930.11 and consists of pages 1 through 14.  
The submitted documentation was reviewed by *Freddy Semino*



NOA No.: 20-0810.05  
Expiration Date: 11/29/22  
Approval Date: 12/17/20  
Page 1 of 14

## ROOFING COMPONENT APPROVAL

**Category:** Roofing  
**Sub-Category:** Cement-Adhesive-Coatings  
**Fire Classification:** See Limitation #1

### SCOPE:

This approves “Henry Company Roofing Cements, Adhesives and Coatings” as a listed herein, manufactured by Henry Company, as described in this Notice of Acceptance, designed to comply with the Florida Building Code, High Velocity Hurricanes Zone

### MANUFACTURING LOCATION

1. Bartow, FL
2. Kingman, AZ
3. Garland, TX.
4. Indianapolis, IN
5. LaGrange, OH.
6. Kimberton, PA.
7. Scarborough, Ontario CANADA

### EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
PRI Construction Materials Technologies	HGC-185-02-01	ASTM D 2824	09/17/12
	HGC-184-02-01	ASTM D 2824	09/17/12
	HGC-186-02-01	ASTM D 2824	09/17/12
	HGC-187-02-01	ASTM D 2824	10/03/12
	HGC-184-02-01	ASTM D 2824	09/17/12
	HGC-186-02-01	ASTM D 2824	09/17/12
	HGC-186-02-01	ASTM D 2824	09/17/12
	HGC-163-02-01	ASTM D 4586	06/12/12
	HGC-164-02-01	ASTM D 4586	06/12/12
	HGC-176-02-01	ASTM D 4586	06/13/12
	HGC-160-02-01	ASTM D 4586	04/23/12
	HGC-157-02-01	ASTM D 4586	04/23/12
	HGC-177-02-01	ASTM D 4586	06/13/12
	HGC-170-02-01	ASTM D 1227	06/12/12
	HGC-166-02-01	TAS 139	06/12/12
	HGC-152-02-01	ASTM D 3019	06/12/12
	HGC-175-02-01	ASTM D 4479	06/13/12
	HGC-174-02-01	ASTM D 41	06/25/12
	HGC-159-02-01	ASTM D 4586	04/23/12
	HGC-158-02-01	ASTM D 4586	04/23/12
	HGC-154-02-01	ASTM D 3019	06/12/12
	HGC-175-02-01	ASTM D 4479	06/13/12
	HGC-153-02-01	ASTM D 3019	06/12/12
	HGC-159-02-01	ASTM D 4586	04/23/12
	HGC-158-02-01	ASTM D 4586	04/23/12
	HGC-174-02-01	ASTM D 41	06/25/12
	HGC-158-02-01	ASTM D 4586	04/23/12
	HGC-163-02-01	ASTM D 4586	06/12/12



NOA No.: 20-0810.05  
Expiration Date: 11/29/22  
Approval Date: 12/17/20  
Page 2 of 14

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
	HGC-159-02-01	ASTM D 4586	04/23/12
	HGC-158-02-01	ASTM D 4586	07/18/12
	HGC-177-02-01	ASTM D 4586	06/13/12
	HGC-154-02-01	ASTM D 3019	06/12/12
	HGC-170-02-01	ASTM D 1227	06/12/12
	HGC-147-02-01	ASTM D 1227	06/12/12
	HGC-201-02-01	ASTM D 2824	10/21/13
	HGC-258-02-01	ASTM D 1227	07/01/16
	HGC-246-02-01	ASTM D 4479	07/01/16
	HGC-245-02-02	ASTM D 3019	07/05/16
	HGC-248-02-01	ASTM D 4586	07/01/16
	HGC-254-02-01	ASTM D 4586/3409	07/01/16
	HGC-260-02-01	ASTM D 4586/3409	07/01/16
	HGC-255-02-01	ASTM D 4586/3409	07/01/16
	HGC-247-02-01	ASTM D 4586	07/01/16
	HGC-249-02-01	ASTM D 4586	07/01/16
	HGC-265-02-01	ASTM D 2824	07/01/16
	HGC-263-02-01	ASTM D 2824	07/01/16
	HGC-261-02-01	ASTM D 4586/3409	07/01/16
	HGC-257-02-01	ASTM D 41	07/01/16
	HGC-253-02-01	ASTM D 4586/3409	07/01/16
	HGC-253-02-02	ASTM D 4586/3409	07/01/16
	HGC-253-02-03	ASTM D 4586/3409	07/01/16
	HGC-257-02-02	ASTM D 41	07/01/16
	HGC-259-02-01	ASTM D 1227	07/05/16
	HGC-258-02-02	ASTM D 1227	07/01/16
	HGC-250-02-01	ASTM D 4586	07/01/16
	HGC-245-02-01	ASTM D 3019	07/01/16
	HGC-246-02-02	ASTM D 4479	07/01/16
	HGC-265-02-02	ASTM D 2824	07/05/16
	HGC-263-02-02	ASTM D 2824	07/05/16
	HGC-264-02-01	ASTM D 2824	07/01/16
	HGC-262-02-01	ASTM D 2824	07/01/16
	HGC-245-02-02	ASTM D 3019	07/01/16
	HGC-264-02-02	ASTM D 2824	07/01/16
	HGC-269-02-01	ASTM D 1227	07/05/16
	HGC-291-02-01	ASTM D 6083	12/20/17
Momentum Technologies, Inc.	AX23G9A	ASTM D 6694	06/21/12



## PHYSICAL PROPERTIES OF COMPONENTS

<b>Trade name:</b>	<b>Henry® 107® Asphalt Emulsion Sealer and Dampproofer</b>
<b>Application Rate:</b>	Apply emulsion by roofing brush or spray. Uniformly cover the surface at the rate of 3-4 Gallons per 100 square feet per application. For additional protection, apply a 2 <sup>nd</sup> coat at the same rate as soon as the first coat is thoroughly dry and firm enough to take foot traffic with damage. Brush the second coat at right angles to the first. Apply a reflective coating as soon as the top coat has completely cured.
<b>Specifications:</b>	ASTM D 1227, Type II, Class I
<b>Description:</b>	A premium, versatile coating for the protection of roofing materials, metal and masonry surfaces. Solvent-free, made from asphalt emulsified with betonite clay and water. It is cold-applied, non-flammable while wet, corrosion-resistant when dry. It will not crack, "alligator," run, or sag under extreme weather conditions. It resists most corrosive fumes and spray.
<b>Container Size:</b>	1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)
<b>Systems Approvals:</b>	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
<b>Manufacturing Location:</b>	#1, #4
<b>Trade name:</b>	<b>Pro-Grade® 155 Flashing Cement</b>
<b>Application Rate:</b>	1/8" to 1/4" with a trowel or putty knife. Coverage 12.5 sq. ft. per gallon applied at 1/8" thick.
<b>Specifications:</b>	ASTM D 4586, Type I, Class I
<b>Description:</b>	Trowel- grade modified rubberized flashing cement for use on dry surfaces in all temperature conditions.
<b>Container Size:</b>	1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)
<b>Systems Approvals:</b>	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
<b>Manufacturing Location:</b>	#1, #4
<b>Trade name:</b>	<b>Pro-Grade® 161 All Weather Flashing Cement</b>
<b>Application Rate:</b>	Apply in a thickness of 1/8" or 12.5 sq. ft. per gallon.
<b>Specifications:</b>	ASTM D 4586, Type I, Class II; ASTM D3409
<b>Description:</b>	A rubber polymer modified mastic compound of asphalt organic fibers and mineral fillers for use on wet or dry surfaces. It is a pliable material that gradually hardens to a flexible, durable, and film. Exhibits superior adhesion to either wet or dry surfaces.
<b>Container Size:</b>	10.1, 10.3, 11 oz., 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)
<b>Systems Approvals:</b>	Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.
<b>Manufacturing Location:</b>	#1, #4

**Trade name:** Henry® 201 Fibered Black Roof Coating  
**Application Rate:** Coverage is approximately 1.5 gallons per 100 sq. ft.  
**Specifications:** ASTM D 4479, Type I  
**Description:** A premium cold-applied, brush or spray-grade asphalt coating in a solvent system. It is a penetrating type protective coating formulated to provide a tough, durable, weather-resistant film to protect existing roofs in good conditions. It is recommended for long wearing protection for metal roofs, smooth surfaced cap sheet SBS or composition roofs.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Henry® 203 Roll Roofing Adhesive  
**Application Rate:** 50 sq. ft. per gallon. Coverage rate varies depending on texture and porosity of surface.  
**Specifications:** ASTM D 3019, Type III  
**Description:** An asphalt roofing adhesive with a bonding strength specially designed for adhering asphalt coated sheets together. This material is formulated for use as a cold adhesive between plies of asphalt coated or saturated roofing sheets such as double coverage or selvage edge roll roofing.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Henry® 204® Plastic Roof Cement  
**Application Rate:** 1/8" to 1/4" with a trowel or putty knife. Coverage 12.5 sq.ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class I  
**Description:** A premium trowel grade compound for sealing roof leaks on dry surfaces. Repair holes, cracks and splits on composition, mineral surface cap sheet, asphalt coated, SBS modified and metal roofs.  
**Container Size:** Quarts, 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4



**Trade name:** Henry® 208® Wet Patch® Roof Leak Repair  
**Application Rate:** 1/8" to 1/4" with a trowel or putty knife. Coverage 12 sq.ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class II; ASTM D3409  
**Description:** A compound for sealing roof leaks on wet surfaces. It patches holes and cracks even in a driving rain or under water, and may be used whether the weather is wet or dry, hot or cold.  
**Container Size:** 11 oz, Quarts, 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #1, #4

**Trade name:** Henry® 208R Rubberized Wet Patch® Roof Leak Repair  
**Application Rate:** 1/16" to 1/4" with a trowel or putty knife. Coverage 12 sq. ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class II; ASTM D-3049  
**Description:** Premium SBS modified bitumen compound for sealing roof leaks on wet surfaces. It patches holes and cracks even in a driving rain or underwater, and is versatile enough to be used whether the weather is wet or dry, hot or cold.  
**Container Size:** 10.1, 10.3, 11 oz., 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #1, #4

**Trade name:** Henry® 209XR Extreme Rubberized Wet Patch® Roof Leak Repair  
**Application Rate:** 1/8" to 1/4" with a trowel or putty knife. Coverage 12.5 sq. ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class II; ASTM D3409  
**Description:** Premium SEBS modified bitumen compound for sealing roof leaks on wet surfaces, especially at moving joints. It patches holes and cracks even in a driving rain or under water, and may be used whether the weather is wet or dry, hot or cold.  
**Container Size:** 11 oz., Quarts, 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #4



**Trade name:** Henry® 280DC White Elastomeric Roof Coating  
**Application Rate:** As specified in the Systems Approvals.  
**Specifications:** ASTM D 6083  
**Description:** A premium white elastomeric roof coating water-based acrylic latex coating. All installation details shall be in accordance with the Henry Company's recommended application procedures.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #1, #2, #3

**Trade name:** Henry® 289 White Roofing Sealant  
**Application Rate:** Approximately 12 ½ sq. ft. per gallon applied 1/8" thick.  
**Specifications:** TAS 139  
**Description:** A white, elastomeric acrylic patching compound specially formulate for repairing and preventing roof leaks prior to coating with an acrylic reflective coating. It will not crack, craze or lose adhesion when applied as directed to a smooth, clean, sound roof surface. Can be used with standard mineral surface cap sheet, smooth surface built up roofing, SBS modified roofing, previously coated asphalt roofs, weathered metal roofs and concrete and stucco parapet walls.  
**Container Size:** 10.1, 10.3, 11oz, 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #7

**Trade name:** Henry® 505 Flashmaster™ Flashing Cement  
**Application Rate:** 1/8" to 1/4" with a trowel or putty knife. Coverage 12.5 sq. ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class I  
**Description:** Trowel- grade modified rubberized flashing cement for use on dry surfaces in all temperature conditions.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #1, #4



**Trade name:** Henry® 553 MBA Gold Modified Bitumen Adhesive  
**Application Rate:** Coverage is approximately 1.5 gallons per 100 sq. ft.  
**Specifications:** ASTM D 3019, Type III  
**Description:** A fibrated rubberized adhesive with a bonding strength designed specifically for adhering modified bitumen and asphalt coated membranes to properly prepared surfaces. It sets by loss of solvent content through evaporation.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #1

**Trade name:** Henry® 869 Rubberized Aluminum Roof Coating  
**Application Rate:** Apply with a soft bristled brush, heavy napped roller or commercial grade spray equipment designed for solvent based coating at a rate of 1.5 to 2 gallons per 100 sq. ft. The roof surface should be free of any dust, oils, debris or other elements which could interfere with proper adhesion. A prime coat is not recommended.  
**Specifications:** ASTM D 2824, Type III  
**Description:** A premium, highly reflective aluminum roof coating made with SBS Polymers which give the coating strength and elastomeric properties.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #4

**Trade name:** Henry® 887 Tropi-Cool® 100% Silicone White Roof Coating  
Henry® 887G Tropi-Cool® 100% Silicone Gray Roof Coating  
Henry® 887T Tropi-Cool® 100% Silicone Tan Roof Coating  
**Application Rate:** As specified in the Systems Approvals.  
**Specifications:** ASTM D 6694  
**Description:** A one component, moisture curing silicone rubber roof coating. All installation details shall be in accordance with the Henry Company's recommended application procedures.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #5





**Trade name:** Henry® 910 Asphalt Primer  
**Application Rate:** Typical coverage 150-200 sq. ft. per gallon depending on temperature and porosity of surface to receive primer. Avoid over-application and build-up of surface film.  
**Specifications:** ASTM D 41, Type II  
**Description:** A thin penetrating solution of selected asphalt base in a petroleum solvent. It readily penetrates the pores of the material to which it is applied and seals surfaces to provide a firm bond for asphalt coatings – hot or cold or cutback types.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Pro-Grade® 151 Plastic Roof Cement  
**Application Rate:** Coverage 12.5 sq. ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class I  
**Description:** A plastic roof cement for repairing leaks in asphalt, metal and composition roof surfaces. This material is used on flashings where a heavy duty product is required and as an emergency patching compound that provides good water resistance.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Pro-Grade® 163 Emergency Leak Repair Sealant  
**Application Rate:** 1/16" to 1/4" with a trowel or putty knife. Coverage 12.5 sq. ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class II; ASTM D-3049  
**Description:** Premium SBS modified bitumen compound for sealing roof leaks on wet surfaces, It patches holes and cracks even in a driving rain or underwater, and is versatile enough to be used whether the weather is wet or dry, hot or cold.  
**Container Size:** 10.1, 10.3, 11 oz., 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4



**Trade name:** Pro-Grade® 167 Extreme Rubberized Flashing Cement  
**Application Rate:** 1/8" to 1/4" with a trowel or putty knife. Coverage 12.5 sq. ft. per gallon applied at 1/8" thick.  
**Specifications:** ASTM D 4586, Type I, Class II; ASTM D3409  
**Description:** A compound for sealing roof leaks on wet surfaces, especially at moving joints. It patches holes and cracks even in a driving rain or under water, and may be used whether the weather is wet or dry, hot or cold.  
**Container Size:** 11 oz., Quarts, 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #4

**Trade name:** Pro-Grade® 197 Asphalt Emulsion  
**Application Rate:** Apply emulsion by roofing brush or spray. Uniformly cover the surface at the rate of 3-4 Gallons per 100 square feet per application. For additional protection, apply a 2<sup>nd</sup> coat at the same rate as soon as the first coat is thoroughly dry and firm enough to take foot traffic with damage. Brush the second coat at right angles to the first. Apply a reflective coating as soon as the top coat has completely cured.  
**Specifications:** ASTM D 1227, Type II, Class I  
**Description:** A premium, versatile coating for the protection of roofing materials, metal and masonry surfaces. Solvent-free, made from asphalt emulsified with betonite clay and water. It is cold-applied, non-flammable while wet, corrosion-resistant when dry. It will not crack, "alligator," run, or sag under extreme weather conditions. It resists most corrosive fumes and spray.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Pro-Grade® 280 Elastomeric White Roof Coating  
**Application Rate:** As specified in the Systems Approvals.  
**Specifications:** ASTM D 6083  
**Description:** A premium white elastomeric roof coating water-based acrylic latex coating. All installation details shall be in accordance with the Henry Company's recommended application procedures.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #2, #3



**Trade name:** Pro-Grade® 581 Fibered Aluminum Roof Coating  
**Application Rate:** Approximately 75 – 100 sq. ft. per gallon. As the roof slope increases coverage rate should be reduced to prevent run-off or slippage.  
**Specifications:** ASTM D 2824, Type III  
**Description:** For use to coat properly prepared smooth surfaced asphalt Built-up and Modified Bitumen membranes. Pro Grade 812 produces a bright aluminum roof surface which reflects damaging ultraviolet sunrays.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Pro-Grade® 586 Fibered Aluminum Roof Coating  
**Application Rate:** Approximately 1 ¼ to 2.0 gallons per 100 sq. ft. As the roof slope increases coverage rate should be reduced to prevent run-off or slippage.  
**Specifications:** ASTM D 2824, Type III  
**Description:** Use as a surface coat for mineral surface cap sheet, smooth built-up, modified PLUS SBS or APP assemblies. Also can be used on metal roofs or other types of roof metal. Can be used with previously asphalt coated masonry surfaces. Also with previously coated asphalt mastic surfaces.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Pro-Grade® 599 Rubberized Aluminum Roof Coating  
**Application Rate:** Apply with a soft bristled brush, heavy napped roller or commercial grade spray equipment designed for solvent based coating at a rate of 1.5 to 2 gallons per 100 sq. ft. The roof surface should be free of any dust, oils, debris or other elements which could interfere with proper adhesion. A prime coat is not recommended.  
**Specifications:** ASTM D 2824, Type III  
**Description:** A premium, highly reflective aluminum roof coating made with SBS Polymers which give the coating strength and elastomeric properties.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #4



**Trade name:** Pro-Grade® 988 Silicone White Roof Coating  
Pro-Grade® 988 Silicone Tan Roof Coating  
Pro-Grade® 988 Silicone Gray Roof Coating  
Pro-Grade® 988 Silicone Light Gray Roof Coating

**Application Rate:** As specified in the Systems Approvals.

**Specifications:** ASTM D 6694

**Description:** A one component, moisture curing silicone rubber roof coating. All installation details shall be in accordance with the Henry Company's recommended application procedures.

**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)

**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #5

**Trade name:** SmartRoof™ Premium 1-Coat High Solids Silicone Roof Coating

**Application Rate:** As specified in the Systems Approvals.

**Specifications:** ASTM D 6694

**Description:** A one component, moisture curing silicone rubber roof coating. All installation details in accordance with the Henry Company's recommended application procedures.

**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)

**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #5

**Trade name:** Premier™ 400 Blind Nailing Cement Cold Process Adhesive

**Application Rate:** 50 sq. ft. per gallon. Coverage rate varies depending on texture and porosity of surface.

**Specifications:** ASTM D 3019, Type III

**Description:** An asphalt roofing adhesive with a bonding strength specially designed for adhering asphalt coated sheets together. This material is formulated for use as a cold adhesive between plies of asphalt coated or saturated roofing sheets such as double coverage or selvage edge roll roofing.

**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)

**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.

**Manufacturing Location:** #1, #4



**Trade name:** Premier™ 550 Aluminum Roof Coating  
**Application Rate:** Typical coverage is 1 to 1.2 gallons per 100 sq. ft.  
**Specifications:** ASTM D 2824, Type III  
**Description:** A highly reflective roof coating. It can reduce the surface temperature of a roof and retard deterioration of the surface. It can be used to coat properly prepared smooth surface asphalt built-up, metal and modified bitumen membranes.  
**Container Size:** 1, 2, 3.5, 5, 50, 55 and 275 gallons (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

**Trade name:** Premier™ 650 Foundation and Roof Coating  
**Application Rate:** Ready to Use. For smooth surface roofs, apply the first coat at a rate of 3 gallons per 100 sq. ft., let dry and apply a second coat at the rate of 3 gallons per 100 sq. ft. As a maintenance coating, use one or two coats followed by a white or aluminum reflective coating. Uniformly covering the surface with one or two separate coats at the rate of 3 gallons per 100 sq. ft. Brush the second coat at right angles to the first.  
**Specifications:** ASTM D-1227, Type II, Class I  
**Description:** A premium, versatile coating for the protection of roofing materials, metal and masonry surfaces. Solvent-free, made from asphalt emulsified with betonite clay and water. It is cold-applied, non-flammable while, wet, corrosion-resistant when dry. It will not crack, “alligator,” run, or sag under extreme weather conditions. It resists most corrosive fumes and spray.  
**Container Size:** Gallon and 5 Gallon (Note all precautions on container)  
**Systems Approvals:** Methods of application and quantities shall comply with the specific Roof Assembly Product Control Notice of Acceptance.  
**Manufacturing Location:** #1, #4

## **LIMITATIONS:**

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. HENRY Company products shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to RER upon request.
5. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



6. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
7. HENRY Company products shall be applied in accordance with manufacturer's published application instructions.
8. The use of a reinforcing fabric in a maintenance coating is only to enhance the coatings ability to deliver efficient and long term performance through the protection of the underlying roof system and in this particular use does not become a roof system itself.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

**END OF THIS ACCEPTANCE**

