



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)  
BOARD AND CODE ADMINISTRATION DIVISION

## NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY  
PRODUCT CONTROL SECTION  
11805 SW 26 Street, Room 208  
Miami, Florida 33175-2474  
T (786) 315-2590 F (786) 315-2599  
[www.miamidade.gov/economy](http://www.miamidade.gov/economy)

Sika Sarnafil, A Division of Sika Corp.  
100 Dan Road  
Canton, MA 02021

### SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

### DESCRIPTION: Sika Sarnafil PVC Single Ply Roofing over Wood Deck

**LABELING:** Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

**RENEWAL** of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

**TERMINATION** of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

**ADVERTISEMENT:** The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

**INSPECTION:** A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews NOA No. 19-0513.03 and consists of pages 1 through 12.  
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 20-0825.09  
Expiration Date: 08/02/26  
Approval Date: 03/04/21  
Page 1 of 12

## ROOFING SYSTEM APPROVAL

**Category:** Roofing  
**Sub-Category:** Single Ply  
**Material:** PVC  
**Deck Type:** Wood  
**Maximum Design Pressure:** -75 psf

### TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<b><u>Product</u></b>	<b><u>Dimensions</u></b>	<b><u>Test Specification</u></b>	<b><u>Product Description</u></b>
G410	48, 60, 72 and 80 mils	ASTM D4434	Fiberglass reinforced PVC roofing membrane.
G410 Textured	48, 60, 72 and 80 mils	ASTM D4434	Fiberglass reinforced PVC roofing membrane.
S327	48, 60, 72 and 80 mils	ASTM D4434	Polyester reinforced PVC roofing membrane.
S327 Textured	48, 60, 72 and 80 mils	ASTM D4434	Polyester reinforced PVC roofing membrane.
S327 (10 ft)	48, 60, 72 and 80 mils	ASTM D4434	Polyester reinforced PVC roofing membrane.
S327 Felt	48, 60, 72 and 80 mils	ASTM D4434	Polyester reinforced PVC roofing membrane.
Sikaplan Fastened	45 mils or 60 mils	ASTM D4434	White polyester reinforced PVC roofing membrane.
Sikaplan Fastened Feltback	45 mils or 60 mils	ASTM D4434	White polyester reinforced PVC roofing membrane.
Sikaplan Adhered	60 mils	ASTM D4434	White polyester reinforced PVC roofing membrane.
Sarnacol 2170 VC	Various	Proprietary	Solvent-based, VOC compliant adhesive.
Sarnatred	3.25' x 32.8'	Proprietary	PVC walkway protection sheet.
Sarnaclad	Various	Proprietary	Heat weldable PVC/galvanized steel flashing



## APPROVED INSULATIONS:

TABLE 2

<b><u>Product</u></b>	<b><u>Product Description</u></b>	<b><u>Manufacturer (with current NOA)</u></b>
Sarnatherm	Isocyanurate Insulation with fiber reinforced felt paper facer	Sika Sarnafil, A Division of Sika Corp.
DensDeck	Silicon treated gypsum with fiberglass mat facer	Georgia Pacific Gypsum LLC
DensDeck Prime	Silicon treated gypsum with an enhanced fiberglass mat facer	Georgia Pacific Gypsum LLC
H-Shield	Isocyanurate Insulation with fiber reinforced felt paper facer	Hunter Panels, LLC



**APPROVED FASTENERS/ADHESIVES:****TABLE 3**

<b><u>Fastener Number</u></b>	<b><u>Product Name</u></b>	<b><u>Product Description</u></b>	<b><u>Dimensions</u></b>	<b><u>Manufacturer (With Current NOA)</u></b>
1.	#12 Standard Roofgrip, #14 Roofgrip, #15 Roofgrip	Insulation and membrane fastener	Various	OMG, Inc.
2.	Sarnafastener #12	Insulation and membrane fastener	Various	Sika Sarnafil, A Division of Sika Corp.
3.	Sarnaplate	Insulation fastening plate.	3" Round	Sika Sarnafil, A Division of Sika Corp.
4.	Sarnabar	Galvanized or stainless steel membrane fastening bar.	Various	Sika Sarnafil, A Division of Sika Corp.
5.	Sarnafastener #14	Insulation and membrane fastener	Various	Sika Sarnafil, A Division of Sika Corp.
6.	OMG Heavy Duty	Insulation and membrane fastener	Various	OMG, Inc.
7.	Sarnafastener-XP	Insulation and membrane fastener	Various	Sika Sarnafil, A Division of Sika Corp.
8.	Sarnadisc-XP	Insulation and membrane fastener	1.5" x 3.75"	Sika Sarnafil, A Division of Sika Corp.
9.	Sikaplan Board Fastener #12	Insulation and membrane fastener	Various	Sika Sarnafil, A Division of Sika Corp.
10.	Sikaplan Fastener #14	Insulation and membrane fastener	Various	Sika Sarnafil, A Division of Sika Corp.
11.	Flat Bottom Metal Plate	Insulation fastening plate.	3" Round	OMG, Inc.
12.	3 in. Ribbed Galvalume Plate	Round galvalume plated steel stress plate	3" Round	OMG, Inc.
13.	Sikaplan Board Plate	Round galvalume plated steel stress plate	3" Round	Sika Sarnafil, A Division of Sika Corp.
14.	RhinoBond Insulation Plate	Black primer coated plate for use with PVC membranes	3" Round	OMG, Inc.
15.	Sarnadisc RhinoBond	Black primer coated plate for use with PVC membranes	3" Round	Sika Sarnafil, A Division of Sika Corp.
16.	Sikaplan RhinoBond Disc	Black primer coated plate for use with PVC membranes	3" Round	Sika Sarnafil, A Division of Sika Corp.
17.	OMG Eyehook Accuseam Plate	Round galvalume steel plate for use with OMG fasteners	2- <sup>3</sup> / <sub>8</sub> " Round	OMG, Inc.
18.	Sikaplan Disc	Round galvalume steel plate for use with OMG fasteners	2- <sup>3</sup> / <sub>8</sub> " Round	Sika Sarnafil, A Division of Sika Corp.

**EVIDENCE SUBMITTED:**

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
Factory Mutual Research	3001396	FM 4470	05/28/99
	3016201	FM 4470	01/28/03
	3021131	FM 4470	07/07/05
	3028309	FM 4470	03/30/07
	3030053	FM 4470	09/12/07
	3032532	FM 4470	08/05/08
	3035670	FM 4470	05/13/09
	3036355	FM 4470	11/10/09
Underwriters Laboratories, Inc.	R8992	UL 790	05/15/13
Trinity   ERD	S42480.08.12	Physical Properties	08/20/12
	S44790.06.13	ASTM D4434	06/05/13
	S44790.08.13	ASTM D4434	08/26/13
	S45990.06.14	ASTM D4434	06/02/14
	S44790.07.14-R2	ASTM D4434	06/01/15
PRI	SARN-087-02-02	FM 4474 / TAS 114	06/22/18
NEMO etc.	2-SIKA-18-001.01.19	FM 4470 / TAS 114	01/03/19



## APPROVED ASSEMBLIES:

<b>Membrane Type:</b>	Single Ply, PVC
<b>Deck Type 1I:</b>	Wood, Insulated
<b>Deck Description:</b>	19/32" or greater plywood or wood plank
<b>System Type C(1):</b>	All layers of insulation simultaneously fastened; membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Thermal Barrier:** Minimum 1/2" DensDeck or DensDeck Prime

One or more layers of any of the following insulations:

<b><u>Base Insulation Layer:</u></b>	<b><u>Insulation Fasteners</u> <u>(Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>Sarnatherm, H-Shield</b> <b>Minimum 1.5" thick</b>	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

<b><u>Top Insulation Layer (Optional):</u></b>	<b><u>Insulation Fasteners</u> <u>(Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>Sarnatherm, H-Shield</b> <b>Minimum 1.5" thick</b>	5, 6, 14, 15	See Design Pressure

**Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** Sarnafil S327, S327 Textured or S327 (10 ft) bonded to RhinoBond Insulation Plates with RhinoBond Plate bonding tool at 6 seconds per plate so the tool reaches 400°F. Minimum 3" wide side lap is sealed with a minimum 3/4" wide heat weld.

<b>Maximum Design Pressures:</b>	<b>Maximum Pressure</b> -45 psf (See General Limitation #7)	<b>Fastener Spacing</b> 2 ft.	<b>Fastener Row Spacing</b> 3 ft.
----------------------------------	---	----------------------------------	--------------------------------------



**Membrane Type:** Single Ply, PVC  
**Deck Type 1I:** Wood, Insulated  
**Deck Description:** 19/32" or greater plywood or wood plank  
**System Type C(2):** All layers of insulation simultaneously fastened; membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Fire Barrier:** Minimum 1/2" DensDeck or DensDeck Prime

One or more layers of any of the following insulations:

<b><u>Base Insulation Layer:</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
Sarnatherm, H-Shield Minimum 1.5" thick	N/A	N/A

**Note: All layers shall be simultaneously fastened; see top layer below for fasteners and density. Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

<b><u>Top Insulation Layer (Optional):</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
Sarnatherm, H-Shield Minimum 1.5" thick	6, 10, 14, 16	See Design Pressure

**Note: Insulation panels listed are minimum sizes and dimensions; if larger panels are used, the number of fasteners shall be increased maintaining the same fastener density. Please refer to Roofing Application Standard RAS 117 for insulation attachment.**

**Membrane:** Sikaplan Fastened bonded to Sikaplan RhinoBond Disc, Sarnadisc RhinoBond with RhinoBond Plate bonding tool at 6 seconds per plate so the tool reaches 400°F. Minimum 3" wide side lap is sealed with a minimum 3/4" wide heat weld.

<b>Maximum Design Pressures:</b>	<b>Maximum Pressure</b> -45 psf (See General Limitation #7)	<b>Fastener Spacing</b> 2 ft.	<b>Fastener Row Spacing</b> 3 ft.
----------------------------------	---	----------------------------------	--------------------------------------



**Membrane Type:** Single Ply, PVC  
**Deck Type 1I:** Wood, Insulated  
**Deck Description:** Min. nominal ¾" APA rated CDX plywood or wood plank at 2 ft spans, attached with 8d ring shank nails 6" o.c.  
**System Type C(3):** Insulation layer fastened through the deck, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

<b><u>Insulation Layer:</u></b>	<b><u>Insulation Fasteners (Table 3)</u></b>	<b><u>Fastener Density/ft<sup>2</sup></u></b>
<b>DensDeck Prime Minimum: ½" Thick</b>	<b>1 (#12), 2, 3 &amp; 11</b>	<b>1:1.6 ft<sup>2</sup></b>

**Note:** Insulation Layer shall be fastened to the deck; see top layer below for fasteners and density Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application RAS 117 for fastener details).

**Membrane:** Sarnafil G410, G410 Textured, adhered with 2170 VC in a contact-application at a rate of 0.75 – 2.0 gal/sq. to the insulation and 0.5 gal/sq. to the membrane backside. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.

**Maximum Design Pressure:** -67.5 psf (See General Limitation #7)





**Membrane Type:** Single Ply, PVC

**Deck Type 1I:** Wood, Insulated

**Deck Description:** Min. nominal 3/4" APA rated CDX plywood or wood plank at 2 ft spans, attached with 8d ring shank nails 6" o.c.

**System Type C(4):** Insulation layer fastened through the deck, membrane adhered

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

One or more layers of any of the following insulations:

<b><u>Insulation Layer:</u></b>	<b><u>Insulation Fasteners</u> <u>(Table 3)</u></b>	<b><u>Fastener</u> <u>Density/ft<sup>2</sup></u></b>
<b>DensDeck Prime</b> <b>Minimum: 1/2" Thick</b>	<b>1 (#12), 2, 3 &amp; 11</b>	<b>1:1.6 ft<sup>2</sup></b>

**Note:** Insulation panels listed are minimum sizes and dimensions; if larger panels are used the number of fasteners per board shall be increased maintaining the same fastener density (See Roofing Application RAS 117 for fastener details).

**Membrane:** Sikaplan Adhered with Sarnacol 2170 VC in a contact-application at a rate of 0.75 – 2.0 gal/sq. to the insulation and 0.5 gal/sq. to the membrane backside. The roof cover is immediately placed into the adhesive and the top surface rolled with a weighted roller. Minimum 3" wide side lap is sealed with a 1.5" wide heat weld.

**Maximum Design Pressure:** -67.5 psf (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type II:** Wood, Insulated  
**Deck Description:** 15/32" or greater plywood or wood plank at 2 ft spans, attached with 2-<sup>3</sup>/<sub>8</sub>" ring shank nails 6" o.c.  
**System Type D(1):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Fire Barrier:** Minimum 1/4" DensDeck Prime, loose-laid.  
**Membrane:** Sikaplan Fastened (min. 60 mil) attached to deck as specified below.  
**Fastening:** Sikaplan Fastener #14, OMG Heavy Duty fasteners with Sikaplan Disc or OMG Eyehook Accuseam Plates spaced 12" o.c. within the 5.5" side lap spaced 54.5" o.c. and sealed with a minimum 1.5" weld.  
**Maximum Design Pressure:** -45 psf (See General Limitation #7)



**Membrane Type:** Single Ply, PVC  
**Deck Type II:** Wood, Insulated  
**Deck Description:** 15/32" or greater plywood or wood plank at 2 ft spans, attached with 2-<sup>3</sup>/<sub>8</sub>" ring shank nails 6" o.c.  
**System Type D(2):** Membrane attached over preliminary fastened insulation.

**All General and System Limitations apply. Roof accessories not listed in Table 1 of this NOA are not approved and shall not be installed unless said accessories demonstrate compliance with prescriptive Florida Building Code requirements and are field fabricated utilizing the approved membranes listed in Table 1.**

**Fire Barrier:** Minimum 1/4" DensDeck Prime, loose-laid.  
**Membrane:** Sikaplan Fastened (min. 60 mil) attached to deck as specified below.  
**Fastening:** Sikaplan Fastener #14, OMG Heavy Duty fasteners with Sikaplan Disc or OMG Eyehook Accuseam Plates spaced 6" o.c. within the 5.5" side lap spaced 54.5" o.c. and sealed with a minimum 1.5" weld.  
**Maximum Design Pressure:** -75 psf (See General Limitation #7)



## GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer.
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.  
**Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.**
5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. Insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117 and/or RAS 137. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
10. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

## END OF THIS ACCEPTANCE

