



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

SOPREMA, Inc.
310 Quadral Drive
Wadsworth, OH 44281

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: SOPREMA BUR and Modified Bitumen Roofing Membranes and Accessories

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA consists of pages 1 through 11.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 20-0825.11
Expiration Date: 08/04/27
Approval Date: 08/04/22
Page 1 of 11

ROOFING COMPONENT APPROVAL

Category:	Roofing
Sub-Category:	Roofing Membranes and Accessories
Material:	BUR and Modified Bitumen Roofing

SCOPE:

This approves **SOPREMA BUR and Modified Bitumen Roofing Membranes and Accessories** as roofing components, as described in this Notice of Acceptance, designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone. Please refer to "Limitations" herein for limits of use.

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
SOPRA IV <i>Manufacturing location #3</i>	36" x 180' (5 sq.)	ASTM D2178, Type IV	Type IV fiberglass reinforced, smooth surfaced plysheet used in multi-ply systems and complies with ASTM and UL Standards. Applied in hot asphalt or cold adhesive.
ANTIROCK <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
MODIFIED SOPRA G <i>Manufacturing location #1, 2</i>	39" x 108' (3.5 sq.)	ASTM D4601	Fiberglass reinforced modified asphalt base sheet for bonding or mechanically attaching to substrate. For use as a base/ply sheet only.
SOPRABASE <i>Manufacturing location #1</i>	39" x 99' (3 sq.)	ASTM D4601, Type II	Oxidized asphalt, polyester reinforced, sand-surfaced base sheet. For use as a base/ply sheet only.
SOPRABASE S <i>Manufacturing location #1</i>	39" x 65' (2 sq.)	ASTM D4601	SBS modified bitumen, polyester reinforced, sand-surfaced base sheet. For use as a base/ply sheet only.
SOPRABASE TG <i>Manufacturing location #1</i>	39" x 65' (2 sq.)	ASTM D4601, Type II	SBS modified bitumen, polyester reinforced, film-surfaced base sheet. For use as a base/ply sheet only.
ULTRA-STICK NAILBASE <i>Manufacturing location #1</i>	39" x 65' (2 sq.)	ASTM D4601, Type II	SBS modified bitumen, fiberglass reinforced, base sheet with a film top surface.
SOPRA 4897 <i>Manufacturing location #3</i>	39" x 41'	ASTM D4897	Fiberglass reinforced, smooth surfaced, modified bitumen venting base sheet for mechanically attaching to substrate.
COLPHENE SP 2.2 <i>Manufacturing location #1</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
COLPHENE SP 3.0 <i>Manufacturing location #1</i>	39" x 49' (1 sq.)	ASTM D6163, Type I, Smooth	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
COLPHENE 180 PS <i>Manufacturing location #1, 2</i>	39" x 49' (1.5 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
COLPHENE 180 Sanded <i>Manufacturing location #1, 2</i>	39" x 49' (1.5 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
COLPHENE 180 SP 3.5 <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
COLPHENE Stick <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Self-adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.
COLPHENE Sanded <i>Manufacturing location #1, 2</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
COLPHENE Flam 180 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
COLPHENE 180 FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
COLPHENE Flam 180 FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
COLPHENE Flam 180 GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
COLPHENE 250 FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).



PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
COLPHENE Flam 250 FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
COLVENT TG <i>Manufacturing location #1</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Fiberglass reinforced, modified bitumen membrane with 1" wide factory applied heat weldable strips on back side.
COLVENT 180 TG <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side.
COLVENT Flam 180 TG <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Polyester reinforced, modified bitumen membrane with 1" wide factory applied heat weld strips on back side and a plastic burn-off film surface.
ELASTOPHENE Flam HS <i>Manufacturing location #2</i>	39" x 33' (1 sq.)	ASTM D6162, Type III, Smooth	Woven fiberglass/polyester composite reinforced modified bitumen membrane with fire retardants and plastic burn-off film on both sides. Applied by heat welding.
ELASTOPHENE FLAM HS FR GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6162, Type III, Granular	SBS-modified bitumen cap ply composed of elastomeric styrene-butadiene-styrene (SBS) polymer modified bitumen and reinforced with a composite polyester/glass fiber reinforcement, underside surfaced with a burn-off film surface
ELASTOPHENE Flam 2.2 <i>Manufacturing location #1, 2</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
ELASTOPHENE Flam 3.0 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Smooth	Fiberglass reinforced modified bitumen membrane covered on both sides with a plastic burn-off film. Applied by heat welding.
ELASTOPHENE HS FR GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6162, Type III, Granular	SBS-modified bitumen cap ply composed of elastomeric styrene-butadiene-styrene (SBS) polymer modified bitumen and reinforced with a composite polyester/glass fiber reinforcement.
ELASTOPHENE PS 2.2 <i>Manufacturing location #1</i>	39" x 49' (1.5sq.)	ASTM D6163, Type I, Smooth	Glass reinforced modified bitumen membrane with a plastic burn-off film for heat weld bonding to the top side. Applied in hot asphalt, cold adhesive or ribbon stripping.
ELASTOPHENE PS 3.0 <i>Manufacturing location #1</i>	39" x 49' (1.5sq.)	ASTM D6163, Type I, Smooth	Glass reinforced modified bitumen membrane with a plastic burn-off film for heat weld bonding to the top side. Applied in hot asphalt, cold adhesive or ribbon stripping.
ELASTOPHENE Sanded 2.2 <i>Manufacturing location #1, 2</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.



PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
ELASTOPHENE Sanded 3.0 <i>Manufacturing location #1</i>	39" x 33' (1sq.)	ASTM D6163, Type I, Smooth	Fiberglass reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripped.
ELASTOPHENE SP 2.2 <i>Manufacturing location #1</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
ELASTOPHENE SP 3.0 <i>Manufacturing location #1</i>	39" x 49' (1 sq.)	ASTM D6163, Type I, Smooth	Glass reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
ELASTOPHENE Stick <i>Manufacturing location #1, 4</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Self-adhered, sanded surfaced, fiberglass reinforced membranes.
ELASTOPHENE ULTRA-STICK <i>Manufacturing location #1</i>	39" x 49' (1.5 sq.)	ASTM D6163, Type I, Smooth	Self-adhered, fiberglass reinforced membrane with a release film on the bottom and a film top surface.
ELASTOPHENE Stick FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Self-adhered, granule surfaced, fiberglass reinforced membranes.
ELASTOPHENE Stick HR FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Self-adhered, granule surfaced, glass reinforced membranes.
ELASTOPHENE Flam FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
ELASTOPHENE Flam FR+ GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Fiberglass reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
ELASTOPHENE Flam LS FR GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Fiberglass reinforced modified bitumen membrane with fire retardants, a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding.
ELASTOPHENE FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
ELASTOPHENE FR+ GR <i>Manufacturing location #2</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
ELASTOPHENE LS FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6163, Type I, Granule	Fiberglass reinforced modified bitumen membrane with fire retardants, sanded on the bottom and mineral granules on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
ELASTOPHENE ULTRA-STICK FR GR <i>Manufacturing location #1</i>	39" x 33' (1.5 sq.)	ASTM D6163, Type I, Granule	Self-adhered, fiberglass reinforced membrane with a release film on the bottom and mineral granules on the top.

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
ELASTOPHENE HS Sanded <i>Manufacturing location #2</i>	39" x 66' (2 sq.)	ASTM D6163, Type III, Smooth	Fiberglass reinforced modified bitumen membrane with fire retardants and sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
SOPRAPHIX Base 611 <i>Manufacturing location # 2</i>	39" x 33' (1.5 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a film surface. Applied by mechanical attachment.
SOPRAPHIX Base 612 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
SOPRAPHIX Base 613 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
SOPRAPHIX Base 614 <i>Manufacturing location #2</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Smooth	Non-woven polyester reinforced modified bitumen membrane. Applied by mechanical attachment.
SOPRAPHIX Base 622 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a 4-inch or 5-inch wide side lap with a plastic burn-off film on the bottom and sanded on the top. Applied by mechanical attachment. Lap heat welded or sealed with an approved cold adhesive.
SOPRAPHIX Base 641 <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a 5-inch wide side lap with a self-adhering compound and release film and sanded on the bottom and top surfaces. Applied by mechanical attachment. Lap self-adhered or sealed with approved cold adhesive.
SOPRALENE 180 PS 2.2 <i>Manufacturing location #1, 2</i>	39" x 49' (1.5 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a sanded bottom and a plastic burn-off film on the top. Applied in hot asphalt, cold adhesive or ribbon stripping.
SOPRALENE 180 PS 3.0 <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the top and sanded on the bottom.
SOPRALENE 180 Sanded <i>Manufacturing location #1</i>	39" x 33' (1 sq.) 39" x 26' (¾ sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt, cold adhesive or ribbon stripping.
SOPRALENE 180 Sanded 2.2 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane sanded on both sides. Applied in hot asphalt or cold adhesive.
SOPRALENE 180 SP 3.0 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top.

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
SOPRALENE 180 SP 3.5 <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE Flam 180 <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE Flam Stick <i>Manufacturing location #1, 2</i>	39" x 49' (1.5 sq.)	ASTM D6164, Type I, Smooth	Self-adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.
SOPRALENE Stick <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Smooth	Self-adhered, polyester reinforced membrane with a release film on the bottom and a sanded top.
SOPRALENE ULTRA-STICK FR GR <i>Manufacturing location #1</i>	39" x 49' (1.5 sq.)	ASTM D6164, Type I, Smooth	SBS-modified bitumen, self-adhered base sheet with fire retardants
SOPRALENE 250 SP <i>Manufacturing location #2</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Smooth	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and sanded on the top.
SOPRALENE Flam 250 <i>Manufacturing location #2</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Smooth	Non-woven polyester reinforced SBS modified bitumen membrane, both sides covered with a plastic burn-off film. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE 180 FR GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE 180 FR+ GR <i>Manufacturing location #2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE Flam 180 FR GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE Flam 180 FR+ GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
SOPRALENE Flam 180 GR <i>Manufacturing location #1, 2</i>	39" x 33' (1 sq.)	ASTM D6164, Type I, Granule	Non-woven polyester reinforced modified bitumen membrane with a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE 250 FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE 250 FR+ GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a sanded bottom and a mineral granules top. Applied in hot asphalt, cold applied adhesive or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE Flam 250 FR GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
SOPRALENE Flam 250 FR+ GR <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants a plastic burn-off film on the bottom and mineral granules on the top. Applied by heat welding or ribbon stripping (after removal of plastic burn-off film).
UNILAY <i>Manufacturing location #1</i>	39" x 33' (1 sq.)	ASTM D6164, Type II, Granule	Non-woven polyester reinforced modified bitumen membrane with fire retardants and surfaced with mineral granules. Applied by mechanical attachment, heat welding or ribbon stripping (after removal of plastic burn-off film).
SOPRALAST 50 TV Alu <i>Manufacturing location #1</i>	various	ASTM D6298	Fiberglass reinforced modified bitumen sheeting faced with aluminum foil. Applied by heat welding of ribbon stripping (after removal of plastic burn-off film).
SOPRALAST 50 TV Alu Sanded <i>Manufacturing location #1</i>	various	ASTM D6298	Fiberglass reinforced modified bitumen sheeting sanded on the bottom and faced with aluminum foil. Applied in hot asphalt, cold adhesive or ribbon stripping.

MODIFIED BITUMEN ROOFING ACCESSORIES

<u>Product</u>	<u>Dimensions</u>	<u>Test Specifications</u>	<u>Product Description</u>
M-Smart Sanded 180 Jumbo M4 <i>Manufacturing location #4</i>	Various	ASTM D6164	A semi rigid, asphaltic board with a modified bitumen base ply
M-XPRESS Sanded 180 Jumbo <i>Manufacturing location #4</i>	Various	ASTM D6164	A semi rigid, asphaltic board with a modified bitumen base ply
M-Smart Flam 180 Jumbo M4 <i>Manufacturing location #4</i>	Various	ASTM D6164	A semi rigid, asphaltic board with a modified bitumen base ply
M-Smart Board FL 180 Jumbo M4 <i>Manufacturing location #4</i>	Various	ASTM D6164	A semi rigid, asphaltic board with a modified bitumen base ply
M-XPRESS Flam 180 Jumbo <i>Manufacturing location #4</i>	Various	ASTM D6164	A semi rigid, asphaltic board with a modified bitumen base ply

MANUFACTURING LOCATION:

1. Wadsworth, OH
2. Gulfport, MS
3. Tuscaloosa, AL
4. Drummondville, CA



EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
NEMO ETC LLC	SOP-040-02-01	ASTM D2178	02/27/12
	SOP-041-02-01	ASTM D2178	02/27/12
	S35860.05.12-1-R2	ASTM D6163	05/04/12
	S35860.05.12-2-R3	ASTM D6164	05/08/12
	S35860.05.12-3-R1	ASTM D6164	05/08/12
	S39970.07.12-1B-R1	ASTM D6163	07/12/12
	S39970.07.12-2	ASTM D6164	07/12/12
	S35860.09.12-R2	ASTM D6163	09/20/12
	M45560.10.13-1-R2	ASTM D4897	10/02/13
	S43400.08.14-7-R1	ASTM D6164	08/08/14
	S43400.08.14-4-R1	ASTM D6163	08/26/14
	S44110.09.14-3	ASTM D6163	08/26/14
	S43400.08.14-6	ASTM D6164	08/26/14
	S44110.08.14-5	ASTM D6164	08/29/14
	S44110.09.14-7C	ASTM D6164	09/02/14
	S43400.09.14-9	ASTM D6164	09/02/14
	S44220.09.14-1	ASTM D6162	09/08/14
	S43400.09.14-10	ASTM D6298	09/08/14
	S44110.01.15-4A-R3	ASTM D6164	01/12/15
	ENTL 001 02 01	ASTM D3019	08/31/16
	ENTL 002 02 01	ASTM D4586	11/30/16
	S43400.08.14-5-R1	ASTM D6163	05/03/17
	SOP-SC14550.02.18	ASTM D6164	02/13/18
	4-SOP-18-001.05.18-2	ASTM D6163	05/11/18
	4-SOP-18-001.05.18	ASTM D4601	05/18/18
	4q-SOP-19-SSMBB-01.B	ASTM D4601	03/11/19
	4q-SOP-19-SSMBB-01.A	ASTM D4601	03/11/19
	4q-SOP-19-SSMBB-01.C	ASTM D4601	03/11/19
	4p-SOP-19-SSLAP-01.A	ASTM D4586	07/29/19
	4q-SOP-20-SSMBB-03.A	ASTM D6164	12/01/21
	4q-SOP-21-SSMBB-01.A	ASTM D6163	05/04/21
	4q-SOP-21-SSMBB-02.A	ASTM D6162	11/11/21
	4q-SOP-20-SSMBB-03.B	ASTM D4601	12/01/21
	4q-SOP-20-SSMBB-03.C	ASTM D4601	12/01/21
	4q-SOP-21-SSMBB-04.A	ASTM D6163	02/08/22
	4q-SOP-21-SSMBB-04.B	ASTM D6164	04/08/22
PRI Construction Materials Technologies LLC	MSA-006-02-01	ASTM D4897	6/17/2015
	MSA-039-02-01	ASTM D2178	09/27/2017
	EVST-003-02-01	ASTM D6083	7/12/2019
UL LLC	R11436	UL 790	06/09/22

LABELING:

All membranes and accessories or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city and state of manufacturing facility, and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. SOPREMA BUR, Modified Bitumen Roofing Membranes and Accessories are designed for use as specified within approved roofing system NOA assemblies.
3. This acceptance establishes the required physical properties testing and traceability of roofing membrane and accessory components listed in approved roofing applications. Minimum deck requirements shall be in compliance with applicable building code. SOPREMA BUR, Modified Bitumen Roofing Membranes and Accessories shall be installed in strict compliance with applicable Building Codes, Product Approvals and Manufacturers' specifications and guidelines.
4. Change in materials or manufacturing process or location of any of the products listed herein shall be cause for termination of this Notice of Acceptance.
5. SOPREMA BUR, Modified Bitumen Roofing Membranes and Accessories may be used with any approved Roof Assembly Notice of Acceptance listing SOPREMA BUR, Modified Bitumen Roofing Membranes and Accessories as a component part of an assembly in the Notice of Acceptance. If SOPREMA BUR, Modified Bitumen Roofing Membranes and Accessories are not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
6. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE

