

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599 www.miamidade.gov/economy

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

Aire Technologies, Inc. 1502 Industrial Drive Monongahela, PA 15063

Scope:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER-Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code. This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Model DC-AGV Aluminum Gravity Ventilator

APPROVAL DOCUMENT: Drawing No. **08-00719** Rev C, titled "DC-AGV Aluminum Gravity Ventilator", sheets 1 through 11 of 11, dated 04/03/2009 and last revised on 04/26/21, prepared by the manufacturer, signed and sealed by Luis R. Lomas, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official. This NOA revises NOA # 19-0213.06 and consists of this page 1 and evidence pages E-1, E-2 and E-3, as well as approval document mentioned above.

The submitted documentation was reviewed by Ishaq I. Chanda, P.E.





NOA No. 21-0510.10 Expiration Date: October 7, 2024 Approval Date: June 17, 2021 Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

- 1. Evidence submitted under previous NOA's
- A. DRAWINGS "Submitted under NOA # 09-0610.11"
 - 1. Drawing No. **08-00719**, titled "DC-AGV Aluminum Gravity Ventilator", Sheets 1 through 10 of 10, dated 04/03/2009, with revision A dated 08/19/2009, prepared by the manufacturer, signed and sealed by Luis R. Lomas, P.E.
- B. TESTS "Submitted under NOA # 09-0610.11"
 - 1. Test report on 1) Uniform Static Air Pressure Test per FBC, TAS 202-94
 - 2) Large Missile Impact Test per FBC, TAS 201-94,
 - 3) Cyclic Wind Pressure Test per FBC, TAS 203-94,

along with marked-up drawings and installation diagram of Model DC-AGV Aluminum Gravity Ventilator, prepared by National Certified Testing Laboratories, Test Report No. **210-3583-1**, dated 02/18/2009, signed and sealed by Gerard J. Ferrara, P.E.

- C. CALCULATIONS "Submitted under NOA # 09-0610.11"
 - 1. Anchor verification calculations, dated 06/12/2009, prepared, signed and sealed by Luis R. Lomas, P.E.
- D. QUALITY ASSURANCE
 - 1. Miami-Dade Department of Regulatory and Economic Resources (RER)
- E. MATERIAL CERTIFICATIONS
 - 1. None.
- F. STATEMENTS "Submitted under NOA # 12-0208.08"
 - 1. Statement letter of code conformance to 2010 FBC and no financial interest, issued by L. Roberto Lomas, dated 01/24/2012, signed and sealed by Luis R. Lomas, P.E.

Ishaq I. Chanda, P.E. Product Control Unit Supervisor

NOA No. 21-0510.10

Expiration Date: October 7, 2024 Approval Date: June 17, 2021

NOTICE OF ACCEPTANCE: **EVIDENCE SUBMITTED**

Evidence submitted under NOA # 18-0828.02 2.

DRAWINGS A.

1. Drawing No. 08-00719, titled "DC-AGV Aluminum Gravity Ventilator", sheets 1 through 11 of 11, dated 04/03/2009, with revision B dated 08/01/2018, prepared by the manufacturer, signed and sealed by Luis R. Lomas, P.E.

TESTS В.

1. None.

C. CALCULATIONS"

Anchor verification calculations dated 08/01/2018, prepared, signed and sealed by Luis R. Lomas, P.E.

D. **QUALITY ASSURANCE**

Miami-Dade Department of Regulatory and Economic Resources (RER) 1.

MATERIAL CERTIFICATIONS E.

1. None.

F. **STATEMENTS**

- Statement letter of code conformance to the 6th edition (2017) FBC and of no financial 1. interest, dated 08/01/2018, issued, signed and sealed by Luis R. Lomas, P.E.
- 2. Bill of sales dated 07/13/2018.

Ishaq I. Chanda, P.E.

Product Control Examiner NOA No. 21-0510.10

Expiration Date: October 7, 2024 Approval Date: June 17, 2021

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

3. New Evidence submitted

A. DRAWINGS

1. Drawing No. **08-00719 Rev** C, titled "DC-AGV Aluminum Gravity Ventilator", sheets 1 through 11 of 11, dated 04/03/2009 and last revised on 04/26/21, prepared by the manufacturer, signed and sealed by Luis R. Lomas, P.E.

B. TESTS

1. None.

C. CALCULATIONS"

1. Anchor verification calculations dated 04/27/2021, prepared, signed and sealed by Luis R. Lomas, P.E.

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER)

E. MATERIAL CERTIFICATIONS

1. None.

F. STATEMENTS

1. Statement letter of code conformance to the 7th edition (2020) FBC, dated 04/26/2021, issued, signed and sealed by Luis R. Lomas, P.E.

G. OTHER

1. This NOA revises NOA # 19-0213.06, expiring 10/07/2024.

Shangl. Charada

Ishaq I. Chanda, P.E.
Product Control Examiner
NOA No. 21-0510.10

Expiration Date: October 7, 2024 Approval Date: June 17, 2021

websti.	REVISIONS				
	REV	DESCRIPTION	DATE	APPROVED	
	С	UPDATED PER NEW CODE	04/26/2021	R.L.	

NOTES:

- 1) THE PRODUCT SHOWN HEREIN IS DESIGNED AND MANUFACTURED TO COMPLY WITH REQUIREMENTS OF THE FLORIDA BUILDING CODE 7TH EDITION (2020). INCLUDING THE HVHZ.
- 2) WOOD FRAMING, CONCRETE AND STEEL FRAMING OPENING TO BE DESIGNED AND ANCHORED TO PROPERLY TRANSFER ALL LOADS TO STRUCTURE. WOOD FRAMING, CONCRETE AND STEEL FRAMING OPENING IS THE RESPONSIBILITY OF THE ARCHITECT OR ENGINEER OF RECORD.
- 3) ALLOWABLE STRESS INCREASE OF 1/3 WAS NOT USED IN THE DESIGN OF THE PRODUCT SHOWN HEREIN. WIND LOAD DURATION FACTOR Cd=1.6 WAS USED FOR WOOD ANCHOR CALCULATIONS.
- 4) CURB MATERIAL: FORMED 14GA, GALVANIZED STEEL
- 5) ROOF SKIN MATERIAL: FORMED 3003 ALUMINUM SHEET .080" THICK.
- APPROVED IMPACT PROTECTIVE SYSTEM IS NOT REQUIRED FOR THIS PRODUCT IN WIND BORNE DEBRIS REGIONS.
- 7) INSTALLATION ANCHORS SHALL BE INSTALLED IN ACCORDANCE WITH ANCHOR MANUFACTURER'S INSTALLATION INSTRUCTIONS, AND ANCHORS SHALL NOT BE USED IN SUBSTRATES WITH STRENGTHS LESS THAN THE MINIMUM STRENGTH SPECIFIED BELOW:
 - A. WOOD MINIMUM SPECIFIC GRAVITY OF G=0.46
 - B. CONCRETE MINIMUM COMPRESSIVE STRENGTH OF 3,200 PSI.
 - C. STEEL 16GA. MINIMUM (WELDING INSTALLATION).
 - D. STEEL .1875" MINIMUM (SELF-TAPPING SCREW INSTALLATION).
- 8) ALL DC AGV, ALUMINUM GRAVITY VENTILATORS MAY BE FITTED WITH AN OPTIONAL EAD DAMPER. DAMPER IS MOUNTED INSIDE OF CURB. SEE SHEET 8 FOR OPTIONAL EAD DAMPER MOUNTING DETAILS. MAXIMUM SINGLE EAD DAMPER SIZE IS 34 3/4" x 56".
- 9) VENTILATOR HAS NOT BEEN TESTED FOR WIND DRIVEN RAIN RESISTANCE PER FBC, TAS 100(A).
- 10) 36" x 36" VENTILATOR HOOD WEIGHT = 66lbs. 48" x 48" VENTILATOR HOOD WEIGHT = 1091bs. $96" \times 144"$ VENTILATOR HOOD WEIGHT = 650lbs.

ANCHORING NOTES:

PRODUCT REVISED as complying with the Florida

Acceptance No 21-0516-10

Expiration Date OCT 7, 202

& Blows Charles

Mark Bolk Fodor Costrol

Isuading Code

- 1) SHIM AS REQUIRED AT EACH INSTALLATION ANCHOR WITH LOAD BEARING SHIM. SHIM WHERE SPACE OF 1/16" OR GREATER OCCURS. MAXIMUM ALLOWABLE SHIM STACK TO BE 1/4".
- 2) FOR ANCHORING INTO CONCRETE USE 3/8" HILTI KWIK BOLT 3 ANCHOR WITH SUFFICIENT LENGTH TO ACHIEVE A 2 1/2" MINIMUM EMBEDMENT INTO SUBSTRATE WITH 4" MINIMUM EDGE DISTANCE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION
- 3) FOR ANCHORING INTO WOOD FRAMING OR 2X BUCK USE 3/8"LAG SCREW SCREW WITH SUFFICIENT LENGTH TO ACHIEVE A 1 7/8" MINIMUM EMBEDMENT INTO SUBSTRATE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS.
- 4) FOR ANCHORING INTO STEEL FRAMING USE 3/8" DIAMETER SELF-TAPPING SCREW WITH SUFFICIENT LENGTH TO ACHIEVE 3-THREAD PITCH MINIMUM BEYOND THE SUBSTRATE. LOCATE ANCHORS AS SHOWN IN ELEVATIONS AND INSTALLATION DETAILS
- 5) FOR ANCHORING INTO STEEL FRAMING USE 1/8" x 1 1/2" FILLET WELDS. LOCATE WELDS AS SHOWN IN ELEVATIONS AND INSTALLATION
- 6) ALL FASTENERS TO BE CORROSION RESISTANT.
- 7) UNITS SMALLER THAN 48"x48" TO BE INSTALLED USING ANCHORING LAYOUT FOR 36"x36" UNIT.
- 8) UNITS SMALLER THAN 96"x144" TO BE INSTALLED USING ANCHORING LAYOUT FOR 48"x48" UNIT.

SIGNED: 04/26/2021

	TABLE OF CONTENTS
SHEET NO	. DESCRIPTION
1	NOTES
2 - 3	ELEVATIONS
4	ANCHORING LAYOUTS
5 - 9	INSTALLATION DETAILS
10 - 11	COMPONENTS

AIRE TECHNOLOGIES, INC. 1502 INDUSTRIAL DRIVE E. MONONGAHELA, PA 15603

DC-AGV ALUMINUM GRAVITY VENTILATOR 48" X 48" AND 96" X 144" NOTES

DRAWN: DWG NO. С 08-00719 TJH SHEET 1 OF 11 SCALE NTS 04/03/09

L. ROBERTO LOMAS P.E. 1432 WOODFORD RD LEWISVILLE, NC 27023 434-688-0609 rllomas@lrlomaspe.com

Mr Lpm STATE OF SONAL ENTIN ALORIDA. Luis R. Lomas P.E. FL No.: 62514



















