



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

System Components Corporation
P.O. Box 2432
Issaquah, WA 98027

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™
High Performance Roof Wraps.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 16-1212.10 and consists of pages 1 through 4.
The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 21-0602.12
Expiration Date: 03/01/27
Approval Date: 02/10/22
Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

SCOPE:

This acceptance is for **FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps**, as described in this Notice of Acceptance, for use with approved prepared roof assemblies where ASTM D226 Type II underlayment is specified and installed with prescribed approved fasteners and fastener densities. Designed to comply with the Florida Building Code and the High Velocity Hurricane Zone of the Florida Building Code.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
FelTex® (Style RX2) <i>Manufacturing Location M-2</i>	48" x 250' rolls 30 lbs. Weight per Roll 10 sq. Coverage per Roll	ASTM D 226 Type II	Synthetic Polymer base sheet with UV stable low-slip backing.
CoverPRO® 1000 <i>Manufacturing Location M-2</i>	40" x 300' rolls 60" x 200' rolls 17.4 lbs. Weight per Roll 10 sq. Coverage per Roll	ASTM D 226 Type II	Synthetic Polymer base sheet with UV stable low-slip backing.
CoverPRO® 2000 <i>Manufacturing Location M-2</i>	40" x 300' rolls 60" x 200' rolls 20.2 lbs. Weight per Roll 10 sq. Coverage per Roll	ASTM D 226 Type II	Synthetic Polymer base sheet with UV stable low-slip backing.
CoverPRO® 3000 <i>Manufacturing Location M-2</i>	40" x 300' rolls 25.6 lbs. Weight per Roll 10 sq. Coverage per Roll	ASTM D 226 Type II	Synthetic Polymer base sheet with UV stable low-slip backing.
Quicksilver™ <i>Manufacturing Location M-3</i>	40" x 300' rolls 35 lbs. Weight per Roll 10 sq. Coverage per Roll	ASTM D 226 Type II	Synthetic Polymer base sheet with UV stable low-slip backing.

MANUFACTURING LOCATION:

1. M-2
2. M-3



NOA No.: 21-0602.12
Expiration Date: 03/01/27
Approval Date: 02/10/22
Page 2 of 4

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Name/Report</u>	<u>Date</u>
QAI Laboratories	RJ3157-P-8B	ASTM D 226	05/27/14
	RJ5049P-4	ASTM D 226	11/11/16
	RJ3157-P-9-2-R1	ASTM D 226	12/13/16
	RJ8090P-1	ASTM D 226	05/13/21

INSTALLATION:

1. FelTex[®] (Style RX2), CoverPRO[®]1000, CoverPRO[®]2000, CoverPRO[®] 3000 and Quicksilver[™] High Performance Roof Wraps shall be installed in strict compliance with applicable Building Code.
2. FelTex[®] (Style RX2), CoverPRO[®]1000, CoverPRO[®]2000, CoverPRO[®] 3000 and Quicksilver[™] High Performance Roof Wraps shall be applied to a smooth, clean and dry roof deck. The roof shall be free of irregularities.
3. FelTex[®] (Style RX2), CoverPRO[®]1000, CoverPRO[®]2000, CoverPRO[®] 3000 and Quicksilver[™] High Performance Roof Wraps shall be installed with a minimum 4-inch head lap in a shingle fashion.
4. FelTex[®] (Style RX2), CoverPRO[®]1000, CoverPRO[®]2000, CoverPRO[®] 3000 and Quicksilver[™] High Performance Roof Wraps shall be fastened with corrosion resistant tin-caps and approved roofing nails spaced 6 inches o.c. maximum at all laps and in the field of the roll fastened at 12 inches o.c. maximum in staggered rows in a grid pattern (vertically and horizontally). Nails shall be driven flush and 90 degrees to the roof deck.
5. FelTex[®] (Style RX2), CoverPRO[®]1000, CoverPRO[®]2000, CoverPRO[®] 3000 and Quicksilver[™] High Performance Roof Wraps shall be fastened with some looseness, notably in valley applications.

LABELING:

All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.



NOA No.: 21-0602.12
Expiration Date: 03/01/27
Approval Date: 02/10/22
Page 3 of 4

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps shall not be hot mopped; refer to manufacturer's published literature for product compatibility.
4. FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps is a component used in roof assemblies. Roof assemblies are approved under specific assembly Notice of Acceptance.
5. FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps shall not be left exposed as a temporary roof for longer than 30 days of application.
6. FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps may be used with Asphalt shingles, Wood shakes and shingles, Non-structural metal roofing, and quarry slate. FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps shall not be used as an underlayment within a roof tile assembly.
7. FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps may be used with any approved roof covering Notice of Acceptance listing FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps as a component part of an assembly in the Notice of Acceptance. If FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps is not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
8. For fire classification of specific roof assemblies using FelTex® (Style RX2), CoverPRO®1000, CoverPRO®2000, CoverPRO® 3000 and Quicksilver™ High Performance Roof Wraps refer to a current Approved Roofing Materials Directory for fire ratings of this product.
9. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 21-0602.12
Expiration Date: 03/01/27
Approval Date: 02/10/22
Page 4 of 4