



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

**MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION**

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 31525-99

www.miamidade.gov/economy

PrimeSource Building Products, Inc.
333 Manley Street
West Bridgewater, MA 02379

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: PrimeSource Grip-Rite ShingleLayment® Underlayments

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #19-1218.03 and consists of pages 1 through 4.
The submitted documentation was reviewed by Alex Tigera.



NOA No.: 21-1018.05
Expiration Date: 08/26/24
Approval Date: 02/10/22
Page 1 of 5

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Underlayment
Material: Polypropylene

SCOPE:

This acceptance is for PrimeSource Grip-Rite ShingleLayment® Underlayments as described in this Notice of Acceptance, for use with approved prepared roof assemblies where ASTM D226 Type II underlayment is specified and installed with prescribed approved fasteners and fastener densities.

PRODUCT DESCRIPTION:

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Grip-Rite ShingleLayment® 15-Pro (Manufacturing Locations #1,#2)	4' x 250' rolls	ASTM D226 Type I & II	Synthetic roofing underlayment comprised of a woven substrate of 8x8 scrim polypropylene, with the bottom surface coated with polypropylene and the top surface coated with a non-woven spun bonded polypropylene.
Grip-Rite ShingleLayment® 15-LWE (Manufacturing Locations #1,#2)	4' x 250' rolls	ASTM D226 Type I & II	Synthetic roofing underlayment comprised of a woven substrate of 8x8 scrim polypropylene, with the bottom surface coated with polypropylene and the top surface coated with a non-woven spun bonded polypropylene.
Grip-Rite ShingleLayment® 15-GRE (Manufacturing Locations #1,#2)	4' x 250' rolls	ASTM D226 Type I & II	Synthetic roofing underlayment comprised of a woven substrate of 8x8 scrim polypropylene, with the bottom surface coated with polypropylene and the top surface coated with a non-woven spun bonded polypropylene.
Grip-Rite ShingleLayment® Premium (4-layer) (Manufacturing Locations #1,#2)	4' x 250' rolls	ASTM D226 Type I & II	Synthetic roofing underlayment comprised of a woven substrate of 10x10 scrim polypropylene, with the bottom surface coated with polypropylene and the top surface coated with a non-woven spun bonded polypropylene.
Grip-Rite ShingleLayment® HT (Manufacturing Locations #3)	3' x 67' rolls	ASTM D1970	Self-adhering, synthetic roof underlayment

MANUFACTURING LOCATION:

1. Lixiang City, China
2. Klang, Malaysia
3. Chengyang, China



NOA No.: 21-1018.05
Expiration Date: 08/26/24
Approval Date: 02/10/22
Page 2 of 5

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Description</u>	<u>Date</u>
NEMO ETC, LLC..	4j-PSBP-19-SSUDL-01.A	ASTM D226	05/01/2019
	4j-PSBP-19-SSUDL-04.A	ASTM D226	12/16/2019
	4J-PSBP-20-SSUDL-03.A	ASTM D1970	05/04/2021

INSTALLATION SPECIFICATIONS:

Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer)

1. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer) shall be installed in strict compliance with applicable Building Code.
2. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer) shall be installed with a minimum 4-inch horizontal lap and 6-inch vertical laps in a shingle layer fashion.
3. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer) shall be attached with PrimeSource Tin Caps-1-5/8" Stress Plates or equivalent fasteners at 5" o.c. at the laps and three staggered rows 12" o.c. vertically and 12" o.c. horizontally in the field of the roll.
4. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer) is a component used in roof assemblies. Roof assemblies are approved under specific assembly Noticed of Acceptance.
5. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer) may be used with Asphaltic shingles, Wood shakes and shingles, Non-structural metal roofing, and quarry slate. Grip-Rite ShingleLayment® Synthetic Roofing Underlayment shall not be used as roof tile underlayment.
6. For fire classification of specific roof assemblies using Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer) refer to a current Approved Roofing Materials Directory for fire ratings of this product.
7. Use caution and safety guidlines when walking on roofs and installing these products. Follow OSHA fall protection guidelines and manufactures precautions.

Grip-Rite ShingleLayment® HT

1. Grip-Rite ShingleLayment® HT shall be installed in strict compliance with applicable Building Code.
2. Grip-Rite ShingleLayment® HT shall be installed with a minimum 3-inch horizontal lap and 6-inch vertical laps.
3. One or more plies of ASTM D 226 Type II or ASTM D 2626 with a minimum 4" side lap and a 6" end lap mechanically fastened to deck with approved nails and tin caps 6" o.c. at the laps and two staggered rows 12" o.c. the field of the roll
4. Grip-Rite ShingleLayment® HT is a component used in roof assemblies. Roof assemblies are approved under specific assembly Noticed of Acceptance.
5. Grip-Rite ShingleLayment® HT may be used with Mechanically Fastened Metal Roofing, Wood Shake & Shingles, Asphalt Shingles, Slate, Simulated Slate.
6. For fire classification of specific roof assemblies using Grip-Rite ShingleLayment® HT refer to a current Approved Roofing Materials Directory for fire ratings of this product.
7. Use caution and safety guidelines when walking on roofs and installing these products. Follow OSHA fall protection guidelines and manufactures precautions.

BUILDING PERMIT REQUIREMENTS:

Application for building permit shall be accompanied by copies of the following:

1. This Notice of Acceptance.
2. Any other documents required by the Building Official or applicable building code in order to properly evaluate the installation of this material.

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. This acceptance is for prepared roofing applications. Minimum deck requirements shall be in compliance with applicable building code.
3. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE, Grip-Rite ShingleLayment® HT and Grip-Rite ShingleLayment® Premium (4-layer) shall be applied to a smooth, clean and dry surface with deck free of irregularities. All nails in the deck shall be carefully checked for protruding heads. Re-fasten any loose decking panels. Sweep the deck thoroughly to remove any dust and debris prior to application.
4. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE, Grip-Rite ShingleLayment® HT and Grip-Rite ShingleLayment® Premium (4-layer) shall not be hot mopped, refer to manufacturer's published literature for product compatibility.
5. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE, Grip-Rite ShingleLayment® HT and Grip-Rite ShingleLayment® Premium (4-layer) shall not be applied over an existing roof membrane as a recover system.
6. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE and Grip-Rite ShingleLayment® Premium (4-layer) shall not be left exposed as a temporary roof for longer than 30 days of application. Grip-Rite ShingleLayment® HT shall not be left exposed as a temporary roof for longer than 180 days of application.

7. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE, Grip-Rite ShingleLayment® HT and Grip-Rite ShingleLayment® Premium (4-layer) is a component used in roof system assemblies. Roof system assemblies are approved under a specific Notice of Acceptance. Refer to Prepared Roofing system Product Control Notice of Acceptance for listed approval of this product with specific prepared roofing products.
8. Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE, Grip-Rite ShingleLayment® HT and Grip-Rite ShingleLayment® Premium (4-layer) may be used with any approved roof covering Notice of Acceptance listing Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE, Grip-Rite ShingleLayment® HT and Grip-Rite ShingleLayment® Premium (4-layer) as a component part of an assembly in the Notice of Acceptance. If Grip-Rite ShingleLayment® 15-Pro, Grip-Rite ShingleLayment® 15-LWE, Grip-Rite ShingleLayment® 15-GRE, Grip-Rite ShingleLayment® HT and Grip-Rite ShingleLayment® Premium (4-layer) is not listed; a request may be made to the Authority Having Jurisdiction (AHJ) or the Miami-Dade County Product Control Department for approval provided that appropriate documentation is provided to detail compatibility of the products, wind uplift resistance, and fire testing results.
9. All membranes or packaging shall bear the imprint or identifiable marking of the manufacturer's name or logo and the following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



END OF THIS ACCEPTANCE



NOA No.: 21-1018.05
Expiration Date: 08/26/24
Approval Date: 02/10/22
Page 5 of 5