



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

Danosa Caribbean, Inc.
P.O. Box 13757
San Juan, PR 00908

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Danosa Modified Roofing Systems Over Concrete Decks.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city and state of manufacturing facility, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 21-0128.04 and consists of pages 1 through 8.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-0224.02
Expiration Date: 04/29/27
Approval Date: 07/14/22
Page 1 of 8

ROOFING SYSTEM APPROVAL

Category: Roofing
Sub-Category: Modified Bitumen
Materials: SBS
Deck Type: Concrete
Maximum Design Pressure: -420 psf.

TRADE NAMES OF PRODUCTS MANUFACTURED OR LABELED BY APPLICANT:

TABLE 1

<u>Product</u>	<u>Dimensions</u>	<u>Test Specification</u>	<u>Product Description</u>
Esterdan RM-4	33.5' x 39"	ASTM D6164	A polyester reinforced modified bitumen membrane with a granule surfacing used as a cap sheet in a two-ply system.
Glasdan R-36	33.5' x 39"	ASTM D6163	A fiberglass reinforced modified bitumen membrane with a smooth surfacing used as a base sheet in a two-ply system.
Esterdan R-36	33.5' x 39"	ASTM D6164	A polyester reinforced modified bitumen membrane with a smooth surfacing used as a base sheet in a two-ply system.
Glasdan AL-80 White	33.5' x 39.375"	ASTM D6298	A fiberglass reinforced modified bitumen membrane with a white reflective foil surfacing used as single ply membrane.
Glasdan AL-80	33.5' x 39.375"	ASTM D6298	A fiberglass reinforced modified bitumen membrane with a reflective foil surfacing used as single ply membrane.
Esterdan RM-Plus	26.25' x 39.375"	ASTM D6164	A polyester reinforced modified bitumen membrane with a granule surfacing used as a single ply.
Esterdan RM-5	33.5' x 39.375"	ASTM D6164	A polyester reinforced modified bitumen membrane with a granule surfacing used as a single ply or as a cap sheet in a two-ply system.
WR Smooth Polyester	33.5' x 39.375"	ASTM D6164	A polyester reinforced modified bitumen membrane with a white reflective film surfacing used as cap ply in a two-ply system.
Glasdan RM-5	33.5' x 39"	ASTM D6163	A fiberglass reinforced modified bitumen membrane with a granule surfacing used as a single ply or as a cap sheet in a two-ply system.
Glasdan RM-4 SC	33.5' x 39"	ASTM D6163	A fiberglass reinforced modified bitumen membrane with a granule surfacing used as a cap sheet in a two-ply system.

APPROVED INSULATIONS:

TABLE 2		
Product Name	Product Description	Manufacturer (With Current NOA)
ACFoam II	Polyisocyanurate foam insulation	Atlas Roofing Corporation
ACFoam III	Polyisocyanurate foam insulation	Atlas Roofing Corporation
Multi-Max FA-3	Polyisocyanurate foam insulation	RMax A business Unit of Sika Corporation
DensDeck Prime	Gypsum insulation board	Georgia-Pacific Gypsum LLC
SECUROCK Gypsum-Fiber Roof Board	Fiber reinforced coverboard	United States Gypsum Corporation

APPROVED FASTENERS/ADHESIVES:

TABLE 3				
Fastener Number	Product Name	Product Description	Dimensions	Manufacturer (With Current NOA)
1.	Karnak #81 AF Modified Bitumen Adhesive	Modified bitumen adhesive	5 gal. pail	Karnak Corporation
2.	OlyBond 500 Adhesive	Insulation Adhesive	Various	OMG
3.	Polyset CR-20	Insulation Adhesive	Various	ICP Adhesives and Sealants, Inc.
4.	Insta-Stik Quik Set Insulation Adhesive	Insulation Adhesive	Various	DuPont de Nemours, Inc.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Name/Report</u>	<u>Report No.</u>	<u>Date</u>
FM Approvals	4470	3018690	04/07/06
	4470	3023353	02/25/05
	4470	3057420	12/15/16
UL LLC	UL790	TGFU.R9069	03/06/20
Momentum Technologies Laboratories	ASTM D6164	DX16C0A-3	04/08/21
	ASTM D6163	DX16C0B	07/07/21
	ASTM D6164	DX16C0A-1	04/08/21
	ASTM D6298	DX27B0A-1	02/22/21
	ASTM D6298	DX27B0A	02/22/21
	ASTM D6164	DX16C0A-2	04/08/21
	ASTM D6163	DX16C0B-1	07/30/21

APPROVED ASSEMBLIES:

Membrane Type:	SBS
Deck Type 3I:	Concrete Decks, Insulated
Deck Description:	2500 psi structural concrete or concrete plank
System Type A(1):	One or more layers of insulation adhered with approved torched roof membranes.

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, AC Foam III, Multi-Max FA-3 Minimum 1.5" thick	N/A	N/A

Note: Base layer of insulation shall be adhered with ribbons 0.75"-1.0" wide of OlyBond 500 Adhesive spaced 12" apart or Insta-Stik Quik Set or 2.5" wide ribbons of Polyset CR-20 spaced 12" apart. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with ribbons 0.75"-1.0" wide of OlyBond 500 Adhesive or Insta-Stik Quik Set spaced 12" apart or ribbons 2.5" wide of Polyset CR-20 spaced 12" apart. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet:	(OPTIONAL with Glasdan AL-80, Glasdan AL-80 White, WR Smooth, Esterdan RM-Plus, Esterdan RM-5 and Glasdan RM-5 membranes): Glasdan R-36 or Esterdan R-36 torched applied with 3" wide side laps.
Ply Sheet:	None.
Membrane:	Esterdan RM-4, Glasdan RM-4 SC, Esterdan RM-Plus, Esterdan RM-5, Glasdan AL-80, Glasdan AL-80 White, WR Smooth or Glasdan RM-5 torch applied with 3" wide side laps.
Maximum Design Pressure:	-120.0 psf. (See General Limitation #9.)

Membrane Type: SBS

Deck Type 3I: Concrete Decks, Insulated

Deck Description: 2500 psi structural concrete or concrete plank

System Type A(2): One or more layers of insulation adhered with approved roof membranes fully adhered with hot asphalt.

All General and System Limitations apply.

One or more layers of the following insulations:

Base Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
ACFoam II, AC Foam III, Multi-Max FA-3 Minimum 1.5" thick	N/A	N/A

Note: Base layer of insulation shall be adhered with ribbons 0.75"-1.0" wide of OlyBond 500 Adhesive spaced 12" apart or Insta-Stik Quik Set or 2.5" wide ribbons of Polyset CR-20 spaced 12" apart. Please refer to Roofing Application Standard RAS 117 for insulation attachment. Insulation listed as Base Layer only shall be used only as base layers with a second layer of approved top layer insulation installed as the final membrane substrate.

Top Insulation Layer	Insulation Fasteners (Table 3)	Fastener Density/ft²
DensDeck Prime, SECUROCK Gypsum-Fiber Roof Board Minimum ¼" thick	N/A	N/A

Note: Top layer of insulation shall be adhered with ribbons 0.75"-1.0" wide of OlyBond 500 Adhesive or Insta-Stik Quik Set spaced 12" apart or ribbons 2.5" wide of Polyset CR-20 spaced 12" apart. Please refer to Roofing Application Standard RAS 117 for insulation attachment.

Base Sheet: (OPTIONAL with Esterdan RM-Plus, Esterdan RM-5 or Glasdan RM-5 membranes): Glasdan R-36 or Esterdan R-36 applied with hot asphalt at a rate of 20-25 lb./sq with 3" wide side laps.

Ply Sheet: None.

Membrane: Esterdan RM-4, Glasdan RM-4 SC, Esterdan RM-Plus, Esterdan RM-5 or Glasdan RM-5 applied with hot asphalt at a rate of 20-25 lb./sq with 3" wide side laps.

Maximum Design Pressure: -255.0 psf. (See General Limitation #9.)

Membrane Type: SBS
Deck Type 3I: Concrete Decks, Non-Insulated
Deck Description: 2500 psi structural concrete or concrete plank
System Type F(1): Base sheet adhered with approved adhesive.

All General and System Limitations shall apply.

Base Sheet: One ply of Glasdan R-36 fully adhered to the deck with Karnak #81 Modified Bitumen Adhesive squeegee applied at a rate of 1.5 gal./100 ft². with a minimum 3½” wide side lap.

Ply Sheet: None.

Membrane: One ply of Glasdan RM-4 SC fully adhered to the base sheet with Karnak #81 Modified Bitumen Adhesive squeegee applied at a rate of 1.5 gal./100 ft². with a minimum 3½” wide side lap.

Surfacing: None.

Maximum Design Pressure: -420.0 psf. (See General Limitation #9.)

Membrane Type: SBS

Deck Type 3I: Concrete Decks, Non-Insulated

Deck Description: 2500 psi structural concrete or concrete plank clean and primed with asphaltic primer.

System Type F(2): Base sheet and Membrane torch applied to deck.

All General and System Limitations shall apply.

Base Sheet: One ply of Glasdan R-36 torch applied as per manufacturer's specifications with a minimum 3" wide side lap to the deck.

Ply Sheet: None.

Membrane: One ply of Glasdan RM-4 SC, Glasdan RM-5, WR Smooth Polyester, Esterdan RM-Plus, Esterdan RM-4 or Esterdan RM-5 torch applied as per manufacturer's specifications with a minimum 3" wide side lap.

Surfacing: None.

Maximum Design Pressure: -352.5 psf. (See General Limitation #9.)

CONCRETE DECK SYSTEM LIMITATIONS:

1. If mechanical attachment to the structural deck through the lightweight insulating concrete is proposed, a field withdrawal resistance testing shall be performed to determine equivalent or enhanced fastener patterns and density. All testing and fastening design shall be in compliance with Testing Application Standard TAS 105 and Roofing Application Standard RAS 117; calculations shall be signed and sealed by a Florida Registered Engineer, Architect, or Registered Roof Consultant.

GENERAL LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire ratings of this product.
2. Insulation may be installed in multiple layers. The first layer shall be attached in compliance with Product Control Approval guidelines. All other layers shall be adhered in a full mopping of approved asphalt applied within the EVT range and at a rate of 20-40 lbs./sq., or mechanically attached using the fastening pattern of the top layer
3. All standard panel sizes are acceptable for mechanical attachment. When applied in approved asphalt, panel size shall be 4' x 4' maximum.
4. An overlay and/or recovery board insulation panel is required on all applications over closed cell foam insulations when the base sheet is fully mopped. If no recovery board is used the base sheet shall be applied using spot mopping with approved asphalt, 12" diameter circles, 24" o.c.; or strip mopped 8" ribbons in three rows, one at each side lap and one down the center of the sheet allowing a continuous area of ventilation. Encircling of the strips is not acceptable. A 6" break shall be placed every 12' in each ribbon to allow cross ventilation. Asphalt application of either system shall be at a minimum rate of 12 lbs./sq.

Note: Spot attached systems shall be limited to a maximum design pressure of -45 psf.

5. Fastener spacing for insulation attachment is based on a Minimum Characteristic Force (F') value of 275 lbf., as tested in compliance with Testing Application Standard TAS 105. If the fastener value, as field-tested, are below 275 lbf. insulation attachment shall not be acceptable.
6. Fastener spacing for mechanical attachment of anchor/base sheet or membrane attachment is based on a minimum fastener resistance value in conjunction with the maximum design value listed within a specific system. Should the fastener resistance be less than that required, as determined by the Building Official, a revised fastener spacing, prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant may be submitted. Said revised fastener spacing shall utilize the withdrawal resistance value taken from Testing Application Standards TAS 105 and calculations in compliance with Roofing Application Standard RAS 117.
7. Perimeter and corner areas shall comply with the enhanced uplift pressure requirements of these areas. Fastener densities shall be increased for both insulation and base sheet as calculated in compliance with Roofing Application Standard RAS 117. Calculations prepared, signed and sealed by a Florida registered Professional Engineer, Registered Architect, or Registered Roof Consultant **(When this limitation is specifically referred within this NOA, General Limitation #9 will not be applicable.)**
8. All attachment and sizing of perimeter nailers, metal profile, and/or flashing termination designs shall conform to Roofing Application Standard RAS 111 and applicable wind load requirements.
9. The maximum designed pressure limitation listed shall be applicable to all roof pressure zones (i.e. field, perimeters, and corners). Neither rational analysis, nor extrapolation shall be permitted for enhanced fastening at enhanced pressure zones (i.e. perimeters, extended corners and corners). **(When this limitation is specifically referred within this NOA, General Limitation #7 will not be applicable.)**
- 10 All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 22-0224.02
Expiration Date: 04/29/27
Approval Date: 07/14/22
Page 8 of 8