

DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER) BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208 Miami, Florida 33175-2474 T (786) 315-2590 F (786) 315-2599

www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

Tremco CPG, Inc. 3735 Green Road Beachwood, OH 44212

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas, where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: Tremco AlphaGuard[™] MTS Maintenance Coating System

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA # 20-0218.06 and consists of pages 1 through 6.

The submitted documentation was reviewed by Alex Tigera.

NOA No.: 22-0228.09 Expiration Date: 12/09/26 Approval Date: 09/22/22

Page 1 of 6



ROOFING COMPONENT APPROVAL

<u>Category:</u> Roofing

Sub-Category: Cement-Adhesive-Coatings

Materials: Urethane

SCOPE:

This approves **Tremco AlphaGuard[™] MTS Maintenance Coating System,** as a maintenance roof coating as manufactured by Tremco CPG, Inc., as described in this Notice of Acceptance, designed to comply with the Florida Building Code, High Velocity Hurricane Zones.

PRODUCT DESCRIPTION

Manufactured by Applicant	Dimensions	Test Specifications	Product <u>Description</u>
AlphaGuard [™] MTS Base Coat	2 or 5 gal.	Proprietary	One-part, moisture triggered, polyurethane roof coating for use as the base-coat.
AlphaGuard [™] MTS Top Coat	2 or 5 gal.	Proprietary	One-part, moisture triggered, polyurethane roof coating for use as the top-coat.

EVIDENCE SUBMITTED

Test Agency	Test Identifier	Test Name/Report	<u>Date</u>
NEMO ETC, LLC	TRM-SC13455.11.17-1-R2	Physical Properties	11/29/17
	TRM-SC14130.04.18-2	Physical Properties	04/16/18
	TRM-SC13345.10.19-1	Physical Properties	10/14/19
	4p-TRM-20-SSLAP-01.A	Physical Properties	06/12/20

MANUFACTURING LOCATION

1. Cleveland, OH

PHYSICAL PROPERTIES OF COMPONENTS

Trade name: AlphaGuard[™] MTS Base Coat

Specifications: Various

Description: A single component urethane maintenance coating. **Container Size:** 2 or 5 gallons. Note all cautions on container label.

Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly,

Product Control Notice of Acceptance.

Trade name: AlphaGuard[™] MTS Top Coat

Specifications: Various

Description: A single component urethane maintenance coating. **Container Size:** 2 or 5 gallons. Note all cautions on container label.

Systems Approvals: Methods of application and quantities shall comply with specific Roof Assembly,

Product Control Notice of Acceptance.



NOA No.: 22-0228.09 Expiration Date: 12/09/26 Approval Date: 09/22/22

Page 2 of 6

INSTALLATION:

- 1. Tremco AlphaGuard[™] MTS Base Coat and AlphaGuard[™] MTS Top Coat shall be installed in accordance with manufacturer's published specifications in compliance with the minimum rate of application and as specified herein.
- 2. Approved Substrate: Asphalt Built-Up Roof (BUR) Smooth; Galvanized Steel; Modified Bitumen APP Granule-Surfaced; Modified Bitumen SBS Granule-Surfaced and Smooth-Surfaced; Single Ply PVC; Structural Concrete; Existing Urethane Coating.

APPROVED MAINTENANCE COATING APPLICATION:

Substrate: Asphalt Built-Up Roof (BUR) Smooth-Surfaced

System 1

Preparation: The surface shall be clean, sound and dry prior to application of AlphaGuard[™] MTS Base

Coat. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with AlphaGuard[™] MTS Base Coat. All surface preparation, and repairs, shall be in compliance with the AlphaGuard's published application instructions and current Miami-Dade

Notice of Acceptance.

Primer (Optional): Unprimed at an application rate of $200 - 250 \text{ ft}^2/\text{gal}$.

Base Coat: AlphaGuard[™] MTS Base Coat at a min. application rate of 3.0 gal./sq.

Fabric: PERMAFAB, wet-laid

Finish Coat: AlphaGuardTM MTS Top Coat at an application rate of 2.0 - 3.0 gal./sq.

Substrate: Galvanized Steel

System 1

Preparation: The surface shall be clean, sound and dry prior to application of AlphaGuard[™] MTS Base

Coat. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with AlphaGuard[™] MTS Base Coat. All surface preparation, and repairs, shall be in compliance with the AlphaGuard's published application instructions and current Miami-Dade

Notice of Acceptance.

Primer: AlphaGuard[®] M-Prime at an application rate of 1,400 - 1,800 ft²/gal.

Base Coat: AlphaGuard[™] MTS Base Coat at a min. application rate of 3.0 gal./sq.

Fabric: PERMAFAB, wet-laid

Finish Coat: AlphaGuardTM MTS Top Coat at an application rate of 2.0 - 3.0 gal./sq.



NOA No.: 22-0228.09 Expiration Date: 12/09/26 Approval Date: 09/22/22

Page 3 of 6

APPROVED MAINTENANCE COATING APPLICATION: (CONTINUED)

Substrate: Modified Bitumen APP Granule-Surfaced

System 1

Preparation: The surface shall be clean, sound and dry prior to application of AlphaGuard[™] MTS Base

Coat. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with AlphaGuard[™] MTS Base Coat. All surface preparation, and repairs, shall be in compliance with the AlphaGuard's published application instructions and current Miami-Dade

Notice of Acceptance.

Primer (Optional): Unprimed or AlphaGuard[®] WB Primer at an application rate of $200 - 250 \text{ ft}^2/\text{gal}$.

Base Coat: AlphaGuard[™] MTS Base Coat at a min. application rate of 4.0 gal./sq.

Fabric: PERMAFAB, wet-laid

Finish Coat: AlphaGuardTM MTS Top Coat at an application rate of 2.0 - 3.0 gal./sq.

Substrate: Modified Bitumen SBS Granule-Surfaced or Smooth-Surfaced

System 1

Preparation: The surface shall be clean, sound and dry prior to application of AlphaGuard[™] MTS Base

Coat. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with AlphaGuard[™] MTS Base Coat. All surface preparation, and repairs, shall be in compliance with the AlphaGuard's published application instructions and current Miami-Dade

Notice of Acceptance.

Primer: AlphaGuard® WB Primer at an application rate of 200 – 250 ft²/gal.

Base Coat: AlphaGuardTM MTS Base Coat at a min. application rate of 3.0 - 4.0 gal./sq.

Fabric: PERMAFAB, wet-laid

Finish Coat: AlphaGuardTM MTS Top Coat at an application rate of 2.0 - 3.0 gal./sq.

Substrate: Single Ply; PVC

System 1

Preparation: The surface shall be clean, sound and dry prior to application of AlphaGuard[™] MTS Base

Coat. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with AlphaGuard[™] MTS Base Coat. All surface preparation, and repairs, shall be in compliance with the AlphaGuard's published application instructions and current Miami-Dade

Notice of Acceptance.

Primer: AlphaGuard® WB Primer at an application rate of 200 – 250 ft²/gal.

Base Coat: AlphaGuard[™] MTS Base Coat at a min. application rate of 3.0 gal./sq.

Fabric: PERMAFAB, wet-laid

Finish Coat: AlphaGuardTM MTS Top Coat at an application rate of 2.0 - 3.0 gal./sq.



NOA No.: 22-0228.09 Expiration Date: 12/09/26 Approval Date: 09/22/22 Page 4 of 6

APPROVED MAINTENANCE COATING APPLICATION: (CONTINUED)

Substrate: Structural Concrete

System 1

Preparation: The surface shall be clean, sound and dry prior to application of AlphaGuard[™] MTS Base

Coat. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with AlphaGuard™ MTS Base Coat. All surface preparation, and repairs, shall be in compliance with the AlphaGuard's published application instructions and current Miami-Dade

Notice of Acceptance.

Primer: AlphaGuard[®] C-Prime at an application rate of $200 - 250 \text{ ft}^2/\text{gal}$.

Base Coat: AlphaGuard[™] MTS Base Coat at a min. application rate of 3.0 gal./sq.

Fabric: PERMAFAB, wet-laid

Finish Coat: AlphaGuardTM MTS Top Coat at an application rate of 2.0 - 3.0 gal./sq.

Substrate: Existing urethane coating

System 1

Preparation: The surface shall be clean, sound and dry prior to application of AlphaGuard[™] MTS Base

Coat. Check for adhesion and compatibility of any remaining, tightly adhered, existing coating with AlphaGuard™ MTS Base Coat. All surface preparation, and repairs, shall be in compliance with the AlphaGuard's published application instructions and current Miami-Dade

Notice of Acceptance.

Primer (Optional): Geogard® Primer at an application rate of 400 ft²/gal.

Base Coat: AlphaGuard[™] MTS Base Coat at a min. application rate of 3.0 gal./sq.

Fabric: PERMAFAB, wet-laid

Finish Coat: AlphaGuardTM MTS Top Coat at an application rate of 2.0 - 3.0 gal./sq.



NOA No.: 22-0228.09 Expiration Date: 12/09/26 Approval Date: 09/22/22

Page 5 of 6

LIMITATIONS:

- 1. Fire classification is not part of this acceptance, refer to a current Approved Roofing Materials Directory for fire rating of this product.
- 2. All products shall be applied in strict compliance with Manufacturer's published application instructions.
- **3.** Tremco CPG products shall not be applied in inclement weather conditions.
- **4.** Tremco CPG shall not be covered with stone chips, screeds, tiles or soil.
- 5. Tremco CPG shall not be applied over existing gravel surfaces.
- **6.** Approved primer is required on all unprotected iron and steel and previously painted surfaces.
- 7. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list any of the products listed herein as part of their roof assemblies Notice of Acceptance.
- **8.** All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Product Control upon request.
- 9. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI:DADE COUNTY
APPROVED

- 10. Change in materials, use, or manufacture of any of the products listed herein shall be cause for termination of this Notice of Acceptance
- 11. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
- 12. The use of a reinforcing fabric in a maintenance coating is only to enhance the coatings ability to deliver efficient and long term performance through the protection of the underlying roof system and in this particular use does not become a roof system itself.

END OF THIS ACCEPTANCE



NOA No.: 22-0228.09 Expiration Date: 12/09/26 Approval Date: 09/22/22

Page 6 of 6