



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION

11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786)315-2590 F (786) 315-2599

www.miamidade.gov/economy

GAF

**1 Campus Drive
Parsippany, NJ 07054**

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: EverGuard® #1121 TPO Bonding Adhesive, EverGuard® TPO 3 Square Low VOC Bonding Adhesive & EverGuard® PVC Quick Lay Adhesive.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 18-1227.08 and consists of pages 1 through 3.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-0331.03
Expiration Date: 04/05/27
Approval Date: 04/21/22
Page 1 of 3

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cement-Adhesive-Coatings
Material: Various

SCOPE:

This approves EverGuard® #1121 TPO Bonding Adhesive, EverGuard® TPO 3 Square Low VOC Bonding Adhesive & EverGuard® PVC Quick Lay Adhesive as described in this Notice of Acceptance. These products have been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone of the Florida Building Code.

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Specification</u>	<u>Date</u>
Momentum Technologies	SX11B5B	Physical Properties	02/23/15
Laboratories	SX11B5D	Physical Properties	02/24/15
	SX16C8A	Physical Properties	03/27/19
	SX11J8A	Physical Properties	03/27/19

PRODUCT DESCRIPTION AND TYPICAL PHYSICAL PROPERTIES:

Note: The physical properties listed herein are presented at typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.

EverGuard® #1121 TPO Bonding Adhesive:

Description	Test Standard	Property
Viscosity @ 75°F (cPs.)	ASTM D 2196	2118
Elongation (%)	ASTM D 412	1119.0%
Tensile Strength (psi.)	ASTM D 412	1460.6
Weight Per Gallon (lbs./gal.)	ASTM D 1475	7.262
Percent Solids	ASTM D 1644	23.6%

MANUFACTURING LOCATION:

1. Ashland, OH

EverGuard® TPO 3 Square Low VOC Bonding Adhesive:

Description	Test Standard	Property
Viscosity @ 75°F (cPs.)	ASTM D 2196	1530
Elongation (%)	ASTM D 412	887.3%
Tensile Strength (psi.)	ASTM D 412	760.0
Weight Per Gallon (lbs./gal.)	ASTM D 1475	7.393
Percent Solids	ASTM D 1644	26.0%

MANUFACTURING LOCATION:

1. Ashland, OH



NOA No.: 22-0331.03
Expiration Date: 04/05/27
Approval Date: 04/21/22
Page 2 of 3

EverGuard® PVC Quick Lay Adhesive:

Description	Test Standard	Property
Viscosity @ 75°F (cPs.)	ASTM D 2196	2530 - 3150
Elongation (%)	ASTM D 412	497.45% - 550.57%
Tensile Strength (psi.)	ASTM D 412	408.40 – 431.07
Weight Per Gallon (lbs./gal.)	ASTM D 1475	7.92 – 8.55
Percent Solids	ASTM D 1644	67.5% - 67.7%

MANUFACTURING LOCATION:

1. Ashland, OH
2. Columbus, OH

BUILDING PERMIT REQUIREMENTS:

1. This Notice of Acceptance
2. Any other documents required by the Building Official or applicable Building Code in order to properly evaluate the installation of this system.

LIMITATIONS:

1. Fire classification is not part of this acceptance; refer to a current Approved Roofing Materials Directory for fire rating of this product.
2. EverGuard® #1121 TPO Bonding Adhesive, EverGuard® TPO 3 Square Low VOC Bonding Adhesive & EverGuard® PVC Quick Lay Adhesive shall not be applied in inclement weather conditions.
3. The products listed herein are components of roof assemblies and are approved for use with roof assemblies that list the products listed herein as part of their roof assemblies Notice of Acceptance. See roof system Notice of Acceptance (NOA) for application rates and uses.
4. All products listed herein shall have an unannounced follow-up quality control program from an approved listing agency. Follow up test results shall be made available to Miami-Dade County Product Control upon request.
5. Change in materials, use, or manufacture of any products listed herein shall be cause for termination of this Notice of Acceptance.
6. EverGuard® #1121 TPO Bonding Adhesive, EverGuard® TPO 3 Square Low VOC Bonding Adhesive & EverGuard® PVC Quick Lay Adhesive shall be applied in accordance with manufacturer's published application instructions unless specified otherwise within the NOA approvals.
7. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.
8. All approved products listed herein shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.

MIAMI-DADE COUNTY
APPROVED

END OF THIS ACCEPTANCE

MIAMI-DADE COUNTY
APPROVED

NOA No.: 22-0331.03
Expiration Date: 04/05/27
Approval Date: 04/21/22
Page 3 of 3