



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
Miami, Florida 33175-2474
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

NOTICE OF ACCEPTANCE (NOA)

OMG, Inc.
153 Bowles Road
Agawam, MA 01001-0508

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami-Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (in Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein and has been designed to comply with the Florida Building Code including the High Velocity Hurricane Zone of the Florida Building Code.

DESCRIPTION: OMG OlyBond Classic, OlyBond 500, OlyBond 500 Green & OlyBond 500 Canister Adhesives

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA renews and revises NOA No. 19-0904.03 and consists of pages 1 through 4.

The submitted documentation was reviewed by Jorge L. Acebo.



NOA No.: 22-0519.04
Expiration Date: 07/29/27
Approval Date: 06/30/22
Page 1 of 4

ROOFING COMPONENT APPROVAL

Category: Roofing
Sub-Category: Cements, Adhesives and Coatings
Material: Polyurethane

SCOPE:

This approves OMG OlyBond Classic, OlyBond 500, OlyBond 500 Green & OlyBond 500 Canister adhesives as manufactured by OMG, Inc., as described in this Notice of Acceptance and designed to comply with the Florida Building Code and the High Velocity Hurricanes Zone. The use of this acceptance is limited to those roof assemblies were OMG OlyBond Classic, OlyBond 500, OlyBond 500 Green & OlyBond 500 Canister adhesives are specifically listed as an accepted component.

PRODUCT DESCRIPTION:

Spray Polyurethane Foam with the properties described below:

<u>Description</u>	<u>Test</u>	<u>Properties</u>
OMG OlyBond Classic		
Flame Spread Index	ASTM E84	15
Smoke Develop Index	ASTM E84	10
Self Ignition Temperature	ASTM D1929-91	698° F
Density @ 73° F	ASTM D 1622	5.03 lbs./ft ³
Compressive Strength @ 10% deformation	ASTM D 1621	18.02 psi
Tensile	ASTM D 1623	42.04 psi
Water Absorption	ASTM D 2842	2.75%
Packaging Options		
	Drum:	15 or 55 gal

Note: The physical properties listed above are presented at typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.

OMG OlyBond 500 Adhesive Fastener

Flame Spread Index	ASTM E84	15
Smoke Develop Index	ASTM E84	10
Self Ignition Temperature	ASTM D1929-91	698° F
Density @ 73° F	ASTM D 1622	5.03 lbs./ft ³
Compressive Strength @ 10% deformation	ASTM D 1621	18.02 psi
Tensile	ASTM D 1623	42.04 psi
Water Absorption	ASTM D 2842	2.75%
Packaging Options		
	SpotShot Cartridge:	1500 ml
	Bag-in-Box:	5 gal
	Drum:	15 gal
	Canister:	68 lbs

Note: The physical properties listed above are presented at typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.



NOA No.: 22-0519.04
Expiration Date: 07/29/27
Approval Date: 06/30/22
Page 2 of 4

OMG OlyBond 500 Green

Flame Spread Index	ASTM E84	15
Smoke Develop Index	ASTM E84	10
Self Ignition Temperature	ASTM D1929-91	698° F
Density @ 73° F	ASTM D 1622	3.38 lbs./ft ³
Compressive Strength @ 10% deformation	ASTM D 1621	25.89 psi
Tensile	ASTM D 1623	67.64 psi
Water Absorption	ASTM D 2842	20.1%
Packaging Options		
SpotShot Cartridge:		1500 ml
Bag-in-Box:		5 gal
Drum:		15 gal

Note: The physical properties listed above are presented at typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.

OlyBond 500 Canister

Flame Spread Index	ASTM E84	0
Smoke Develop Index	ASTM E84	0
Self Ignition Temperature	ASTM D1929-91	518° F
Density @ 73° F	ASTM D 1622	2.6 lbs./ft ³
Compressive Strength @ 10% deformation	ASTM D 1621	12.0 psi
Tensile	ASTM D 1623	34.0 psi
Water Absorption	ASTM D 2842	34%
Packaging Options		
Canister:		68 lbs

Note: The physical properties listed above are presented at typical average values as determined by accepted ASTM test methods and are subject to normal manufacturing variation.

MANUFACTURING LOCATION:

1. Rockford, MN

EVIDENCE SUBMITTED:

<u>Test Agency</u>	<u>Test Identifier</u>	<u>Test Specification</u>	<u>Date</u>
NEMO ETC LLC	4p-OMG-21-SSLAP-01.A	Physical Properties	02/08/2022
UL LLC	UL 723	R18910	06/27/17
FM Approvals	3001472	4450/4470	04/14/99
	3008869	4470	03/19/01
	3014692	4470	08/05/03
	3031350	4470	09/27/07
	PR456420	4470	12/22/20
RCMA Americas, Inc.	CX23A7A	Physical Properties	03/07/17
	CX16C7A	Physical Properties	04/19/17
R & D Services, Inc.	RD17092	ASTM D2842	02/16/17
	RD17420	ASTM D2842	06/30/17



NOA No.: 22-0519.04
Expiration Date: 07/29/27
Approval Date: 06/30/22
Page 3 of 4

INSTALLATION:

OMG OlyBond Classic, OlyBond 500, OlyBond 500 Green & OlyBond 500 Canister adhesives shall be installed in strict compliance with the Roof Assembly Notice of Acceptance and manufacturer's published literature.

LABELING:

OMG OlyBond Classic, OlyBond 500, OlyBond 500 Green & OlyBond 500 Canister adhesives shall be labeled in compliance with TAS 121 and shall bear the imprint or identifiable marking of the manufacturer's name or logo, city, state and following statement: "Miami-Dade County Product Control Approved" or the Miami-Dade County Product Control Seal as shown below.



BUILDING PERMIT REQUIREMENTS:

As required by the Building Official or applicable Building Code in order to properly evaluate the installation of this system. This Notice of Acceptance on its own cannot be used to obtain a building permit.

LIMITATIONS:

1. OMG OlyBond Classic, OlyBond 500, OlyBond 500 Green & OlyBond 500 Canister adhesives shall have a quality control testing program by an approved independent listing agency having unannounced follow-up visits. Follow up test results shall be made available to Miami-Dade County Product Control upon request.
2. All products listed herein shall have a quality assurance audit in accordance with the Florida Building Code and Rule 61G20-3 of the Florida Administrative Code.

END OF THIS ACCEPTANCE



NOA No.: 22-0519.04
Expiration Date: 07/29/27
Approval Date: 06/30/22
Page 4 of 4